













## WORKS OF

## **PROFESSOR F. R. HUTTON**

#### PUBLISHED BY

## JOHN WILEY & SONS

The Mechanical Engineering of Power Plants.

750 pages and 500 illustrations. 8vo, cloth, \$5.00.

#### Heat and Heat-engines.

A study of the principles which underlie the mechanical engineering of a power plant.

576 pages and 198 illustrations. 8vo, cloth, \$5.00.

## HEAT AND HEAT-ENGINES.

## A STUDY OF THE PRINCIPLES WHICH UNDER-LIE THE MECHANICAL ENGINEERING OF A POWER PLANT.

BY

FREDERICK REMSEN HUTTON, E.M., PH.D., Professor of Mechanical Engineering at Columbia University.

FIRST EDITION.

FIRST THOUSAND.



NEW YORK: JOHN WILEY & SONS. London: CHAPMAN & HALL, Limited. 1899.



Copyright, 1899, BY FREDERICK REMSEN HUTTON. 78267

ROBERT DRUMMOND, PRINTER, NEW YORK.

## ERRATA IN EDITION OF 1899.

6.6	79, heading of 8th column should read:
	Calorific Power
	observed
	in Calories.
"	79, heading of 10th or last column should read:
	Calorific Power
	calculated
	in Calories.
"	86, line 5 from bottom, equation should read:
	$Q = w' \times c' \times (t_1 - t_2)$
66	99, line 9 from bottom, for reducing D to $32^{\circ}$ F. read reducing $D_c$ to $32^{\circ}$ F.

Page 15, line 10 from top, for heat unit read degree

" 104, line 9 from top should read:

$$E = D^2 - \frac{8}{12}D + \frac{1}{9} = A - \frac{2}{3}\sqrt[4]{A}$$
 nearly

" 104, line 11:

$$E = \frac{\pi}{4} \left( D^2 - \frac{8}{12} D \right) = A - 0.592 \ \sqrt{A}$$

" 107, line 10 from top:

$$V_c = V_a \frac{T_e}{T_a} = 6000 \frac{1085}{521},$$

whence

 $V_c = 12,500$  cubic feet

" 107, line 6 from bottom, for it BELOW the fire read it ABOVE the fire.

" 110, line 7 from bottom:

 $\therefore p = H(D_1 - D_2)$ = 3.51 lbs, per square foot

and

 $p_1 = 3.51 \times .192$ 

· 142, line 11:

44

$$t = vv \times c \times (t_1 - t) = vv' \times c' \times (t - t_2)$$

142, line 4: grew less intense by square of distance

- " 165, line 5 from bottom, for by multiplying by 778 read by dividing by 778
- " 180, line 21, equations should read:

$$p_1'v_1 = p_0v_0(\mathbf{I} + at_1)$$

and

$$p_2'v_2 = p_0v_0(\mathbf{I} + at_2)$$

- " 181, lines 14 and 15, for inversely read directly.
- " 207, line I, column I, top of page, for 24.3 read 25.7
- " 216, line 3 from bottom:

$$\theta = \int \frac{dq}{T} = \text{etc.}$$

" 224, line 6 from bottom should read: If, then, from the preceding paragraph, the total heat re-

<sup>44</sup> 226, line 12 from bottom should read: an evaporation of 34.488 pounds

" 229. line 7 from bottom:

$$PLA = \frac{P \times \mathbf{I44}A \times L}{\mathbf{I44}} = paL$$

" 236, line 3 from bottom: the mean pressure  $p_m$  results

[Over.]

Page 236, last line:

$$\frac{A}{7} = p_m = \text{etc.}$$

" 241, line 3:

$$W_1 = p_1 v_1^n \int \text{etc.}$$

" 243, 4th equation from top:

$$\left(\frac{V_1}{\overline{V}_2}\right)^n = \text{etc.}$$

" 243, 6th equation:

$$\frac{p_2 v_2}{p_1 v_1} = \text{etc.}$$

" 244, lowest equation:

$$E_1 - E_2 = W_1 = Jc(T_1 - T_2) \times i$$

144) 
$$\div$$
 0.3148, the latter, etc.

" 261, 4th equation should read:

$$=p_1v_1^n \int_{v_2}^{v_1} \frac{dv}{v^n} = \frac{p_2v_2 - p_1v_1}{n-1}$$

" 263, first equation of Art. 183 should read:

$$n = \frac{C_p}{C_v}$$

" 290, equation middle of page should read:

$$le: lk: V: V_1 \text{ or } le = \frac{V}{V_1} lk$$

" 301, equation middle of page should read:  $H_3 = C_v T_2 \text{ hyp. log } r.$ 

" 301, below this:

44

$$H_4 = C_v T_1$$
 hyp. log r.

- " 306, line 17 from top: the  $\phi$  is not a subscript, but should be same size as T, and should read  $T\phi$
- <sup>14</sup> 308, line 12, for Water per H.P. per hour read Work per H.P. per hour <sup>14</sup> 331, line 3 of Art. 233, for values read values
- " 332, bottom line should read:

$$LK = NA = f(AL)$$
, since  $\frac{LK}{KT} = \frac{C}{AL}$  and  $\frac{NA}{KT} = f$ 

" 333, third equation from top should read:

$$\frac{\mathbf{I}}{r} = \frac{NB}{LI} = \frac{AB + NA}{LK + KI} = \frac{AB + KIf}{KI + KIf} = \frac{\overline{r} + f}{\mathbf{I} + f}$$

" 351, second equation from bottom:

$$Q_e = Q + Q_j - Mq_4 - G(q_k - q_i) - AW$$
  
351, last equation should read:

$$Q_{c} = H_{a} - H_{a} - Q - Q_{i} + Q_{a} + A(W + W)$$

"368, lines 12 and 13 should read: perature  $T_4$  in this last equation. That is, place

$$W'_{4} = 778M(C_{p} - C_{r})T_{3}\left(I - \frac{f_{4}}{f_{3}}\right) = 778MC_{p}(T_{3} - T_{x})$$

- " 372, bottom, and page 373, top: in these equations what appears as Cp should read  $C_p$
- " 391, line I of (3), for compresses read displaces
- " 401, line 4 of Art. 274, for stant temperatures read stant volume



## PREFACE.

THE effort has been made under another title, "The Mechanical Engineering of Power Plants," to discuss the steam-engine and the steam-boiler with their accessory apparatus, so as to enable students and others to make an intelligent selection of successful designs for a set of conditions which might be imposed. The object of the author was to make the reader familiar with accepted solutions of the power-house problem in all its details, but no attempt was made to discuss the questions of design of such apparatus. It was intended that the student should ask at the end of his study of that book: What are the principles of physics and dynamics upon which these machines depend; and how do engineers proceed when called upon to design such powerhouse engines ?

This book, under the title of "Heat and Heat-engines," has been prepared to answer these questions in part. It discusses the energy resident in fuels, and the methods of its liberation as heat for power purposes; the transfer of such heat to convenient media whereby it can be used in heatengines; the laws and properties of such media, and the design of cylinders of the necessary volume to give a desired mechanical effect or horse-power. Then, this point having been reached, and relations being established for the mutual variations of temperature with pressure and volume in such media when operated in a cylinder with a piston, it becomes

iii

#### FREFACE.

easy and natural to go farther and discuss the air-compressor and its complement, the air-engine; and to extend this discussion to include the problem of mechanical refrigeration. The hot-air engine using a permanent gas as a medium naturally leads to the gas-engine and the oil-engine; and the engine using steam as a medium leads naturally to those using other media, such as naphtha, alcohol, and ammonia. The chapter on the Injector as a heat-absorbing and energytransforming device closes the book.

If the distinction were a conceded one, the first book designated as the *mechanical* engineering of power plants might be said to lead to this supplementary discussion upon the *dynamical* engineering of power plants. The treatment assumes and does not attempt to prove the dynamic or mechanical theory of heat, and does not ask nor require to know whether there is an intermolecular ether or not, nor whether the energy of heat manifests itself by producing a vibratory or undulatory or vortex motion of matter, or is an electro-magnetic phenomenon. These discussions belong to a transcendental sphere of investigation and research with which the practical engineer as a rule need not concern himself.

It is somewhat in this latter view also, that for the purpose in hand the term "thermodynamics" has been largely avoided, as well as the attractive development of the truths of the science of heat-engine design by the methods of exponential equations and the use of the calculus. No one is more ready than the writer to recognize the elegance of the deductive method from fundamental equations, and the delights of the revelations of law which are thus secured. But on the other hand it must not be overlooked that the very ease and elegance of the deductive method makes it an unsafe tool in the hands of the inexperienced who are without the steadying effect of long familiarity with the actual conditions of the applications of theory, which should prevent the drawing of conclusions which the mathematical treatment

#### PREFACE.

v

alone does not pronounce unsound. The science of thermodynamics has this singular distinction, that it has been developed deductively from fundamental equations by masterminds, using the methods familiar to the physicist and the skilled mathematician. But it has often moved so far in advance of the ordinary attainments of the practitioner in the power-house on the one hand, and so far in advance of the experience of the student on the other hand, that both have often lost the connecting-link between the advanced theory and the current practice. The effect on the student has been to weaken his appreciation of the subject if he was not of a mathematical bent; or if he was gifted with facility in this method of thought, he failed to satisfy his early employers because he applied the deductive methods and conclusions with a zeal not always according to knowledge. The practitioner, on the other hand, as the result of years of training in the inductive method of generalizing from particulars in his daily affairs, is out of touch with the deductive method and has no use for the unfamiliar process and its practitioner. He therefore unjustly undervalues his young technical graduate and his method of training.

This treatise tries to occupy a middle ground. It might wisely be used as a groundwork for a subsequent treatment of heat-phenomena by the analytic or mathematical method after the student has become familiar with the physical facts of which the equations of thermodynamics are condensed statements. By pursuing this middle course, however, a few places may be detected where the logical mind will miss the antecedent premise upon which the conclusion is based, or where it is stated upon authority, and the proof is not given. This is the result of trying to treat thermodynamics without the calculus, and the result should be to turn the student to further and exhaustive research in the higher field. At least, this is the author's desire.

Equations could not be avoided, nor the use of loga-

#### PREFACE.

rithms; but the use of the temperature-entropy diagram for the graphical representation of relations has been abundantly permitted. The appendices also open doors into departments of further research and knowledge beyond the scope set by the limits of the text.

The student and writer of to-day is the heir of the work and thought of his predecessors who have inspired and guided him. The bibliography in the appendix will show how many workers in these lines have left their impress upon the modern treatment of the subject. The influences most felt in this book are those from Rankine, Cotterill, Ewing, Peabody, Wood, Reeve, and Richmond, to whom heartfelt acknowledgment is extended and to whose treatises the advanced student is referred. To the last name in the list special thanks are due for valuable suggestions and a criticism upon certain parts in the proofs. To Profs. Thurston, Carpenter, and other contributors to the Transactions of the American Society of Mechanical Engineers, and to Prof. Reeve, the author is indebted for use of helpful illustrations.

The specialist will require to pursue the lines of his selection by supplementing the basal treatment of this book by further study in the excellent treatises on the gas- and oil-engine, the injector, the refrigerating-machine, and in the field of the application of compressed air. It will be a great pleasure if the treatment and its methods shall make the book useful also to that growing class of persons who are brought into touch with engineering matters and are anxious to learn about them, and yet who are not fitted to profit by an exclusively mathematical discussion. The object which has been sought in its preparation will be secured if the book shall prove helpful and useful as a stimulus to further study.

COLUMBIA UNIVERSITY, NEW YORK, July, 1899.

vi



#### CHAPTER I.

PAR

#### INTRODUCTORY.

		TAGE
I.	Sources of Motor Energy	I
2.	Limitations of Muscular Force and the Force of Gravity	I
3.	Importance of the Motor Energy Liberated on Combustion	3
4.	Analysis of a Power Plant	3
5.	Scheme of Classification	5

#### CHAPTER II.

GENERAL NOTIONS ON THE PHENOMENA MANIFESTED IN HEAT-ENGINES.

6.	General and Introductory	6
7.	Graphic Representation of the Work of a Piston-engine	8

#### CHAPTER III.

#### GENERAL NOTIONS ON HEAT.

8.	Introductory	12
9.	Mechanical Theory of Heat	13
10.	Mechanical Equivalent of Heat	13
11.	The British Thermal Unit	14
12.	The Specific Heat	14
13.	Temperature	15
14.	Thermometers	16
15.	Air-thermometer	17
16.	Absolute Temperature	18
17.	Total and Intrinsic Energy	19

#### CHAPTER IV.

GENERATION OR LIBERATION OF HEAT. COMBUSTION.

18.	Introductory	20
19.	Heat from Combustion	20
	vii	

PAR.		PAGE
20.	Certain Phenomena of Combustion, Ignition, Flame, Incandes-	
	cence	21
21.	Spontaneous Combustion. Explosion	23
22.	Calorific Power of a Fuel	24
23.	Coal-calorimeters	25
24.	Air Required for Combustion of Carbon	25
25.	Air Required for Combustion of Hydrogen	27
26.	Air Required for Combustion of Compounds	28
27.	Combustion of an Analyzed Fuel	29
28.	Weight of Products of Combustion with an Analyzed Fuel	30
29.	Volume of the Products of Combustion with an Analyzed Fuel	31
30.	Dilution of the Products of Combustion	32

## CHAPTER V.

#### FUELS.

31.	Introductory	34
32.	Solid Fuels. Anthracite Coal	34
33.	Bituminous Coal	37
34.	Lignite	39
35.	Asphalt	40
36.	Peat	40
37.	Coke	41
38.	Wood	42
39.	Bagasse, Straw, Tan-bark	44
40.	Charcoal	46
41.	Artificial or Patent Fuels	47
42.	Liquid Fuel. Petroleum	48
43.	Kerosene	50
44.	Alcohol	50
45.	Liquid-fuel Furnaces	51
46.	Oil-vapor Burners	52
47.	Oil-gas Systems	55
48.	Advantages of Oil-fuel	56
49.	Disadvantages of Oil-fuel	57
50.	Gaseous Fuels. General	58
51.	Natural Gas	58
52.	Producer-gas	60
53.	Water-gas. Dowson Gas	62
54.	Coal-gas or Illuminating-gas	67
55.	Acetylene-gas	69
56.	Comparison of Gaseous Fuels	69
57.	Powdered Fuel	72
58.	Calorific Power of a Hydrocarbon	73

viii

Р	А	R	
-			•

PAR.		PAG	E
59.	Evaporative Power of a Fuel.	Efficiency, Heat-balance 7.	4
60.	Data Concerning Fuels		8

#### CHAPTER VI.

#### TEMPERATURES OF COMBUSTION. PYROMETERS.

61.	Introductory	85
62.	Temperature of the Fire	86
6 <b>3.</b>	Pyrometers. General	89
64.	Metal-ball Pyrometer	90
65.	Wiborgh's Air-pyrometer	91
66.	Uehling-Steinbart Pyrometer	91
67.	Le Chatelier Thermo-electric Pyrometer. Siemens Pyrometer	92
68.	Mesuré and Noel's Pyrometric Telescope	93
69.	Some Standard Temperatures	93

#### CHAPTER VII.

#### RATE OF COMBUSTION. DRAFT.

75.	Introductory	95
76.	The Rate of Combustion	95
77.	Draft for Combustion. General	96
78.	Chimney-draft. General	97
79.	Theory of Chimney-draft by Péclet	98
80.	Discussion of Péclet's Theory of Chimney-draft	101
81.	Some Accepted Chimney Formulæ and Data	104
82.	Cross section of Chimney	106
83.	Draft-gauges	107
84.	Flue gas Analysis	III
85.	Stability and Structure of Chimneys	113
86.	Artificial or Mechanical or Forced Draft	117
87.	Advantages of Mechanical Draft	119
88.	Disadvantages of Mechanical Draft	121
89.	Smoke-prevention	123
90.	Mechanical Stoking	129

#### CHAPTER VIII.

#### TRANSFER OF HEAT. HEATING-SURFACE.

91.	Introductory	139
9 <b>2.</b>	Transfer of Heat. General	140
93.	Transfer of Heat by Radiation	142
94.	Transfer of Heat by Contact	145
95.	Transfer of Heat by Conduction	148
96.	Transfer of Heat by Convection. Circulation	151
97.	General Remarks on the Transfer of Heat	152

PAR.		PAGE
98.	Heating-surface	153
99.	Ratio of Heating-surface to Grate-surface	157
100.	Evaporation in Boilers per Pound of Coal	159
101.	Water per Horse-power per Hour	160
102.	Refrigerating-surface	162
103.	Conclusion	163

## CHAPTER IX.

#### MEDIA USED TO TRANSFER HEAT ENERGY.

105.	Introductory	164
106.	Solids, Liquids, and Gases	164
107.	General Characteristics of a Medium to be used in a Heat-engine	166
108.	Some Heat-carriers which have been used as Media in Heat-	
	engines	171
109.	Vapors	172
110.	Liquefaction, Fusion or Melting. Latent Heat of Fusion and	
	Vaporization	172

#### CHAPTER X.

PHYSICAL LAWS, EXHIBITING EFFECTS OF HEAT UPON HEAT-CARRIERS.

111.	Introductory	176
112.	Law of Gay-Lussac, or Charles' Law	177
113.	Coefficients of Expansion	178
114.	Law of Mariotte, or Boyle's Law	179
115.	Combination of Mariotte and Gay-Lussac Law. Value of Sym-	
	bol <i>R</i>	180
116.	Specific Heat at Constant Pressure and at Constant Volume	183
117.	Joule's Law	184
118.	Graphical Representation of the Thermal Changes in a Gas	185
119.	Lines of Constant or Equal Pressure. Isopiestic Lines or Isobars	186
120.	Lines of Constant or Equal Volume. Isometric Lines	187
121.	Lines of Constant or Equal Temperature. Isothermal Lines	187
122.	Isodynamic or Iso-energic Lines	188
123.	Adiabatic Lines	188
124.	Iso-entropic Lines. Entropy	190
125.	Plotting of Isothermal and Adiabatic Lines	195

#### CHAPTER XI.

#### VAPORS AS HEAT-CARRIERS. STEAM.

130.	Introductory	198
131.	Saturated Vapor. Saturated Steam	199
132.	Superheated Vapor. Superheated Steam	200

х

PAR.	P	AGE
133.	Relations of Pressure and Temperature in Saturated Steam-	
	vapor (Regnault)	201
134.	Rankine Formula for Pressure of Saturated Steam	203
135.	Other Formulæ for Pressure and Temperature of Saturated Steam	204
136.	Steam Tables	205
137.	Saturated Vapor Pressures and Temperatures for Media other	
	than Steam	210
138.	Total Heat of Steam	211
139.	Heat of the Liquid	211
140.	Heat of Vaporization. Internal Latent Heat	2 <b>12</b>
141.	Specific Volume of Hot Liquids	213
142.	Critical Temperature	214
143.	Increase of Entropy of a Mixture of Liquid and Vapor Entropy of	
	the Liquid	215
144.	Increase of Entropy of the Vapor	217
145.	Superheated Steam, Total Heat of	218
146.	Specific Heat of Steam	218
147.	Negative Specific Heat of Saturated Steam	219
148.	Specific Heat of Superheated Steam at Constant Volume	220
149.	Specific Volume of Superheated Steam	220
150.	Specific Volume of Saturated Steam	221
151.	Condensation in Adiabatic Expansion of Steam	222
152.	Evaporation from a Feed-water Temperature	223
153.	Evaporation from and at 212° Fahr	224
154.	Rankine's Factor of Evaporation	225
155.	Theoretical Evaporation of Water per Pound of Fuel	225
156.	Output of a Steam-boiler in Heat-units	226
157.	Efficiency of a Steam-boiler	226

#### CHAPTER XII.

#### WORK DONE BY ELASTIC HEAT MEDIA IN CYLINDERS OF HEAT-ENGINES, CYLINDER DESIGN.

160,	Introductory	228
161.	Work done with Constant Pressure in the Cylinder	229
162.	Constant-pressure Work with Air or Permanent Gases	231
163.	Constant-pressure Work with Steam	232
164.	Work done by an Elastic Heat-carrier Expanding in a Cylinder.	
	Cut-off or Degree of Expansion	232
165.	Work of a $pv$ Diagram represented by an Area	235
166.	Work of an Elastic Heat Medium Expanding Isothermally	237
167.	Work of an Elastic Heat Medium Expanding Adiabatically	239
168.	Adiabatic Work in Terms of Pressures	242
169.	Temperature Changes in Adiabatic Expansion	243

xi

PAR.	•	AGE
170.	Conclusions regarding Isothermal and Adiabatic Expansion	<b>2</b> 45
171.	Design of Cylinders for Piston-motors	<b>2</b> 45
172.	The Compound or Multiple-expansion Engine	247
173.	Advantages of the Compound Engine	250
174.	Disadvantages of the Compound Engine	253
175.	Design of the Rotary Engine	254
176.	The Steam Turbine	255

#### CHAPTER XIII.

#### MECHANICAL COMPRESSION OF HEAT MEDIA.

180.	Introductory	26 <b>0</b>
181.	The Air-compressor with Pressures Given	260
182.	The Air-compressor with Volumes Given	263
183.	Value of the Factor <i>n</i> in Air-compressing	<b>2</b> 63
184.	Mean Pressure in the Compressing-cylinder	265
185.	Isothermal Compression	<b>2</b> 66
186.	Effect of Clearance in Compressing-cylinders	267
187.	Volume of Compressing-cylinder	269
188.	Cooling of Compressing-cylinder	270
189.	Compression in Two or More Stages. Compound Compressors	270
190.	Fluid Compressors	273
191.	Conclusions and Remarks	273

#### CHAPTER XIV.

#### TEMPERATURE-ENTROPY DIAGRAMS FOR HEAT-ENGINES.

195.	Introductory	276
196.	The Temperature-entropy Diagram	277
197.	Temperature-entropy Diagram for an Ideal Heat-engine	279
198.	Deductions from the Temperature-entropy Diagram	282
199.	Entropy-temperature Diagram applied to a Perfect Steam-engine	
	working with Complete Expansion	284
200.	Amount of Condensation in Adiabatic Expansion	286
201.	Temperature-entropy Diagram when Expansion is Incomplete	<b>2</b> 88
202.	Temperature-entropy Diagram when there is no Expansion	200
203.	Temperature entropy Diagram when Steam is Superheated	200
204.	Plotting of Entropy-temperature Curves for Water and Steam	201
205.	Transfer of the Indicator-diagram to the Entropy-temperature Di-	,
-	agram	204

#### CHAPTER XV.

#### THE IDEAL CYCLE HEAT-ENGINE.

210.	Introductory	296
211.	The First Law of Thermodynamics	297

## xii

PAR.	PAGE	
212.	The Second Law of Thermodynamics 297	
213.	Carnot's Cycle 298	
214.	Carnot's Cycle Reversed 301	
215.	Carnot's Criterion of Reversibility 302	
216.	Efficiency of the Carnot Cycle 303	
217.	The Rankine and Clausius Cycles 305	
218.	Theoretical Weight of Heat Medium for a given Work 306	
210.	Recapitulation	

#### CHAPTER XVI.

#### THE CYCLE OF THE ACTUAL STEAM-ENGINE.

220.	Introductory	311
221.	Elements of Departure of the Actual Cycle from the Ideal Carnot	
	Cycle	311
222.	Progress in Steam-engine Efficiency	316
223.	Ideal and Actual Efficiency Compared	317
224.	Methods of Reducing Internal Condensation	319
225.	The Steam-jacket	321
226.	Conditions and Action of an Effective Steam-jacket	323
227.	Gain from the Use of the Steam-jacket	324
228.	Non-conducting Cylinders	325
229.	Superheating, to Prevent Cylinder Condensation	325
230.	Methods of Superheating	328
231.	Objections to Superheating	330
232.	Gain or Economy by Superheating	331
233.	Loss by Clearance	331
234.	Probable Amounts of Clearance	334
<b>2</b> 35.	Clearance Losses Diminished by Compression	335
236.	Calculation of Mean Effective Pressure when Clearance and Com-	
	pression are Considered	335
237.	Friction in Steam-pipes	337
238.	Loss of Pressure and Temperature from Cooling in Pipes	337
239.	Efficiencies Experimentally Determined in Terms of Thermal	
	Units	337

## CHAPTER XVII.

## THERMAL ANALYSIS OF HEAT-ENGINES.

240.	Introductory	340
241.	Pounds of Heat Medium per Horse-power Calculated Theoret-	
	ically from an Indicator-diagram	340
242.	Hirn's Analysis	343
243.	Application of Hirn's Analysis	349
244.	Limitations of Hirn's Analysis	351

PAR.		PAGE
245.	Thermal Analysis by Temperature-entropy Diagram	353
246.	Losses Revealed by the Temperature-entropy Diagram	357
247.	Reeve's Entropy-temperature Chart	359
248.	Conclusion	360

## CHAPTER XVIII.

## COMPRESSED-AIR ENGINES.

<b>2</b> 50.	Introduction	361
251.	Loss of Energy in Transmitting Air through Pipes	363
252.	The D'Arcy Formula for Compressed Air	364
253.	Compressed Air-engine with Complete Expansion	365
254.	Compressed-air Engine at Full Pressure, without Cut-off	366
255.	Compressed-air Engine with Incomplete Expansion	369
256.	Compressed-air Engine with Isothermal Expansion	370
257.	Volume of the Cylinder of a Compressed-air Engine	37I
258.	Compound Compressed-air Engine	371
259.	Combined Efficiency of Compressor and Air-engine	374
260.	Heat Range in the Air-engine Cylinder	375
261.	Preheating the Air for the Air-engine	376
262.	Temperature-entropy Diagram for Compressed-air Engine	377
263.	Temperature-entropy Diagram for the Air-compressor	380
264.	Temperature-entropy Diagram for the Combined Air-compressor	
	and Air-engine	381
265.	Concluding Summary	384

#### CHAPTER XIX.

#### HOT-AIR ENGINES.

Introductory	386
Types of Hot-air Engine	387
Regenerator for Hot-air Engine	388
Hot-air Engine with Temperature Changes at Constant Volume.	
Stirling's Engine	389
Temperature-entropy Diagram for a Stirling Hot-air Engine.	391
Hot-air Engine with Temperature Changes at Constant Pressure.	
Ericsson's Engine	394
Other Forms of Hot-air Engine	396
Hot-air Engine with Separate Compressing Cylinder	398
Temperature-entropy Diagram of a Hot-air Engine Changing	
Temperatures Non-Isothermally	401
Joule's Equivalent Hot-air Engine with Closed Cycle	402
Internal Combustion Hot-air Engine Using Solid Fuel	403
Concluding Summary	405
	Introductory Types of Hot-air Engine Regenerator for Hot-air Engine Hot-air Engine with Temperature Changes at Constant Volume. Stirling's Engine Temperature-entropy Diagram for a Stirling Hot-air Engine. Hot-air Engine with Temperature Changes at Constant Pressure. Ericsson's Engine Other Forms of Hot-air Engine Hot-air Engine with Separate Compressing Cylinder Temperature-entropy Diagram of a Hot-air Engine Changing Temperatures Non-Isothermally Joule's Equivalent Hot-air Engine with Closed Cycle Internal Combustion Hot-air Engine Using Solid Fuel Concluding Summary

## xiv

## CHAPTER XX.

IN	TERNAL-COMBUSTION ENGINES. THE GAS AND THE OIL ENGINE.
PAR.	PAGE
<b>2</b> 80.	Introductory-Historical 406
281.	Lenoir Gas-engine of 1860 407
282.	Hugon's Gas-engine of 1865 409
283.	Otto and Langen Atmospheric or Free-piston Gas-engine of 1867. 409
284.	Brayton Gas-engine or Ready Motor of 1873 411
285.	Four-phase Cycle of Beau de Rochas 412
286.	Otto Silent Gas-engine of 1876 413
287.	Dugald Clerk Gas-engine of 1880 415
288.	Atkinson Differential or Cycle Gas-engine of 1885 416
289.	Classification of Gas-engines 420
290.	Methods of Igniting the Gas-charge 421
291.	Indicator-diagrams from the Gas-engine 424
292.	Some Phenomena of Ignition in the Gas-engine 427
293.	Usual Mixtures of Gas and Air 430
294.	Thermodynamic Efficiency of the Otto Engine Considered as a
	Carnot Engine 431
295.	Temperature-entropy Diagram for the Gas-engine 433
296.	Compound Gas-engines 440
297.	The Oil-engine for Kerosene or Non-volatile Oils 441
298.	The Oil-engine for Gasoline or Light Volatile Oils 444
299.	The Diesel Petroleum-motor 445
300.	Performance and Economy of Direct-combustion Engines 447
301.	Advantages of the Gas- and Oil-engine 449
302.	Disadvantages of the Gas- and Oil-engine 451
303.	Conclusion

## CHAPTER XXI.

#### VAPOR-ENGINES.

305.	Introductory	454
306.	Formulæ for the Work of a Vapor	455
307.	Experimental Data for a Problem in Vapors as Heat Media	458
308.	Efficiency of a Volatile Vapor between given Temperature Limits.	462
309.	Efficiency of a Volatile Vapor between given Pressure Limits	464
310.	Effect on Efficiency of Certain Vapors by Adjusting Back-pressure	
	and Expansion Ratio	467
311.	Effect on Efficiency of Certain Vapors by an Increase in Pressure	
	Range	468
312.	Usual Vapor Media. Their Disadvantages	471
313.	Naphtha- and Gasoline-engines	473
314.	Binary Vapor-engines	474

xv

PAR.		PAGE
315.	Wellington Series Vapor-motor	476
316.	Ammonia Vapor-engines	479
317.	Combined Vapor-engines-Aero-steam Engines	480
318.	Storage of Energy in Liquefied Vapors	480
310.	Concluding Remarks	481

#### CHAPTER XXII.

## MECHANICAL REFRIGERATION.

325.	Introductory
326.	Analogy between the Heat-engine and the Ice-machine
327.	Refrigeration for Ice-making or for Cooling-chambers. Brines. 484
328.	Media for Use in Refrigerating-machines. Advantages and Dis-
	advantages
329.	Refrigerating-machines using Air as a Medium 488
330.	Ammonia Refrigerating-machines. Compression Type 492
331.	Hot or Cold and Dry or Hot Systems of Ammonia-compression. 496
332.	Ammonia Refrigerating-machines. Absorption Type 497
333.	Refrigerating-machines on Pictet System. Carbonic-acid
	Machines
334.	Temperature-entropy Diagram of Refrigerating Cycle 499
335.	Efficiency in a Refrigerating Cycle 502
336.	Refrigeration by a Series Process. The Step-by-step Process 505
337.	Design of a Refrigerating-machine 507
338.	Performance of Refrigerating-machines 510
339.	Freezing Mixtures. Some Low Temperatures. Liquid Air 511

#### CHAPTER XXIII.

## THE INJECTOR.

340.	Introductory	7 • • • • • • • • • • • • • • • • • • •	514
341.	The Injector	r Defined. The Ejector	514
342.	Mechanical	Principles Underlying the Injector. The Induced-	
	current P	rinciple	516
343.	Heat-transfe	er, Work, and Efficiency in the Injector	517
344.	Mechanical	Principle of Impact in the Injector	519
345.	Double-tube	Injector. The Inspirator	5 <b>2</b> 0
3.16.	Re-starting	or Automatic Injectors	521
347.	Exhaust-ste	am Injectors	522
348.	Advantages	of the Injector	522
349.	Disadvantag	ges of the Injector	522
350.	Appendix.	Tables of Hyperbolic Logarithms	525
351.	" .	Historical Bibliography	528
352.	**	General Bibliography	529
353.	**	Names of Scientists and Investigators	530
354.		Notes, Tables and References	530

'xvi

## LIST OF ILLUSTRATIONS.

FIG,	PAGE
1.	Indicator-diagram, with no Expansion 10
2.	" " Cut-off 10
3.	Hoadley's Air-thermometer 18
4.	Barrus' Coal-calorimeter 25
5.	Hollow Grate-bar, with Forced Draft 44
6.	Bagasse Furnace
7.	Thurman Oil-burner
8.	Urquhart Oil-burner 54
9.	Siemens Producer
10.	Taylor Producer
11.	Dowson Producer
12.	Lencauchez Producer
13.	Diagram of Chimney as a Siphon
14.	" Showing Chimney Capacity 105
15.	U Tubes as Draft-gauge 109
16.	Wollaston-Prentiss U Tube Draft-gauge 109
17.	U Tube Draft-gauge, with Hook-gauge Reading 110
18.	" Water-gauge 110
19.	Orsat Apparatus for Flue-gas Analysis III
20.	Chimney Constructions 116
21.	" "
22.	" " 116
25.	Induced-draft System, with Pre-heating of Air, S. S. Kensington 118
26.	Kafer's Forced-draft System, U. S. S. Swatara 119
27.	Mechanical Draft Arrangement, Union Traction Co., Phila 122
28.	Induced-draft Plant, American Line Pier 122
29.	Ash-pit, Hotel Iroquois, Buffalo 123
30.	Hawley, Down-draft Furnace 126
31.	Marston, Down-draft Furnace 127
32.	Sellers Extension Furnace 128
33.	Roney Step-grate 131
34.	Coxe Travelling-grate
35.	Wilkinson Mechanical Stoker 133
	xvii

## LIST OF ILLUSTRATIONS.

	P	GE
FIG.	Columbia Mechanical Stoker	134
30.	American Under-fed Stoker	135
25	" " " " Forced Draft	136
20	Ringelmann Smoke-scale	137
39.	Radiation Varying with Distance	143
40.	" and Contact Compared	146
41.	Heating surface Increases with Initial Temperature	155
12	Isopiestic Lines	186
43.	Isometric "	186
44.	Isothermal "	187
+5.	Adjabatic "	180
17	Isothermal "	105
15	Isentropic "	195
10.	Drawing of Isothermal Lines	196
50	" " Equilateral Hyperbola through a Point	106
51	Diagram of Regnault's Relation of Temperature to Pressure	203
52.	Fairbairn and Tate, Apparatus to Determine Specific Volume of	5
52.	Steam	221
53.	Diagram representing a Resistance f.s	230
51.	" an Effort $p.v.$	230
61.	" " a Variable Effort	235
62.	" " a Piston Effort with Back Pressure	237
63.	" Isothermal Expansion	238
64.	" Steam Effort in a Woolf Engine	247
65.	" ' in a Compound Engine	248
66.		248
67.	Diagram representing Steam Effort in a Receiver Compound	
	Engine	249
<b>6</b> 8.	Typical Rotary Engine	255
69.	De Laval's Steam Turbine	258
70.	Dow's Outward-flow Turbine	259
75.	Isothermal and Adiabatic Compression Compared	267
76.	Diagram representing Effect of Clearance in Compression	268
77.	" " " Multiple Stage Compression	271
78.	Two-stage Tandem Air-compressor, Ingersoll-Sergeant	274
79.	Diagram representing Isothermal Expansion	<b>2</b> 80
80.	" Temperature-entropy	280
81.	" for Actual Engine	285
82.	Diagram representing Temperature-entropy Vaporization incom-	
•	plete	287
83.	Diagram representing Temperature-entropy Expansion incom-	
~	plete	289
84.	Diagram representing Temperature-entropy, no Expansion	290
85.	" Steam superheated	291

## xviii

<i>LIST OF ILLUS</i>	TRA TIONS.
----------------------	------------

FIG,			PAG	GE
86.	Diagram	representing	Entropy of Water and Steam 20	92
87.		"	Saturation and Adiabatic Curves 20	93
88.	* *	**	Transfer of Points from pv to te Diagram 20	95
89.	" "	**	Carnot's Cycle 20	99
90.	6 6		Efficiency of Heat-engine 30	04
φı.		" "		01
02.	Diagram	representing	y Duty and Economy of Steam-engines	
	since 18	00		16
03.	Diagram 1	representing	Efficiency and Water Consumption	18
0.1.	"	"		т8
05.	* *	* *		10
-06.	Diagram	representing	Temperature and Pressure Change in	- 9
90.	Steam	representing		27
07	Diagram	representing	Temperature and Pressure Change in	-/
97.	Steam	representing	remperature and ricobare onange m	28
20	Tunical Si			20
901 100	i ypical St	iperneating.	fract of Clearance	30
100.	"	" C	coloulation of Clearance Volume	32
101.	D:	to illustrate	Colouistion of Mann Effective Processor	34
102.	Diagram	( (	Water per H. D. from Indicator diagram	35
103.			Water per HP. from indicator-diagram. 3	41
104.			Thermal Analysis of Engine test	45
105.			Inermal Analysis of Engine-test	54
100.				50
107.				57
108.	ъ. г.			00
109	Diagram	to illustrate	Gain by Reheating in Multiple-expansion	
	Air-eng	gines	3.	73
110.	Reheater	for Compres	ssed-air Transmission 3	77
115.	Diagram	representing	Complete Expansion 32	78
116.	••	" Ter	mperature-entropy in Complete Expansion. 3	78
117.	Diagram	representing	g Temperature-entropy in Partial Expan-	
	sion or	no Expansio	n	79
118.	Diagram	representing	g Compression 38	30
119.	" "	"	Adiabatic Compression 38	32
120.	" "	" "	" Expansion 38	32
121.	* *		Combination of the above 38	32
122.	" "	**	Temperature-entropy for above 38	32
125.	Stirling's	Hot-air Eng	gine	30
126.	Pressure	-volume Diag	gram of Stirling Air-engine 39	<b>)</b> I
127.	Tempera	ture-entropy	Diagram for Ideal Hot-air Engine 39	)2
128.		" "	" Stirling Engine 39	)2
129.	Ericsson	Hot-air Pum	ping-engine, Perspective 30	95
130.	" "		" , Section 39	<b>9</b> 5
131.	Pressure	-volume Diag	gram of Ericsson Engine 39	96

xix

## LIST OF ILLUSTRATIONS.

FIG.	Den de Diacon Frainc	AGE								
132.	Pressure-volume Diagram of Ericsson Engine									
133.	Section of Rider Hot-air Pumping-engine									
134.	Pressure-volume Diagram for Products of Combustion-engine	399								
135.	Temperature-entropy Diagram for a Hot-air Engine heating non-isothermally	401								
136.	Joule's Air-engine	403								
137.	Buckett's or Cayley's Products-of-combustion Engine	404								
140.	Lenoir Gas-engine, Sections 407,	408								
141.	" " Diagram	408								
1.12.	Otto and Langen Atmospheric Gas-engine	410								
1.13.	Beau de Rochas or Otto Cycle Ideal	413								
14.1.	Otto Engine Section	414								
145.	Clerk Engine Section	415								
1.16.	Atkinson Differential Gas-engine 417,	418								
147.	······································	418								
118.	" Cycle Gas-engine	419								
1.10.		419								
155.	Barnett Igniting-cock	422								
156.	Indicator-diagram Gas-engine	425								
157.		425								
158.	ee ' ee ee ee	425								
150.	ee ee ee	426								
160.		426								
161.	26 28 66 66	426								
162.	" " from Separate Cylinder	427								
163.	" " Ideal	432								
161.	Temperature-entropy Diagram for Gas-engine	433								
165.		135								
166.		137								
167.	««	439								
168.	66 66 66 66 <del>6</del> 6	440								
169.	66 66 66 66 <u>66 66</u>	446								
170.	Diesel Gas or Oil Motor	448								
171.	·· ·· ·· ·· ·· Card	448								
173.	Section of Otto Gas-engine Slide-valve	453								
175.	Ideal Indicator-diagram of Vapor-engine	456								
176.		463								
177.	es es es es	466								
178.	es es és és és	469								
179.	Naphtha-launch Engine	474								
185.	Binary Engine	475								
181.	Diagram illustrating Series Engine	479								
185.	Type Scheme of Heating and Refrigerating Organs	483								
186.	" " Organs Bell-Coleman Ice-machine	490								

 $\mathbf{x}\mathbf{x}$ 

## LIST OF ILLUSTRATIONS.

FIG.							PA	GE		
187.	Pressure-volume Diagram of Bell-Coleman Ice-machine 40									
188.	Ammonia Compression Refrigerating-machine 495									
189.	" Absorption Refrigerating-machine 498									
190.	Temperature-entropy	Diagram	for	Rei	frigera	ting Mach	nine	499		
191.	"	"	" "			"		501		
192.	**	"	" "	1	"	**	· · · ·	501		
193.			" "		" "	* *		502		
194.	Wellington Series Eng	gine	• • • •	• • •			· · · · · · · · · · · · · · · · · · ·	477		
195.	Temperature-entropy Diagram of Refrigeration by a Step-by-									
	step Process			• • •	• • • • • •		••••••	506		
196.	Type Section of Injec	tor		• • •			••••••••••••	515		
197.	Self-adjusting Injecto	r		• • •			•••••	521		
198.	Double-tube Injector.			• • •		• • • • • • • • • •	••••	521		

xxi



# HEAT AND HEAT-ENGINES.

## CHAPTER I.

## INTRODUCTORY.

**I.** Sources of Motor Energy.—There are three great sources of force or energy for industrial uses. The first to be utilized is the force resident in the contractile tissue of the muscles in man and animals, which is known as muscular force. The second is called the force of gravity and is the force by which the earth attracts all masses toward its centre. The third is the group of forces which become manifest or are released upon chemical reactions such as combustion or oxidation; the two most important of these latter are the forces of heat and electricity.

2. Limitations of Muscular Force and the Force of Gravity.—While the muscular force of men and animals varies with the race, species, size, health, training, temperament, and muscular endowment of the individual, yet certain fixed limits are set to the amount of energy to be gotten from any single unit. Large powers can only be obtained by aggregating many units, which is inconvenient and costly; but more than all, a limit is set by the endurance of the animal unit, which must have periods of rest and recuperation. Speed is also limited by the ability of the animal motor to

maintain a maximum effort for any length of time. Finally, there is no considerable reserve store of energy to be drawn npon if more effort is required.

The force of gravity becomes available as a motor force when a weight or mass is lifted to a higher level and is permitted to descend to a lower one. Solid weights are only serviceable when lifted by some other mechanical force; water and air are the only weights which are otherwise lifted further from the centre of the earth independent of man. The former is lifted by the sun in vapor to high levels of land, whence it seeks to descend to tide-water level again; and the winds are produced when colder and heavier air descends and displaces the lighter air which the earth has warmed. Gravity, therefore, as a motor force is dependent upon the availability of higher levels of land at which a sufficient mass of water can be accumulated, and an adequate reservoir in any particular region or an adequate flow from a source is a necessarv condition for the use of water-motors; and while there is an abundance of energy present in the atmospheric ocean at the bottom of which all industry is carried on, yet at present the reliability, controllability, and capacity which must belong to the satisfactory working of an industrial motor are lacking to windmills in most places except where used for pumping or where they can be used to store some other form of energy in accumulators.

This same series of difficulties has beset the successful application of the energy stored by the winds and other disturbances in the ocean waves. Tide-motors depend upon the lifting of the ocean level by the stellar or planetary attractions, and are reliable and controllable, although only made of large capacity at great cost; but the types of motors as yet devised to use the impact or lifting force of coast-waves have not proved reliable or permanent enough for engineers to venture to adopt or install them.

Since it is the sun's heat energy which lifts the water

and disturbs the equilibrium of the strata of air, it would appear that water-motors and windmills are in this sense heatmotors in the last reduction.

3. Importance of the Motor Energy Liberated on Combustion.-It will be at once apparent, on a moment's thought, that while the energy resident in falling water is most serviceable and is destined to become more so as the means of transmitting energy are improved, yet there are many causes which have acted to make the use of the steam-engine, the gas-engine, and the hot-air engine by far the most widespread at this time. The energy in falling water with a few notable exceptions is limited in amount both by the weight available and by the height of fall; while in combustible fuel or oil or gas there is stored an amount of available energy which is practically unlimited where the supply of combustible is not The energy, moreover, is in a compact bulk; fuel limited. can be had native in many regions where there is no head of water, and where fuel is not native it can easily be transported. It will be seen, therefore, that the study of those forms of motors which are so widespread compels the study of the laws and principles which underlie the phenomena of heat, and that the general name of heat-engines may properly be applied to such engines.

While every one believes that the near future is to reveal methods for generating or liberating energy directly from fuel in the form of electromotive force, and this is now done by the chemical reactions which occur in various electric batteries, yet at this writing the importance and extent of the applications of such methods make them lie in the province of the physicist still, rather than in that of the engineer.

4. Analysis of a Power Plant.—The industrial result in a power plant is the production of something which shall have a commercial or salable value. This may be a manufactured article, or it may be a safe transportation of goods or persons for which the community shall be willing to pay. Hence the last link in the power-plant chain will be as extensive as the entire field of industry.

The first step or link is the generation or liberation of energy to furnish the necessary power. In the heat-engine this occurs where the combustible fuel is burned in a proper furnace or fire-box. This liberated or generated energy must be suitably stored in a reservoir or accumulator from which it may be drawn off as required. In a steam plant this function is discharged by the boiler; in gas-engines this storage step is lacking. In water-power plants the liberation and storage are done for the engineer either before his work begins, or else the storage reservoirs or dams become very important features of his undertaking. The third step or link is the appliance whereby the energy stored in the second step, and held as potential energy, shall be transformed into actual energy by being permitted to act through a prescribed path under the control of a capable intelligence. This appliance is the engine or motor, which must be adapted to the force which is to be utilized both as to capacity and as to form, and which demands a knowledge of the laws and properties which attach to the medium whereby the energy is revealing itself. Fourth in the chain comes the machinery of transmission, whereby the motion of the motor or engine and its developing power shall be adapted or properly transformed to meet the uses and purposes of the machine whereby manufacturing or transportation is effected at the industrial end of the series.

The subject of transmission of power is by itself so important and extensive, and the industrial field so limitless, that power-plant study may properly be limited to the other or first three steps for convenience. The water-motor and the wind-motor will also be excluded from present consideration for the sake of confining the scope of study. The field will therefore become that which embraces the generation or liberation of energy in the form of heat, and the utilization of that energy in the heat-engine.

4
#### INTRODUCTORY.

5. Scheme of Classification.—In this view the subject of heat and heat-engines will group itself for study under the following heads:

- I. General Notions on the Phenomena manifested in Heat-engines.
- II. Sources of Heat, or Fuels; Generation or Liberation of Heat. Combustion.
- III. Transfer of Heat. Heating-surface.
- IV. Media used to Transfer Heat Energy to Engine-orgars. Properties and Physical Laws.
  - V. Work done by a Heat Medium; Relations of Heat and Force in Expansion and Compression. Cylinder Design.
- VI. Thermal Analysis of a Heat-engine. Heat Cycle and Efficiency.
- VII. Air-Compressor and Compressed-air Engine.
- VIII. Hot-air Engines.
  - IX. Internal-combustion Engine. Gas- and Oil-engines.
    - X. Vapor-engine.
  - XI. Mechanical Refrigeration.

A final chapter on the Injector is appended.

It will be observed that the latter sections are in a sense to be viewed as the fuller application of the principles discussed in the first six headings.

## CHAPTER II.

# GENERAL NOTIONS ON THE PHENOMENA MANIFESTED IN HEAT-ENGINES.

6. General and Introductory.-In order that the engineer may have a satisfactory form of motor, it must be one in which an adequate force acts through the desired space in a unit of time. A force of illimitable extent is of no practicable value unless it is exerted through a finite and measurable space. Hence every real engine has an organ capable of receiving the action of a force or effort, and capable of moving through a constrained path under the action of that effort. while the force is overcoming the resistance moving through the required distance. In countries which use and prefer the metric system, the unit of force is the kilogram, and the unit of path is the meter. The product of effort into its path is called work, and the unit of work is a kilogrammeter. Where the pound is the unit of force, and the foot is the unit of path traversed by the effort, then the work will be expressed by their product as before, but the work-unit will be in footpounds. For a large output of work from a motor, the footpound or kilogrammeter is inconveniently small; hence multiples are usual. The accepted standard as evaluated by James Watt from experiment is that called a "horse-power," and is equivalent to a work of 33,000 foot-pounds done in one minute. The equivalents of the horse-power are:

PHENOMENA MANIFESTED IN HEA	T-ENGINES.
-----------------------------	------------

Horse-power.	English	French	Austrian
	Foot-pounds	Kilogrammeters	Foot-pounds
	per Minute.	per Minute.	per Minute.
English and American	33,000	4,562.46	25,233.6
French	32,548.2	4,500	25,420.8
Austrian	33,034.2	4,567.14	25,800

The metric horse-power is more usually expressed as 75 kilogrammeters per second. The unit of electric output is known as the Watt, and represents a work in foot-pounds equivalent to  $\frac{1}{746}$  of a horse-power. One thousand watts or a kilowatt is therefore equal to 1.34 horse-power.

In heat-engines the universal practice is to have the effort which overcomes the resistance take the form of a pressure of a gas or vapor exerted upon a given area. It will appear hereafter how and why the heat produces pressure. If the elastic tension of the gas or vapor be expressed in pounds per square inch, and its pressure is exerted upon a disk or piston which fits a cylinder without leakage and which has an area expressible in square inches, then the product of the pressure into the area in these units will give a total effort in pounds. If the unit be the kilogram per square centimeter, and the area be in square centimeters, the effort will be in kilograms. The piston therefore must move through the necessary number of feet or meters per minute, in order that the horse-power required may be generated. Hence if S denote the space in the desired units through which the effort PA in the corresponding units is made to move in one minute, then the total work of one minute will be PAS in the required compound unit of foot-pounds or kilogrammeters. Since the usual heat-engine cylinder is of comparatively short length for convenience of construction, the common requirement is that the piston which fits it must traverse its short length many times in one minute. If L denote the length of the traverse of the piston in meters or feet, and N denote the number of times this traverse is made in one minute, then the

initial S above may be replaced by LN; whence the workexpression becomes

$$Work = PALN$$

in whatever units are used. Since the horse-power of the engine will be as many as the number of times that the unit 33,000 is contained in the total work in foot-pounds, the above will become

$$\frac{\text{Work}}{33000} = \text{H.P.} = \frac{PALN}{33000}.$$

Furthermore, if A be expressed in square feet instead of square inches, then AL represents the volume of the cylinder in cubic feet effectively filled at the end of each traverse of the piston, and if N denotes the number of times per minute that this volume is filled, it follows that the work-expression can be written

Work = 
$$PLAN = PV$$
,

when V denotes the volume filled in a unit of time by the working vapor or gas which causes the pressure P in the cylinder. The latter now must be given in pounds per square foot. PV is therefore a very general expression for work in foot-pounds per unit of time. It can also be used to express the foot-pounds of work done in one stroke of an actual engine if N be called unity, or the work done by one unit weight of vapor which occupies a specific volume V.

A steam-, gas-, air-, or vapor-engine operating so as to make the foregoing discussion apply to it may conveniently be designated by the general name of a *piston-engine*, and this term will be generally used for such machines in the discussions which follow. It applies equally well to a pump in which a fluid resistance represented by P in pounds per square foot is overcome, and a volume V of the fluid in cubic feet is displaced in one minute, whether by piston or by plunger.

7. Graphic Representation of the Work of a Pistonengine.—Since the work of a piston-engine is the product of

## PHENOMENA MANIFESTED IN HEAT-ENGINES

two factors—feet multiplied by pounds, or foot-pounds,—it is obvious that a closed figure can be drawn enclosing an area which, upon an assumed scale of units, shall be the same as the given product in foot-pounds. Furthermore, whatever the shape of that figure, a rectangle can be drawn the product of whose base into its altitude will give the same area, or represent that same number of foot-pounds of work.

In piston-engines it will become manifest later that the figure representing the work takes a small number of typical It is convenient to agree to represent pounds by the shapes. vertical ordinates, parallel to the coordinate axis of Y, and to represent feet by the horizontal abscissæ, parallel to the coordinate axis of X. A piston-engine can then be made to draw its own work-diagram by a simple device. If the pressure P from the storage source of supply which is to force the piston forward be also let into a small cylinder of known area of cross-section, and bear upon a piston in that cylinder whose motion is resisted by a calibrated spring, then the piston effort and spring distortion will balance at a certain point. If a marking-point or pencil be attached to the spring piston, the position of equilibrium of pressure and spring can be marked and noted. Further, if the motion of the enginepiston be given to a board or drum in a horizontal direction, while the pencil which is controlled by the calibrated spring travels vertically, the condition is fulfilled of having the horizontal dimensions of the traced diagram represent feet or be proportional to feet, while the vertical dimensions represent pounds or are proportional to pounds. An instrument embodying this principle, and modified to conform to conditions of convenience and accuracy, is called the Indicator.

If the P.V. form of the expression for work is preferred, then the horizontal lines will be proportional to volumes. The linear length of the engine-stroke must be multiplied by a factor representing the area A of the engine-piston. In the first case, the area of the work-diagram gives the work per each square inch of area of the engine-piston, and must

be multiplied by the same area A to give the work of the entire piston. Hence either method may be followed as is most convenient.

The simplest case of work-diagram is presented in Fig. 1.



Here the pressure Pfrom the boiler or reservoir is constant throughout the stroke of the engine, and the diagram is essentially a rectangle. If, however, the pressure is not constant (and it will be seen hereafter to be desirable that it should

not be) throughout the whole stroke, then the general form of the diagram will be that of Fig. 2. Here, beginning at



FIG. 2.

the upper right-hand corner, there is an admission at constant pressure up to the end of the upper horizontal line, and

# PHENOMENA MANIFESTED IN HEAT-ENGINES. II

then a fall of pressure gradually, as given by the curved lines, indicating a variable or varying pressure down to the lower left-hand end. The curves at the right and left sides of Fig. 2 indicate a variation of pressure with volume of cylinder; and the how of such variation (if there is one) has obviously a considerable effect on the work done in a piston-engine per stroke. It further deserves study to ascertain what it is which causes a variation in the vertical distance apart of the upper and lower lines of the work-diagram and what are the laws of its action. These obviously affect also the power to be gotten from the engine.

Here, then, is the problem. The proportions of the work-diagram in a heat-engine as to size and shape are affected by heat. What is heat, and what are its laws and principles?

There are other diagrams which may be drawn to present the operation of heat-engines, besides the pressure-volume diagram above discussed. These will be referred to in their proper connection hereafter, and after the indicator (or P.V.) diagram has been considered.

# CHAPTER III.

#### GENERAL NOTIONS ON HEAT.

8. Introductory.—It should be stated at the very outset of study that the essence or nature of what is called heat is not known. Like the nature of the force of gravity or the vital force, a mystery as yet impenetrable shrouds everything concerning it except the phenomena which it occasions. Hence it has been the function of the physicist and mathematician to find hypotheses or assumptions which shall explain and agree with the phenomena, and which shall further enable predictions to be made as to the results to be anticipated with untried combinations. Such hypotheses or theories must explain and agree with *all* phenomena if they are to be acceptable, and one discordant or unexplained phenomenon is sufficient to throw doubt on the working theory then in general acceptance.

It belongs to the province of the physicist rather than to that of the engineer to review the theories concerning heat which have heretofore prevailed. Fortunately it is not necessary for the engineer to be conversant with the refinements of theory to be able to use its general principles with intelligence.

The universally accepted theory of heat is based upon the postulate which is known as the Conservation of Energy. This announces that force is as indestructible as matter, and that the most which happens to energy when apparently dissipated is its conversion into other forms of energy, just as

## GENERAL NOTIONS ON HEAT.

matter is converted into other forms of matter when a combination is apparently destroyed. This theory is known as the Dynamic Theory of Heat or the Mechanical Theory of Heat, and its axiom is that "Heat is a Mode of Motion."

9. Mechanical Theory of Heat.—The phenomena of the conversion of work into heat have been long observed in the effects of impact, of heat from rubbing friction and abrasion, and the like. Rumford's historic experiment (1798), Davy's investigations (1799), and the work of other physicists led up to the work of Dr. Julius Robert Mayer of Heilbronn (1832–1842) in Germany, and the quantitative research into the convertibility of work into heat by Dr. Joule of Manchester, England (1843). Later Sir William Thomson (1850) extended analogous principles to electricity, and the name Thermodynamics has been applied to the science which is concerned with the relations between heat and mechanical energy under all conditions.

The fundamental law of thermodynamics, sometimes called the first law, is that *Heat and mechanical energy are mutually convertible*; and heat requires for its production and produces by its disappearance mechanical energy in the proportion of 778 foot-pounds for each British thermal unit. This law is physical and experimental; it is a deduction from phenomena and tests, rather than an intuition or an axiom.

10. The Mechanical Equivalent of Heat.—The factor 778 was originally determined by Joule to be 772; later determinations give it the higher value (Rowland). Joule's experiment was to find the weight which, falling through one foot in height, would produce an amount of heat sufficient to raise one pound of water one degree on the Fahrenheit thermometer-scale. This factor is called the mechanical equivalent of heat; in metric units it has a similar definition, but the value of the factor is 426.8 kilogrammeters per kilogram of water raised 1° centigrade. Out of respect to its first investigator it is usually designated by the first letter of his

name, and is represented in formulæ by the initial J. Its reciprocal, or  $\frac{I}{J}$ , is often designated by the capital letter A.

**II.** The British Thermal Unit.—In enunciating the first law of the accepted theory of heat, the words British Thermal Unit were used. What is a thermal unit?

The thermal unit, or unit of heat, is the quantity of heat or the corresponding energy in foot-pounds which will raise a unit of weight of water through one degree of the accepted scale of a thermometer. The British thermal unit is therefore the quantity of heat or energy which raises one pound of water one degree Fahrenheit; the metric unit is the quantity of heat or energy which will raise one kilogram of water one degree on the centigrade scale. The metric unit is called the calorie and is 3.968 (roughly 4) times the B.T.U. Strictly, the B.T.U. is the heat required to raise one pound of water from 39° to 40° Fahrenheit, and the calorie is the heat necessary to raise one kilogram of water from 4° to 5° These figures are those at which water has its centigrade. greatest density from experiment. Many engineers and writers use the temperature of melting ice as the startingpoint, and recent British and French authorities prefer to use 62° Fahrenheit or 15° Centigrade as the base. This difference will explain some discrepancies among accepted authorities upon these questions.

12. Specific Heat.—It must follow from § 9 that if heat and energy are mutually convertible, then different bodies must vary with respect to their capacity for receiving, storing, and giving out this energy. In the general field of mechanical science it has been found that the measure of stored energy in a moving organ of a machine or a free body is made up of the product of its MASS by the half-square of its velocity of motion  $\left(\frac{Mv^2}{2}\right)$ . In molecular or atomic motions such as those in question in heat-motion, the same conceptions

### GENERAL NOTIONS ON HEAT.

are supposed to apply, the only differences being the infinitesimal character of the atomic mass, and the probably inconceivably great velocity of the motion—whatever it may be. Hence the mind is ready to accept the observed fact of such great differences in the thermal capacities of different bodies, and also the differences in the same body in different states.

Speaking generally, then, the quantity of heat or energy which is required to raise a unit mass of a substances by one heat-unit will be called its specific heat. It will be seen hereafter that this general statement needs to be guarded in cases where any other change occurs by heat applied to a body besides an increase in its temperature (see § 116). The specific heat of bodies, solids, liquids, vapors, and gases requires to be experimentally determined by the physicist in the laboratory. Tables of specific heats appear in an Appendix. Water has a specific heat of unity by agreement among experimenters, both because its value is so large, and also because it is so conveniently used in comparisons and transfers.

13. Temperature.—It follows from the mechanical theory of heat and the above discussion that temperature, as measured by the appliance called a thermometer or by the human sensorium, is not a measure of the amount of heat energy resident in any two or more different bodies or masses. It is an indication of its intensity, however, and of that portion of the total energy which can affect the senses of the observer. An experiment to show this is made by taking equal weights of two bodies like iron and water at the same temperature, and putting them into another quantity of some liquid at another temperature. The water will transfer much the more heat to the liquid.

It will appear shortly, however, that the product of the mass or weight by its specific heat and by its temperature (the latter being properly observed) will give a measure of the heat energy. Of two bodies of the same substance and therefore having the same specific heat, but being at different temperatures, and near each other, the hotter body tends to become cooler, and the cooler body becomes hotter by the receipt of transferred heat-motion. Heat passes of itself from a hotter to a cooler body, but this process does not reverse except by introducing a factor of mechanical energy to cause it to do so.

14. Thermometers.—Appliances for measuring or observing differences in temperature (but not differences of heat necessarily) are called thermometers. Most of them depend upon the property of a liquid—mercury or alcohol—whereby it expands equally for constant increments of temperature (see § 113). If the liquid is confined in a tube of fine calibre, the expansion is easily read on a properly graduated scale. Solids have this same property of expansion by heat, and can be used for higher temperatures. They are then often called pyrometers. Gases can also be used in thermometry.

Without entering too deeply into this subject, there are two fixed points of temperature which are used in graduating thermometers: the point at which ice melts, and the point at which water boils under a pressure of one atmosphere. The latter is that given by Regnault's determinations, of 14.7 pounds per square inch above vacuum, or 2116.2 pounds per square foot.

The Fahrenheit scale calls melting-ice temperature that denoted by 32° on its scale, and boiling-water temperature is 212°. Its zero-point is thus 32 degrees lower than melting ice.

The centigrade scale divides the 180 degrees Fahrenheit between melting ice and boiling water into 100 parts, and places its zero at the melting-ice point.

The Réaumur scale divides the 100 degrees of the centigrade scale into 80 parts.

The transformations from one scale to the other are not difficult. See Appendix.

### GENERAL NOTIONS ON HEAT.

15. Air-thermometer.—At high temperatures the liquids used in thermometer-tubes become vapors, and at low temperatures the liquids freeze. This change of state of the registering body is not only inconvenient, but is accompanied by inaccuracy and uncertainty near both limits. Hence it has been sought to use a permanent gas as a thermometer, and air has been most used by reason of its convenience and adaptability.

In principle the air thermometer consists of a perfectly cylindrical tube, closed at the bottom, and containing a quantity of air below a bubble or drop of mercury in the tube, which is to serve as a register for the expansion of the air below it. If the air-volume below the mercury be exposed at the pressure of one atmosphere (the barometer reading 20.022 inches) to the temperature of melting ice, and the position of the bottom of the mercury telltale is marked, and then to the temperature of boiling water, and a similar mark made there, the range for the 100 or 180 degrees of the usual thermometer is given, and the fixed points are determined. Regnault's investigations showed that for a length of air-column below the lower mark, represented by unity, the length from the bottom to the upper mark would be 1.3665-that is, the expansion between these limits is 0.3665 of the original volume. Hence it would appear possible to graduate such a tube by means of this property, assuming that no changes in other properties occur at wide ranges beyond the range of experience. The graduation upward for high temperatures offers nothing unusual, but the graduation below the point of melting ice leads to an interesting inference.

If the Fahrenheit degrees be used for the length of 0.3665 times the unit length, then each degree of the air-thermometer has a length

$$\frac{0.3665}{180} = 0.00203611$$

of the unit length below the line marked for melting ice, or for each degree Fahrenheit of increase in temperature or decrease the airvolume increases or decreases by that fraction of its length. If it decreases by ..... i of its length for each degree Fahrenheit, then at a temperature Fahrenheit represented by 491.13 below 32°, or 459.13 below zero, a temperature must be reached at which the property of further reduction of volume by withdrawing heat or heat energy disappears. In other words, the body appears to have no heat energy at that This is called, therefore, the absolute point. zero of the air-thermometer. If the degrees be numbered from this point, ice melts at 491.13° and boils at 671.13°. For centigrade scale of degrees the air-thermometer zero is 273° below the zero of the ordinary scale at melting-ice temperature. Fig. 3 illustrates a form of air-thermometer, the result of effort by Mr. Fred W Prentiss and the late J. C. Hoadley.

16. Absolute Temperature.—If air were a perfect gas, or one which would expand exactly so that its rate of expansion would be the same as that at which it absorbs heat, the air-thermometer scale could be used as an absolute temperature scale. It is practically so, and will be so used hereafter. The only error comes in determining the zero of the absolute scale. The work of Joule and Thomson (1854) and that of Rowland (1879) have shown the discrepancies between the real and ideal readings (see Appendix).

The absolute zero as computed for a perfect gas is  $492.66^{\circ}$  F., or  $273.7^{\circ}$  C., below the melt-ing-point of ice.

G

Air Thermometer: constant volume: Safe up to ew E- say cash, C. Scale, ¼ full size

## GENERAL NOTIONS ON HEAT.

The significance and usefulness of the absolute scale is very great in work with heat and heat-engines. In fact it is indispensable. From what has preceded (§§ 9, 12, 13) the total heat energy present in any body at any time will be the product of its weight by its specific heat by its absolute temperature, when no energy or heat is in process of absorption in doing work upon the body itself. If the mass is a unit of weight, and two differing states of the same body are compared, then the difference in absolute temperature measures the heat energy which has been given out or absorbed under the same limitations.

17. Total and Intrinsic Energy.-It will appear finally from the foregoing discussion that the total energy resident in a body is not always to be evaluated by its temperature or by the thermometer alone. Part of it may be measured when changes of such energy occur, when the specific heat is known, and the initial and final temperatures absolute or But such parts of the heat energy as are taken up ordinary. in changing the molecular motion of the atoms of the body are said to become latent or hidden because the usual appliances do not record them, and by certain other parts of an applied heat energy an external work in foot-pounds may be done which the thermometer will not reveal (§ 111). It is obvious, therefore, that some attention must be directed to the effects of heat energy upon the substances upon which it acts, and the means of producing that energy or liberating it if stored.

The latter will be taken up first.

Intrinsic energy in a body is its capacity for performing work by virtue of the heat energy resident in it, without addition of such energy from without. The zero of heat energy is at the absolute zero. The inner or intrinsic energy at any other absolute temperature will be the product of its weight into its specific heat into the range of its absolute temperature above absolute zero.

# CHAPTER IV.

### GENERATION OR LIBERATION OF HEAT.

# COMBUSTION.

18. Introductory.—To supply the energy in foot-pounds required to overcome a considerable resistance, and to do this for a heat-engine in which 778 foot-pounds shall correspond to one heat-unit, requires that there shall be continually introduced into the heat-engine through a proper organ the necessary supply of heat-units in each unit of time. From what source or sources shall this heat and energy be drawn ? While heat appears as a transformation of mechanical energy in friction, impact, abrasion, attrition, and in overcoming electrical resistances, these sources are excluded when the object sought is heat which may itself be transformed into mechanical energy.

19. Heat from Combustion.—The most widespread, convenient, and cheap source of heat has been found as the result of causing the oxygen of the atmosphere to combine chemically at a sufficiently rapid rate with certain other of the chemical elements. Oxygen combines with many of the metals or bases or elements as with iron, manganese, boron, phosphorus, and the like, but these are either too costly to serve as convenient sources for heat, or else the process of oxidation is so slow that sufficient heat cannot be derived from them in a short time.

*Combustion* may be defined as a combination with oxygen which takes place with sufficient rapidity to be accompanied by the phenomena of heat and light. The elements which are found to possess the affinity for oxygen which is required

### GENERATION OR LIBERATION OF HEAT.

for combustion are Carbon and Hydrogen, as elements or as compounds. Sulphur often enters into compounds of carbon and hydrogen, but has an unimportant position, so as to be usually negligible. A carbon or a hydrogen element or a hydrocarbon compound, found native or manufactured so as to be obtainable in sufficient quantities and at a low cost to be used as a source of heat, will be called a *fuel*.

20. Certain Phenomena of Combustion.—It is desirable to secure a greater exactness of conception concerning certain facts in connection with the generation of heat from fuel.

In order that practical combustion of a fuel may occur, it must be "set fire to." *Ignition* is the beginning of active chemical action, and the first step in a combustion. Most combustibles require to be raised at their surface to a certain temperature before this ignition, or "taking fire" will occur, or if kept cooled below this temperature of ignition the combination of oxygen will not occur, or will cease if it has before been in progress. This temperature of ignition is quite high for many fuels, and its maintenance has an important bearing upon smoke-prevention. Ignition is most easily secured by a flame, and a flame is one of the indications of such ignition.

A *flame* is a body or current of gas carrying in it solid particles at such a temperature as to glow or give out heat and light. These solid particles are usually carbon in a finely divided state, and the heat of the flame is roughly measured by the degree of the incandescence or glowing of these particles. A red flame is not so hot as a yellow flame, and a white flame is the hottest of all. Flame is produced when the supply of oxygen at the place where ignition occurs is not quite sufficient to form at once a gaseous product of the combustion. When the supply of oxygen is copious and means are taken to heat it and mix it thoroughly with the combustible matter, then the heat is very great at the

2 I

point of combustion, but there is little or no flame. The gases are blue or colorless and have little heating power except by contact. The heat from the particles glowing in the flame is given off from a large extent of surface, and for many purposes the flame is preferred to the non-luminous gas-current of theoretically perfect combustion. Purely gaseous substances do not as a rule become luminous by heat.

If by means of preheating the air or by other expedients a great elevation of the temperature of ignition be secured, it has been found possible to exceed the limit at which oxygen will combine with carbon or hydrogen. The gases move separately without uniting, or if united they seem to separate. This excessively high temperature is called the "temperature of dissociation of the gases."

In the combustion or ignition of solid fuel it is probable that the first effect of the heat of the igniting flame is to distil off from the surface or render gaseous a thin external film, which gas combines with the oxygen. All ignition or inflammation takes place at the surface of large bodies whether of solid, liquid, or gaseous combustibles. Hence the imperative necessity of intimate mixture of oxygen with the combustible gas if combination is to take place in a short period of permitted contact.

Incandescence is strictly to be defined as a condition of great heat energy, accompanied by light and heat, without chemical action. True incandescence is that of the filament in an incandescent or glow electric lamp. The so-called incandescence of the glow-worm and that which appears in forms of phosphorescence and fluorescence are so called only by a permitted extension of the term. True incandescence involves the idea of light due to heat. Incandescence, however, is often extended to include the condition in which the chemical action is quite relatively slow. It is in this sense that the particles of glowing carbon in a flame-current are incandescent, or the bed of coke or carbon free from volatile

# GENERATION OR LIBERATION OF HEAT.

compounds is incandescent when undergoing slow combustion without appearance of flame or gas.

It is the slowness or reluctance of the combination with oxygen on the part of the incandescent particles in flame which makes perfect combustion of luminous flames a troublesome problem in some cases. If the carbon particle does not burn to gas while hot enough to unite with oxygen, it cools to black-carbon, lampblack, or soot. A current of gas carrying such solid black particles in it is called "smoke" in the engineering use of that word.

21. Spontaneous Combustion. Explosion. - While it usually requires the heat of a flame to start combustion by ignition, yet the absorption of oxygen by a body in a favorable condition for this action may be so rapid that this chemical combination will raise the temperature of a combustible up to the point at which it will burst into a flame. This action is called spontaneous combustion. Spontaneous ignition would be a better term and more exact. The condition favorable for it is the presence of a readily oxidizable body, distributed in a finely divided state over some material whereby a great surface is exposed to action by the oxygen. Oilv rags and greasy waste fill this condition, and both are particularly liable to the accident. The more oxidizable the oil, the worse the danger. Vegetable oils are particularly liable to this rapid action. Coal-dust in bunkers, by reason of the oxidation of the sulphur in it, also may set fire to itself. Τf the heat of oxidation can be conducted off as fast as generated, spontaneous ignition is less likely to occur, but as a rule the porosity which exposes a large surface to oxidation is unfavorable to the transfer of the heat. Capillary action may also act to help the oxidizing process.

An *explosion* is a form of combustion or ignition which is practically instantaneous, or so rapid that a large volume of gas is generated and fills the volume previously occupied by the material which has been transformed into gas from some

less bulky form. This great increase of volume forces the air in every direction, and its concussion outward or its return inward causes the report or noise. The conditions for an explosion are the presence of combustible gas mixed with air and brought by flame at some one point to the temperature required for ignition; or the combination of gasifying solids with others rich in oxygen and ready to give it up, and the bringing of one point up to ignition by heat or friction or percussion.

A phenomenon essentially identical with an explosion appears when an atmosphere is full of a combustible dust in a finely divided state. The fine division produces a condition analogous to that when spontaneous combustion is probable; the large surface for oxidation makes the gas from combustion form so copiously and rapidly that the ignition is practically an instantaneous gasification when a spark or flame is introduced into such an atmosphere. Coal-dust in mines, and flour-dust in mills, are liable to this form of rapid gasification.

22. Calorific Power of a Fuel.—It will be obvious that different elements and different compounds will differ from each other in their ability to supply heat for use in a heatengine. The Calorific Power of a fuel is the amount of heat, expressed in thermal units, which is liberated upon the combustion of a unit of weight of the combustible material. The calorific power of a fuel does not depend upon the rapidity of the combustion nor on the time taken in the process of absorbing the total heat of the combustion. The temperature produced by the combustion does depend upon the rate of combustion, as will be seen in the next paragraph.

The calorific power of a compound is the sum of the calorific powers of its constituents. If, therefore, the calorific power of the elements carbon and hydrogen have been carefully and exhaustively determined in the physical laboratory, the calorific power of a natural fuel or an artificial mix-

## GENERATION OR LIBERATION OF HEAT.

ture may either be computed from the percentage or weight of each constituent in the analyzed fuel, or the fuel may itself be exposed to experimental determination of its calorific power as the elements were. This latter method is the most satisfactory.

23. Coal-calorimeters.—The calorific power of a fuel is found experimentally by causing a known weight of the fuel

to burn in a closed vessel surrounded by an observed weight of water. The number of heat-units absorbed by the rise of that weight of water through its observed range of temperature gives the calorific power. The apparatus used in this experiment is called a calorimeter or heat-measurer, and rightly. Fig. 4 illustrates Mr. Geo. H. Barrus' appliance. To eliminate errors caused by introducing the nitrogen of atmospheric air, oxygen gas is usually supplied to support combustion. It would be foreign to the present purpose to pursue the subject of calorimetry fully, but references to more exhaustive treatises will be found in the Appendix. Values for the calorific power are given under the data concerning fuels (§§ 58 to 60).

BARRUS' COAL CALORIMETER FTG. 4.

24. Air Required for Combustion of Carbon.—Since combustion is the chemical union of oxygen with the combustible elements, it must take place according to the laws of chemical combinations, and the weights of air for each element will be those which will furnish the oxygen weight demanded by the relations of the atomic weights in the chemical compounds which are formed.

Atmospheric air contains oxygen and nitrogen in the following proportions, at a temperature of melting ice:

В	y Weight.	By Volume.
Oxygen	0.236	0.213
Nitrogen	0.764	0.787
	1.000	I.000

Whence a given quantity of air weighs  $\frac{1000}{236} = 4.25$  times the weight of the oxygen which it contains, and  $\frac{1000}{764} = 1.31$  times the weight of nitrogen which it contains.

By volume a given quantity of air will occupy  $\frac{1000}{213} =$  4.69 times the volume of oxygen which it contains; and  $\frac{1000}{787} =$  1.27 times the volume of the nitrogen which it contains.

When carbon burns to carbonic acid, which is the normal and preferred combustion process, the chemical equation for the process and result is

$$C + O_2 = CO_2,$$
  
 $12 + 32 = 44,$ 

in which C is the symbol for one part by weight of carbon;  $O_{a}$  is the symbol for the two parts of oxygen required to burn the carbon to carbonic acid, whose symbol is  $CO_{a}$ . The figures below each are the respective multiples of their atomic weights for combination; whence it appears that the oxygen weight needed will be given by the proportion:

or 2.66 pounds of oxygen must be furnished to burn the one pound of carbon completely. The weight of the carbonic acid, CO<sub>2</sub>, will be the sum of the weights of carbon and oxygen, or 1 + 2.66 = 3.66 lbs.

When the combustion is effected by supplying atmospheric air, there must be supplied from the foregoing calculation concerning atmospheric air  $2.66 \times 4.25 = 11.3$  lbs. of

air. Add 1.0 lbs. of carbon. The products of the combustion will weigh 12.3 lbs. and will consist of carbonic acid and nitrogen.

Similarly the volume of air in cubic feet to burn one pound of carbon can be calculated from the weight of it. At atmospheric pressure and at the temperature of melting ice a pound of air occupies 12.39 cubic feet. Hence 11.3 pounds of air will occupy  $11.3 \times 12.39 = 140$  cubic feet at  $32^{\circ}$  F., or 152 cubic feet at  $62^{\circ}$  F.

When carbon (C) burns to carbonic oxide (CO) instead of to carbonic acid  $(CO_3)$ ,

$$C + O = CO,$$
  
 $12 + 16 = 28,$ 

whence the oxygen is  $\frac{16}{12}$  of the unit weight of the carbon, and 1.33 pounds of oxygen or 1.33  $\times$  4.25 = 5.65 pounds of air are required. The products of the combustion are 2.33 pounds of carbonic oxide. The weight of air for this combustion will be 1.33  $\times$  4.25 = 5.65 pounds of air, or 5.65  $\times$  12.39 = 70 cubic feet of air at 32° F., or 76 at 62° F.

If the CO burns as a combustible gas to CO<sub>2</sub>, the additional supply of air is required as in the preceding case.

25. Air Required for Combustion of Hydrogen.—Hydrogen burns to water-vapor or steam-gas, whose chemical symbol is H.O. The chemical equation is

$$H_{2} + O = H_{2}O,$$
  
2 + 16 = 18,

whence one pound of hydrogen requires  $\frac{1.6}{2} = 8$  pounds of oxygen, and 8 + 1 = 9 pounds of water-vapor result as products of the combustion, if oxygen is used alone.

Eight pounds of oxygen need  $8 \times 4.25 = 34$  pounds of air, making 34 + 1 = 35 pounds of water and nitrogen as the actual weights of the products of combustion. The volume of air for hydrogen combustion is  $34 \times 12.39 = 421$ cubic feet of air at  $32^{\circ}$  F. or 457 cubic feet of air at  $62^{\circ}$  F.

26. Air Required for Combustion of Compounds.—In the burning of compounds of carbon and hydrogen each acts as though the other did not exist, and the air required is the sum of the requirements of the constituents. Marsh-gas, for instance, known also as light carburetted hydrogen or methane, of composition CH<sub>4</sub>, requires

$$C + O_{2} = CO_{2} = 12 + 32 = 44$$
  
H<sub>4</sub> + O<sub>2</sub> = 2(H<sub>2</sub>O) = 4 + 32 = 36  
Total = 16 + 64 = 80

The added oxygen is four times the weight of the original gas, or one pound of gas gives five pounds of carbonic acid and water if no nitrogen is added. Four pounds of oxygen will be furnished by  $4 \times 4.25 = 17$  pounds of air at  $32^{\circ}$ , or  $17 \times 12.39 = 208$  cubic feet of air at  $32^{\circ}$ , and giving 18 pounds of CO<sub>2</sub>, H<sub>2</sub>O, and N.

The proportions of the CO<sub>2</sub> and H<sub>2</sub>O were respectively  $\frac{44}{80}$  of the former and  $\frac{36}{80}$  of the latter; or there was one part of water to 1.22 parts of carbonic acid, since

Similarly for olefiant gas, ethylene, C<sub>2</sub>H<sub>4</sub>, the equations will be

$$C_{2} + O_{4} = 2CO_{2} = 24 + 64 = 88$$
  
 $H_{4} + O_{2} = 2H_{2}O = 4 + 32 = 36$   
 $Total = 28 + 96 = 124$ 

That is, for a weight of gas (28) will be required a weight of oxygen (96), or 3.43 pounds for one pound of gas, making 4.43 pounds of CO<sub>2</sub> and H<sub>2</sub>O, and calling for  $3.43 \times 4.25 =$  14.58 pounds of air, or 14.58  $\times$  12.39 = 180 cubic feet of air, at 32°.

The products of combustion will be 14.58 + 1 = 15.58 pounds of CO<sub>2</sub>, H<sub>2</sub>O, and N, and in this combustion one part of water goes to 244 parts of carbonic acid.

If there is sulphur enough in the fuel not to be negligible,

## GENERATION OR LIBERATION OF HEAT. 29

then an additional chemical equation is required and more oxygen; S burns to SO<sub>4</sub>, or 32 + 32 = 64.

One pound of oxygen is required for each pound of sulphur, corresponding to 4.25 pounds of air or 12.39  $\times$  4.25 = 52.65 cubic feet of air at 32° or 57 cubic feet at 62° F.

27. Combustion of an Analyzed Fuel.-The chemical analysis of a fuel gives the percentage or weight of C, H, S, and O in a pound. Hence the calculation for the weight or volume of air is identical with the foregoing, except by reason of the provision for satisfying the oxygen in the fuel itself. The investigations of Dulong and Despretz and others have shown the principle to hold, that when oxygen and hydrogen exist in a compound in the proper proportions to form water by union with each other, these constituents have no effect either in affecting the calorific power or the demand for outside oxygen for combustion. It is only the surplus hydrogen above that necessary to form water with the oxygen which need be considered; or instead of using the total per cent or weight of hydrogen, the latter is diminished by one eighth of the weight of oxygen, since one part of hydrogen by weight goes to eight weights of oxygen.

By volume

each per cent of C requires 140  $\times$  C  $\div$  100 cu. ft. of air, 66 " " " " " H " 421 X H ÷ 100 " ·· S " " 66 "  $52 \times S \div 100$ " "

so that the above principle gives

Volume of air = 
$$\frac{140C + 421(H - \frac{O}{8}) + 52S}{100}$$
.

By weight, for a fuel containing C and H,

Weight of air =  $11.3C + 34(H - \frac{O}{8})$ . This is more usually written:

Weight of air =  $12C + 36(H - \frac{O}{8})$ .

28. Weight of Products of Combustion with an Analyzed Fuel.—Bringing together the data and results of the preceding paragraphs:

One pound of C makes 2.66 + I = 3.66 pounds of CO<sub>2</sub>; " " " H " 8 + I = 9 " " H<sub>2</sub>O; " " S " I + I = 2 " " SO<sub>2</sub>.

Hence if C, H, and S denote the respective percentages of these elements in the fuel in question, then

3.66	÷	100	=	.0366C	=	weight	of	CO,,
9	÷	100	=	.09H	=	" "	" "	H₂O,
2	÷	100	=	.02S	=	" "	"	SO,

if the combustion were in oxygen. Being effected by air, however, the weight of the products of combustion will be greatly increased, since the nitrogen weighs  $\frac{764}{236}$  or 3.23 times the weight of oxygen it contains. Hence for

I	pound	of	С	are	added	2.66	Х	3.23	=	8.59	pounds	Ν,
I	" "	"	Η	"	" "	8	X	3.23	=	25.84	" "	Ν,
I	" "	"	S	"	" "	I	×	3.23	=	3.23	" "	Ν,
I	" "	"	Ν	" "	" "	I			=	I	"	Ν,

if the fuel analysis shows nitrogen in it. So that if these weights be reduced to percentages of each by multiplying the weight of each constituent by the above weight of N and dividing by 100, the weights of  $CO_2$ ,  $H_2O$ ,  $SO_2$ , and N become increased as shown in this expression:

Weight of	Per cent	of C $>$	<	for ''	$\frac{O_{3}}{N} = .122C;$
$\left. \begin{array}{c} \text{Products} \\ \text{of Com-} \end{array} \right\} =$		'' H >	< { .090	"	$\frac{O}{2}$ = 24 C ·
bustion			(.258	"	N = .34C;
-		" S >	\$.020	4.4	$O_{1} = .052S$
		- ,	`(.032	" "	N 10,220,
·	L "	" N >	10. >	" "	N = .010N;

in which C, H, S, and N in the last column are the respective percentages as given by the analysis.

29. Volume of Products of Combustion with an Analyzed Fuel.—While the foregoing calculation is most general, since the weight is independent of the temperatures of the products of combustion, the practical form of the problem is more often concerned with their volume, and this varies with the temperature. With the same conditions of pressure, if  $V_{\circ}$  denote the volumes at the temperature of melting ice as given hitherto, and  $T_{\circ}$  the corresponding absolute temperature, while V and T are the volume and absolute temperature corresponding to the state of the hot and expanded gases, a later discussion will show that  $V_{\circ}T = VT_{\circ}$ , or the volumes will be proportional to the absolute temperatures, whence

$$V = \frac{V_{\circ}T}{T_{\circ}}.$$

Similarly if the initial volumes be observed or taken at 62° F., the final or expanded volumes can be calculated. For example,

whence

Adding and neglecting the smaller weight of SO<sub>2</sub>, the volume at 62° F. becomes

$$V_1 = 1.475C + 5.39H$$
,

and the volume  $V_{1}$  at any greater temperature will be found

by multiplying the above expression by the fraction  $\frac{T_s}{T_1}$ , in which  $T_1$  is the absolute temperature corresponding to  $62^{\circ}$  F., and  $T_s$  the absolute temperature at which the volume is sought.

30. Dilution of the Products of Combustion.-Where the arrangements for the air-supply to the combustible fuel are inadequate, and where proper mixture of oxygen and the combustible gases is lacking, it may come about that the spaces in and above the fire are so filled with CO, or carbonic acid gas, which is not a supporter of combustion, that an excess of air has seemed to be required to dilute the excess of CO, and to secure a complete combustion. This difficulty has appeared at its worst with fuels containing volatile combustible gases, or which contain moisture, and which are burned with the natural draft caused by a short chimney. The excess of gas distilled off from the coal after freshly charging it upon the fire finds difficulty to get oxygen enough at temperature high enough under these conditions, when the provision for the supply of oxygen is abundant for a later period in the combustion. Water-vapor also, from damp fuels, keeps oxygen away from the combustible gases, by simple mechanical displacement, if the temperature is not high enough to dissociate the oxygen and hydrogen of which it is composed. It may act also to sweep along with it particles of carbonaceous matter, which show as smoke when unconsumed.

Hence as far back as the investigations of Prof. Johnson for the U. S. Government (1844), the principle was advocated of introducing twice as much air into a furnace as the theoretical computations demanded; or where 12 pounds of air per pound of carbon fuel were theoretically required, the engineer should arrange to introduce 24 pounds. This rule has also been followed and urged by British engineers, who were familiar with gaseous coals and other fuels.

#### GENERATION OR LIBERATION OF HEAT.

A better understanding of the proper conditions, and attention to the matter of minutely dividing and distributing the air-supply, have reduced this excess from twice the theoretical weight to one and one half times, or 18 pounds where 12 is needed. And the best modern practice with the regular feeding of fresh fuel by mechanical stokers, and the principles and applications of forced mechanical draft in furnaces, have reduced this excess of diluent air to its lowest terms, and in many successful cases only the theoretical quantity is This feature is specially an advantage of firing supplied. with gas as fuel to be discussed hereafter. The excess of air, and especially its nitrogen, has to be heated, and by its presence lowers the average temperature prevailing at or near the fire. It may even check combustion of any gas which it can cool below the ignition-point, and modern designers are seeking to improve practice along these lines and to approach. more nearly to the requirements of the chemistry of combustion. Data for weight of air and the effect of excess of air on the temperature of the fire will appear with the discussion of fuels in a succeeding chapter.

# CHAPTER V.

## FUELS.

31. Introductory.—A fuel has already been defined (§ 19) as a carbon or hydrogen element or a hydrocarbon compound found native or manufactured so as to be obtainable in sufficient quantities and at a low cost, so as to be used as a source Fuels are solid, liquid, and gaseous. of heat.

32. Solid Fuels. Anthracite.—The solid fuels include:

32. Solution  $COAL \begin{cases}
Anthracite \\
Semi-anthracite \\
Bituminous \\
Caking bituminous \\
Long-flaming bituminous, or cannel
\end{cases}$ 

ASPHALT

PEAT

Coke

 $WOOD \begin{cases} Tree-wood and slabs \\ Bagasse \\ Tan-bark \\ Straw and stubble \end{cases}$ 

CHARCOAL

ARTIFICIAL FUEL BRIQUETTES

Such fuels all seem to have been of vegetable origin, and the differences between the coals seem to have been mainly due to varying conditions during their formation in geologic periods, varying pressures after formation, and varying

antiquity. The following table shows a relation between the fuels on the basis of the completeness of the carbonization of the wood fibre or cellulose:

Description.	Carbon.	Hydrogen.	Oxygen.
Wood-fibre (cellulose)	52.65	5.25	42.10
Peat	60.44	5.96	33.60
Lignite	66.96	5.27	27.76
Lignite (brown coal)	74.20	5.89	19.90
Coal (bituminous)	76.18	5.64	18.07
Coal (semi-anthracite)	90.50	5.05	4.40
Anthracite.	92.85	3.96	3.19

From their vegetable origin the solid fuels usually contain a proportion of incombustible mineral matter, sometimes fusible and sometimes not, which is known by the general name of ash. The ash from wood is mainly composed of the alkalies; coal-ash may be iron, clay, alkaline earths, etc.

Anthracite is often called hard coal—sometimes blind coal, or stone coal,—and consists almost entirely of fixed or free carbon, with inorganic matter or slaty material. It was formed at high heat and great pressure in geologic periods, and has little if any volatile matter or hydrocarbons. It is this pressure which gives it its greater hardness and density as compared with a coke which has the same carbon analysis.

Its hardness and compact structure cause it to break up or decrepitate when charged upon a hot bed of fuel, and the small chips are liable to loss by falling into waste with the ash, or to be carried away with strong draft of air through or over the fire. The English and French anthracites are worse in this respect than the American.

Anthracite is hard and lustrous, with vitreous fracture; does not break in transportation; is not easily ignited; burns with a short flame (unless damp) and little or no smoke; gives an intense fire; is readily extinguished by cutting off the air, or by cooling the fire-temperature. Its hardness and strength make it possible to break and screen anthracite to

size without excessive loss, and in Pennsylvania the recognized sizes are, from the smallest downward:

Designation.	Diameter of Perforation over which Coal will pass.	Diameter of Perforation through which Coal will pass.
Dust Barley Bird's-eye No. 3 buckwheat No. 4 buckwheat, or rice No. 7 buckwheat Pea Chestnut Small stove Large stove Egg Broken Steamboat	$ \begin{array}{c} 1/16 \text{ inch} \\ 3/32 & `` \\ 1/8 & `` \\ 3/16 & `` \\ 3/16 & `` \\ 9/16 & `` \\ 5/8 & `` \\ 1 & `` \\ 134 & `` \\ 234 & `` \\ 234 & `` \\ 4 & `` \end{array} $	3/32 inch 1/16 " 3/16 " 5/16 " 3/8 " 9/16 " 7/8 " $1\frac{1}{5}$ " $1\frac{1}{5}$ " $2\frac{1}{5}$ "

What passes through a sieve of  $\frac{1}{16}$  inch mesh is called waste or culm or dust. Anthracite shades off into graphite on the one side—Rhode Island anthracites are so hard as to be difficult to burn alone—and into the softer varieties on the other. The semi-anthracites have some volatile matter, break with a lamellar or conchoidal fracture, and are more readily ignited. Their flame is short, however. The analyses of typical anthracite average:

Per ce	nt.
90 to	94
3 to	7
I to	2
<b>4 t</b> o	3
90	
58	
19	
-	
	90 to 3 to 1 to 4 to 58

The anthracites do their work of heating mainly by the radiant heat of the incandescent or glowing carbon. They will therefore be burned in furnaces with a large grate-area, and the fire will be as thin as consistent with having no holes in it. The use of water in ash-pits of such fires often increases the apparent flame by decomposition of the steam-gas, which cools the fire by the heat required to decompose the water, but which same heat is regained beyond the fire upon the recomposition of the dissociated gases.

American anthracites are mainly found in the eastern parts of the Allegheny Mountains and in the Rocky Mountains of Colorado.

33 Bituminous Coals. —Bituminous coals are separated from the anthracites by the possession of varying amounts of volatile matter, which distil off as gases upon the application of the heat of the fire upon which the coal is charged. The semi-anthracites or semi-bituminous coals form a wide class intermediate between those which have the characteristics of their several groups strongly marked. They have from 15 to 20 per cent of gaseous matter, a high heating or calorific power, but are of little value for making illuminating-gas by the retort process. They are valued for steam-making, because while burning with a good flame they do not give so long a flame as to be inconvenient in a boiler-setting. The following analyses of Maryland and Pennsylvania types will illustrate these properties:

Locality.	Specific Gravity.	ecific Fixed avity. Carbon.		Sulphur.	Ash.	
Cumberland, Md	1.41	68.44	17.28	0.71	13.98	
Blossburg, Pa	1.32	73.11	15.27	0.85	10.77	

The true bituminous coals are softer than the anthracites, have less lustre on the fracture, break into layers or lamellæ or splints, and are the most widely distributed of the fuels.

Their fragility makes it inconvenient to sort them into sizes as can be done with anthracite, so that but three grades are usual: lump, nut, and slack. When no attempt is made to sort by size the coal is known as the "run of the mine," or is used as extracted from the bed in which it lay.

Dry bituminous, open-burning, free-burning, or furnace coal is a class of coal which can be used native in the blastfurnace, because of the absence of pitchy or "fat" material in its composition which would cause it to cake together and agglomerate into lumps upor exposure to heat.

Caking or coking coals have this property of caking together, and after the distillation from them of the 30 to 50 per cent of volatile matter which they contain the residue is a valuable coke, available for furnace or other industrial use. These usually have sulphur in them, but when free from it a valuable gas-coal is the result.

The long-flaming or cannel coals have more gas than the foregoing, but are usually lower in calorific power, and are of less industrial importance because their coke is not so valuable. They lack a certain pitchy brilliancy found in the other varieties, and are usually higher in ash.

Splint-coal is a variety of cannel with a high per cent of carbon, high calorific power, but less percentage of gas.

The bituminous coals are easily ignited, and by reason of the readily oxidizable character of the pyrites usually contained in them are liable to spontaneous ignition (§ 21) in their bunkers or bins. They form, however, the basis of successful industry in England and America and elsewhere.

Typical proximate compositions are as follows:

Fixed carbon	52	to	84	per cent.
Volatile matter	48	to	I 2	" "
Earthy matter	2	to	20	"
Sulphur	I	to	3	" "

FUELS.

Ultimate analyses of representative coals would show:

Carbon	to	80	per cent.
Hydrogen	to	б	
Nitrogen I	to	2	" "
Oxygen 4	to	10	" "
Sulphur 0.4	to	3	" "
Ash or earthy matter 3	to	10	" "

Cannel-coals would be fairly represented by the following table: "

Locality.	Specific	Fixed	Volatile	Earthy
	Gravity.	Carbon.	Matter.	Matter.
Franklin, Pa Dorton's Branch, Ky Breckenridge, Ky Davis County, Ind	I.25 I.23	40.13 55.1 32.0 42.0	44.85 42.9 55.7 52.0	15.02 2.0 12.3 6.0

COMPOSITION OF CANNEL-COAL.

34. Lignite.—The lignites are coals of more recent geologic period than the previous fuels, the process of carbonization of the wood not having proceeded so far nor under so great pressure. Lignites are brown or black. The brown lignite is sometimes of a woody texture, while the black is either woody or of a homogeneous structure with a resinous fracture. They occur in California, Utah, Colorado, Wyoming, Arizona, Alaska, New Mexico, and Oregon. Their heating capacity will be from one half to two thirds that of the older bituminous coals, and they are tender to transport. Their coke is either powdery or fibrous like that of the original wood. Lignites contain more oxygen than coal. The following table will show their composition:

Locality.	Specific Gravity.	Fixed Carbon,	Volatile Combusti- ble Matter	Water.	Ash.	Total Volatile Matter.	Coke.
Kentucky	I. 201	40.00	23.00	30.00	7.00	53.00	47.00
Washington		52.85	31.75	7.00	3.00	61.25	38.75
Colorado	I. 271	41.25	46.00	3.50	9.25	50.50	49.50

COMPOSITION OF LIGNITE.

35. Asphalt.—Asphalt as a fuel has a large proportion of hydrogen and burns like a tar or fat bituminous coal. It yields a porous coke, and in comparison with lignite shows the following average composition:

		Lignite.	Asphalt.		
Carbon	69	per cent.	79	per cent.	
Hydrogen	5	٠٠ ·	9	" "	
Oxygen and nitrogen.	20	" "	9	" "	
Ash	6	" "	3	" "	
	100		100		
a 1 ( 1 '			-		

Coke from analysis... 47 per cent. 9 per cent. Heating power ..... 13,108 B.T.U. 17,040 B.T.U.

36. Peat.—Peat is derived from the bituminization of mosses, grasses, and similar matter, as lignite is derived from more massive wood. It occurs in bogs, in which the upper part is turf, and peat occurs below. As piled and dried in the air after digging it contains from 25 to 30 per cent of water and from 7 to 11 per cent of ash. Regnault's standard analysis of dry peat shows:

Carbon	58 1	per cent.
Hydrogen	6	"
Oxygen	31	" "
Ash	5	" "
	100	

Freshly dug peat will show 75 to 80 per cent of water. It is little used in America, but is of importance in England, Belgium, Germany, and Sweden, on account of its low cost.

A typical composition of ordinary Irish peats, both exclusive and inclusive of the moisture, which they always contain in their natural condition, would give:

Description.	Moist- ure.	С	н	0	N	s	Ash.	Coke.
Good air-dried Poor air-dried Dense, from Galway	· · · · · · · · · · · · · · · · · · ·	59•7 59•6 59•5	6.0 4·3 7.2	31 20 24.8	1.9 9.8   2.3	  o.8	2.4 6.3 5.4	44.3
Averages		59.6	5.8	20	9.6	0.3	4.7	•••••

EXCLUSIVE OF MOISTURE.
#### FUELS.

INCLUSIVE OF MOISTURE.

Good air-dried Poor air-dried Dense, from Galway	24.2 29.4 29.3	45.3 42.1 42.0	4.6 3.1 5.1	24.1 21.0 17.5   1.7	 0.6	$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$
Averages	27.8	43.1	4.3	21.4	0.2	3.3

The average composition of Irish peat, disregarding sulphur, which is seldom present, at least in quantity sufficient to have any appreciable influence, may be taken to be as given below:

AVERAGE COMPOSITION OF	F IRISH PEAT.
------------------------	---------------

Perfectly Dry.	Including 25 per cent of Moisture.	Including 30 per cent of Moisture.
59.0	44.0	41.2
30.0	4.5	4.2 21.0
1.25	1.0	0.8
4.0	3.0	2.8
	59.0 6.0 30.0 1.25 4.0	Perfectly Dry.         Including 25 per cent of Moisture.           59.0         44.0           6.0         4.5           30.0         22.5           1.25         1.0           4.0         3.0

The thermal value of dry Irish peat would be  $(\S 22)$ : Carbon.... 14,650 × 0.59 = 8,643.5 B.T.U. Hydrogen.. 62,100 ×  $\left(.06 - \frac{30}{8}\right)$  = 1,397.25 B.T.U. Total = 10,040.75 B.T.U.

37. Coke.—When a coal containing a proportion of volatile hydrocarbon or other gas is exposed to a distilling action by heat, either in a retort or an oven, the residue is called coke after the distillation is complete. It is usually dark gray in color, porous, with a slight metallic lustre, hard and brittle. It is likely to contain from 80 to 93 per cent of fixed carbon, from 17 to 5 per cent of ash, and the remainder sulphur or other impurities. The weight of coke ranges at about 66 per cent of the coal charged, with an increase in bulk of about one fourth. It will absorb moisture with avidity, up to even 20 per cent. It gives a nearly smokeless combustion, with short or no flame if dry, and burns with a steady constant fire.

Modern coke-ovens condense and recover the gases from the distillation, and give most valuable by-products of the coke manufacture. The two best known are the Semet-Solvay and the Hofman-Otto, saving tar and sulphate of ammonia, and if possible using the excess of combustible gas as fuel.

Coke is less used in America as a source of motor energy, but more in metallurgy. Its absence of flame in combustion lessens its convenience for the one use and increases it for the other.

The following standard figures for the making of coke are due to Mr. A. L. Steavenson (Iron and Steel Inst. of Great Britain):

'Element.	Original Analysis of Coal.	Loss in Coking.	Yield of Coke.
Oxygen. Carbon Hydrogen. Nitrogen Sulphur. Ash	6.7 84.9 4.5 1.0 0.6 2.0	16.6 68.1 11.2 2.5 1.6	96.2 

38. Wood.—In the older countries and the more thickly settled parts of the new, wood is becoming less and less used as a source of heat energy, by reason of its growing scarcity and the proper opposition to deforestation for the sake of the country as a whole. It is, however, of importance still as refuse in chips and dust from a wood-working process of manufacture, and for the disposition of stalks or similar annual product of tillage.

Fire-wood or slabs may be either of the soft woods, such as pine, birch, or poplar, or the hard woods, like oak, hickory, ash, elm, or beach. Ash is small in woods and varies from

#### FUELS.

I to 5 per cent. Fresh-cut fire-wood usually holds about 40 per cent of moisture, which upon air-drying for several months will diminish to 15 to 25 per cent. If dried in kilns or ovens and exposed afterward to the air, the wood absorbs water rapidly in the first few days—perhaps 5 per cent in the first three—and thereafter will absorb slowly till the normal percentage of dry wood is reached, and this will fluctuate according to atmospheric conditions. Various tree-woods are much alike chemically, averaging as follows:

Kind of Wood.	С	н	0	N	Ash.	Moisture.
Beech	49.36	6.01	42.69	0.91	1.06	
Oak	49.64	5.92	41.16	1.29	1.97	
Birch	50.20	6.20	41.62	1.15	0.81	
Poplar	49.37	6.21	41.60	0.96	1.86	
Willow	49.96	5.96	39.56	0.96	3.37	
Averages, kiln-dry	50.0	6.0	41.0	1.00	2.0	25
Average, 25% water	37.5	4·5	30.75	0.75	1.5	

The heating power of wood is usually called 7838 B.T.U. dry or 5879 when wet. This would be about four tenths that of an equal weight of coal, or in other words,  $2\frac{1}{2}$  pounds of wood are equivalent to one pound of coal. In substituting wood for coal as a fuel, the furnace usually has to be enlarged, principally in its height, perhaps, so that it may carry an equal weight of combustible at any one time as it formerly did with coal. Wood, like the gaseous coals, distils off volatile or tarry matters, which are often sticky and brown in color, and are combustible if a high enough temperature can be commanded. These do not constitute a true smoke as heretofore defined (§ 20), but are often judged to be one, and should be as avoidable.

When sawdust from manufacturing processes is to be used as a fuel, the conditions of intimate mixture of the oxygen required for the combustion have to be secured by special forms of grate, and usually by a forced draft (§§ 24 to 26, and

86 to 88). Hollow grate-bars form a usual method of meeting this requirement (Gordon's or Gadey's), with a fan forcing



air into the cored passages and out and up through the fuelbed (Fig. 5).

39. Bagasse, Straw, Tan-bark.—The three most usual forms of woody fibre used as refuse for fuel are the residue from crushing the sugar-cane to press out its juice, which is called bagasse; the stalks or stubble from cotton, wheat, or barley harvests; and the spent bark from tan-pits out of which the tan-liquor has dissolved the desired acids and left the woody fibre behind. The accepted analyses of tropical cane and the resulting bagasse after crushing give:

	Cane.	66% Bagasse.	70% Bagasse.	72% Bagasse.
Woody fibre Water Combustible salts	12.5 73.4 14.1	37 53 10	40 50 10	45 46 9
	100.0	100	100	100

The figures 66, 70, and 72 refer to the proportion of mill extraction of the juice from the cane.

FUELS.

Dry Louisiana bagasse will analyze:

Constituents.	Percentage.
Volatile matter	. 81.37
Fixed carbon	. 14.26
Ash	. 4.6

If the woody fibre contains 50 per cent of carbon, and the combustible salts 42 per cent, as has been found, then the calorific power of bagasse would be about 1200 B.T.U.; or one pound of coal equals 5 or 6 pounds of wet bagasse, or  $2\frac{1}{2}$  to 3 pounds if dry. In burning it, it is fed continuously into a very hot fire-brick chamber, and generous space must be provided to take care of the volume of steam and gas generated.

Straw is composed in its ordinary and air-dried condition as follows:

	Dry Wheat Straw. Russia.	Wheat Straw. Head.	Barley Straw.	Mean.
Carbon	46. I	35.86	36.27	36.00
Hydrogen	5.6	5.01	5.07	5.00
Nitrogen	43.7	37.08	38.20	38.00
Ash	4.18	5.00	4.50	4.75
Water		16.00	15.50	15.75
	100.00	100.00	100.00	100.00

The calorific power of such straw would prove to be \$144 B.T.U., or 1 pound of coal equals  $2\frac{3}{4}$  to  $3\frac{3}{4}$  pounds of cotton-stalks or straw.

Tan-bark containing 30 per cent of water has a calorific power of a little over 4200 B.T.U. and contains 15 per cent of ash. That is, one pound of coal equals  $2\frac{1}{3}$  to 3 pounds of dry tan-bark, or 6 to 8 pounds if the latter is wet. The evaporative capacity of tan-bark, expressed in pounds of water evaporated from and at 212°, is given as follows:

	Perfectly Dry.	With 30 per cent , of Moisture.
Water supplied at 62°	5.46 pounds	3.84 pounds
Water supplied at 212°	6.31 pounds	4.44 pounds

The conditions of success in burning tan, as is the case with all wet fuel, consist in completely surrounding it with heated surfaces and burning fuel so that it may be rapidly dried, and then so arranging the apparatus that thorough combustion may be secured. Here again, as with sawdust, the hollow grate-bar and forced-blast systems in combination with the hot fire-brick furnace seem to meet the conditions most satisfactorily. Fig. 6 shows the overhead-hopper feed-



FIG. 6.

ing plan to secure automatic stoking of the furnace (§ 90), as applied to a water-tube boiler with the forced current of air from a fan entering the fuel-bed from below, and the furnace is arched over with fire-brick, which becomes very hot and secures the necessary conditions.

40. Charcoal.—Charcoal is the product of distillation from wood to expel its volatile constituents as coke is produced

from bituminous coal. It is done in heaps or pits or ovens at about 600° to 800° F. So much of the heat-making properties of native wood are expelled in the process of making charcoal that it is of little moment for motive-power purposes. It is easily ignited and burns with a flameless and smokeless incandescence. Charcoal has its quality improved as the temperature of its distillation is increased. The results of this process when applied to black alder, previously dried at about 300°, are as follows:

COMPOSITION OF CHARCOAL PRODUCED AT VARIOUS TEMPER-ATURES.

Temperature	Constituents of the Solid Product.					
Carbonization.	Carbon.	Hydrogen.	Oxygen.	Nitrogen and Loss.	Ash.	
302° F. 392 482 572 662 810 1873	47.51 51.82 65.59 73.24 76.64 81.64 81.97	6.12 3.99 4.81 4.25 4.14 4.96 2.30	46.29 43.98 28.97 21.96 18.44 15.24 14.15	0.08 0.23 0.63 0.57 0.61 1.61 1.60	47.51 39.88 32.98 24.61 22.42 15.40 15.30	

Peat charcoal, produced by the carbonization of ordinary air-dried peat, is very friable and porous, and extremely difficult to handle without reducing it to very small particles almost powdery in their character. Although it is easily ignited and burns readily, its physical characteristics are such as to prevent its general use.

41. Artificial or Patent Fuels.—Combustible materials in the form of dust or grains which in that state are ill adapted to convenient use for heat-making can be made into a practicable and salable fuel by agglomerating such loose particles into blocks or bricks by means of some tarry or bituminous compound such as pitch, resin, or even glue. The fine dust or grains would clog a fire or be lost in ashes or by the draft, and would burn too rapidly and unsteadily if fed irregularly

or by hand. By moulding into briquettes the combustion is made gradual and from their outer surfaces inward, and the larger mass is not so readily extinguished. This plan is much used in Belgium and in some other places in Europe, and has been tried in America as an expedient to work over the heaps of waste coal in the dumps of mines. Mechanical stoking with proper travelling grates has been found a more successful method of using such material.

42. Liquid Fuel. Petroleum.—The second great class of fuels (§ 31) are those which can be supplied in a liquid state and burned to a gas with the consequent liberation of stored heat. These liquid fuels are hydrocarbons and are called oils. Oils of animal origin are now supplied to such a limited extent as scarcely to deserve consideration, and the cost of extracting vegetable oils from the seeds or other products which carry it preclude the use of such oils for fuel. Hence the mineral oil, or petroleum, is the principal source of heat from liquids, either in its crude form as it comes native from the oil-well, or after a part of the constituents of natural oil have been eliminated by the refining process. The average composition of crude petroleum is usually given as:

Carbon	From 82	То 87.1	Average. 85
Hydrogen	11.2	14.8	I 3
Oxygen and impurities	0.5	5.7	2
			100

Its specific gravity is from 0.79 to 0.82. Lima oil from the Ohio wells is of a dark green color, is quite fluid and volatile, and has a disagreeable odor. Its volatility makes it flame easily, and give off an explosive vapor in a confined space. These two properties have resulted in restrictions upon its use in many cities; the health boards object to the odor, and the fire departments to the danger of fire from explosions. Hence the refining companies have introduced what is called fuel-oil. This is the residue after a part of the

FUELS.

No.	Temperature Fahrenheit.	Distillate.	Probable Per Cent.	Specific Gravity.	Flashing-point.
1 2 3 4 5 6 7 8 9	$ \begin{array}{c}     113 \\     113 to 140 \\     140 to 158 \\     158 to 248 \\     248 to 347 \\     338 + \\     482 \\     \end{array} $	Rhigolene ) Chymogene ) Gasolene Benzine, naphtha C ""B "A Polishing-oils Kerosene Lubricating-oil Paraffine wax Residuum and loss	traces 1.5 10.0 2.5 2 50 15 2 16	.590 to .625 .636 to .657 .680 to .700 .714 to .718 .725 to .737 .802 to .820 .850 to .915	I4 32 Ioo to 122 230

fractional distillation process has been completed. A tabular summary of this process is as follows:

The distillation for fuel-oil is stopped after the kerosene has been obtained. In many refineries only the three products of crude naphtha, burning oil, or kerosene, and the distillate are recognized, the latter being the fuel-oil. Its average specific gravity is about .818 or 40° Baumé at 60° F., so that a gallon weighs 7.3 pounds, as against 6.81 pounds for the crude oil. It flashes at 218° F., or just above the boiling-point of water. It is thick in consistency. The calorific power of crude oil is from 20,000 to 21,000 British thermal units, and that of the fuel-oil is from 17,000 to 19,000 heat-Fuel-oil is called "astatki" by the Russians. units. Thos. Urguhart of Russia, in considering the use of petroleum for locomotives, gives the following table of the theoretical evap-

Real	Specific Gravity - at	Chemic	ical Composition.		Heating- power,	Theore:. Evap., Lbs. Water per	
Fuel.	32° F., Water = 1.000.	C.	н.	о.	Thermal Units.	Lb. Fuel, from and at 212° F.	
Penna. heavy crude oil Caucasian light crude oil "heavy"" Petroleum refuse., Good English coal, mean of 98 samples	0.886 0.884 0.938 0.928 1.380	84.9 86.3 86.6 87.1 80.0	13.7 13.6 12.3 11.7 5.0	I.4 0.1 I.1 I.2 8.0	20,736 22,027 20,138 19,832 14,112	21.48 22.79 20.85 20.53 14.61	

orative power of petroleum in comparison with that of coal, as determined by Messrs. Favre and Silbermann.

The further details of refining for elimination of coloring matter, and the steps of acid and alkaline agitation, are aside from the present purpose.

43. Kerosene.—Kerosene has already been referred to as the "burning oil" or No. 6 in the process of fractional distillation of petroleum. Usually  $3\frac{1}{2}$  parts of crude oil render one part of kerosene.

The heat of combustion ranges between 27,000 and 28,000 B.T.U. The quicker the distillation the poorer the product, albeit more abundant; but the more abundant the lighter elements the less safe is the kerosene.

The flashing-points at which an ignitible vapor is given off by heating will range between 115° and 125° F.; the oil will itself ignite and burn when heated to 130° to 140° F. This is called its burning-point. Besides its use as a lamp-oil, kerosene is used in certain forms of oil-engine to supply the heat for motive power. The limited use of the more volatile petroleum liquids will be referred to in Chapter XX (§§ 297 to 299).

44. Alcohols.—There are two kinds of alcohol used in the arts and as sources of heat: methylic alcohol or wood-alcohol, which has the chemical symbol  $CH_4O$ , and ethyl alcohol, the ordinary form, which is represented by  $C_2H_4O$ .

Wood-alcohol is formed by dry distillation of wood in iron retorts (usually horizontal) at a heat not above  $900^{\circ}$  F. It has a strong characteristic odor and boils at  $150^{\circ}$  F. It would be a most popular source of heat in many places where corn is abundant if there were no restrictions upon its manufacture.

Ethyl alcohol is obtained by distillation from the fermented infusions of the cereal grains, which contain either sugar or starch. It has a specific gravity of 0.792 and boils

at 173° F., but will freeze only at 200° below zero when pure. It expands  $3\frac{1}{8}$  times as much as water between  $32^{\circ}$ and 173° F.

Hydrated alcohols contain water ranging from 50 per cent by volume (proof spirits) to 93 per cent (cologne spirits). The affinity for water is very strong.

Pure alcohol is very inflammable and burns with a paleblue smokeless flame. Its calorific power is about 28,500 B.T.U., which runs down to 12,000 with greater hydration.

45. Liquid-fuel Furnaces.—The heat may be derived from burning oil by setting fire to it in the presence of oxygen while the oil is a liquid, or is a finely divided mist or vapor of liquid particles in a current or stream of air or steam, or the liquid may be made into a gas and then ignited.

The heat of combustion may furthermore be utilized directly in a motor cylinder (the oil-engine, Chapter XX), or the heat may be used as the heat of combustion of solid fuels is, in a furnace or fire-box from which it is transferred by a medium to the cylinder.

The American methods have been the vapor or gas systems exclusively. The liquid systems are Russian or Indian in the main. Four general plans have been tried. First, bowl- or pan-furnaces, in which the liquid oil was delivered through a series of pipes into shallow vessels in the fire-box, and burned from their surface. This plan is old and primitive, and gave difficulty from smoke because air-supply was difficult. Second, step-furnaces, in which a series of shallow troughs was arranged across the furnace in steps, and the oil fed into these troughs from above overflowed into the one below and met the air for combustion in flat strata between the steps. This answered for stationary conditions. Third, drop-furnaces had the oil fed in thin streams from many pipes over a grooved plate, whereon it met the air and was burned. Fourth, wick- or oozing-furnaces, where the liquid

oil is made to rise up from below at many points through a layer of an incombustible substance like lime or asbestos or pumice-stone, or even sand. The oil divides itself among the interstices and burns from the top surface, where it meets the air as a lamp-flame from a wick. The difficulty is the certain clogging of the capillary surfaces by the heavy residual matters, which are sticky and refuse to come to the top and burn

46. Oil-vapor Burners.—The most widely extended and successful system for generating heat from oil-fuel is to comminute or atomize the oil by a current of air or steam which blows across or through it under pressure in an appliance or apparatus which is called a burner. The oil is drawn into the current of air or steam by induction and is torn into shreds or drops by the high velocity through a small opening, so that it enters as a mist into the fire-box, and ignites by flame or heat already there, all through the saturated atmosphere, forming a volume of flame of great intensity and heating effect. It is rarely or never wise to have the oil flow by gravity to the burner, since the flow of oil should positively cease when the inducing current of air or steam is shut off, and to diminish the fire danger.

The burner is usually a modification of the injector in principle. Its outlet is either a slit or a nozzle. In the slit sprinklers the orifice is divided by a thin partition, the oil coming on one side of it and the air on the other. When the slit is horizontal, as has been usual, the oil is above and the air or steam blows through the film of oil. Sometimes the partition has grooves, so that oil passes in threads. Slit sprinklers are wasteful of oil and of steam as compared with the other types. They will call for 6.6 pounds of oil per H.P. per hour, and will use from 6 to 8 per cent of the steam which is made by the boiler for which the burner supplies necessary heat. They also are liable to become clogged



## FUELS.

with the solid matters of the oil residue, and to become blown out by their own operation.

Nozzle sprinklers have the air and oil concentric in a converging tube—the air usually in the middle. The air- or steam-nozzle is usually adjustable within the oil-tube, so as to vary the flow of oil, and to permit cleansing of the oil-tube by retracting the air-nozzle. Such burners will require from 4.4 to 5.5 pounds of oil per H.P. per hour, and will consume from 4 to 6 per cent of the steam which the burner will make. When there is no nozzle adjustment the sprinkler will be called a pipe burner rather than a nozzle sprinkler. Some forms of burner aspirate a current of air first by a steam-jet, and then the combined air- and steam-current aspirate and



atomize the oil. The jet of oil-vapor should impinge upon fire-brick or similar refractory material, which becomes incandescent and keeps the flaming vapor alight. Metal surfaces are eroded rapidly from the intense heat when the flame impinges upon them. The fire is started by an igniter of chips or waste soaked with kerosene; but after becoming well started the mass of fire-brick will start the flame anew after the oil has been shut off for a while. There are several designs of oil-burner, known by their manufacturers' names. (Figs. 7 and 8 illustrate types.)

With respect to the use of air or steam for the inducing means to draw up and atomize the oil, it may be said on behalf of steam that it requires no air-compressing plant to bring it up to pressure for use under boilers, and there is not introduced into the flame a mass of inert nitrogen which must be heated at the expense of the oil-fuel, and acts to cool it. Steam is hot, furthermore, when it enters the flame,



FIG. 8.

and may be superheated. On the other hand, air must be introduced for combustion, and it is best to introduce it as the spraying and subdividing medium; steam dilutes the burning gas if it is not dissociated; and if it is, the heat of dissociation is lost unless the temperature is high enough for recombination. 47. Oil-gas Systems.—The third group of methods for getting heat from oil is the plan of making the oil into a gas by heating it in a proper retort, into which also superheated steam is introduced, at a temperature above 300° F. The Archer process is one of the best known of its class, and has the steam and oil enter a cylindrical retort or thermogen in such a way as to secure an intimate mixture of the constituents. The plant at the outset involves more than the burner or vapor plans, and the retort connections are liable to clogging from the residues of the oil. Sometimes, however, by the finer subdivision and better access for air which gas-firing permits, the gas systems burn less oil for a given heating effect than the vapor-furnaces.

A form of oil-gas is much used wherein the gas is made by forcing air under pressure through a liquid hydrocarbon, such as gasoline. The carbureter is placed between the pressure-tank and the burner, and the air on its way to the burner picks up enough carbon to form an illuminating-gas. This method has been considerably applied for railway-car lighting. When so used, the air is delivered to the carbureter from the air-brake tanks, passing through a spiral coil of fine copper pipe in the chimney of the lamp. The carbureter contains a gasoline of about 88° Baumé, absorbed in a tightly compressed cotton wicking.

The Pintsch oil-gas (Julius Pintsch, Berlin, 1871) is a true or fixed gas made in retorts by vaporization of crude petroleum. From 70 to 85 cubic feet of a 50- to 60-candlepower gas results from distillation of one gallon of oil. For railroad use this gas is compressed in tanks, to 150 pounds pressure or more, which supply the smaller gas-tanks under the cars. Each of these car-tanks will hold enough for from two to six days' travel. The gas is rich in illuminating properties and does not lose so much of its illuminating power by compression as a coal-gas. A small deposit of hydrocarbon is found in the bottom of the storage tanks, however. 48. Advantages of Oil-fuel.—Oil or liquid fuel offers many attractive advantages over the solid fuels. Many of these are those incidental to mechanical firing, to which oil lends itself easily, but besides these there are many others of its own.

Mechanical handling of oil by pumps or aspirating burners gives the following advantages:

I. Economy of labor. One fireman by handling the necessary valves can manage eight to ten or more boilers of 100 horse-power each. With hand-firing of coal, one man can never manage more than four such boilers.

2. No ashes, and their attendant labor and possible cost. Economy and convenience in oil-firing result from:

3. No waste of fuel in ashes and cleaning of fires

4. No waste of fuel in banking fires overnight.

5. No opening of furnace-doors for firing or cleaning. This is easier upon the brick-work of the setting, and on the metal of the boiler, by diminishing strains of sudden contraction.

6. No injury from firing-tools in fire-boxes.

7. No sparks pass out from a chimney, to set fire to combustibles outside.

8. Absence of dust and ashes in fire-room and adjoining engine-room.

9. Wide range of controllability of fire, not only within the limits of ordinary consumption, but beyond these. The fire is put out when demand for heat stops; an excessive demand for heat can be met by unusually great supply of oil. With solid fuel, a charge once made must burn itself out. In boilers, safety-valve waste is diminished.

10. The greater calorific power of oil, and its controlled combustion, enable more energy to be gotten from a plant whose capacity has been calculated upon a solid fuel basis.

11. Smokeless combustion is more easily secured, and there is diminished loss of unburned carbon.

FUELS.

12. Lower temperatures of fire-rooms, and lessened physical strain upon firemen.

13. Absence of sulphur to corrode metal.

14. Fires easily started.

15. Economy of stowage and carriage of oil as compared with solid fuel.

16. Economy of fuel-stations for navy or locomotive practice.

17. No grates are required.

Usual relations of oil to coal as fuel give I pound of oil to  $1\frac{8}{4}$  pounds of coal; or I gallon of oil equals 6.5 to 6.7 pounds of oil and will compare to 12 pounds of coal; or 190 gallons of oil will equal a long ton of coal of 2240 pounds.

49. Disadvantages of Oil-fuel.—There are objections to oil as a dependence for a source of heat.

I. The use of crude oil with the volatile constituents in it is opposed by the health ordinances of some cities. In others the fire or insurance ordinances permit the use of oil only if the oil-tank is below ground, or so placed that it cannot flow out of its reservoir and carry flame to other buildings in case of conflagration.

2. The vapor from crude oil is ill-smelling and makes an explosive mixture with air. It vaporizes even at low temperatures.

3. If fuel-oil must be used, it is usually more costly than coal in most places. The problem is really to get the most heat-units for a unit of value. If the quotient of the calorific power of oil per pound divided by its price per pound at any point is greater than the same quotient for solid fuel, the oil is the cheaper.

4. The total oil-production of the world would supply but a small portion of the demand for heat as a source of energy. This would immediately affect the price of oil, if any large number of consumers were to decide to use oil. 5. Most of the spray burners make an objectionable roaring noise.

6. The surfaces exposed to an oil-flame usually become coated with a deposit of residue from the burning oil.

7. Oil creeps past valves and leaks in a way which is annoying and may be dangerous.

8. Explosions occur from the flame blowing out, and igniting again with dangerous combinations of oil-vapor and air.

9. Auxiliary apparatus in the way of a source of steam or compressed air is required for the burners; in starting, there must be a supply available of air or steam from a boiler or reservoir.

50. Gaseous Fuels. General.-It is one of the most tenable theories of the combustion of solid and liquid fuels, that the effect of the igniting heat is to gasify the carbon or hydrocabron on the surface, and that chemical union with oxygen takes place when both are gases, the carbon gas being in a nascent state. If this view is sound, there are advantages connected with the plan of making gas on a large scale artificially, or in using natural gas as a fuel. Gas-firing offers the same advantages as a principle as those which underlie the use of oil in the matter of mechanical handling, control, cleanliness, and convenience. Gas-firing, further, requires less excess of air for combustion-or none; and when gas can be used as a source of heat energy direct in the cylinder, the advantages are introduced which follow from avoiding some of the necessities for losses which are introduced in other systems.

Gas-fuel may be natural gas or a manufactured article. Manufactured or artificial gas may be producer-gas, watergas, or illuminating-gas.

51. Natural Gas.—In certain parts of America, notably in Pennsylvania, Ohio, and Indiana, large accumulations of a natural fuel-gas are found in subterranean cavities or strata, which can be reached by wells. This gas is either a stored product of a previous distillation, or else is a product of a process still in operation. It is usually under considerable pressure at the wells, so that it can be piped to industrial centres without too great losses, or artificial pressure may be secured by proper gas-pumps.

Various districts give varying constitution of gas and hence varying calorific power; around Pittsburg, Pa., 1 pound of coal is considered to be the equivalent of from  $7\frac{1}{2}$ to  $12\frac{1}{4}$  cubic feet of gas. The following tables give some analyses:

Constituents.	I	2	3	4	5	6
Marsh-gas	57.85	75.16	72.18	65.25	60.70	49.58
Hydrogen	9.64	14.45	20.02	26.16	29.03	35.92
Ethylic hydride	5.20	4.80	3.60	5.50	7.92	12.30
Olefiant gas	0.80	0.60	0.70	0.80	0.98	0.60
Oxygen	2.10	1.20	1.10	0.80	0.78	0.80
Carbonic oxide	1.00	0.30	1.00	0.80	0.58	0.40
Carbonic acid	0.00	0.30	o.80	0.60	0.00	0.40
Nitrogen	23.41	2.89	0.00	0.00	0.00	0.00

VARIATION IN COMPOSITON OF NATURAL GAS.

Analyses from various wells in Indiana and Ohio indicate the composition to be as follows:

COMPOSITION OF NATURAL GAS FROM OHIO AND INDIANA.

		Ohio,		Indiana.			
Constituents.	Fostoria	Findlay	St. Mary's.	Muncie.	Ander- son.	Koko- mo.	Marion.
Hydrogen	1.80	1.64	1.04	2.35	1.86	1.42	1.20
Marsh-gas	92.84	93.35	93.85	92.67	93.07	94.16	93.57
Olefiant gas	0.20	0.35	0.20	0.25	0.47	0.30	0.15
Carbonic oxide	0.55	0.41	0.44	0.45	0.73	0.55	0.60
Carbonic acid	0.20	0.25	0.23	0.25	0.26	0.29	0.30
Oxygen	0.35	0.39	0.35	0.35	0.42	0.30	0.55
Nitrogen	3.82	3.41	2.98	3.53	3.02	2.80	3.42
Hydrogen sulphide	0.15	0.20	0.21	0.15	0.15	0.18	0.20

The Indiana gas weighs 0.045 pound per cubic foot.

52. Producer-gas.-Gas made by distilling bituminous or anthracite coal in a closed furnace, using part of its own heat of combustion to effect the chemical reactions, is often called producer-gas, from the name given to the gas-generator. А thick bed of fuel rests upon properly constructed grates, and air or steam or both is forced from below the grates up through the bed of fuel. The first combustion is to carbonic acid (CO<sub>2</sub>) with air alone, or to CO<sub>2</sub> and hydrogen if steam is used also. This carbonic acid gas, meeting the layers of carbon above where no free oxygen reaches, is decomposed by the carbon into two units of carbonic oxide (CO), which with the hydrogen passes up through the bed of fuel and outwards through a proper pipe to the place where it may meet the required oxygen and be burned at the point desired. Early producers of the Siemens type, operating with open ash-pits and no pressure below the grates, lost much of their possible effectiveness in the cooling of the gases after leaving the producer. This loss is estimated at 30 per cent. To blow with air alone is to introduce inert nitrogen which dilutes the gas and lowers its calorific power. On account of the loss of heat in the producer itself in the distilling process, and some loss in the dissociation of the water, which is not all recovered, producer-gas usually carries only 87 per cent of the calorific energy of the carbon. Some loss in unreduced CO, must be allowed for, and the cost of making the steam Eighty-two per cent is a more usual figure when used. anthracite is used as fuel instead of bituminous coal. Much inferior grades of fuel can be used in the producer than could be used direct, however.

If an analysis of 85 per cent of solid carbon be assumed for an anthracite stock, with 5 per cent of volatile hydrocarbons and 10 per cent of ash, and the further assumption be made of a combustion of 80 pounds to CO<sub>2</sub> and 5 pounds of CO, the following calculated statement of process, products, and resulting energy may be agreed to:

бо

	Products.				
Pounds.	Cubic Feet.	Anal. by Vol.			
186.66	2529.24	33.4			
18.33	157.64	2.0			
5.00	116.60	1.6			
3.75	712.50	9.4			
301.05	4064.17	53.6			
514.79	7580.15	100.0			
	Pounds. 186.66 18.33 5.00 3.75 301.05 514.79	Pounds.         Cubic Feet.           186.66         2529.24           18.33         157.64           5.00         116.60           3.75         712.50           301.05         4064.17           514.79         7580.15			

Energy in the above gas obtained from 100 pounds anthracite:

186.66 lbs. CO 807,304	heat-units.)
5.00 " CH4 117,500	
3.75 " H 232,500	44
 1,157,304	* *
Total energy in gas per lb 2,248	
" " 100 lbs. of coal. 1,349,500	" "
Efficiency of the conversion	86 per cent.

If the gas-stock be a bituminous coal with 55 per cent of fixed carbon, 32 per cent of volatile matter, and 13 per cent of ash, and the calorific power of the hydrocarbons be taken at 20,000 heat-units to the pound, the following table results under the same assumptions:

Desser		Products.					
Process.	Poun	ds. C	ubic Feet.	Anal, by Vol.			
50 lbs. C burned toCO	116.	66	1580.7	27.8			
5 lbs. C burned toCO <sub>2</sub>	18.	33	157.6	2.7			
32 lbs. vol. HC (distilled)	32.	00	746.2	13.2			
80 lbs. O are required, of which 20 lbs., derived from H <sub>2</sub> O, liberateH	2.	5	475.0	8.3			
withN	200.	70	2709.4	47.8			
	370.	19	5668.9	99.8			
Energy in 116.66 lbs. CO """ 32.00 lbs. vol. HC "" " 2.50 lbs. H	 2	504,55- 640,000 155,000	heat-un o '' o ''	its.			
Energy in coal Per cent of energy delivere	ים נ ו d in נ	,299,55 ,437,50 ;as	- + '' - ''	0.0			
Heat-units in 1 lb. of gas			3	484			

Fig. 9 illustrates the old type of Siemens producer without artificial blast, and Fig. 10 the more modern Taylor producer with forced steam-blast and revolving grates.



F1G. 9.

Ordinary producer-gas has a calorific value of 110 B.T.U. per cubic foot.

53. Water-gas.-A great deal of gas for illuminating and power purposes is now made by the process of intermittent and alternate blowing of air and steam through a thick bed of fuel in a cylindrical producer of boiler-plate lined with refractory material. The fuel is blown by air from below until it becomes highly incandescent; the producer may be open at the top, and waste the lean carbonic oxide which comes off from the top, or the latter can be caught and used. After blowing with air as long as necessary, the air is shut off, and steam is similarly blown from below, with the producer closed except at its delivery to a gas-holder. The steam is dissociated by the incandescent carbon into hydrogen and oxygen, and the latter unites with the carbon as in the airproducer, to be reduced to carbonic oxide. The hydrogen passes out without further chemical reaction. This process



FIG. 10a.

was introduced in 1874 by Mr. T. S. C. Lowe, and is often known generally as the Lowe process. For illuminating purposes this fuel gas is more highly carburefted by sprays of hydrocarbon vapors (such as naphtha or similar petroleum



FIG. 10b.

products) which are made a fixed gas by later heating in a superheater.

Fig. 11 illustrates what is called in England the Dowson gas-producer, which belongs to this class. Its product is sometimes known in America as semi-water-gas. Its analysis runs by volume:

Hydrogen,	H	. from	18.73	to	26.55
Marsh-gas,	СН,	. "	.31	1	
Olefiant gas,	$C_2H_4\ldots\ldots$	. ''	.31	5	1.11
Carbonic oxide,	СО	. ,''	25.07	" "	18.20
Carbonić acid,	CO <sub>2</sub>		6.57	" "	11.30
Oxygen,	Ο		.03	" "	•47
Nitrogen,	N		48.98	" "	42.28

The ash-pit B is closed and air and steam are forced through N and up through the mass of anthracite or coke which fills the producer-chamber. The feeding is done through the hopper A' by means of its double lid and air-lock action. The gas passes up through the coke-scrubber into the holder K.



A French form of water-gas producer is known as Lencauchez'. Its object is to improve on the Dowson type by saving waste heat, and render it available for coals having some tendency to fuse together from the presence of tarry matters (Fig. 12). The hanging bridge E forces the gases

above the middle of the fuel-bed to pass downwards before escaping to the flue F, and so out to the holder through the



passage I. The annular chamber H is a steam-boiler, whose water cools the outflowing gases, and whose steam entering the chamber G meets with air from a blower through the pipe

L, and the combined air and steam are forced through the pipes M into the closed ash-pit and so up through the fuel. The descent of the distilled gas through the hot fuel before passing out is the feature which is expected to break up the tarry elements of the distillation. Lencauchez' gas analysis shows:

Hydrogen,	H	18.34
Olefiant gas,	СН,	1.25
Hydrocarbons,	C, H,	1.55
Carbonic oxide,	CO	27.32
Carbonic acid,	CO <sub>2</sub>	3.60
Sulphur dioxide,	SO <sub>2</sub>	.04.
Hydrogen disulphide,	H,S	.06
Nitrogen,	N	47.84

Dowson gas has a calorific value averaging 150 B.T.U. per cubic foot, while the true water-gas should have 290.

54. Coal-gas or Illuminating-gas.-The ordinary gas used in cities and large towns, and which was universal previous to the introduction of water-gas, is made by distilling bituminous coal in retorts. These retorts are long semi-cylindrical tubes holding each from 160 to 300 pounds of caking bituminous coal-often enriched by some cannel-coal-under and around which the heat from a coke-fire is maintained. The vapors distilled off become a fixed gas by being passed through that part of the distilling apparatus which is kept at a white heat. Other features of the process involve the methods for condensing tarry and offensive vapors and for cleansing, which are aside from the present purpose. The products of distillation of 100 pounds of ordinary gas-coal are usually:

Coke	64	to	65 pc	ounds
Purified gas	15	"	12	"
Ammonia liquor	10	" "	12	" "
Tar	6.5	" "	7.5	" "
Loss and impurities	4.5	"	3.5	"
-			<u> </u>	
1	100.0		100.0	

The composition by volume usually ranges:

Hydrogen		38	to	48 p	er cent
Carbonic oxide		2 -	" "	14	" "
Marsh-gas, CH,		43	"	31	" "
Heavy hydrocarbons	Ethylene Propylene Benzole vapor	7.5	""	4•5	"
Nitrogen		I	"	3	"

The following analyses are taken from a report of Dr. Gideon E. Moore on the Granger Water-gas, 1885:

	Compo	sition by V	olume.	Composition by Weight.			
	Water-gas.		Coal-gas.	Water-gas.		Contain	
	Worcester	Lake.	Heidel- berg.	Worcester	Lake.	Coal-gas.	
Nitrogen Carbonic acid Oxygen Ethylene Propylene Benzole vapor Carbonic oxide Marsh-gas Hydrogen	2.64 0.14 0.06 11.29 0.00 1.53 28.26 18.88 37.20	3.85 0.30 0.01 12.80 0.00 2.63 23.58 20.95 35.88	2.15 3.01 0.65 2.55 1.21 1.33 8.88 34.02 46.20	0.04402 0.00365 0.00114 0.18759  0.07077 0.46934 0.17928 0.04421	0.06175 0.00753 0.00018 0.20454 0.11700 0.37664 0.19133 0.04103	0.04559 0.09992 0.01569 0.05389 0.03834 0.07825 0.18758 0.41087 0.06987	
Density: Theory Practice	0.5825	0.6057	0.4580	1.00000	1.00000	1.00000	
B. T. U. from 1 cu. ft.: water-liquid "vapor	650.1 597.0	688.7 646.6	642.0 577.0	· · · · · · · · · · ·	• • • • • • • • • • • • • • • • • • •		
Flame-temp., Fahr	5311.2°	5281.1	5202.9°				
Av. candle-power	22.06	26.31		• • • • • • • • •	•••••		

ANALYSES OF WATER-GAS AND COAL-GAS COMPARED.

	Heat-units from 1 lb.			
	Water-liquid.	Water-vapor.		
Ethylene	21,524.4	20,134.8		
Propylene	21,222.0	19,834 2		
Benzole vapor	18,954.0	17,847.0		
Carbonic oxide	4,395 6	4,395.6		
Marsh-gas	24,021.0	21,592.8		
Hydrogen	61,524.0	51,804.0		

CALORIFIC EQUIVALENTS OF CONSTITUENTS OF ILLUMINATING-GAS.

55. Acetylene-gas.—The gas  $C_2H_3$  released from calcium carbide by addition of water is as yet of no significance for large-scale heating, but has been much examined for use in motor-carriages and elsewhere where gas-power in small bulk is the prerequisite. One pound of calcium carbide with a half-pound of water will liberate  $5\frac{3}{4}$  cubic feet of gas. It has a heat capacity of 18,260 B.T.U. per pound or 1259 per cubic foot, at  $14\frac{1}{2}$  cubic feet to the pound. It requires  $12\frac{1}{2}$ volumes of air to burn it, which is usually raised to 14 or 15 in practice. It has been compressed to a liquid at 68° F. by a pressure of 600 pounds per square inch.

Acetylene ignites at 510° F. in proper mixtures with air.

56. Comparison of Gaseous Fuels.—Of the four sorts of gas used as a source of heat, water-gas has the highest theoretical temperature of combustion—4850° F. Producer-gas gives 3441°. The natural gas and coal-gas are nearly of the same value as the water-gas. The following tables quoted from Mr. Emerson McMillin give some interesting facts.

Including natural gas the relative volumes and weights of gaseous fuels are:

	By Weight.	By Volume.
Natural gas	. 1000	1000
Coal-gas	· 949	666
Water-gas	. 292	292
Producer-gas	. 76.5	130

### COMPOSITION OF GASES BY VOLUME.

	Findlay,O., Natural Ga <b>s.</b>	Coal-gas.	Water-gas.	Penna. Steel-works Producer-gas.
Hydrogen Marsh-gas. Carbonic oxide Olefiant gas. Carbonic acid Nitrogen Oxygen Water-vapor Sulphydric acid.	2.18 92.60 0.50 0.31 0.26 3.61 0.34 0.00 0.20	46.00 40.00 6.00 4.00 0.50 1.50 0.50 1.50	45.00 2.00 45.00 0.00 4.00 2.00 0.50 1.50 	6.00 3.00 23.50 0.00 1.50 65.00 0.00 1.00

COMPOSITION OF GASES BY WEIGHT.

	Findlay.O., Natural Gas.	Coal-gas.	Water-gas.	Penna. Steel-works Producer-gas.
Hydrogen Marsh-gas Carbonic oxide Olefiant gas Carbonic acid Nitrogen Oxygen Water-yapor	0.268 90.383 0.857 0.531 0.700 6.178 0.666	8.21 57.20 15.02 10.01 1.97 3.75 1.43 2.11	5.431 1.931 76.041 0.000 10.622 3.380 0.965 1.630	0.458 1.831 25.095 0.000 2.517 69.413 0.000 0.686
Sulphydric acid	0.417			· · · · · · · · · · · · · · · · · · ·
	100.000	100.00	100.600	100.000

TABLE OF RELATIVE EVAPORATION OF WATER IN A STEAM-BOILER.

	Natural-gas.	Coal-gas.	Water-gas.	Producer-gas.
Cubic feet gas	1000	1000	1000	1000
Pounds of water	893	591	262	115

TABLE OF RELATIVE COSTS OF GASES PER MILLION B.T.U. WHICH THEY ARE THEORETICALLY ABLE TO PRODUCE.

						Mi	Cents per llion B.T.U	J
Coal-gas	734,976	units,	costing	20.00	cents		27.21	
Water-gas	322.34ú	"		10.88	• •	• • • • • • • • • • • • • • • • • • •	33.75	
Producer-gas	117,000	64	**	2.58			22.05	

#### FUELS.

E. P. Reichhelm has discussed the use of gaseous fuel for forge fires, for drop-forging, in annealing-ovens, and furnaces for melting brass and copper, for case-hardening, mufflefurnaces, and kilns. Under ordinary conditions, in such furnaces he estimates that the loss by draft, radiation, and the heating of space not occupied by work is with coal 80 per cent, with petroleum 70 per cent, and with gas above the grade of producer-gas 25 per cent. He gives the following table of comparative cost of fuels, as used in these furnaces:

Kind of Gas.	Number of Heat-units in rooo cu. ft. used.	Number of Heat-units in Furnaces after deducting 25% Loss.	Average Cost per 1000 ft,	Cost of 1,000,000 Heat-units obtained in Furnaces.
Natural gas Coal-gas, 20 candle-power Carbureted water-gas Gasolene gas, 20 candle-power Water-gas from coke Water-gas from bituminous coal Water-gas and producer-gas mixed	1,000,000 675,000 646,000 313,000 377,000 185,000	<b>750,000</b> <b>506,250</b> 484,500 517,500 234,750 282,750 138,750	\$1.25 1.00 .90 .40 .45 .20	\$2.46 2.06 1.73 1.70 1.59 1.44
Producer-gas	150,000 306,365	112,500 229.774	.15 .15	1.33 .65 .73

In the use of natural gas in boiler-firing, it has been found that one man can attend to 1500 horse-power of boilers, while with coal he could handle only 200 horse-power; hence a ratio of 2 to 15 in labor cost would show that where wages are \$2.50 per day and the boilers require 4 pounds of coal per horse-power per hour, the cost of firing with coal will be, per ton of coal per 12-hour shift,

$$\frac{2.5 \times 2000}{12 \times 200 \times 4} \text{dollars} = 52 + \text{cents},$$

while tor gas but  $\frac{2}{15}$  of this will be required. Hence the following table will show the relative costs of coal and gas (water) with and without difference in labor cost:

	Price of Gas per 1000 cubic feet.					
Cost of Coal delivered to Boiler-room per Ton of 2000 lbs.	Not including D of At	Difference in Cost ttendance.	Including Difference in Cost of Attendance.			
	Carbureted.	Uncarbureted.	Carbureted,	Uncarbureted.		
\$6.co 5.00 4.00 3.00	14.8 cts. 12.3 " 9.9 " 7.4 "	$\begin{array}{c} 6.5 \text{ cts.} \\ 5.4 \\ 4.4 \\ 3.3 \\ 2.4 \end{array}$	16.0 cts. 13.6 " 11.1 " 8.6 "	7. 1 cts. 6.0 '' 4.9 '' 3.8 ''		
1.00	2.5 "	I.I "	3.7 "	1.6 ''		

The uncarbureted gas, exclusive of interest on capital, costs from 10 to 20 cents per 1000 cubic feet. Hence the advantages in the use of gas are from other directions than economy. The calorific power of the uncarbureted gas is about 54 per cent of that of the carbureted gas in the above table.

The heating value of New York City illuminating-gas, as used in gas-engines and for general heating, has been reported by Mr. E. G. Love, per cubic foot at 60° F. and barometer at 30 inches:

715, 692, 725, 732, 691, 738, 735, 703, 734, 730, 731, 727, giving an average of 721.

Probably 710 heat-units would be more nearly representative of average good quality. The coal-gas of London, with 16 to 17 candle-power, has a calorific power of 668 units per foot and costs from 60 to 70 cents per thousand cubic feet. It ignites at temperatures of 750° to 800° F. with proper mixtures of air.

57. Powdered Fuel.—Among the many experiments which have been tried to utilize waste coal in dust or culm from mine or breaker refuse is to be mentioned the plan of reducing the coal to powder, and blowing it into the furnace in the state of fine division. The pulverizers may be of any type; the fuel-dust is injected by means of an injector such as is used for oil-vapor systems, using air as the conveying medium. The furnace has to be lined with fire-brick which must be first brought to a high temperature by an open fire. Then the powder is blown in, and once ignited burns regularly and with good economy and without smoke, maintaining an intense heat.

58. Calorific Power of a Hydrocarbon.—It has been already said that the calorific power of a compound was the sum of the calorific power of its components (§ 22). Thus for olefiant gas,  $C_2H_4$ , made up of

 $C_2 + H_4 = 24 + 4 = 28$  parts by weight,

 $\frac{4}{28} = \frac{1}{7}$  will be hydrogen, and  $\frac{24}{28} = \frac{6}{7}$  will be carbon. If then  $\frac{1}{7}$  of the calorific power of hydrogen be added to  $\frac{6}{7}$  of the calorific power of carbon, their sum will be the calorific power of the compound. With analyzed hydrocarbons the percentages of each constituent will be used instead of the fraction above.

The accepted formula for computing the calorific power from an analysis is due to the physicist Dulong and is known by his name. It is:

Calorif. power of 1 lb. in B.T.U. = 
$$14500C + 62500\left(H - \frac{O}{8}\right)$$
.

In this C, H, and O are the percentages respectively of carbon, hydrogen, and oxygen, divided by 100 to reduce them to actual fractions of one pound. This is often transformed by the expedient of factoring the constants denoting the respective calorific powers of carbon and hydrogen so as to read:

Calorif. power = 14500 
$$\left[C + 4.31 \left(H - \frac{O}{8}\right)\right]$$
,

since  $\frac{62500}{14500} = 4.31$ .

For an analyzed gas, when the weight of a cubic foot is known and the proportion of each combustible in such cubic foot, the calorific power is found by multiplying each weight as a fraction of the whole by the calorific power of a whole unit of that combustible and adding these products together. The calculated calorific powers in the following tables (§ 60) were calculated in this way.

59. Evaporative Power of a Fuel. Efficiency. Heatbalance.-When a fuel is used for making steam to be used as a medium in an engine-cylinder, the weight of water at 212° F. which that fuel will make into steam at atmospheric pressure becomes of interest, and is a standard unit of com-Experiment has shown parison between fuels. that to change the state of water at 212° into steam at 212° requires an absorption of 966 British thermal units per pound of water so evaporated. Hence if the calorific power of the fuel be divided by 966, the quotient will be the maximum evaporative capacity of that fuel. For pure carbon the calculation is

 $E = \frac{14500}{966} = 15$  pounds of water from and at 212°.

This figure, of course, is never reached in actual firing of boilers. Eighty per cent of the total heat can be obtained in special conditions; 70 to 75 in regular practice with good anthracite coal. What are the reasons why the theoretical efficiency is not attained?

1. The loss in raising the air and the resulting products of combustion from the temperature of the fire-room to that of the flues and chimney-stack. This loss will be diminished by preheating the air by some waste heat, and by diminishing the weight of diluent air in excess of that needed for combustion.

2. The loss in evaporating any water in the coal, and in

the air itself. This moisture has to be raised to 212° and made into steam at atmospheric pressure.

3. The heat lost in heating up the earthy matter or ash in the coal from the temperature of the fire-room to that of the fire. Obviously, therefore, the less the percentage of such ash the more effective the fuel.

4. The heat absorbed in distilling off from the fuel the volatile matter or hydrocarbons, if any, and raising them and the solid carbon of the fresh-fuel charge to the point at which they will burn. This often makes the softer bituminous coals show to a disadvantage in competition with hard coal containing less volatile matter.

5. The loss of unburned carbon dropping down with the ash and removed with it.

6. Radiation losses from the furnace outwardly to the air. In brick-set furnaces the mass of brick absorbs heat in starting, which it returns in part at the latter part of a run; but the continuous transfer after stationary conditions are reached is never regained. These are largely unavoidable. Preventable losses will arise from:

7. Unnecessarily high stack temperature, due either to excessive firing or to inability of an inadequate absorbing surface in the boiler to take care of heat supplied to it.

8. Incomplete combustion, with loss of available carbon up the chimney-stack as gas or as smoke.

9. Excess of diluting air either below the grate or above it, or behind the bridge-wall.

10. Loss of solid carbon as sparks or cinders with a strong draft.

Many of these are interrelated to each other, and will furthermore be affected by size of the fuel selected for use. Their diminution by mechanical stoking and forced draft conditions will be discussed in subsequent chapters.

A comparison of water evaporated by different qualities of fuel has been made by Mr. Geo. H. Barrus, in which

broken anthracite is assumed to have a capacity of 11 pounds of water if free from ash. The figure given in the table for this fuel is that corresponding to 11 per cent of ash.

Kind of Coal,	Water Evaporated from and at 212° by One Pound of Dry Coal.	Relative Efficiency In Per Cent. Cumberland = 100.
Cumberland	11.04	100
Anthracite, broken	9.79	89
Anthracite, chestnut	9.40	85
Two parts pea and dust and one part Cumberland	9.38	85
Two parts pea and dust and one part culm	9.01	82
Anthracite, pea	8.86	80
Nova Scotia culm	8.42	76

An interesting computation of the results and requirements with a combustion of 100 pounds of anthracite is given in the following table, where it is assumed that the coal and air have a temperature of  $60^{\circ}$  and that the chimney-gases are at  $500^{\circ}$ . Hot ashes are withdrawn at  $450^{\circ}$ , and 2 per cent of carbon goes out with them. Under the assumed conditions 21 per cent is lost, for which ash and moisture in coal and air are responsible for over 5 per cent.

# HEAT-LOSSES INCIDENT TO THE COMBUSTION OF 100 POUNDS ANTHRACITE COAL.

Heat-losses.	Number of B. T. U.	Per cent of Total Heat of Fuel.
By water = $[(212-60) \times wt.] + 965.7 \times wt. + [sp. heat \times (500-212) \times wt.]$ By carbonic acid = wt. × sp. heat × (500 - 60). By ntrogen = wt. × sp. heat × (500 - 60). By free oxygen = wt. × sp. heat × (500 - 60). By ash = wt. × sp. heat × (450 - 60). By carbonin ash = wt. × sp. heat × (450 - 60) + wt. × 14650 By carbonic oxide = wt. × sp. heat × (500 - 60) + wt. × 4400	37012.5 27994.2 158452.8 21973.6 1105.7 29488.3	2.83 2.13 12.07 1.67 0.03 2.24
Total heat lost exclusive of loss by radiation Theoretically possible evaporation in pounds of water from and at 212° per pound of combustible utilized Theoretically possible evaporation in pounds of water from and at 212° per pound of fuel utilized	276027 <b>.</b> 1 12 10	21.02 •73 •44
FUELS.



TOTAL HEAT OF FUEL.

Weight of C × 14,650 =  $82 \times 14,650 = \dots$  1,201,300 B. T. U. Weight of H -  $\left(\frac{\text{Wt. of O}}{8}\right) \times 62,100 = 2 - \left(\frac{1.6}{8}\right) \times 62,100 = 111,780$ 

#### HEAT GENERATED.

80 × 14,650 =	1,172,000 B	. T. U.
$2 - \left(\frac{1, \ell}{8}\right) \times \mathbf{62, 100} = \dots$	111,780	**
	1,283,780	**

This method is interesting as presenting for the purpose in hand, the practice of striking a heat-balance in any test of a heat appliance. It will be noted that the heat-engine or boiler will be charged with the total quantity of heat energy delivered to it from all sources during a test, and credited with the units of heat delivered from it in all directions as observed in the test or assumed from experience with like apparatus. The form of balance-sheet would be as follows:

HEAT-BALANCE.

Dr.		Cr.
Fo heat	By heat	
from coal,	in dry steam,	
from air,	in moisture and water mechanically	suspended in
from feed-water.	steam,	
	in dry flue-gases,	
	in moisture in coal,	at temper-
	in water resulting from combustion,	ature of
	in vapor in air,	) flue-gases.
	lost through incomplete combustion t	o CO,
	in ashes,	
	lost by radiation and otherwise unacc	ounted for.

Of two appliances for utilizing heat energy, that is the more effective which most completely renders the available heat into useful work or product. Examples of the distribution of the available heat as reported by various authorities are given in the following table:

DISPOSITION OF HEAT IN STEAM-BOILERS.

			Au	thority	r.		
Disposition of Heat.	Bunté.	Sche at Meu	eurer nd inier.	к	Donkir and Cenned	n y.	adley.
		A	в	С	D	Е	Hot
Waste in flue-gases, including evaporation of moisture in coal and heating vapor in air when these losses are not separately							
given Evaporating moisture in coal	18.6 3•5	5.5 2.5	14.8 6.1	9.4 0.1	22.5 0.1	6.5 0.0	5.04 1.55
Imperfect combustion	8.0 4.I	6.0		12.7 0.1	0.0	0.0	1.44
Radiation and heat not otherwise accounted for	7.6 58 2	23.5 61.0	13.4 65.7	13.9 63.8	11.0 66.2	15.0 78.5	4.00 87.79

60. Data Concerning Fuels.—In the following tables gathered from various sources are grouped summaries of the data which have been discussed in the foregoing paragraphs. The results are from experiment and analysis.

Wét	Calorific Por calculated	8450 8172 8531 8360 8215	8767 8688 8689 8689 8829	8710 8644 9011	6610 6270	4947 4264 5609	7957 8130 8078
wer,	Calorific Po excluding Water and	8256 8216 8532 8456 8203	8656 8834 8574 8857	8668 8408 8768	9499 9709	4828 4200 5903	8001 8044 8036
19W	Calorific Por observed.	7484 7468 7828 7828 7850 7773	8392 8426 8051 8392	8210 7870 7761	6284 5536	4477 4200 5489	7665 7787 7528
vola-	Per cent of tile Matter exclusive o Water and	3.00 5.20 5.20 6.00	14.08 11.93 21.51 20.84	30.41 39.96 31.64	50.34 49.95	68.93 68.93 68.93	68.93 68.93 68.93 68.93
	.faA.	5.900 4.400 5.450 6.300	1.700 5.000 4.000	4.100 3.400 10.900	4.750 6.750	0.333 0.750 0.920	4.200 3.200 5.900
	Hydro- scopic Water,	3.450 4.700 2.800 1.775 1.760	I.350 0.625 I.100 I.250	1.200 3.000 0.600	0.710 3.144	6.940 6.920 6.125	0.500 0.500 0.233
nalysis.	Oxygen and Nitro- gen.	2.199 2.969 2.731 5.005 6.278	4.338 5.240 5.761 5.432	7.193 8.173 5.058	24.303 25.799	39.780 49.390 34.230	2.629 1.585 2.146
Y	Ηλάτοgen.	1.995 1.367 2.733 2.892 2.916	4.139 4.139 4.385 4.385	5.089 5.245 5.060	4.782	5.581 6.170 5.542	0.444 0.633 0.685
	<b>Carbon.</b>	85.456 86.564 85.746 84.928 82.746	88.473 85.937 83.754 84.546	82.418 80.182 78.382	65.455 59.795	47.366 41.440 53.183	92.727 94.58 <b>2</b> 91.036
	Kind of Coal.	Anthracite from Pennsylvania	Semi-bituminous from Anzin	Gas-coal from Béthune	Lignite from Styria. Lignite from Vaugirard	Norwegian pine, partially dried Cellulose, C <sub>12</sub> H <sub>10</sub> O <sub>10</sub> Tourbe from Bohemia	Coke, Commentry coal

FUELS.

HEAT OF COMBUSTION OF FUELS.

## TABLE OF AMERICAN COALS.

	Con	stituen Tota	ts in P al Weig	er Cen ght.	t of	Fuel	Value of Coa	per Lb. l.
COAL. Name or Locality.	Moisture.	Volatile Matter.	Fixed Carbon.	Ash.	Sulphur.	B. T. U. Calculated.	B. T. U. by Calorimeter.	Theoretical Evaporation in Lbs., from and at 212°.
ARKANSAS. Coal Hill, Johnson Co Coal Hill, Johnson Co Huntington Co Huntington Co Lignite Jenny Lind, Sebastian Co Spadra, Johnson Co	1.35 1.70 1.30 1.30 1.27 1.26 1.47	14.93 14.60 18.95 18.90 18.89  17.64 13.27	74.06 74.91 71.51 73.15 71.74  72.48 78.63	9.66 8.79 8.24 6.65 8.10  8.62 6.63	3.04 3.04 0.78 0.75 0.65  2.11 1.60	13713  9215 13964 14420	11812 11756 11907 12537	14.10 12.22 12.17 12.32 12.97 9.54 14.40 14.90
Lignite Lignite Lignite, slack Rouse Mine	14.80 18.88 3.13	32.00 31.74 37.32	42.86 40.08 30.00	10.34 9.30 8.25	0.76 0.61	13560 13865 8500	·····	14.04 14.35 8.80
Big Muddy, Jackson Co Big Muddy, Jackson Co Big Muddy, Jackson Co Big Muddy, Jackson Co Bureau Co Colchester Colchester Slack	7.30 6.12 5.85 6.35 11.60 5.30	28.28 30.95 31.84 31.50 25.02 25.45	53.87 53.74 55.72 55.25 44.76 38.15	10.46 9.19 6.59 6.90  18.62 31.10	0.98 1.22 2.92 2.02	12567 13025	11466 11520 11781  9848 9035	11.87 11.93 12.19 13.00 13.48 10.19 9.35
Collinsville, Madison Co Dumferline Slack Duquoin Jupiter, Perry Co Ellsworth, Macoupin Co Gillespie, Macoupin Co Girard, Macoupin Co Girard, Macoupin Co Heitz Bluff, St. Clair Co.	9.20 9.64 11.30 9.26 12.61 9.70 8.90	45.89 28.86 30.31 42.22 30.58 34.39 32.25 37.81	31.57 39.48 49.91 42.17 45.27 45.76 42.80 48.24	13.34 22.02 8.48 6.35 11.54 10.15 15.96	5.34 0.91 2.62 1.45 3.49 8.10	12175	10143 9401 10710  9739 9739 9739 9739	10.50 9.73 11.08 12.60 10.09 10.30 10.63
Johnson's, St. Clair Co Loose's, Sangamon Co Mercer Co Montauk Co Mt. Olive, Macoupin Co Oakland, St. Clair Co Reinecke, St. Clair Co	5.50 10.71 10.38 8.30 7.56	40.14 37.62 36.68 34.40 39.81	40.14 40.53 45.07 46.10 43.12 42.49	13.83 6.60 6.84 14.18 10.14	3.53 4.80 2.39  3.53 4.42 4.02	11723 11479 13123 12659 11763 11720	10395	12.10 11.90 13.58 13.10 12.20 10.76 12.10
Riverton, Sangamon Co St. Clair St. Clair St. Clair St. Bernard St. John, Perry Co St. John, Perry Co St. John, Perry Co	11.06 7.80 10.25 11.15 14 36 9.82 13.60	37.94 30.69 33.10 34.19 30.86 28.35 34.46	42.98 39.68 41.79 44.94 48.39 45.77 43.54	8.02 21.83 14.86 9.72 6.39 16.08 15.40	3.27 9.62 6.92 4.27 1.38 2.06 1.83	11406	9261 10294 10647 10080 9765 9828	11.80 9.58 10.65 11.02 10.44 10.10 10.18
Trenton, Clinton Trenton, Clinton Vulcan nut, St. Clair Co INDIANA. Rlock	12.01 13.34 9.95 7.44 10.30	35.32 30.39 31.04 30.86 27.91	48.78 51.96 52.03 45.04 48.99	3.89 4.31 6.98 16.61 12.80	2.38 0.92 1.04 1.32 0.71		11403 10584 11245 9450 10626	11.80 10.96 11.63 9.78 11.00
Block Caking Cannel	3.50	32.50		1.00	0.98	14020 13588 14146 13097	•••••	14.50 14 38 14.64 13 56

## FUELS.

	Con	stitue Tot	nts in 1 tal Wei	Per Ce ght.	nt of	Fuel	Value of Coa	per Lb. al.
COAL. Name or Locality.	Moisture.	Volatile Matter.	Fixed Carbon.	Ash.	Sulphur.	B. T. U. Calculated.	B T. U. by Calorimeter.	I heoretical Evaporation in Lbs., from and at 212°.
INDIAN TERRITORY.								
Atoka Choctaw Nation Iowa.	6.66 1.59	35.42 23.31	51.32 66.85	6.60 8.25	3.73 1.18		11088 12789	11.47 13.23
Guod Cheer	10.85	30,32	31.38	27.45	7.32		8702	9.01
KENTUCKY. Caking Cannel Cannel Lignite		· · · · · · · · · · · · · · · · · · ·				14391 15198 13360 9326		14.89 16.76 13.84 9.65
Bevier Mines						••••	9890	10.24
MARYLAND. Cumberland George's Creek	 			· • • • • • •	 	12226 13500	 	12.65 13.98
New Mexico. Coal. 1	2.35	35.53	50.24	11.88	<b>0</b> .61		11756	12.17
Ohio.								
Briar Hill, Mahoning Co Hocking Valley	2•47 8.25	31.83 35.88	64.25 53+15	1.45 2.72	0.56 0.43	13714 13414		14.20 13.90
PENNSYLVANIA.								
Anthracite Anthracite Anthracite Anthracite, pea. Anthracite, buckwheat. Cannel. Connellsville Pittsburgh (av.). Pittsburgh (av.). Pittsburgh (coking) Youghiogheny Youghiogheny Reynoldsville	2.04 3.88  1.80 1.43 1.96 2.02 1.20	6.36 3.84 35.34 30.22 34.06 32.14 27.12	78.41 81.32 54.94 61.87 58.98 58.66 65.88	13.19 10.96 7.92 6.48 5.00 6.88 5.80	0.67 1.97 1.35 0.88	14199 13535 14221 12300 12200 13143 13368  14415 	13104 12936 12600 12981	14.70 14.01 14.72 12.73 12.63 13.60 13.84 13.46 14.90 13.39 13.03 13.44
TENNESSEE.								
Glen Mary, Scott Co	2.15	31.47	61.63	4•75	0.94	•••••	13167	13.63
TEXAS, Ft. Worth Lignite	14.42 4.60	30 03 34•72	42.53 49 <b>.</b> 27	13.02 11.41	1.47 1.56		9450 11403	9.78 11.80 13.41
WEST VIRGINIA.								
New River New River. New River. New River.	 0.94 0.76	 18.19 18.65	75.89 79.26	4.68 1.11	0.30 0.23	14200 13400		14.70 13.87

	TABLE	OF	AMERICAN	COALS.
--	-------	----	----------	--------

			the second se	L. Britsman,	the second of the second of the	A	A statement of the stat
Description of Coal.	Carbon.	Hydrogen.	Oxygen.	Nitrogen.	Sulphur.	Ash.	Specific Gravity.
ANTHRACITES :			1		ļ		
French	00.0	1.47	1.53	1.00	0.80	4.20	1.25
Welsh	01.7	3.78	1.30	1.00	0.72	1.50	1.27
Rhode Island	85.0	3.71	2.30	1.00	0.00	7.00	1.42
Pennsylvanian	78.6	2.50	1.70	0.80	0.40	14.80	1.45
SEMI-BITUMINOUS :					1		
Maryland	80.0	5.00	2.70	1.10	1.20	8.20	1.22
Welsh	88.3	4.70	0.60	1.40	1.80	3.20	
EITUMINOUS:			1		1		
Pennsylvanian	75.5	4.93	12.35	1.12	1.10	5.00	1.32
Indiana	69.7	5.10	19.17	1.23	1.30	3.50	1.25
Illinois	61.4	4.87	35.42	1.41	1.20	5.70	1.31
Virginian	57.0	4.96	26.44	1.70	1.50	8.40	1.32
Alabama	53.2	4.81	32.37	1.62	1.30	6.70	1.30
Kentucky	49.1	4.95	41.13	1.70	1.40	7.20	1.28
Cape Breton	672	4.26	20.16	1.07	1.21	6.10	1.33
Vancouver's Island	66.9	5.32	8.76	1.02	2.20	15.80	1.28
Lancashire gas-coal	80.1	5.50	8.10	2.10	1.50	2.70	
Boghead cannel	63.1	8.90	7.00	0.20	1.00	19.80	
LIGNITES :						-	
Californian brown coal	49.7	3.78	30.19	1.00	1.53	13.80	1.32
_ Australian brown coal	73.2	4.71	12.35	1.11	0.63	8.00	1.27
PETROLEUMS:					-		
Pennsylvanian, crude	84.9	13.70	1.40				o.886
Caucasian, light.	86.3	13.60	0.10				0.884
heavy	8ó.6	12.30	1.10				0.938
Petroleum refuse	87.1	11.70	1.20				0.938
		1	1	1	1	ι ,	

## COMPOSITION OF COALS, PER CENTS.

TABLE SHOWING THE COMPOSITION AND CALORIFIC POWER OF VARIOUS COMBUSTIBLES—THE QUANTITY OF OXYGEN AND AIR NECESSARY FOR COMBUSTION—AND THE VOLUME OF THE PRODUCTS OF COMBUSTION OF I LB. OF COMBUSTIBLE.

		Comp	osition		wer.	bxy- tary stion	n for	Cor.	lucts cet.
Name of Combustible.	с	н	Volatile Matter.	Ashes.	Calorific Po	Weight of C gen Necess for Combu	Weight of A Necessary Combustio	Vol. of Air responding Cubic Feet	Vol. of Prod in Cubic F
Carbon Anthracite coal Bituminous coal Lignite Peat. Coke. Peat.coao water. Coke. Dry wood. Wood.charcoal Dry wood. Wood.co.zo water. Wood.charcoal Hydrogen Carbonic oxide Iluminating-gas.	1.00 0.90 0.85 0.70 0.55 0.39 0.85 0.82 0.48 0.40 0.80 0.43 0.02	0.03 0.05 0.05 0.05 0.05 0.05 0.05 0.05	0.03 0.06 0.20 0.30 0.50 0.25 0.25 0.04  0.57 0.17	0.04 0.06 0.05 0.10 0.07 0.10 0.18 0.01 0.01 0.07	14400 13500 14400 11700 9000 7200 12600 9000 7200 5400 1800 4320 18000	2.66 2.64 2.66 2.26 1.86 1.49 2.26 2.18 1.75 1.40 1.86 8.00 0.57 2.64	11.29 11.21 11.29 9.69 7.90 6.32 9.69 9.25 7.43 5.94 7.90 33.97 2.422 11 22	137.6 138.9 139.6 120.2 97.9 78.3 120.2 1120.2 114.5 91.9 73.5 97.9 420.6 20.9 136.3	137.6 136.2 140.1 116.3 102.1 81.5 116.9 112.7 89.2 71.8 90.3 475.4 35.6 176.7

### FUELS.

CO         0.50         6.0         45.0         27.0         2           H         2.18         46.0         45.0         12.0         1           CH4         92.6         40.0         2.0         1.2         1	as.
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	itu.
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	7.0
CH4	2.0
	2.5
$C_2H_4$	0.4
CO <sub>2</sub>	2.5
N	6.2
0 0.34 0.5 0.5 0.3	0.3
Vapor	
Pounds in 1000 cubic feet \$45.6 32.0 45.6 65.6 6	5.9
Heat units in 1000 cubic feet 1,100,000 735,000 322,000 137,455 15	5,917

## COMPARATIVE COMPOSITION OF GAS.

NATURAL GAS IN OHIO, INDIANA, AND PENNSYLVANIA.

		Ohio.			Indi	ana.		Penn.
Description.	Fos- toria.	Findl <b>a</b> y	St. Mary's.	Muncie	Ander- son.	Koko- mo,	Mar- ion.	Pitts- burgh.
Hydrogen	1.89	1.64	1.94	2.35	1.86	1.42	1.20	22.
Marsh-gas	92.84	93.35	93.85	92.67	93.07	94.16	93.57	67.
Olefiant gas	. 20	.35	. 20	.25	•47	. 30	.15	Í.
Carbon monoxide	- 5 5	.41	.44	•45	·73	• 55	.60	о.
Carbon dioxide	.20	.25	.23	.25	. 26	. 29	. 30	0.6
Oxygen	• 35	.39	• 35	· 35	. 42	. 30	- 5 5	0.8
Nitrogen	3.82	3.41	2.98	3.53	3.02	2.80	3.42	3.0
Hydrogen sulphide.	.15	.20	. 21	.15	. 15	18	. 20	

Approximately 30,000 cubic feet of gas have the heating power of one ton of coal.

PRODUCER-GAS FROM ONE TON OF COAL.

Analysis by Vol.	Per Cent.	Cubic Feet.	Lbs.	· Equal to—
Co H CH4 C <sub>2</sub> H4 CO N (by difference)	25.3 9.2 3.1 0.8 3.4 58.2	33,213.84 12,077.76 4,069.68 1,050.24 4,463.52 76,404.96 131,280.00	2451.20 63.56 174.66 77.78 519.02 5659.63 8945.85	1050.51 lbs. C + 1400.7 lbs. O. 63.56 '' H. 174.66 '' CH <sub>4</sub> . 77.78 '' C <sub>2</sub> H <sub>4</sub> . 141.54 '' C + 377.44 lbs. O. 7350.17 '' Air.

## RELATIVE CALORIFIC VALUES.

	By We	ight. By	Volume.
Natural gas	. 1,00	1 00	,000
Coal-gas	• 94	49	666
Water-gas	. 29	92	292
Producer-gas	•	76.5	130

The following table gives the accepted power capacity of various sources of heat energy in their relation to motors using these combustibles for power in gas or other engines.

Material.	Heat-units per Pound.	Heat-units per Cubic Foot.
Hydrogen Carbon Crude petroleum, W. Va., sp. gr873 Light petroleum, Pa., sp. gr841 Benzine C <sub>8</sub> H <sub>6</sub> Gasoline Illuminating-gas, 28 c. p ""19" ""15" Water-gas, American Producer-gas, English Water producer-gas Ethylene-olefiant gas C <sub>2</sub> H <sub>4</sub> Gasoline vapor	per Pound. 61560 14540 18324 18401 18443 11000	Cubic Foot. 293-5 
Acetylene, C <sub>2</sub> H <sub>2</sub> Natural Gas, Leechburg, Pa " " Pittsburg, Pa Marsh-gas, methane, CH4	21492	868 584 495 1051

## CHAPTER VI.

## TEMPERATURES OF COMBUSTION. PYROMETERS.

61. Introductory.--It will have been noticed that the calorific power of a fuel, or the total heat liberated from it upon combustion, is a quantity which is independent of the time required for that combustion. It is equally a fact of common observation that when a fuel is forced to burn rapidly the fire is hotter, or the flame has a higher temperature, than when the fuel is burned more gently, and the combustion process is extended over a longer time. In other words, the temperature of the fire is not independent of the time taken for combustion, but varies inversely as such time, while the calorific power is independent of time. This makes it a vital matter that the engineer should be able to control the rapidity of the combustion of the fuel, and this is most easily done by controlling the weight and velocity of the supply of air.

The higher temperature in the fire under rapid or forced combustion is due not only to the fact that under the assumption of a constant condition of intensity more fuel units will be supplied by the fireman or the firing machinery per unit of time when the combustion is more rapid. It is also true that the more intense the chemical activity, the higher the heat which accompanies such activity; and besides, the transfer of heat from the fire to absorbing bodies whereby its temperature is lowered will be greater the longer any given weight of fuel is permitted to occupy the grate or combustion area. This would imply that where transfer is a principal

feature of a combustion—as in a boiler—there may be an economical maximum rate of combustion which it would not be desirable to exceed. And finally, when rapid chemical combination with air is secured, as with oil- or gas-firing, and proper provision is made for admitting air and compelling chemical action by attention to details, a less excess (or none) of free oxygen is required in the products of combustion, and the cooling and diluting effect of the air and its inert nitrogen is diminished. Two questions are then suggested: I. What is the probable temperature of a fire and how may it be observed? 2. By what means shall the rate of combustion be secured and controlled?

62. Temperature of the Fire.—It will appear to be an obvious deduction from Chapter III (§§ 11 to 14) that when one body conveys or transfers heat to another substance which absorbs it entirely in raising its temperature, the quantity of heat in heat-units so transferred will be represented by the product of the weight (w) by its specific heat (c) by the change in temperature indicated by the difference between its final temperature and its initial temperature  $(t_2 - t_1)$  if the body in question was hotter after the transfer than it was before. This holds true also for the body or substance which has cooled, since the one has lost heat to the same extent as the other has gained it. In symbols, if Q represents the quantity of heat in units transferred from one body to the other,

$$Q = w \times c \times (t_2 - t)$$

for the body which has become warmed, and

$$Q' = w' \times c' \times (t_2 - t_1)$$

for the body which has cooled, having a different weight and different specific heat. But Q = Q'. It has therefore been a convention to assume that the temperature of the fire was the same as that of the flaming products of the combustion

## TEMPERATURES OF COMBUSTION. PYROMETERS. 87

at the instant when combustion was complete; and that all the heat liberated from the fuel was used to raise the products of combustion to this fire temperature. All that is unknown then in the above formula is the final high temperature of the products of combustion, when the total heat transferred, the weight of the products of combustion (§§ 24 to 28) are known, and their specific heat. This theory is sound and applicable for the conditions which prevail in a determination with a coal-calorimeter (§ 23), but the considerations advanced in the preceding paragraph throw some doubt upon its reliability as applied to practice. The assumption is further implied that specific heats are constant at all temperatures. The specific heats under constant pressure of the constituents of the fire are:

For	carbonic acid gas	0.217
" "	steam or water-vapor	0.480
" "	nitrogen	0.244
" "	air	0.238
" "	ashes (probably)	0.200

The data for the computation of a hypothetical fire-temperature for two combustibles, such as pure carbon and olefiant gas, will be:

		Carbon, C	Olefiant Gas, C <sub>2</sub> H <sub>4</sub>
(1)	Calorific power	14,500	21,300
(2)	Pounds weight of products of combustion	13.00	16.43
(3)	Mean specific heat	0.237	0.257
(4)	Specific heat and weight	3.08	4.22
	Value for $(t_2 - t_1)$ , or $(I) \div (4)$	4580°	5050°

This assumes no dilution of the products by air. The use of diluting air will act to lower the hypothetical temperature by increasing the weight to be heated. The specific heat of course approaches more nearly to that of air the greater the proportion of air in the products of combustion.

Recent investigations with the pyrometer show that tem-

peratures hitherto have been often overestimated, and that the high values obtained by the above method are not reached in practice. A generally accepted series of data is given in the table below, constructed by M. Pouillet. Its use of course must be subject to the peculiarities of the individual and the degree of general illumination prevalent.

Heat	Deg. C.	Deg. F.	Heat.	Deg. C.	Deg. F.
Incipient red Dull red Incipient chorry Cherry-red Clear cherry-red Deep orange	535 700 800 900 1000 1100	977 1292 1472 1652 1832 2021	Clear orange White heat Bright white heat Dazzling white heat. {	1200 1300 1400 1500 to 1600	2192 2372 2552 2732 to 2912

The melting or heating of metals with fuel implies that the heat of the fire should not be less than that demanded by the metal. Recent determinations by Prof. Roberts-Austen give melting-temperatures as follows:

Copper 1929° to	1996° F.
Cast-iron, white	2075
" gray	2228
Steel, hard	2570
" mild	2687
Wrought iron 2732 to	2912
Platinum	3227

The melting-temperature of steel at the end of its conversion in the open-hearth steel process is among the highest usually met in industry, and is about  $2732^{\circ}$  F. Even this, however, is only attained by preheating both gas and air used in the process. The heat in a furnace for baking hard porcelain may rise to 2500° F. Furthermore, it is a question somewhat of quantity of heat rather than its intensity. The platinum value is that for material which is only fusible before the oxyhydrogen blowpipe. All these data tend to throw a certain doubt upon the validity of the accepted

## TEMPERATURES OF COMBUSTION. PYROMETERS. 89

method of working out flame or fire temperatures, and leave the field open for practical determinations by pyrometer.

Hoadley gives the temperature in a boiler-fire as ranging from 2493° F. to 2793° F. in its heart, and 1340° to 1600° F. at the bridge-wall. In a marine boiler, Durston records 1644° in the combustion-chamber. Clark gives 1705° for a combustion rate of 20 pounds per square foot grate, rising to 2100° at a 120-pound rate.

63. Pyrometers. General.—The usual appliances for measuring temperature (§§ 13 to 15) are not suitable for high heats, with the possible exception of the air-thermometer. Mercury-thermometers with nitrogen gas in the tube above the mercury can be used up to  $800^\circ$  F.; the ordinary construction being open to the objection that the rate of expansion of mercury increases with the rise of temperature, so that a mercury-thermometer which agreed with an air-thermometer at 212° would read low at temperatures below this point, and high at temperatures above it.

The name pyrometer is given to an appliance for measuring or observing high temperatures. There are several principles which have been applied in such instruments.

I. Melting-points of various metals or alloys. This is approximate only, since the melting-point varies with chemical purity of the metals in question, and undergoes change with time, with frequency of melting, and deterioration by heat.

2. Expansion of metals by heat. These may be single bars, or compound bars of two or more metals whose rate of expansion is not the same. Copper and iron are two usual metals to use (as in Brown's pyrometer and Bulkley's); the bar flexes, and the amount of flexure indicates the heat on a convenient dial. To this class belongs the use of clay bars, which contract under heat, as in the Wedgwood pyrometer formerly used by potters for their ovens. Clay, however, is not uniform nor permanent, and in the case of the metal bars

a permanent change occurs by and by in the molecular structure consequent upon the prolonged heating, which prevents accuracy.

3. Changes in volume and action of a permanent gas such as air, either using its expansion, as in the air-thermometer and nitrogen-thermometer, and in the Wiborgh pyrometer, or depending on the changes in rate of flow with temperature, as in the Uehling-Steinbart pyrometer.

4. Methods based upon the specific heat of solids, raised to the fire-temperature and cooled in water.

5. Time required to heat a weighed quantity of water enclosed in a vessel, as in the water-pyrometer.

6. Changes in the electric resistance of a refractory conductor such as platinum exposed to heat, as in the Siemens pyrometer.

7. Measurement of the strength of a thermo-electric current produced by heating the junction of two metals, as in the Le Chatelier pyrometer.

8. Optical effects in deflection of light rays from incandescent solids, as in Mesuré and Nouel's pyrometric telescope.

64. Metal-ball Pyrometer.—The metal-ball pyrometer is one of the easiest to arrange for. A ball or other mass of metal of known weight and specific heat is put into the place whose heat is desired, and left there until it gains the same temperature as the medium around it. It is then withdrawn and dropped into a known weight of water of observed temperature, and the rise of temperature is observed which it causes in the water. The principles of transfor demand that if W is the weight of water with a specific heat of unity and an initial temperature of  $t^{\circ}$  F., while w is the weight of the ball, c its specific heat, T the final temperature of the water, then the unknown temperature x of the ball will be given from the equality

 $W \times \mathbf{I} \times (T - t) = w \times c \times (x - T);$ 

whence

$$x=\frac{W(T-t)}{wc}+T.$$

For greater accuracy, corrections must be made for variations of specific heat, for the capacity of the cooling vessel itself for heat, for losses in transit from fire to cooling vessel, etc. The ball may be platinum, iron, or other metal, or fire-clay or fire-brick.

65. Wiborgh Air-pyrometer.—This form of pyrometer involves the use of a porcelain globe or cylinder connected through a capillary tube with the exterior air. The air in the globe is heated by the temperature to be measured, with the tube open. Then a known volume of air of known temperature is forced into the globe with its outlet closed, and the resulting pressure observed by a delicate pressure recording-device. Then, since the initial volume and pressure are known before the addition of the cooler air, and the final pressure is observed when the volume and temperature of the added air are known, the only unknown factor is the original temperature, which is the quantity desired.

This form of apparatus is useful for temperatures between  $0^{\circ}$  and 2400° F., such as occur at metallurgical and similar furnaces.

66. Uehling-Steinbart Pyrometer.—The Uehling pyrometer depends on a principle of the flow of a permanent gas, such as air through a minute aperture, which makes the weight which flows in a given time a function of the density of the air, which varies directly as the absolute temperature. This is applied by having a closed tube or chamber fitted with minute inlet and outlet orifices and causing air to flow in through one and out through the other, by means of proper aspirating appliances, while the tension in the chamber is carefully measured by a sensitive manometer. The air to enter is made to have the desired temperature by locating the inlet aperture in the end of a platinum tube in the bulb of a porcelain tube over which the hot gases pass, or which is inserted in the chamber or place whose temperature is to be ascertained. The outlet aperture is kept at a lower but constant temperature, and is operated at a constant suction effort by surrounding it with boiling water in a proper coupling and aspirating by means of a water-column kept at a constant height.

67. Le Chatelier Thermo-electric Pyrometer. Siemens Pyrometer.-The principle of the thermo-electric pile is used in this apparatus. Two wires, one of platinum and the other of platinum with 10 per cent of rhodium, are made into the usual thermo-electric couple of the physical laboratory, and are presented to the heat to be measured. The action of heat creates a current of electricity in the couple, whose intensity is measured by a galvanometer. The instrument should be calibrated experimentally by heating the junction of the pile to temperatures which are known as observed by the air-thermometer, and plot the curve of deflections from these data. The error of a Le Chatelier pyrometer is usually less than 50°, up to its limit of use. The Siemens pyrometer depends upon the principle that the conductivity of platinum wire is diminished by heat, and measurably to a degree proportional to that temperature if the wire is thoroughly homogeneous. If, therefore, an electric current is divided, and by a Wheatstone bridge or other controllable resistance the two branches are made to have equal resistance at the same known temperature, it becomes easy, by raising one branch of the wire to known temperatures and equating the varying resistance, to make a calibration whereby unknown temperatures may be determined, either by the galvanometer-reading directly, or by the resistance necessary to introduce to keep its reading constant. An uncertainty is introduced, however, by the difficulty of avoiding a molecular change in the conductor which is exposed to heat, of whose extent and effect there is alwys some uncertainty.

## TEMPERATURES OF COMBUSTION. PYROMETERS. 93

68. Mesuré and Noel's Pyrometric Telescope .- For observing temperature of incandescent or glowing bodies by the color of the rays of light which they emit, an appliance can be easily constructed which shall serve as a pyrometer, basing it on the principle that a plate of quartz cut at right angles to the crystalline axis rotates the plane of polarization of polarized light to a degree nearly inversely proportional to the square of the wave-length of such light. If, then, two Nicols prisms be placed in a tube and a ray of monochro matic light be passed through the first prism or polarizer, and watched through the second or analyzer, with the plate of quartz between them, a part of the light which passed the first and in the absence of the quartz was extinguished will be made visible when the quartz is present. To extinguish it the analyzer must be rotated, and rotated further as the light from the hot body gathers the shorter waves of orange and yellow and emits them all as it passes to the dazzling glow of white light. The degree to which the analyzer must be turned is a measure of the temperature of the radiating body.

Like the foregoing instruments, this should be calibrated experimentally, and has the great advantages of cheapness, convenience, and portability to offset the absence of exact definition of temperature, and the difficulty in applying it to widely varying materials.

69. Some Standard Temperatures.—For use in standardization of other appliances, or for direct use in pyrometry, certain accepted temperatures gathered from various sources are here presented in tabular form.

Deg. F.	Deg. C.		Deg. F.	Deg. C.	
212	100	Water boils.	1733	945	Silver melts.
618	326	Lead melts.	1859	1015	Potassium sulphate
676	358	Mercury boils.			melts.
779	415	Zinc melts.	1913	1045	Gold melts.
838	448	Sulphur boils.	1929	1054	Copper melts.
1157	625	Aluminum melts.	2732	1500	Palladium melts.
1229	665	Selenium boils.	3227	1775	Platinum melts.

#### BOILING-POINTS AT ATMOSPHERIC PRESSURE.

## 14.7 lbs. per square inch.

Ether, sulphuric 100° F.	Average sea-water	213.2° F.
Carbon bisulphide 118	Saturated brine	226
Ammonia 140	Nitric acid	248
Chloroform 140	Oil of turpentine	315
Bromine 145	Phosphorus	554
Wood-spirit 150	Sulphur	570
Alcohol 173	Sulphuric acid	590
Benzine 176	Linseed oil	59 <b>7</b>
Water 212	Mercury	6 <b>76</b>
ma 1 111 1 1 1 1 1 1		

The boiling-points of liquids increase as the pressure increases.

## MELTING-POINTS OF VARIOUS SUBSTANCES.

The following figures.are given by Clark (on the authority of Pouillet, Claudel, and Wilson), except those marked \*, which are given by Prof. Roberts-Austen in his description of the Le Chatelier pyrometer. These latter are probably the most reliable figures.

Alloy, I tin, I lead. 370 to 466° F.
Tin 442 to 446
Cadmium 442
Bismuth 504 to 507
Lead 608 to 618*
Zinc 680 to 779*
Antimony 810 to 1150
Aluminum 1157*
Magnesium 1200
CalciumFull red heat.
Bronze 1692
Silver 1733* to 1873
Potassium sulphate 1859*
Gold 1913* to 2282
Copper 1929* to 1996
Cast iron, white 1922 to 2075*
" gray 2012 to 2786 2228*
Steel 2372 to 2532
" hard 2570*; mild, 2687*
Wrought iron 2732 to 2912
Palladium 2732*
Platinum 3227*

## CHAPTER VII.

### RATE OF COMBUSTION. DRAFT.

75. Introductory.—It has been previously observed that the calorific power of a fuel is a reasonably fixed quantity and is independent of the time taken to burn it (§§ 22, 23, 58, and 59). On the other hand the temperature of the fire depends on the number of pounds of fuel burned therein per hour (§§ 61 and 62), and the permitted dilution with excess of air (§ 30). It becomes of interest then to examine how many units of weight of a fuel, with a given heating effect, are usually burned per unit of grate-surface in a given time.

76. The Rate of Combustion.—The rate of combustion with English units is usually expressed by giving the number of pounds of fuel burned per square foot of grate-surface per hour. The table on page 96 gives a summary of practice and opinion upon this subject as respects steam-boilers.

An interesting comparison of tests recently made shows a tendency to regard 13 pounds per hour per square foot as representing prevalent American practice for stationary boilers on land. The use of higher pressures will be likely to increase this rate. The number of pounds of fuel which can be burned will be determined absolutely by the weight of oxygen or volume of air which can be supplied to it in a unit of time. It becomes a question of moment, therefore, to decide on the method of supplying the necessary air for combustion (§§ 24 to 27), and to provide a method to remove the

Type of Boiler.	Pounds of Coal Square Foo	per Hour per t of Grate.	Draft.	Authority.
-,,,-	Anthracite.	Bituminous.		
Land types Marine types " " " Cornish Flue Factory Marine Locomotive Torpedo-boat }	6-12 7-16	12-27 65-80 12-27 18-20 20-30 4-6 10 12-16 16-14 40-100 60-125	Chimney Forced Chimney " Forced Chimney " " " Forced "	Whitham Seaton Shock " Seaton Rankine " " "
Average		12–18 60	Chimney Forced	-

TABLE OF RATES OF COMBUSTION.

products of combustion (§§ 28 and 29) which are not supporters of such combustion, but tend to extinguish it if not removed.

77. Draft for Combustion. General.-There are two generic ways of bringing air to a motive-power fire: it may be done by a mechanical apparatus, such as a fan or a steamjet; or it may be done by means of the greater weight of cold air per cubic foot as compared with warm air, in a vertical column of such warm air enclosed within the walls of what is called a chimney. The first plan is known as mechanical or forced draft; the second is called natural draft or chimney-The term natural draft is unfortunate, because the draft. chimney is a simple machine, and both methods are mechanical, or equally dependent on a natural law. The term forced draft, on the other hand, should be restricted to cases in which the velocity of the air-current is made greater than it is possible to make it with a chimney of any ordinary or practical height. A mechanical appliance must be used in this case because the velocity is caused by a higher pressure

## RATE OF COMBUSTION. DRAFT.

of the air where it enters the fire than can be secured by natural processes. The two alternatives are therefore natural or forced draft, having respect to the differences in pressure and velocity usual on the one hand; and the other division would be into chimney-draft or mechanical draft according as the current is produced by chimneys or by fans.

78. Chimney-draft. General.-It has long been a matter of common observation that heated air is lighter than the same bulk of cold air. In any volume of air either in enclosed spaces or in the open, the greater weight of the colder air will tend to draw it into the parts nearer to the earth, and in so doing it will displace the lighter warmer air and send If either the warmer or the cooler air or both it upward. are confined in tubes or ducts or flues, the movement of displacement becomes a definite flow through the flue or tube. and the action of gravity on the denser air becomes a means of moving the necessary weight or volume of air through the fuel to be burned. The chimney is the tube containing the lighter gas, at the bottom of which is the fire or source of heat. The column of cooler and heavier air outside of the chimney is the motor energy which sets the warm column in motion against the resistances of friction and the obstruction at the fire itself. The volume which the chimney will pass through its area will vary with its cross-section and with the velocity of flow through this cross-section. The velocity of flow will be fixed by the difference in weight of the hot column and of the cold column of equal height. This difference is fixed by the temperature outside the chimney and within it, which determines the density or weight per cubic foot of each column.

While it would appear, however, that the velocity increases with temperature, it must not be overlooked that the weight is decreasing with the higher temperature, and that weight of oxygen is really the important thing to be presented to the fire. There is therefore a certain temperature

of chimney-gas at which the greatest weight of oxygen will be passed through the fire. Below this the velocity is not high enough, and above this the weight per cubic foot is decreasing faster than the velocity is increasing. It is moreover of advantage not to have too high a chimney temperature made necessary to cause proper draft, because each unit of heat passing off in the chimney unnecessarily (§ 59) is a waste which should have been utilized, and that heat should have been transferred to the motor fluid in the form of heat energy instead of being wasted to create draft.

79. Theory of Chimney-draft by Péclet.—The most widely accepted theory of the action of the chimney was first elaborated by Péclet, and developed and quoted by Rankine



and other writers. His discussion can be made most easily to be understood by the conception of the chimney as an inverted siphon, with the fire-grate at the bend at the bottom. In Fig. 13 the hatched section represents the chimney,

## RATE OF COMBUSTION. DRAFT.

and the dotted lines the siphon leg of cold external air. A diaphragm A-B in the bend of the siphon will have unequal pressures on its two sides if the legs are of equal length and equal cross-section, because if  $D_a$  denotes the density of the external air and its weight per cubic foot, and  $D_c$  denote the density of the warmer lighter chimney-air, then  $HD_a$  acts on one side, and the less  $HD_c$  on the other. To equalize the pressures an extra effort must be exerted on the lighter leg to balance the heavier, so that an extra length of column of hot air of unknown height h, and having a density  $D_c$ , must exert a pressure  $p = hD_c$  to effect this balance. Or, since

$$HD_a = HD_c + p,$$

we can write

$$\phi = HD_a - HD_c$$

as the pressure exerted on the diaphragm or on a film of air at the base of the siphon and which causes the flow when there is no balancing pressure at the top of the chimney. But since  $p = hD_c$ , the height of the column of hot gas will be

$$h=\frac{H(D_a-D_c)}{D_c},$$

and the question of the values of these two densities is a question for observation or calculation. At  $32^{\circ}$  F.,  $D_{\circ}$  for air is .0807, and by reducing D to  $32^{\circ}$  F. the value for k can be found in feet, or more conveniently the expression can be transformed to read in absolute temperatures instead of densities by the relation that the densities will be inversely as the temperatures, so that

$$\frac{D_c}{D_o} = \frac{T_o}{T_c}.$$

But the chimney-gas is a mixture, and not a constant or permanent gas. An accepted value for its ordinary density

at 32° F. is .08424, which is derived from an averaging of many analyses and experiments which give for such gases:

Carbonic a	acid 10	per	cent,	weighing	at	32°	••••	.12344
Nitrogen	79	"	<b>'</b> .	"	"	"	• • • • •	.07860
Oxygen	II	"	٠ ·	6 6	" "	"	• • • • •	.08926

Multiplying the per cent of each by its weight, we have:

]	Γot	al	.08424
66	"	0	,00981
" "	" "	N	.06209
Weight	of	CO <sub>2</sub>	.01234

If the composition of the gases differs from the above assumption as determined by analysis or otherwise, additional data are given in the following table:

	Specific Volumes.	Specific Heat in Gaseous Condition.	Density or Weight of OneCubicFoot.
Hydrogen Oxygen Nitrogen Carbon dioxide Carbon monoxide Water Air	178.881 11.2070 12.7561 8.10324 12.81 12.3900	3.4090 0.2175 0.2438 0.2169 0.2450 0.4805 0.2375 0.2	0.00559 0.08928 0.07837 0.12341 0.07806 

Substituting, then, for D in the formula for height the expression

$$D_c = .08424 \frac{T_o}{T_c},$$

the expression for that height becomes

$$h = H \frac{\left[ .0807 \frac{T_{o}}{T_{a}} - .08424 \frac{T_{o}}{T_{c}} \right]}{.08424 \frac{T_{o}}{T_{c}}},$$

a Marka Marka Ing a

## RATE OF COMBUSTION: DRAFT.

which becomes by performing the operations that it is the inter-

$$h = H\left(.96\frac{T_c}{T_a} - 1\right).$$

The velocity in feet per second caused by a height h in feet will be denoted by  $v = \sqrt{2gh}$ ; the volume V per second if the cross-section be denoted by A square feet will be Av, and becomes

$$V = Av = A\sqrt{2gH\left(\frac{.96T_c - T_a}{T_a}\right)}$$

for the temperature of  $32^{\circ}$  F. If it be required to burn W pounds of coal per second, and KW cubic feet of gas at  $32^{\circ}$  F. be the result, we shall have an equation for W, since V = KW,

$$W = \frac{A\sqrt{2gH\left(\frac{.96\,T_c - T_a}{T_a}\right)}}{K}$$

the second of the

as the theoretical pounds of coal which will be burned by a chimney of height H and area A when the resistances to flow of air and gas are disregarded.

80. Discussion of Péclet's Theory of Chimney-draft.— Péclet developed a later theory in which the dynamic energy for the flow of air to the furnace was a head in feet expressed in terms involving the cold gas or external air. He also developed an expression for the velocity of flow, starting from the general expression for the relation between the head in a pipe and the flow which it produces in the case of a liquid. A form for this is

$$h = \frac{v^2}{2g} \left( \mathbf{I} + K + K_1 + \frac{fl}{m} \right),$$

IOI

1011-1

which in Peclet's form appears as

$$h = \frac{v^3}{2g} \left( \mathbf{I} + G + \frac{fl}{m} \right).$$

In this equation *h* is the head; *g* is the acceleration due to gravity; *f* is the friction against sides of pipe or duct or flue; *K* and  $K_1$  or *G*, which combines them, are coefficients to express the resistances offered by bends, elbows, valves, and fittings in hydraulic work and by the grates, tubes, and damper in boiler-furnace work; *l* is the length of the pipe or gaspassage; and *m* is the ratio of area of cross-section to the perimeter, called the hydraulic mean depth. For square or round flues *m* will be one fourth of the side or diameter, since  $\frac{b^2}{4b} = \frac{b}{4}$  for a square flue, and  $\frac{\pi r^4}{2\pi r} = \frac{r}{2} = \frac{D}{4}$  for a round one. Péclet's value for *G* he puts at 12 for cases where 20 to 24 pounds of coal are burned per hour, and for *f* his value is 0.012 for surfaces covered with soot. Hence his formula becomes

$$h=\frac{v^2}{2g}\left(13+\frac{0.012l}{m}\right),$$

whence the expression for volume per second with a height H would appear

$$V' = Av' = A \sqrt{\frac{2gH(\frac{.96T_c - T_a}{T_a})}{13 + \frac{0.012l}{m}}}.$$

The uncertainty as to coefficients; the fact that it is not true that  $v = \sqrt{2gh}$  for a flow of a gas which undergoes any notable change in pressure or temperature, and the chimney problem introduces both; the fact that the chimney temperature  $T_c$  is not constant from top to bottom; and the necessity for the assumptions of area and temperature and velocity

before a height can be worked out, have thrown designers upon the data of experience rather than upon the foregoing calculations.

The Péclet formula, however, possesses this interest. Since the velocity of the gas in the chimney increases as the square root of the height of the dynamic column, and therefore with  $\sqrt{.96T_c - T_a}$  when the external-air temperature is fixed, and since the density is inversely proportional to the temperature in the chimney, the weight discharged will be proportional to

$$\frac{\sqrt{.96T_c-T_a}}{T_c},$$

which becomes a maximum when

$$T_{c} = \frac{2T_{a}}{.96} = \frac{25}{12}T_{a} = 2\frac{1}{12}T_{a};$$

or the greatest weight will be discharged when the absolute temperature within the stack is  $\frac{25}{12}$  of the absolute temperature of the external air. That is, if the external air be at 62° F., or an absolute temperature 522°, the temperature within the chimney for a greatest weight of gas flowing should be  $522 \times \frac{25}{12}$  or  $1087^{\circ}$  absolute, or  $626^{\circ}$  F. This explains the usual preference for temperatures around 600° F. in ordinary boiler-stacks. This is about the temperature of melting lead. On the other hand, for many metallurgical purposes a higher temperature in the stack is a necessity, and a greater velocity than is usual in steam-boiler practice. When this maximum temperature prevails h = H; or the extra column of hot gas has a height equal to that of the original chimney, and the density of that gas is one half of that of the external air. The formula also indicates that chimneys draw best with cold air outside and at high barometric pressures.

81. Some Accepted Chimney Formulæ and Data.—Mr. Wm. Kent in 1884 proposed a formula based on successful practice and on the idea that the effective area of a chimney was less than its gross area by a dead-space of two inches radially from each wall of a square chimney or all around a round one. This idea, if A be the gross area expressed in square feet, and E the effective area, will make: For square chimneys

$$E = D^2 - \frac{8}{12}D = A - \frac{2}{3}\sqrt{A}.$$

For round chimneys

$$E = \pi (D^2 - \frac{8}{12}D) = A - 0.592 \sqrt[4]{A}.$$

This is so nearly the same for both that it can be written

$$E = A - 0.6\sqrt{A}.$$

Since the power of a chimney varies both as the square root of its height at best temperature conditions and as its effective area, it can be written that

$$H.P. = E\sqrt{h} \times C,$$

in which  $\hat{C}$  is a constant to be determined from successful practice. A boiler horse-power is assumed to be equivalent to an evaporation of 30 pounds of water per hour (§ 101). Assuming 5 pounds of coal per horse-power per hour to take account of poor conditions, and observing the number of pounds of coal which a successful chimney will take care of, an acceptable value for C is found to be  $3\frac{1}{8}$ . Hence

H.P. = 
$$3.33EVh = 3.33(A - .6VA)Vh$$
;

which can be written also

$$E = \frac{0.3 \text{H.P.}}{\sqrt{h}},$$

when the quantities of the second member are the known data.

A series of observations by Morin & Tresca from French

#### RATE OF COMBUSTION. DRAFT.

practice have resulted in the following table, which is a very safe guide. The grate is eight times the chimney crosssection.

. 50 Heights in ft. of chimney ..... 20 35 40 60 25 30 45 55 65 Lbs. per hour per sq. ft. grate.... 7.5 """ " " " " chimney. 60 8.5 9.5 10.5 11.6 12.4 13.1 13.8 14.5 15.1 76 68 84 93 99 105 111 116 121 Heights in ft. of chimney...... 70 '75 80 85 00 95 . 105 100 110 Lbs. per hour per sq. ft. grate.... 15.8 16.4 16.9 17.4 18.0 18.5 19.0 19.5 20.0 " " " " " chimney. 126 131 144 148 152 156 160 135 139

A simple formula by Thurston agreeing quite closely with the above table is

# Rate of combustion $= 2\sqrt[n]{h} - 1$ ,

in which *k* is the height in feet.

Other designers have aimed to deduce formulæ from practice which should take account of the prevalent resistances in grates and fires with different grades of fuel, introducing the results of tests into formulæ as coefficients. But successful practice of others will remain the preferred guide. Sectionalboiler practice using water-tubes has deduced the following diagram (Fig. 14) to represent the draft in inches of water DIAGRAM OF DRAFT AND CAPACITY OF CHIMNEY.



(§ 83) corresponding to any number of pounds of air delivered when the chimney is 100 feet high and the external air is at 60°, as well as the maximum rendition-point between  $500^{\circ}$  and  $600^{\circ}$ .

Chimneys over 150 feet in height are rarely justified; but

250 feet of height may be compulsory in towns to carry off gaseous or noxious products without possibility of nuisance. The following table represents conservative data:

 Pounds of coal consumed per hour.... Up to 100
 500
 1000
 2000
 3000
 4000
 5000

 Height in feet......
 60
 100
 120
 140
 160
 180
 200

Several smaller chimneys are often used instead of one large one, where location does not compel great height, with considerable economy.

Fine anthracite coal needs a higher stack than good bituminous coal, both on account of the grate resistance and the lower temperature of the gases, and wood requires less than either of the other two.

Tallest chimneys of record are:

Townsend's Chemical Works, Glasgow	468	feet
Hallsbruckner Hütte, Saxony	460	" "
Metropolitan Street Railway Co., New York	353	" "
Omaha & Grant Smelting Co., Denver	352	" "
Clark Thread Co., Newark, N. J	335	" "
Amoskeag Mills, Manchester, N. H	250	"
Narragansett E. L. Co., Providence	238	"
Maryland Steel Co., Sparrows Pt., Md	225	" "
Passaic Print Works, Passaic, N. J.	200	"
Edison Electric Light Co., Brooklyn (two)	150	" "

82. Cross-section of Chimney.—The weight of chimneygas moving per second through the fire is conditioned both upon velocity and cross-section, which for a fixed quantity of gas can vary inversely as each other. Too large a crosssection causes the chimney to draw badly because the lower velocity of the gases permits eddies from back-draft; the gases are cooled by contact with the material of the chimney, and the chimney is unnecessarily costly to build. Hence a sort of empiric standard makes the cross-section of the chimney to be one eighth of the area of the grates burning coal for it. This can be shown to be ample for any usual assumptions or normal velocity; for, if an area of one square foot be

taken, and a temperature for maximum output  $v_1 = \sqrt{2gH}$ , and if H be taken at 64 feet of height for illustration.

$$v_1 = 64$$
 cubic feet per second  
=  $64 \times 3600 = 296,000$  cubic feet per hour.

Suppose 20 pounds of coal burned per hour per square foot of grate, and 300 cubic feet of air per pound of coal; then  $20 \times 300 = 6000$  cubic feet of air at  $62^{\circ}$  will be required per square foot of grate. At  $626^{\circ}$  F. in the chimney this air will have twice its volume at  $62^{\circ}$ , since

$$V_c = V_a \frac{T_c}{T_a} = 300 \frac{1085}{521};$$

whence

 $V_e = 12,000$  cubic feet,

which, if multiplied by the assumed relation of chimney I : grate 8 = 96,000, is only about  $\frac{96000}{296000}$ , or one third of what the chimney of only 64 feet high will take care of per foot of area of cross-section.

The friction becomes greater if the chimney be too small, and plants are usually enlarged after some years of use. Hence, although this one-eighth value is large, it is usually best not to pass much below it in small plants. Possible excess of area is corrected by partly closing the damper in the flue to the stack.

An ingenious designer has proposed to use the dead area of the Kent formula, or the back-draft area in the above discussion, as a passage to bring preheated air down the stack so as to introduce it below the fire and avoid the consumption of fuel required to raise this air to fire-temperature.

83. Draft-gauges.—It is usual to observe the pressure prevailing at the base of the stack after the resistances caused by the fire, grate, damper, and flues have been encountered, and to call this pressure that which causes the flow in the

siphon. In the foregoing discussion it was given in feet of head of hot gas (h), but can be transformed into pounds per square foot by multiplying (h) by the weight of a cubic foot of the gas  $(D_c)$ , or

$$p = hD_c$$
,

as shown in § 79. The velocity is then worked out from the pressure by finding the value for h in feet when p and  $D_c$  are observed, and by calling  $v = \sqrt{2gh}$ .

The most usual form of draft-gauge is a U tube or inverted siphon of water, of which one leg is connected to the chimney-base by a convenient pipe-connection, and the other is open to the atmosphere (Fig. 15). This gauge gives a reading in inches of water, and the relation between the two units is found as follows: since I cubic foot of water exerts a pressure per square foot of 62.5 pounds, hence I inch exerts  $\frac{62.5}{12} = 5.2$  pounds per square foot, and  $\frac{1}{5.2} = 0.192$ . If then  $D_a$  and  $D_c$  are densities as before, and we have values

$$D^{a} = .0807 \frac{T_{o}}{T_{a}}$$
 and  $D_{c} = .084 \frac{T_{o}}{T_{c}}$ .

Then, if the force of the draft be denoted by f,

$$f = .192 H(D_a - D_c);$$

or, when the values are substituted,

$$f = .192H\left(\frac{39.79}{T_a} - \frac{41.41}{T_c}\right) = H\left(\frac{7.64}{T_a} - \frac{7.95}{T_c}\right).$$

A similar calculation under the condition of maximum quantity of draft, with 60° F. outside and 600° in the chimney, gives

f (in inches of water) = .0073H.

The U tube or siphon-gauge is not sensitive to very slight differences of pressure, and many improvements have been

## RATE OF COMBUSTION. DRAFT.

suggested, such as using fluids of different specific gravities in the two tubes (Fig. 16); using a large surface to receive the light pressure, while reading the change of pressure by a hook-





FIG. 16.

gauge (Fig. 17); the use of the gas-holder principle, and many other arrangements. Five to seven inches of water is as high a reading as is secured with the intense forced draft of locomotives or torpedo-boat practice; two inches is more

usual when the air is forced into the ash-pits from below the grates; a fraction of an inch (from  $\frac{5}{10}$  to  $\frac{6}{10}$ ) is all which can



FIG. 17.

be usually counted on with ordinary chimneys, as by the following illustrative example:

What would the water-gauge G (Fig. 18) read when  $D_1$  for outer air = .0764, and  $D_2$  in the chimney = .0413 ?

$$\frac{D_1}{D_0} = \frac{T_0}{T_1}.$$
  
$$\therefore \quad D_1 = \frac{D_0 T_0}{T_1}.$$
  
$$\frac{D_2}{D_0} = \frac{T_0}{T_2}.$$

$$\cdot \quad p = h(D_1 - D_2)$$

= 3.51 lbs. per square foot,

and

 $p_1 = 3.51 \times 100 \times .192$ = .67 inch of water,

or

 $3.51 \times 1 = p_1 \times 62.5.$  $p_1 = .056$  foot = .67 inch.

### RATE OF COMBUSTION. DRAFT.

84. Flue-gas Analysis.—It has long been appreciated that much valuable information can be derived from an analysis of the flue-gases in the chimney, at any rate so far as the presence of uncombined oxygen, carbon monoxide, and carbonic acid are concerned. An excess of oxygen means a loss by dilution and a lowered fire-temperature; any quantity of carbonic oxide means a waste of carbon unconsumed because there is available heat in it which has not been liberated by combustion.

The remainder of the flue-gases is commonly assumed to be nitrogen, but it includes unburned hydrocarbon, if there be any, and steam or vapor of water. The Orsat apparatus is the most used in analyzing flue-gases and is illustrated in Fig. 19. P''', P'', and P' are pipettes containing, re-



FIG. 19.

spectively, solution of caustic potash to absorb carbon dioxide, pyrogallic acid and caustic potash to absorb oxygen, and cuprous chloride in hydrochloric acid to absorb carbon monoxide.

At d is a cock to control the admission of gas to the

III

apparatus; at B is a graduated burette for measuring the volumes of gas; and at A is a pressure-bottle connected with B by a rubber tube to control the gases to be analyzed. The pressure-bottle is commonly filled with water, but glycerine or some other fluid may be used when, in addition to the gases named, a determination of the moisture or steam in the flue-gases is made.

The several pipettes P', P'', and P''' are filled to the marks g, f, and e with the proper reagents, by aid of the pressure-With a three-way cock to open to the atmosbottle A. phere, the pressure-bottle A is raised till the burette B is filled with water to the mark m; communication is then made with the flue, and by lowering the pressure-bottle the burette is filled with the gas to be analyzed, and two minutes are allowed for the burette to drain. The pressure-bottle is now raised till the water in the burette reaches the zero mark and the clamp c is closed. The value in the pipe to the flue is now opened momentarily to the atmosphere to relieve the pressure in the burette. Now open the clamp c and bring the level of the water in the pressure-bottle to the level of the water in the burette, and take a reading of the volume of the gas to be analyzed; all readings of volume are to be taken in a similar way. Open the cock g and force the gas into the pipette P''' by raising the pressure-bottle, so that the water in the burette comes to the mark m. Allow three minutes for absorption of carbon dioxide by the caustic potash in P''', and finally bring the reagent to the mark a again. In this last operation, brought about by lowering the pressure-bottle, care should be taken not to suck the caustic reagent into the stop-cock. The gas is again measured in the burette, and the diminution of volume is recorded as the volume of carbon dioxide in the given volume of gas. In like manner the gas is passed into the pipette P'', where the oxygen is absorbed by the pyrogallic acid and caustic potash; but as the absorption is less rapid than was the case with the carbon monoxide,
more time must be allowed, and it is advisable to pass the gas back and forth, in and out of the pipette, several times. The loss of volume is recorded as the volume of oxygen. Finally, the gas is passed into the pipette P', where the carbon monoxide is absorbed by cuprous chloride in hydrochloric acid.

The solutions used in the Orsat apparatus are:

P'''. Caustic potash, 1 part; water, 2 parts.

P''. Pyrogallic acid, I gram to 25 cc. of caustic potash.

P'. Saturated solution of cuprous chloride in hydrochloric acid having a specific gravity of 1.10.

These reagents will absorb per cubic centimeter:

P'''. Caustic potash absorbs40 cc. of CO2;P''. Pyrogallate of potash absorbs22 '' '' Oxygen;P'. Cuprous chloride absorbs6 '' '' CO.

Improvements in the Orsat apparatus and its manipulation have been made by Hempel, Carpenter, Hale, and others, and the student is referred to Hempel's treatise for further detail.

85. Stability and Structure of Chimneys .- The chimney and a proper foundation for it belong rather to structural engineering than to a treatise upon heat, and it would divert from present purposes to discuss these questions at length. Wind-pressure is not likely to reach 55 pounds per square foot of flat surface; and the chimney may be viewed as a cantilever loaded uniformly with this load. In brick structures this must never produce tension on the windward side, when compounded with the resistant weight of the bricks, which will range from 100 to 130 pounds per cubic foot; nor on the compression side must the stress exceed 8 tons to the square foot, which the brick should be able easily to with-That is, if h be the height in feet, d the average stand. breadth, and b the breadth at the base, there must be equilibrium between W, the weight of the chimney in pounds,

and the quantity  $C\frac{dh^a}{b}$ . In the latter, the coefficient C is a factor for wind-pressure per square foot of area. It is 56 for a square chimney, 35 for an octagonal, and 28 for a round chimney. A brick chimney so proportioned will withstand any gale likely to be experienced. It will appear, however, that a chimney from these causes and the concentration of weight on a small area is a structure particularly liable to unequal settling of its foundations. The latter, therefore, should receive most careful attention from a competent designer of foundations, and should be laid by experienced persons. Natural and undisturbed soil will carry one ton per square foot; loam, compact sand, or hard-pan can carry two tons per square foot. Where natural foundations cannot be had, piling and other artificial methods are to be resorted to.

With respect to their structure, chimneys may be grouped into—

(I) Brick.

(2) Steel or iron shell, brick-lined.

(3) Skeleton iron and brick.

Brick chimneys are round, square, octagon, or starshaped. Circular section seems best, as lighter, stronger, and more shapely. English rule is, base equals one tenth of height; the batter or taper in American practice is from one sixteenth to one quarter inch to the foot on each side. One in thirty-six is the English standard.

The upper 25 feet is one brick thick (8'' or 9''); thickness increases by one half brick per 25 feet. If the diameter exceeds 60 inches, begin at top with one and a half bricks.

An inner lining or core, detached from the wall proper and running either nearly to top or over 50 or 60 feet up, prevents expansion from cracking the walls. It need not be firebrick all the way up, or even further than one half. The core is made of tangent-laid brick, with an occasional header to guide the core by the wall.

Another practice is to make a 100-foot chimney in three sections: first, 20 feet high, 16 inches thick; second, 30 feet high, 12 inches thick; third, 50 feet high, 8 inches thick. Core in three sections of 12, 8, and 4 inches thick, respectively.

The top of a chimney is exposed to weather and frost and snow, melting and freezing. There should be a cast-iron cap, or a stone, to protect the top edge of the brick. Large moulded terra-cotta or fire-clay blocks are also used, clamped and dowelled together.

Cylindrical steel chimneys of riveted plate steel, secured by a flare in the lower 10 to 25 feet to a cast-iron base-plate, which again is anchored by heavy foundation-bolts to a masonry foundation, require no guy or stay ropes and are 35 to 50 per cent cheaper than a brick stack. They take less room, are strong and safe, and no air leaks in to cool the gas. They are brick-lined part way or all the way up. They must be kept painted.

Stacks when not anchored to foundations by bolts, and all light and unlined stacks, require to be stayed by guys of wire rope. They are attached opposite the centre of effort of the winds, at two thirds of the height; are usually four in number, the first being led in the direction of the most violent wind, and each guy of a cross-section in square inches one thousandth of the exposed area in feet.

Skeleton chimneys have been put up by iron-works, but have no advantage over steel cylinders, and for many reasons are not as good. Brick is built in between uprights of rolled iron, which are banded by flat rings on the outside.

Access should be permitted to the chimney at its base through a proper door either in the flue or in the foundation of the chimney, and it is best that a ladder on the outside of the chimney should give access to its top. In a square chimney this ladder can be made by bars let into two walls at a corner. Figs. 20, 21, and 22 show chimney constructions and the proportions which have been found satisfactory,



according to which the thickness may be reduced as the chimney attains height.

86. Artificial or Mechanical or Forced Draft.—It has been already pointed out  $(\S 72)$  that a movement of the air for combustion might be mechanically produced by a proper appliance for this purpose.

A calculation of efficiencies shows that for heights of chimneys such as are ordinarily used the mechanical methods of securing draft are the more efficient, so that it becomes a question of consideration whether the necessary air for combustion shall be furnished by a costly chimney or group of them, or by a continuously running machine of some different type. Artificial draft can be secured by two general methods. The first type is that made familiar in locomotive practice, in which a rapid motion is given to the air to draw it out of the smoke-box so that the reduction of pressure within the latter shall cause a flow through the grates, fire, and tubes to equalize this rarefaction. This is called the induced-draft system, and as applied when fans are used, as in steamship practice, is illustrated in Fig. 25.

The other plan is to cause a pressure of air in the ash-pit below the grate-bars so that the air will flow up through the fire, the setting, and flues by the excess of pressure which prevails in the ash-pit. This is called the forced-draft system, and is becoming more usual in high-speed marine prac-The movement of the air can be produced either by tice. means of a steam-jet inducing a current of air to flow, or fans or blowers either of the centrifugal or positive type may be If the first or aspirating principle is used, the products used. of combustion must pass over the aspirating appliance. These gases are hot and possibly corrosive. The heat makes lubrication difficult, and almost excludes the use of apparatus where lubrication must be provided unless all bearing-surfaces can be without the flues which carry the gas. Protection against corrosion can be secured if proper trouble is taken,

but where this is not guarded against the apparatus deteriorates rapidly. The forcing system has the fresh cool air pass through the forcing appliance, and has furthermore the advantage of maintaining a higher tension within the setting



F1G. 25.

than prevails outside of it, so that there is little or no tendency for cool air to leak through cracks or porous brick-work into the gas-currents. This is a difficulty present where the draft is done by aspiration. On the other hand, the pressure system makes a hot and gassy fire-room if there are places where gas can escape through cracks, doors, or elsewhere from within the setting into the room. Fig. 26 shows Mr.

Jno. C. Kafer's closed ash-pit system, similar to that on the U. S. S. *Swatara* and *Kearsarge*. Since combustion is more efficient the denser the air used to effect it, the pressure



FIG. 26.

system offers an advantage from this point of view, as compared with natural draft or the aspiration system.

87. Advantages of Artificial Draft.—It is to be said in favor of natural or chimney draft that, when the chimney is once built and paid for, the draft-machine costs nothing to run except the heat which is used for this purpose, and it undergoes little or no deterioration with use. Furthermore, in cities the necessities imposed upon the power plant to carry the products of combustion high enough up to create no nuisance in its neighborhood compel a height and cost of chimney which makes the consideration of artificial draft

unnecessary, since the high chimney must be there in any case. Again, where the plant is so large that the cost of the draftmachine becomes considerable, or, what is the same thing, the cost of the expensive chimney becomes distributed over a large number of horse-power units, the advantages of artificial draft are not so apparent.

Artificial draft, on the other hand, offers the following advantages:

(1) The rapidity of combustion in the fire-box is not limited by atmospheric conditions. With a demand for high steam-pressure and great capacity in a limited space the forced draft is a necessity, as in war-ship practice.

(2) It is possible to increase the evaporative capacity of a given plant without other change than the velocity of the draft-machine. This increase may be either permanent or to meet sudden demands for steam, such as occur in street-railway practice at busy hours. With natural draft the chimney must be designed to meet the maximum requirement, and will be partly shut off at other times.

(3) It is possible to burn inferior, cheaper, and smaller sizes of fuel with artificial draft, because a high pressure can be maintained which will force the necessary air through a compact body of fuel.

(4) The draft arrangements are more portable than chimneys can be.

(5) The plant is more flexible for changes in quality or size of fuel, and the desirable thickness of fuel-bed on the grates. Grate-bars can be altered more easily if this should be desirable.

(6) Where high stacks are not made necessary the cost which they entail is avoided, or is obviated by a less cost of the draft-machine. The troublesome settling of massive stacks is avoided when foundations are difficult or defective.

(7) Leakage of air into the setting does not occur with forced draft on the pressure system.

**88. Disadvantages of Artificial Draft**.—The objections to be raised against the artificial draft are:

(1) The running cost of the machine. While it takes less coal than the chimney to do a given work, the fuel is not the only expense where an engine must be run, consuming oil and other supplies, calling for repairs and supervision, and the expense of the latter may be considerable.

(2) The artificial-draft machine occupies space which can often be ill spared.

(3) Running machinery, and particularly that at high speed such as most draft appliances demand, is rarely silent, is often noisy, and is liable to breakdowns which compel it to stop.

It will be seen that chimney-draft is not liable to these disadvantages.

The machine for causing the draft may be a centrifugal fan driven either by its own directly coupled engine or by a detached engine, or a revolving shaft, or by means of an electrical motor. The positive blowers will be driven by belts, or their own direct-coupled engine or motor, whether used for pressure or suction methods, and the steam-jet, which is the third appliance, requires no moving machinery when used in either system. It will be seen that each of these offers some advantages and disadvantages of its own. The fan method, if driven by belting, increases the running cost; and if electric current must be generated, the cost of its transformation must be considered. The steam-jet plan occupies very little space and is cheap to buy in the first instance. It is, however, wasteful of steam as compared with the other systems, and is in most cases too noisy. If used as a forcing system, the steam passes through the fire and is objectionable. If used as a suction system, the steam goes out with the products of combustion and does no harm.

The methods which have been used in marine practice to secure the necessary forced draft are either the closed ash-

pit system, the closed fire-room system, or the induced-draft system. The combination of closed ash-pit system with the



FIG. 28.

induced-draft system enables preheating of the air to be easily done before it enters the ash-pit. Figs. 27, 28, and 29 show typical stationary arrangements.

**89.** Smoke-prevention.—The preceding discussion on the liberation of heat from a fuel for motive-power purposes would not be complete without a reference to the loss of energy which occurs when combustible carbon passes out with the products of combustion, and without having undergone complete oxidation at the desired point. When this carbon goes off as carbon monoxide, the loss is that made



FIG. 29.

manifest in § 24. When incandescent solid carbon fails to meet oxygen under favorable conditions for its union with it, the extinction of the glowing particles forms them into lampblack or soot, which particles color the products of combustion, and cause them to darken the air and to defile the surfaces which they touch. A smoke, in its exact sense, is a current of products of combustion from a fire, in which the otherwise colorless gases carry finely divided particles of black carbon. This carbon resulting from incandescence which has ceased is practically incombustible at ordinary heats. It could have been burned, however, if the union with oxygen had taken place while the carbon was in the nascent or favorable state of its first incandescence, and the effort of the designer and manager of the combustion must be directed to keep up the gases to the temperature of the ignition of the carbon, and with a full supply of oxygen at sufficient temperature to satisfy the carbon. Pure hydrogen combustions are normally smokeless, because of the absence of solid matter in the flame. Such flames are usually non-luminous for the same reason.

The various methods for smoke-prevention have been grouped under the following heads:

(I) The supply of excess of air by steam-jets, inducing currents which they warm, and supplying excess of warm air above the fire and behind the bridge-wall. The difficulty with these has been that, after distillation of the gas is completed, after a charge of fresh fuel is thrown on the fire, this excess of air is not needed, and the products of combustion are cooled by the diluting oxygen. Attempts have been made to correct this by graduating the supply of fresh air by chronometric or other appliances, so that the excess should be cut off after such an interval as is usually needed for the first distillation of gas.

(2) By the coking methods of firing. By these plans a large dead-plate was used, so that the gases should be distilled off from the fresh fuel before its combustion was really begun on the grate-surface proper, and when the coking was complete only fixed carbon remained to burn on the grate-surface proper when pushed back. The gas distilled from the fuel on the dead-plate passed over the hot fire, and was so warmed that it was ready to combine and burn. Alternate firing of the two sides of the furnace, or the use of two furnaces delivering into a common combustion-chamber which were fired alternately, belong to this same class.

(3) The methods belonging to the principles of mechanical stoking are smoke-preventing methods in that each part of the fire always remains in the same condition, and the fresh

coal which distils off gas is received in the coolest part of the grate, and passes to the hotter sections only after the volatile matter has been distilled off and burned in passing over those hottest portions.

(4) Gas- and oil-firing are smoke-preventing methods, since when properly done the combustion ought to be complete, and no carbon should pass out of the setting except in the form of carbonic acid. It is to this group that those settings belong in which the actual combustion of the fuel containing volatile matter is done in a separate furnace and away from contact with the boiler. This makes a relatively smokeless and efficient apparatus, and will answer with coals which cannot be economically burned in any other way.

(5) The down-draft furnace appears to be one of the most successful appliances for smoke-prevention with smoky coals. As satisfactorily applied it involves the use of two sets of grate-bars, one over the other, so arranged that the draft passes downwards through the upper and lower sets of bars, or else passes downwards through the upper and upwards through the lower. Each set has its own fuel, but the intention is that the gases shall be distilled off from the fresh fuel on the upper grate, and shall be drawn downwards to mix with the hot products escaping from the lower where the solid carbon is burning. By this the temperature of ignition is maintained for the distilled gas, so that it shall burn with the abundant supply of warm air admitted for this purpose. Figs. 30 and 31 show boiler-settings of this type.

(6) The use of fire-brick or similar refractory material for the furnace or in the combustion-chamber (Fig. 32). This becomes hot by the impact of flame and gas, and keeps the temperature of the gas up to ignition. It imparts some of its heat to the boiler by radiation after it is once brought up to full heat.

(7) Preheating of the air-supply by hollow walls or flue-







boxes which the hot gases surrourd while the fresh air flows within them.

The objections to most of the smoke-prevention devices have been that the introduction of such appliances diminishes either the economy or the capacity of the plant as compared with what it was when the chimneys were allowed to smoke. The excess of air diluting products of combustion explains a loss of economy and capacity, and the superior efficiency of the yellow flame, as compared with the colorless flame of perfect combustion, is also responsible in part for this result. The losses seem to be about 12 per cent of power or from 7 to 13 per cent of economy.

The term smoke-consumption or smoke-burning is an improper one. Lamp-black once made is incombustible and cannot be burned. The products of combustion are often colored brown by the presence of tarry or similar combustible matters, and these will ignite if the temperature be made hot enough. It is possible to prevent appearance of smoke by catching it in water through which the products of combustion pass, and in which the carbon is thrown down.

**90.** Mechanical Stoking.—Modern successful combustion is also much indebted to improvement in the grate-bar of the furnace for the securing of smokelessness. While the shaking-grate has made the fireman's work more easy, it is to the step-grate and the travelling-grate that smokeless combustion is more largely due.

In the step grate the bars are flat surfaces or treads arranged so that the upper one slightly overlaps the one below it, while leaving open for the passage of air the space which corresponds to the riser in stairway construction. It will be seen that this construction permits abundance of access of air with little or no possibility of coal dropping through the grate-surface; or the principle of a forced draft can be applied (Fig. 33). When the bars are laid across the furnace, as is usual, the slice-bar of the fireman can cleanse each bar separately by working through the vertical opening between the bars, or the method of firing may be used whereby the coal is fed first on the upper bar, and from that is gradually pushed down the steps from bar to bar until at the bottom it will be pushed off with all available combustible matter utilized, and only refuse and ash remaining (Fig. 33).

It is very easy to convert such a step-grate into a shaking- or dumping-grate by arranging each bar so as to permit a motion to tip its burden down the steps. This can be done either by hand or mechanically.

The principle of successful passage of fuel from bar to bar suggested in the previous paragraph leads to a construction of grate which is known as the travelling-grate. The bars, instead of being continuous and solid, are made up of a series of short bars which are pinned together so as to form a flat chain with the links edgewise. These chains, made endless, mounted upon proper carrying-rollers at the front of the furnace and at the rear, and having the width of the furnacearea, can be driven by machinery attached to the rollers so as to draw the chain from the front of the furnace to the back, carrying on its surface the fuel to be burned. The speed of driving should be so proportioned that the fresh fuel charged at the front upon the travelling bed of the grate should be completely burned during the period of its transition to the back, so that when a given chain of links reaches the rear roller and is dropped over, there is carried with it and dropped only the incombustible matter in that given amount of coal. Such a grate is practically self-cleansing and leads at once to the use of an automatic appliance for feeding the fuel to it to make it complete. Fig. 34 shows a typical travelling-grate, and the plan shown in Fig. 33 can be made automatic.

If the self-cleansing mechanical grate can be combined with automatic or mechanical feeding of the fresh fuel which



is to be burned upon it, it will be apparent that not only has the supply of fuel as a source of heat energy become continuous and uniform, but the combustion of the fuel is made regular and continuous because the fire is at all times in the same condition. Furthermore the labor of the fireman has changed from a hard muscular exertion of hand-firing to the skilled supervision of machinery of sufficient power to do the required work. In the mechanical stokers which have been



FIG. 34.

approved the coal is fed upon the travelling or mechanical moving grate from a hopper, either through an opening or between rails which carry ribs lengthwise so as to form pockets to receive the fuel. Thus the speed of these pockets measures the quantity of fuel delivered. The travelling-grate or the measuring-rollers can have their speed regulated by simple mechanical means connected with the steam-pressure; and if the air for combustion is supplied by mechanical means, the volume of that air can be regulated by the rise and fall of the pressure of steam by causing the latter to vary the speed of the engine which drives the fan or controls the valve which supplies the steam-jet. Figs. 33 and 35 show types

in which the motion of the step-bar itself causes the fuel to be carried down the steps to be delivered as ash at the bottom. It will be seen that the form of grate shown in Fig. 36 can also be very easily and properly fitted to the principle



of automatic stoking. The supply of fuel to the hoppers at the boiler-fronts will be done by the principle of mechanical conveyors with elevators if the supply of coal in pockets cannot conveniently be made overhead. If the coal-vault can be over the boiler-room, the coal may descend by gravity through proper spouts into the furnace-hopper without handling.

This principle of mechanical handling of fuel, combined with mechanical handling of ashes and with the principle of automatic control of the machinery of stoking as the steampressure may vary, gives to a modern power plant where the principle is applied all advantages derivable from doing away with human labor and replacing it with intelligent control of



FIG. 36.

inanimate force. It has not been proved that the advantages from uniformity and continuous action always represent a surplus sufficient to pay for the increased cost of the installation, but the saving of labor expense usually leaves a margin, in a plant of any considerable size, which is abundant to offset such cost.

Mechanical stoking has not achieved its best success with the hard varieties of anthracite coal with which the fireman's labor is the least. Again, with certain varieties of bituminous coal which cake and melt it has been found that their working





is not satisfactory in every case. Fig. 37 shows a form of stoker in which the feeding of fresh fuel is done from the bottom, so that the products of the first distillation are forced to pass up through the bed of incandescent fuel from which the gases have been removed. This brings them up to the point of ignition, and the slope of the sides of the bed of fuel is covered with coal in the condition of fixed carbon, which when completely burned falls off as clinker or ash at the sides of the grate, or is removed by slicing. Forced draft on the closed ash-pit or closed fire-room system can often be applied to this stoker with advantage (Fig. 38).



FIG. 38.

It has recently been suggested that a standard color scheme should be accepted by engineers and inspectors in dealing with the smoke problem. The Ringelmann scale is exhibited in Fig. 39, which proposes four standards. The smoke is to be observed against a clear sky, and its color





No. 3.

No. 4.

THE RINGELMANN SCALE FOR GRADING THE DENSITY OF SMOKE. Fig. 29.

compared with the effect upon the eye of an 8-inch square black-and-white grating of the scale standard held at 50 feet distance from the eye. No. I would be pure white paper, and No. 6 in the series would be entirely black; hence each intermediate proportion corresponds to a 20 per cent range.

# CHAPTER VIII.

# TRANSFER OF HEAT. HEATING SURFACE.

91. Introductory.—In the four chapters which have preceded (Chapters IV to VII) it has been the object to show how the energy stored in the fuel could be liberated therefrom at the will of the engineer for motive power or industrial uses. The next step must be to examine how this liberated energy in the form of heat-units per pound of combustible can be made available for the doing of mechanical work. Two steps or stages are involved in this transformation: the first is the transfer of the heat to a medium convenient to carry the energy from the fire to the motor cylinder or organ of the machine; the second is the effect produced upon that medium by such increase of its previous heat energy, and a discussion of the availability and convenience of various media.

Certain necessary investigations are at once suggested:

1. How is heat transferred from one body to another.

2. What are the best media, or those which give most efficient transformations of the heat energy of the fire into motor energy.

It is also apparent that from this point onward the properties of the medium used as a heat-carrier from the fire to the cylinder are likely to require to be taken into consideration either expressly or by implication, and that a sort of general division along this line seems to be required. This scheme of differentiation would separate heat-motors into

two great classes. The first class would include those in which the liberation of heat occurs directly in or around the motor-cylinder; the second class would be those in which the liberation of heat occurs in or at a second apparatus from which the energy passes to the motor-cylinder through pipes or passages by which generated pressure is supplied to the cylinder. The first class would include the gas-engines, the hot-air engines, the oil-engines, the explosive-vapor engines, the gunpowder-engines. The second class contains the steam-engines, the ammonia or volatile-vapor engines, the compressed-air engines, and other types in which a boiler or generator and a reservoir of pressure are necessary features in addition to or outside of the engine proper. The significance of this division will appear more manifest in later chapters and after detailed discussion.

Speaking more roughly and with less regard to exactness of detail, heat-motors may be classified into those using the permanent gases, which, like air, do not change their state under changes of heat-condition, which form one class; and those using water or other liquids which will form gases or vapors under increase of heat energy, which motors form the second class. This does not quite coincide with the fundamental idea of the previous division, and yet does not disagree with it and has some conveniences. The subject of transfer of heat, however, may be discussed with both classes in view.

92. Transfer of Heat. General.—In every heat-engine operating by pressure caused by heat, that pressure must be contained in or resisted by a closed vessel—usually metallic —and in most cases the heat is outside of this vessel and must be transferred to the motor medium within it. Hence the heat must be first transferred to the metal enveloping the medium, and secondly must pass from the metal to the medium, and thirdly must distribute itself through the medium if the latter has any extended volume. In oil- or gas-engines,

where combustion takes place directly in the working cylinder, only the two latter steps occur. The combined process of giving out heat by the fire, and its absorption by the medium, is called the transfer of heat. Refrigeration as a process is also a transfer of heat, but in the opposite direction, since the object is to diminish the heat energy of the body acted on, and not to increase it as in heating. In more exact language, the object of a process of transfer of heat is to increase the heat energy of the cooler body, and to equalize the intensity of heat-motion of their respective molecules. If the hotter body receives no increment of heat during the transfer process, it is refrigerated by the transfer. Ordinarily, of course, the heat condition of the hot body is kept as near uniform as possible, and heat energy passes constantly out to the absorbent body.

It will be at once apparent that the rate of transfer should be faster the further apart the heat condition of the two bodies, and that when their heat condition is nearly equalzied the transfer per unit of time will be correspondingly diminished, and will become zero when both are in the same state of heat energy.

Experience and observation show that heat can be transferred by four processes:

- (1) By radiation.
- (2) By contact.
- (3) By conduction in solids.
- (4) By convection in fluids.

In radiation the two bodies are separated by a space. In contact they touch each other but are not one. In conduction the heat-motion is at first more active in one part of a solid body than in another, and that heat-motion is transmitted neither by radiation nor by contact with another body. In convection the cooler denser particles of a mobile fluid displace the hotter lighter particles,—which seems like a transfer of heat, but is rather a mechanical displacement of particles until all are equally heated.

The principles of transfer by each method will be discussed hereafter.

When two bodies are equalizing their heat conditions by a transfer of heat from one to the other, as when a metal mass at one temperature is immersed in a fluid at another, the action may be expressed by an equation which shall express the gain or loss of heat in heat-units. It takes the following form:

$$U = w \times c \times (t_1 - t) = w' \times c' \times (t_2 - t).$$

In this U is the desired units of heat transferred; zv and zv' are the respective weights in pounds; c and c' are the respective specific heats;  $t_1$  and  $t_2$  their respective initial temperatures, and t their common final temperature. One body will have gained what the other has lost, and the value of U can be calculated from either. The application of this expression, however, must be restricted to the cases for which it is true.

93. Transfer of Heat by Radiation.—When a body is radiating heat, its condition is one in which lines of heat energy emanate from the body in every direction into space. Bodies which are in the path of these heat-lines receive the impact of the heat-waves, and their heat condition increases in intensity until their own tendency to transfer heat to other bodies precludes their rising any higher in the heat scale. Heat behaves like light in a transfer by radiation so far as the radiating body is concerned. Unlike light, however, the effect of heat on the absorbing body is cumulative, up to the point where the absorbent begins itself to transfer.

Heat from radiation appears to vary inversely as the square of the distance, because a body at a distance 2 from a centre of heat-motion receives only one quarter as many heat-impulses in a given time upon a given area as that same

#### TRANSFER OF HEAT.

area would receive at a distance unity; or the area at 2 to receive as many heat-impulses as are intercepted at 1 must have twice the height and twice the breadth needed at 1 (Fig. 40). If the rays also grew less intense by distance, the effect of distance would be to make the effect of heat



vary as the fourth power of the distance when absorbing areas were the same. This same area effect explains why radiation is less effective in heating inclined surfaces than when the heat-impulses are normal. The projected area is the effective one only.

Radiation has been studied by physicists with heated solids having a radiating area. Dulong and Petit's formula is, for metric units,

$$Q = C_{\mathbf{1}}(a^{t_{\mathbf{1}}} - \mathbf{I}).$$

 $C_1$  is a constant depending on the surface of the radiating body, large for dark color and rough surface and least for smooth and polished surfaces light in color. *a* is the number 1.0077, a constant according to Dulong and Petit, variable according to De la Provostaye and Desains. *Q* is the quantity of heat in calories emitted from a unit of surface in a unit of time.  $t_1$  is the excess of the temperature of the radiant body over the absorbent in centigrade degrees.

The radiation formula is also written

 $Q = Ca^{t}(a^{t_1} - \mathbf{I}),$ 

in which t is the temperature of the absorbent body.

Experimental formulæ by Hopkins give:

For glass,	$Q = 9.566a^t(a^{t_1} -$	1).
For sandstone,	$Q = 8.377a^t(a^{t_1} -$	1).

For polished limestone,

 $Q = 9.106a^t(a^{t_1} - 1).$ 

In this, Q is the quantity of heat radiated per minute from one square foot of surface in units to raise a kilogram of water 1° C.

Better ideas about radiation are derived from tables of comparison. This table is by Leslie, the experiments being made at  $180^{\circ}$  F.:

Lampblack	100	Mica	80
Paper	98	Graphite	75
Resin	96	Tarnished lead	45
Sealing-wax	95	Mercury	<b>2</b> 0
Crown glass	<b>50</b>	Polished lead	19
India ink	88	Polished iron	15
Ice	85	Tin-plate	12
Red lead.	80	Gold and silver	12

Darkness and roughness of surface increase radiation, while smoothness and polish diminish it.

Magnus' experiments at 270° F. give relations for radiating effect:

Blackened silver	100	Rock salt	13		
Glass	64	Polished silver	9.7		
Fluor-spar 45.5					

The conditions in a boiler or a heat-engine furnace are very different from those of the foregoing, and the only data

usually referred to are from Péclet, who, having found the total heat of combustion, says that from a fire of coal, coke, or charcoal it is 50 per cent, from peat-charcoal 48 per cent, and from wood and peat about 25 to 29 per cent. Flame heats by radiation from the incandescent particles in it. Gases without such incandescent material seem to produce no effect by radiation however high their temperature.

Radiant heat does not warm air or other gases directly. Open fires warm only the objects and persons in a room, which in turn warm the air by contact.

94. Transfer of Heat by Contact.—By far the most important in transfer of heat in the heating of buildings, and in the heating and cooling of air in engines, is the interchange when the two bodies are in contact, as when the hot products of combustion pass over the metal of the boiler and give up their heat to it. Transfer by contact is also of primary importance in refrigeration.

For contact of solids with fluids the Péclet formula is

$$Q = C_1 t^{1.233},$$

the notation as before. Balfour Stewart gives as Hopkins's formulæ:

For air, 
$$Q = 0.0372 \left(\frac{p}{720}\right)^{.45} t_2^{1.233};$$

For CO<sub>2</sub>, 
$$Q = 0.0359 \left(\frac{p}{720}\right)^{.517} t_2^{1.233}$$
.

when p is the pressure of the gas in millimeters, and Q is the quantity of heat emitted from one square foot as in § 93.

These data also are not of great significance for design of generators, while more practical than the radiation results; but the hot gases do not heat the motor fluid directly, but heat the metal of the enveloping reservoir, which conducts the heat to the motor-fluid.

It is interesting to note, however, that in these two formulæ for radiation and contact the difference in temperature enters in one as an exponent, and in the other as a coefficient. Hence for a given difference in temperature radiation will be enormously more effective than contact in transferring heat. This can be shown graphically by the diagram Fig. 41, where differences of temperature are abscissas and



heat units, Q transferred are ordinates. The curve ae is for radiation, the line ab for contact.

The transfer for 800° difference of temperature is over 70 times as great by radiation as by contact. This is one of the reasons for the superiority of flaming coals over short-flame fuels, and for the lessened economy of gas-firing from gas made from coal in a separate generator. Anthracite as a short-flame fuel requires a large furnace area, as its heat is

mainly radiated from the solid carbon and not from the flame.

Rankine's formula for transfer by contact per square foot of boiler heating-surface per hour is

 $Q = \left(\frac{T' - T}{a}\right)^{2},$ 

in which T' and T are the temperatures of the two fluids in contact with the two faces of the metal, and a is a factor varying from 160 to 200. This he calls a rough approximation, and Q is B.T.U. and differs from the Dulong and Petit formula in substituting 2 for 1.233 and changing the constant.

In the transfer of heat in the heating of air by coils or radiators, using contact of air and hot metal in the rooms to be heated, or in the direct-radiation system, it is usual to calculate the condensation representing the transfer at 2 to 3 heat units per square foot of transferring surface per degree difference in temperature, per hour. That is, experiments show such condensation to average from 1.66 heat-units with ineffective radiators up to 2.25 with flat pipe-coils or good Otherwise stated, it appears that with low-presradiators. sure steam of one or two pounds pressure the condensation per square foot ranges from 0.25 to 0.30 pound per square foot per hour. In the transfer of heat to air from coils in ventilating systems, where the air from out of doors is passed over metal surfaces to warm it before distribution, the rough rule may be used that one square foot of radiating-surface with steam at 212° will heat 100 cubic feet of air from zero to 150° per hour or 300 cubic feet from zero to 100° in the same time; or the relation of specific heats for equal masses may be used to calculate the water required. If the specific heat of air be called 0.238, while the specific heat of water is called unity, it is obvious that one pound of water will heat

 $\frac{1}{0.238} = 4.2$  pounds of air through a given range. If a pound of air occupies 12.39 cubic feet, the lowering of one pound of water one degree will raise  $4.2 \times 12.39 = 52$  cubic feet of air one degree. If low-pressure steam is used, so that 966 units are transferred in cooling steam to water (§ 58) at 212°—which may be called 1000 units without sensible error —it appears that the pounds of water to be made into steam per hour bear to the cubic feet of air required to be warmed one degree per hour the relation of unity to 50,000. Roughly speaking, the evaporation of 30 pounds of water per hour will heat a cubic capacity as follows:

Brick dwellings, in blocks, as in cities 15,000 to	20,000 cu. ft.
" stores, " " 10,000 "	15,000 ''
" dwellings, exposed all round 10,000 "	15,000 ''
" mills, shops, factories, etc 7,000 "	10,000 ''
Wooden dwellings, exposed 7,000 "	10,000 ''
Foundries and wooden shops 6,000 "	10,000 ''
Exhibition buildings, largely glass, etc 4,000 "	15,000 ''

The water to be evaporated per hour having been found, the calculation of boiler, grates, and the like will be made by methods to be treated in later chapters.

In a negative transfer where cold brine is circulated in coils to cool a room (see Chapter XXII), each square foot of surface can take care of 1200–1300 heat-units per hour, to be withdrawn from the material to be cooled.

95. Transfer of Heat by Conduction.—When one end of a bar of metal is exposed to heat by putting it into or near a fire, the heat energy imparted at the one end is conducted to the parts farther from the source of heat by overcoming a certain resistance to such increase of heat energy. This resistance has been called the thermal resistance; or the conductivity of the metal is the reciprocal of such resistance. The transfer is cumulative, since the bar grows hotter and hotter, up to the point at which the transfer of heat away from the bar by radiation or contact or both becomes equal
to the amount which it receives by conduction in the same time.

The conductivity of metal and the rate of such conduction are primary elements of transfer of heat in all cases where the medium to be heated is enclosed in a vessel upon whose exterior surface the heat of the fire is brought in order to raise the temperature of such enclosed medium. The outer layer of the metal nearest the fire should be as nearly at the temperature of the fire or the hot gases resulting from combustion as the efficiency of the transfer of heat by radiation or by contact will permit, provided there were no conduction to the presumably cooler inner layers. The more instantaneous the conduction, and the less loss of heat energy in the process, the more nearly will the inner layer which touches the enclosed medium approach to the temperature of that which heats the outer layers. When the conducting metal is thin-having but a small fraction of an inch in thicknessthe transfer is practically complete, and with a medium enclosed such as water and having a high specific heat (§ 12) the metal has throughout the same temperature, which is that of the cooler fluid. With thicker walls of metal, the greater mass to be affected by changes of heat energy, or through which the thermal resistance may act, will increase the difference of temperature between the outer hot layer and the inner cool layer. In other words, for a given transfer per unit of time the outer layer must be hotter with thick plates than with thin. Thin boiler-plates absorb heat more effectively from the hot gases which pass over them because the outer layer is further removed from the temperature of such gases than when the plate is thick, particularly when the gases are moving rapidly and the time for absorbing heat from each pound of gas is short.

Conduction is expressed by a formula

$$Q = \frac{C(T' - T)}{e}$$

in which e is the space separating the two surfaces which are at the temperatures T' and T respectively, and C is a coefficient for each material to be determined by experiment, and the conductivity to be relative to a standard.

Relative conductivities as measured by Wiedemann and Franz are:

In Air.	In Vacuo.
100	100
73.6	74.8
53.2	54.8
23.6	24
14.5	15.4
11.9	10.1
11.б	10.3
8.5	7.9
8.4	7.4
6.3	7·3°
1.8	
	In Air. 100 73.6 53.2 23.6 14.5 11.9 11.6 8.5 8.4 6.3 1.8

Conductivity of metals drops as the temperature increases. For iron, with an increase of 100° F. the foregoing figure diminishes 15 to 25 per cent (Forbes).

The quantities of heat in B.T.U. transmitted per second through an area of one square foot one millimeter in thickness for one degree F. difference in temperature are approximately for the following materials (Neumann):

Copper	41.2	Iron	б. і
Zinc	11.4	German silver.	4.I
Brass	II.2	Lead	I.4

The absolute values of conductivity in liquids are uncertain and are certainly low. The received values (Guthrie, Philos. Trans., 1869) have been determined in terms of the resistance to transfer of heat, which is the reciprocal of the

conductivity and is called the thermal resistance. This thermal resistance is for

Water	I	Sperm-oil	8.85
Glycerine	3.84	Alcohol	9.09
Acetic acid	8.38	Turpentine	11.75

The conductivity of liquids is greater at higher temperaures than at low; but when convection is not possible it is small in any case.

Despretz puts that of water  $= \frac{1}{100}$  that of copper.

Conducting-power of gases is very slight, and it is often supposed they have none. Magnus gives that for air  $= \frac{1}{1400}$  that of lead.

In a boiler, when the hot gases are at one constant temperature and the water at another, it would appear that the thickness of the plate would not affect the rapidity of transfer. But the gases are moving in the apparatus at speed, and do not stay long in contact with the plate; hence a thick wall prevents the heat of gas from being so efficiently abstracted by retarding the equalization downward to the temperature of the cooler (the water), and so heat is wasted by escaping unreduced. This loss should be diminished by proper use of what are called "retarders."

96. Transfer of Heat by Convection. Circulation.— The process whereby heat is transferred from the outer layers of a fluid to the inner ones, or from the bottom to the top, must differ from the simple conduction which takes place in a solid. The molecules being easily mobile among themselves, the cooler ones being heavier tend to descend and displace the lighter and warmer ones within the confining vessel, and there is thus produced a continual movement of the confined medium, whereby imparted heat is carried about within it, the hotter part going to the top and the cooler to the bottom. This movement due to differences of specific gravity caused by heat is called the convection of heat. It

is much less rapid than the process of conduction in solid matter, but is the only way in which large bulk of water or gas can be heated. The source of heat should obviously always be on the bottom of such masses of fluid. When water is being heated and vaporized as in a steam-boiler there occurs not only the convection process, but as soon as steam-gas bubbles begin to form, which are much lighter than the water, a different movement begins, accelerated in character as compared with the earlier convection, because of the difference in weight of the same bulk of steam and of water. The steam-bubbles tend to rise to the surface, and tend to accelerate the convection when they conform to its direction, and to disturb it when opposed to its direction. This motion in a steam-boiler is called the circulation, and is of primary importance as respects the transfer of heat. It can be directed but cannot be antagonized. Surprising results have been secured by mechanical circulation, where the speed of motion is greater than it would be if differences of specific gravity were alone depended upon.

The difficulty of transfer of heat from gases or to them makes it necessary that the gases should be finely divided into thin layers or small bulks if the transfer of heating or cooling effect must be rapid. This principle underlies the use of small tubes in tubular boilers, and is a sound one if only abstraction of heat from hot carbonic acid is the object of such tubes. Small tubes are not favorable to combustion, and will make a gaseous fuel a smoky one. The forcing of hot gases in large flues to move in eddies by baffle-plates or cross-partitions causes a continual convection motion which is favorable to the abstraction of heat by cooling surfaces presented to the gases.

97. General Remarks on the Transfer of Heat.—In discussing the usual formula for an exchange of heat,

 $Q = C_1 \times \tau v \times (t' - t),$ 

which may be written

 $Q = C_1 \times v \times D \times (t' - t),$ 

in which Q = quantity of heat transferred;

w = weight of gas passing per unit of time;

v = its volume in cubic feet, and

D = its weight per cubic foot;

t' - t = the range of temperature change.

It will appear-

Ist. The quantity will increase as the difference in temperatures. Hence circulation is beneficial, and the hotter gas should meet the hottest water, and the coolest gas the coldest water, to keep the difference a maximum.

2d. The denser the gas the more heat it transfers. Hence plenum and forced-draft systems are more efficient than aspiration systems.

3d. Liquids transfer heat faster and more efficiently than gases by reason of greater density. The presence of moisture in an air causes it to take more heat from the body than a dry air. Hence the coldness of damp winter days. The cylinder-walls give heat to the damp air of the exhaust of the steam-engine at a rate seventy times faster than if that gas were dry and free from moisture.

98. Heating-surface.—The area of metal exposed on one side to the heating effort of the fire and on the other to the medium to be heated by conduction of heat through that surface will be called the heating-surface. The coolingsurface is the same thing, only with the direction of transfer reversed. The practical result therefore to be sought by the engineer and designer is the proportioning of the absorbing surface for heat so that with a given liberation of heat-units in the fire there may be a transfer of heat energy to the working medium with the containing vessel which shall raise its heat energy to the greatest possible extent. With the steam-

boiler this means the evaporation of a given weight of water into steam at a given pressure with the combustion of a given weight of fuel or combustible, per unit of time. Confining the discussion for the present to the steam-boiler, it may be said that the quantity of heat transferred to the water will therefore depend upon the extent or weight of that contactsurface of metal, and the difference of temperature between that metal (or the water which touches it) and the imparting source of heat—fuel, flame, or gas. Hence the amount of heating-surface for a given evaporation of water or absorption of heat will be fixed—

Ist. With relation to the rate of combustion to be employed—since the faster this rate the higher the temperature of the fire and the gases.

2d. In some relation to the absolute quantity of heat supplied in a given time—which is a relation to the square feet of grate-surface on which the fuel is burned, if the rate of combustion is assumed.

It will appear at once that the terminal temperature of the gases when leaving the generating apparatus must be considered and fixed. If the gases are too cool, they do not transfer heat to the heating-surface and water; chimneydraft is dependent on a certain minimum temperature in the stack as compared with the outer air. If the gases are too hot, heat is wasted in the chimney, because there was not surface enough to abstract the heat as fully as might be, and coal has been burned to waste, heating the stack and outer air and not the water.

Hence it is usual to fix the terminal temperature at about  $600^{\circ}$  F. (the maximum draft temperature, § 80), since steam at 250 pounds pressure has a temperature of  $401^{\circ}$  F., and these gases will give off their heat to the steam even when the difference is reduced to 200°. For lower pressures they are so much more effective, and can be cooler if the draft need not be considered.

If the terminal temperature in the flue Ob (Fig. 42) be set at 600°, represented by an ordinate bf, and the curve for the transfer of heat be drawn through f according to the formula Q = Cw(t' - t), there will be found a point A which will indicate the initial difference of temperature between the fire



and the water such that the heat would be abstracted down to  $600^{\circ}$  in that extent of contact and transfer.

But if a higher rate of combustion be assumed, and a higher initial temperature represented by A'', then the curve will not pass through f as before, but through a point f' beyond it, so that with an extent of heating-surface represented

by the length Ob, the gases would leave unduly hot, and the heating-surface should be extended till b'' is reached, at which point the terminal temperature is the same 600° as for the first case. For a higher difference the third curve results, and an extent of heating-surface as much greater than the first case as Ob''' is longer than Ob.

This increase of heating-surface to absorb greater amounts of heat is not usually done by lengthening the boiler as indicated, but by increasing the number of tubes, and the diameter of shell as well as the length.

Experimental data on this subject have been obtained in two ways: by keeping the heating-surface constant and varying the rate of combustion, or by finding the increase of heating-surface to keep an evaporation constant. The following table is by Isherwood, for a marine tubular boiler using anthracite fuel and having a constant heating-surface 25 times the area of the grate.

The following table from D. K. Clark, "Railway Machinery," gives for higher rates of evaporation the relation between heating- and grate-surface to maintain a constant evaporation of 9 pounds of water for each pound of coke:

Pounds of coke per square foot grate 14 Heating - surface per square foot grate 30	19 35	25 40	31 45	38 50	47 55	56 60	65 65	76 70	87 75	98 80	110 85	125 90	129 95	153 100
---	----------	----------	----------	----------	----------	----------	----------	----------	----------	----------	-----------	-----------	-----------	------------

Hence it appears necessary to decide upon the conditions of rate of combustion to be anticipated as usual, and fix the heating-surface accordingly.

The following table gives accepted data on this subject:

TRANSFER OF HEAT.

Type of Boiler.	Pounds of Co per Square Fo	al per Hour oot of Grate.	Draft.	Authority.
	Anthracite.	Bituminous.		
Land	6-12	12-27	Chimney	Whitham
Marine	7–16	12-27 18-20	Chimney	Shock
"		20-30 4	Forced Chimney	Seaton Rankine
Ordinary flue '' factory		10 12–16		••
" marine " locomotive.		16 <b>-24</b> 40 <b>-12</b> 0	" Forced	
Average		12-18	Chimney	Rankine

Thurston's formula for the rate of combustion per square foot of grate with a given chimney is:

Rate = 
$$2\sqrt{\text{height in feet}} - 1$$
.

99. Ratio of Heating-surface to Grate-surface.—There is further a certain agreement that the ratio between the grate-area and the heating-surface shall be generally main-tained, approximately as follows:

With a grate-area of unity the heating-surface will be:

In	Plain cylinder boilers	10	to	15,	average	12
	Cornish flue-boilers	30	" "	40,	"	35
	Elephant boilers	25	"	40,		33
	Flue-boilers	17	"	25,	" "	21
	Tubular boilers	25	" "	30,	٠.	<b>2</b> 8
	Traction-engine boilers				"	32
	Marine (Martin type) boilers				**	25
	Locomotive-boilers	40	"	100,	" "	75

The Morin and Tresca rule, which has influenced much European practice, was to fix for each type a rate of combustion per square foot of heating-surface which was not to be

exceeded, and is given in the second column of the following table. Then the ratio and rates were as in the other columns.

Type of Boiler.	Pounds of Fuel	Ratio	Combustion
	per Sq. Ft. H. S.	H. S. to G. S.	per Sq. Ft. Grate.
(a) Land	0.6	24 : 1	14.4
	0.5	28 : 1	14
	0.8	70 : 1	56

Old English practice was to require and expect an evaporation of one cubic foot of water (62.4 pounds) per square foot of heating-surface when water was delivered at  $60^{\circ}$  F. and evaporated at  $212^{\circ}$ .

Old U. S. Navy practice was to allow 8 pounds of anthracite coal to the cubic foot per hour to raise it from 212° to steam at 30 pounds pressure. This required  $\frac{2}{3}$  of a square foot of grate (at 12 pounds per square foot per hour), and with a ratio of 25 to I the heating-surface for this unit was  $16\frac{2}{3}$  square feet.

	•		
Type of Boiler.	Heating-surface per I. H. P.	Water per Pound Combustible.	Combustible per Hour per Sq. Ft, Grate.
Marine tubular	19	12	II
	19	II.2	0.16
	16.8	11.8	9.3
Vertical water-tube	20	12.4	10
Horizontal flue	15.6	11.2	9.9
** **	15	10.4	9.3
Marine tube	18	11.1	11.2
•		•	Average 10.2

From Isherwood's historic experiments the following table is taken:

#### TRANSFER OF HEAT.

Type of Boiler.	Square Feet of H. S. per H. P.	Coal per Hour per Sq. Ft. H. S.	Relative Economy.	Relative Steaming Rapidity.	Authority.
Water-tube Tubular Flue Plain cylinder Locomotive Vertical tubular	10-12 14-18 8-12 6-10 12-16 15-20	•3 •25 •4 •5 •275 •25	1.00 .91 .79 .69 .85 .80	1.00 .50 .25 .20 .55 .60	Isherwood "'Trowbridge "'

Another series of data is the following:

100. Evaporation in Boilers per Pound of Coal.— Again, the design of the boiler may be approached directly on the basis of water to be evaporated per pound of coal burned.

It will be recalled (§ 22) that a pound of carbon of calorific power 14,400 will evaporate as many pounds of water at  $212^{\circ}$  into steam at  $212^{\circ}$  as 966 (which is the number of heatunits required to do such evaporation) is contained in 14,400.

 $\frac{14400}{966} = 15 + lbs.$ 

If commercial coal is used instead of pure carbon, as standard, having a calorific power of 12,000 by reason of ash and moisture in it, the pounds of water per pound of coal will be

$$\frac{12000}{966} = 12 + \text{lbs.}$$

It is doing very well in a test when II pounds is reached, and in every-day service 7, 8, and 9 are acceptable. Less than 7 is poor.

If then the pounds of water per hour required in the form of steam are known, the grate-area will be determined, and the ratio of heating-surface to grate-area is taken from the foregoing tables.

The weight of water and steam for an engine service can

be found from volume and pressure at cut-off or at release from an indicator-card by consulting steam-tables for the weight per cubic foot at those pressures.

Or if no tables are available, it can roughly be calculated as follows: Volume of cylinder in cubic feet  $\times 2Rpm \times 60$ = cubic feet of steam per hour at boiler-pressure and no cut-off. This volume in cubic feet multiplied by

 $\frac{I}{n} \times \frac{p}{I} \times \frac{62.5}{I} \times \frac{I}{1700} =$ lbs. water per hour,

when n = point of cut-off in terms of piston-stroke;

p = pressure in atmospheres at point of cut-off;

62.5 =pounds per cubic foot of water;

1700 = multiplier to reduce steam at atmospheric pressure to water at same pressure, since I cubic inch of water makes 1700 cubic inches of steam at one atmosphere pressure.

**101.** Water per Horse-power per Hour.—Or again, experiment has shown that in various grades of engine an engine horse-power should be developed with the following pounds of water:

High-grade compound	16–20	
Condensing single	22-24	
Good large non-condensing	28	
Average size condensing	30	
Small	30-45	
Pumps, elevators, and non-expansive engines	50	upwards.

The American Society of Mechanical Engineers, choosing a safe figure, has said a boiler of N horse-power should evaporate 30N pounds of water from a feed-water temperature of  $100^{\circ}$  to steam at 70 pounds pressure. This is  $34\frac{1}{2}$  pounds of water (34.488) evaporated from and at  $212^{\circ}$  with easy firing, moderate draft, and ordinary fuel, and showing good economy. By forcing the boiler should be able to do one third more.

This standard boiler horse-power is equivalent to a development of 33,305 thermal units  $(34.488 \times 965.7 = 33.305)$  and therefore corresponds to a condition of economy belonging to a combustion of  $\frac{33305}{12000} = 2.8$  pounds of coal (usually called 3) per horse-power per hour in the engine. Hence from these data also a boiler-, grate-, and heating-surface can be derived. If this principle be applied to the data in § 99, the accepted proportion of  $\frac{1}{8}$  of a square foot of grate per horsepower is seen to be the result.

Still another path to solution is the assumption of  $1.1\frac{1}{2}$  to 12 square feet of heating-surface to the horse-power on the above unit; or about 3 pounds of water will be evaporated from and at 212° per square foot of heating-surface. At slow rates of evaporation more square feet will be required. Kent gives the following table (p. 678):

Pounds $H_2O$ from and at 212° per square foot heating-surface per hour Square feet heating-surface per H. P Ratio H. S. to G. S. at $\frac{1}{2}$ sq. ft, of G. S. to I. H. P Probable relative economy Probable temperature of chimney-gas	2 17.3 52 100 450	2.5 13.8 41.4 100 450	3 11.5 34.5 100 450	3.5 9.8 29.4 95 518	4 8.6 25.8 90 685	5 6.8 20.4 85 652	6 5.8 17.4 80 720	7 4.9 13.7 75 787	8 4·3 12.9 70 855	9 3.8 11.4 6- 922	10 3.5 10.5 60 990
--	-------------------------------	-----------------------------------	---------------------------------	---------------------------------	-------------------------------	-------------------------------	-------------------------------	-------------------------------	-------------------------------	-------------------------------	--------------------------------

As two examples the following cases will illustrate the different results from assuming different conditions:

No. I. Chimney-draft: 12 pounds of coal per square foot grate per hour evaporation = 9 pounds of water per pound of coal. Required to evaporate 5000 pounds of water per hour.

 $\frac{5000}{9 \times 12} = 48$  square feet of grate.

If H.S. : G.S. :: 25 : 1, then heating-surface = 1200 square feet.

No. II. Artificial draft: 60 pounds of coal per hour per

square foot grate; 7 pounds water per pound of coal. Then

$$\frac{5000}{7 \times 60} = 12$$
 square feet of grate.

And if H.S.: G.S.:: 70: I, then heating-surface = 840 square feet.

Case I would probably be two boilers of 24 square feet each.

 $2 \times 24 \times 12 = 576$  lbs. coal per hour, and  $576 \times 9 = 5184$  lbs. water per hour.

Case II.  $12 \times 60 = 720$  lbs. coal per hour, and  $7 \times 720 = 5040$  lbs. water per hour.

This illustrates an advantage of central power stations over road generation of steam for short lines.

102. Refrigerating-surface.—The transfer of cold in refrigeration and condensing is the same in principle as the reverse transfer of heat.

The standard experiments are Joule's (*Jour. Franklin Inst.* 1862) and Isherwood's (Shook's '' Steam-boilers,'' p. 58).

Isherwood's results are:

I. The number of heat-units per hour transmitted per square foot of surface is in direct ratio to the difference in temperature of the sides of the intervening metal.

2. Within limits, the rate of transmission of heat through a metal is independent of its thickness  $(\frac{1}{8}, \frac{1}{4}, \frac{3}{8})$ .

3. The thermal conductivities of four metals is as follows:

Material.	Thermal Conductivity or Heat-units per Hour per Square Foot for 1° Dif- ference Fahrenheit.	Relative Thermal Conductivity.		
Copper (refined)	642.543	1		
Brass (60 Cu, 40 Zn)	556.832	0.866607		
Wrought iron	373.625	0.581478		
Cast iron (several times remelted)	315.741	0.491393		

Prof. Jay M. Whitham's formula for condensing-surface is

$$S = \frac{WL}{ck(T_1 - t)}.$$

In this, S = condensing-surface in square feet;

L = latent heat of saturated steam at temperature  $T_1$ ;

 $T_1$  = temperature of steam at pressure recorded by the vacuum-gauge;

t = mean temperature of condensing water—the half-sum of initial and final temperatures;

- k = perfect conductivity of 1 square foot of condensing-surface of metal used from above table;
- c = fraction denoting efficiency of condensing-surface: probably about .3.

Standard experiments give a value for ck = 180, hence

$$S = \frac{WL}{180(T_1 - t)}.$$

Joule found the resistance to conductivity to be due to a film of water on each surface, and that to circulate the condensing water rapidly was to increase the conductivity of the metal.

In cooling brine by coils containing a cold fluid, experimental values give a result of 79 square feet of coil-surface to dispose of 100,000 heat-units negative per hour.

103. Conclusion.—While further topics belonging to the proper appliances for the actual liberation and transfer of heat might properly be introduced here, to do so would make the discussion too voluminous to be convenient. Students will find the subjects of boiler-setting, boiler accessories, care and management of boilers, and the like fully treated elsewhere, to which references will be found in the Appendix.

## CHAPTER IX.

#### MEDIA USED TO TRANSFER HEAT ENERGY.

105. Introductory.—A heat-engine has been heretofore defined (§ 6) as one in which an effort in pounds was exerted through a space or path in feet, and where such effort was the result of a pressure on an area, such pressure being caused by heat. The preceding chapters have been concerned first with the generation or liberation of heat from the storage of such heat energy in fuel; and secondly, with its transfer to a proper medium to act upon the piston which is the mechanical organ to receive that effort. The subject next to be entered upon must then be the effect of increase of heat energy in proper motor media, and the laws of their action under changes which they may undergo in the amount of heat represented in heat-units on the absolute temperature scale.

The properties of these media and the effects of heat changes upon them are physical phenomena for investigation by the physicist in his laboratory. The engineer, however, is concerned with a comparatively narrow range of those phenomena and properties which are properly within the domain of physics in the field of heat.

106. Solids, Liquids, and Gases.—It will be generally agreed that the matter of the earth (and, so far as known, of the universe) appears in solid or in fluid form. The solid matter is that which can be changed in shape or figure only by considerable exercise of force, while the particles

## MEDIA USED TO TRANSFER HEAT ENERGY. · 165

of the fluids are mobile among each other, and only remain in any relation to each other by the exertion of some force. The fluid matter is again subdivided into liquids, which have a considerable weight per cubic foot and some cohesion of particles and no inherent elasticity or tension at usual pressures; and gases, whose weight per cubic foot is small, and which have at all usual pressures a tendency to expand and fill larger volumes as soon as such increased volume exists in connection with the gas. Instead of the solid and fluid subdivision, that into solids, liquids, and gases is preferred by many, and for present purposes is most convenient.

This threefold division is further of advantage since the accidental conditions of temperature and pressure may cause the same matter to appear in one or the other of the three Water, for instance, at atmospheric pressure is a states. solid below 32° F., a liquid between 32° and 212°, and a gas above the latter point. Mercury is a solid below 39° below zero Fahrenheit, a liquid up to 648° F., and a gas above this point. All of the usual metals are solid as they commonly are found, will become liquid or melt at a sufficient temperature, and are volatilized at the temperatures of the electric arc or furnace and in that of the sun. On the other hand, many of the substances which at atmospheric pressure and ordinary temperatures are known as gases will become liquid by sufficient pressure and lowering of their temperature. Such condensable gases are ammonia, sulphurous acid, some petroleum products, carbonic acid gas, the air, and others. When the pressure is released or the temperature is raised, they will return to the condition of gases. It is proper to say, therefore, since the foot-pounds required to compress a gas can be translated into heat-units by multiplying by 778 (§ 10), that the state of a body as to its condition as a solid, a liquid, or a gas is dependent upon its heat condition. A gas which has not yet been made into a liquid by pressure or cold or both is called a permanent gas. Improvements in apparatus, how-

ever, are continually shifting gases from the list of permanent gases into that of condensable gases. A more exact definition will be given in a following paragraph.

107. General Characteristics of a Medium to be used in a Heat-engine.—It has been already established (Chapter II, § 7) that the effort of a piston-engine in foot-pounds can be expressed by the product of the two factors PV, either per stroke or per minute or per pound. It is the effort of the engineer who is to use the motor energy of heat to make this product as large as possible with the least expenditure of his store of heat in the fuel. With a cylinder which has been actually constructed in cast iron or other material the value for Vhas become a fixed quantity in any one engine, so that P must be the quantity which it is desired to have increase as more heat energy is supplied. Hence the medium to be used in the heat-engine should be one in which the following equation should be true:

$$PV = ZT,$$

in which T represents degrees of temperature on the absolute scale (§ 16) and Z is a factor or multiplier constant or variable, but determinate, with which the temperature is to be multiplied in order to produce the desired or observed value for the first member, with any selected medium. V is the volume at the end of the stroke, through which the piston has swept, and P the pressure at the end of the stroke and which has prevailed throughout it if the pressure was constant, or is the mean pressure if the latter was variable. All solids are at once thrown out as media, because they lack the property of any considerable range of volume except in the form of coiled springs which are not available where heat energy is the motor energy, and consideration can be confined to media in liquid and gaseous states. Liquids in the liquid state are thrown out for the same reasons: the change of volume by heat alone, if they remain liquids, is too small to

## MEDIA USED TO TRANSFER HEAT ENERGY. 167

make them useful. Gases, on the other hand, have the property of undergoing wide ranges of volume, and of experiencing considerable changes of condition for small changes of temperature. Their great elasticity enables the gases to be conveniently stored in considerable weights in bulks which are not inconvenient; and when liberated from the motorcylinder after their work is done they pass out easily, and cause the least negative pressure or effort to expel them. It will furthermore be evident that, other things being equal, a medium which has a high value for the factor Z will make a more powerful motor with a given size of cylinder than one which has a low value for that factor. It goes without saying that the greater the value for the quantity of heat in units which is brought into the cylinder and utilized there per stroke, the more powerful and economical is the motor for its size or bulk. Shall now the gases to be selected as media be permanent or condensable gases?

It must not be overlooked that the volume of gas which has filled the volume V of the cylinder at the end of the completed stroke must be expelled therefrom on the return of the piston to its starting-point. The effort necessary to do this work of expulsion is a charge upon the net or effective work outside of the cylinder, because it must be subtracted from the gross or driving effect of the working-pressure medium, and it is of advantage to make it as small as possible in the interests of size of engine for a given effective power, and for the sake of reducing ineffective effort on general principles. Now with the permanent gases, the best which can be done is to open the cylinder-volume by generous passages and valves to a larger and cooler volume in which by the lowering of T and the increase of V, the value of P shall be lowered as far as it can be done for that gas. For now a definition can be made of a permanent gas which shall be more exact and definite than that of the preceding paragraph. Α permanent gas is one in which the value for the multiplier Z

determined experimentally for one condition of pressure volume and temperature is true for all other natural conditions, or in which Z is a constant. The equation is then usually written

$$PV = RT$$
,

and values of R for different media will be given shortly. With the condensable or non-permanent gases a relation of pressure and temperature exists in which the gas changes to a liquid with a very great diminution of volume at that period of change, and of course a very great drop in the value for P. If then a condensable gas be used, and it be convenient at the end of the working or forward stroke to establish the conditions under which the gas goes back to liquid, the negative pressure for the expulsion stroke drops much further than it can conveniently be made to do with the permanent gases. If then the engine works without condensation of its medium, it makes little difference whether the gas be permanent or not, but the value for Z is the important primary matter; if the engine can work with condensation, the use of the condensable gases gives a smaller engine. The condensable medium, however, must be so chosen that the appliances for its condensation and revaporization shall not be inconvenient to an extent which may offset its advantage.

It is, however, not enough to have the value of the factor Z or R large in the above formula. It is obvious that if the equation is a true one it will hold for all values of V, and will be true for a volume of one cubic foot. If D denote the weight per cubic foot or the density of the medium, then these must vary inversely as each other, or  $v = \frac{I}{D}$ . Then the formula will be written

$$\frac{P}{D}=RT,$$

## MEDIA USED TO TRANSFER HEAT ENERGY. 169

an expression in which the volume does not appear, and which states that the density of the gas must diminish as the temperature is made to increase, and when R is large the density must diminish faster than the pressure rises for such a medium. Hence the conclusion that a desirable medium is one in which the changes of temperature within a given range do not produce wide differences in specific gravity. Such media must cause the change in T to cause changes in pressure, which is the thing sought for.

The equation

$$\frac{P}{D} = RT$$

permits of an interesting extension of its discussion. If the equation as written is true for air, it will take for any other permanent gas whose density is D' and which has for its factor a quantity represented by R' a form

$$\frac{P}{D'} = R'T.$$

Dividing these equalities member by member,

$$\frac{D'}{D} = \frac{R}{R''},$$

or the factors R and R' will vary inversely as the weights per cubic foot or the densities. These latter are usually well known and of easy access in tables, from which the values of R can be found. If the densities are given with air as a standard, then

$$\frac{D'}{D}$$
 = specific gravity = S.

From this R' can be found by dividing R for air by S; or

$$R'=\frac{R}{S}.$$

The following table gives such determinations made by this method:

	Spec. Grav. S.	R Centigrade.	R Fahrenheit.
Atmospheric air Nitrogen	1.00000 .97137	96.0376 98.867	53·354 54.926
Oxygen Hydrogen	1.10563 .06926	86.862 1386.579	48.257 770.322
Steam-gas (ideal, Rankine)	.62209 .62300	154.379	34.895 85.766 85.641
Steam, saturated (Zeuner)	.64000	150.160	83.422

Much effort has been directed towards securing a medium which should pass from a liquid to a gaseous state with least absorption of heat in such vaporization process, so as to secure a high vapor tension or pressure of the gas in its generator with a low specific heat or heat in the liquid when in a state to make itself into a gas. The difficulty so far encountered in all these attempts has been an inherent one: that the vapors from the volatile liquids which heat easily are so much more dense than the vapor of water with which they compete and are compared, that just about as much greater weight of the substituted liquid has to be vaporized as appears to be saved by the lower temperature of vaporization if the same mechanical energy is developed at the piston.

Another way of stating the same truth or result is, that to carry into the working cylinder as much heat as possible per stroke is one of the objects sought in a medium, and to have it carry out with it the least possible heat is the other. The volatile vapors with low specific heat compel a large weight of their substance to be used to carry into the cylinder a great number of heat-units, and it is not easy to prevent their carrying too many out of the engine with them, since, unless great quantities of cool condensing water are used, these easily vaporizable media refuse to return back to liquids. If they do not return to liquids, they carry away

#### MEDIA USED TO TRANSFER HEAT ENERGY. 171

the heat used to vaporize them, which is lost; and the work of handling great weights of water for condensing more than offsets the apparent gain.

108. Some Heat-carriers which have been used as Media in Heat-engines.—The two media most used in heatengines are steam, which is the gaseous state of water, and air. These are accessible, cheap, safe, innoxious, odorless, non-inflammable.

Other media may be mentioned:

Ammonia (NH<sub>3</sub>). Acetone (C<sub>3</sub>H<sub>6</sub>O). Alcohol (C<sub>2</sub>H<sub>6</sub>O). Bisulphide of carbon (CS<sub>3</sub>). Chloride of carbon (CCl<sub>4</sub>). Chloroform (CHCl<sub>3</sub>). Ether (C<sub>4</sub>H<sub>16</sub>O). Naphtha and Gasoline (C<sub>6</sub>H<sub>14</sub> to C<sub>8</sub>H<sub>18</sub>).

These are all more volatile than water, or make a vapor at a lower temperature; but they are costly to buy and hence must be condensed after working in the cylinder, and require for this an excess of cool condensing water. Many of them have an odor, some an offensive one; some are inflammable, some explosive, some irrespirable.

The objection to air and the other permanent gases is the high range of temperature under which it must work, and the high initial pressures corresponding to such high temperatures, and yet withal the low mean pressure which must follow expansive working of the air. There can be no condensation and hence the working cylinder has to be bulky. This will be illustrated in detail later. Some of the properties of heat media are exhibited in the table on page 173, and others will be found in appendices under their respective heads. The only objection to steam as a heat-carrier is its possession of a property whereby the withdrawal of heat

while doing work during expansion in the cylinder causes a condensation of some of the steam, resulting in the formation of a mist which has an enormous absorptive capacity for heat and causes the phenomenon of cylinder condensation, to which later reference will be made. This very property, however, gives steam an advantage as far as size of cylinder is concerned.

109. Vapors .- The term vapor which has been used above is often employed to define the gaseous state of a body which is commonly a liquid within ordinary ranges of pressure and heat. In this sense steam is the vapor of water, and any condensable gas should be called a vapor. This is the proper use of the term. It is often, however, loosely applied to define a gaseous body having or carrying finely subdivided liquid particles in it which do not combine into drops, but give an opacity or visibility to the mixture of gas and liquid. The white cloud of watery particles which appears to issue from the exhaust-pipe of a steam-engine is not the true vapor of water (steam is an invisible gas), but it is often called a vapor when it should properly either be called vesicular vapor or nebulous vapor or be known as a mist. The term vapor is often popularly used to cover those gases other than steam which are used for motive-power purposes.

110. Liquefaction, Fusion, or Melting. Latent Heat of Fusion and Vaporization.—If the notion of the mechanical theory of heat be sound, it follows that a solid which has become a liquid by the process of applying heat to it, as in the melting of ice or sugar or tallow or lead or iron, must have had its heat condition or heat energy greatly increased by that process. Very considerable quantities of heat in units have been expended upon it, and yet the temperature changes recognizable by the thermometer are not so very great between the condition of hot solidity and that of incipient fluidity. Conversely, a body like water, in passing to

UF FRESOURE FROM 100 10 14.1 Coal per hour per Probable coal per Frac. I.H.P., assume hour per H.P., in- at ex. Rue boiler to utilize of did for oflinder col. 5, soon heat-units per ondensation for useful inder of coal suttacted vapors, useful inder soores and records apors,	an engine, tion neglected—in heated vapors—in lbs.	6 7 8	.14 2.30 3.10	.15 2.15 2.88	.13 2.48 2.48	.15 2.15 2.88	.17 1.99 2.68	.46 0.70 0.70	
i	Efficiency tion of pended which ca	work in	-	0	ō	ò	Ō	ò	ō
URE 14.7 LBS ditish Thermal finits necessary to the expended in rder of generate pound of vapor rown (remp. of	feed" equal to that given in column 4.	מ	1002	632	940	195	163	160	
CUT-OFF, THE EXPANSION BEING SUFFICI LBS, PER SQUARE INCH, MEAN BACK-PRES Temperature in Degrees I Substance used as a Heat in Liquid Condition.	e in Degrees t at pres- square inch	14.7 lbs.	4	212	- 27	80	95	115	70
	roo lbs.	æ	328	56	282	215	248	607	
		2	I.00	0.99	0.99	o. 55	0.24	0.24	
		_	Steam	Ammonia, saturated	" superheated	Ether	Carbon bisulphide	Air — worked as in Joule's engine (see Rankine's "Steam- engine," p. 373)	

MEDIA USED TO TRANSFER HEAT ENERGY.

the state of ice, requires the withdrawal of a large number of units of heat just at the freezing-point, to enable the change to occur. This is usually explained by saying that an increased energy is characteristic of the fluid state of that body over that attaching to it in its solid state; and that the heat or energy which disappears in effecting this change of state is used in overcoming molecular attractions. It is generally called latent heat (meaning concealed heat) because it is not recognizable as heat except when the reverse change occurs, although necessary to produce it. When the change is from a solid to a liquid, it is called the latent heat of fusion or liquefaction. The following table gives the accepted values determined by M. Person. The figures are the pounds of water which are raised one degree Fahrenheit by the release of heat when the bodies solidify; or the degrees Fahrenheit through which one pound of water would be raised by the same process. They must also be the same quantities for the lowering of the heat condition of water when its heat is demanded to liquefy the substance at the temperature of its fusion.

Water (ice)	140 to 142	Bismuth	22.726
Zinc	50.682	Sulphur	16.954
Silver	38.057	Lead	9.740
Tin	25.702	Phosphorus	9.018
Cadmium	24.588	Mercury	5.086

These figures, which are in B.T.U., must not be confounded with the temperatures of fusion already referred to in  $\S$  69.

When the change is from a liquid to a gas, the heat required for vaporization is called the latent heat of evaporation. This will be further discussed in a following chapter; but it will be apparent that media which have a high value for their latent heat of evaporation will carry more heat into the engine-cylinder than media in which this quantity is

## MEDIA USED TO TRANSFER HEAT ENERGY. 175

smaller, and that upon usefully entrapping this large latent heat by condensation after the working stroke, the motor rejects less heat to waste than when the medium is reluctant to part with its latent heat or has none to give, as in the case respectively of the volatile vapors or the permanent gases used as media.

# CHAPTER X.

## PHYSICAL LAWS EXHIBITING THE EFFECTS OF HEAT UPON HEAT-CARRIERS.

**III.** Introductory.—The accepted principles of the mechanical theory of heat exact that when a body like a motor medium undergoes an increase of its heat energy, that increase shall be distributed to produce three effects:

I. An increase in the sensible temperature as discernible by thermometer or measurable by other means of observing actual energy.

2. An increase of volume, which means the doing of a certain amount of internal work upon the substance itself in overcoming the attractions of the particles for each other.

3. An overcoming of the forces exerted externally upon or against the body in its first state which have resisted the  $\bullet$ increase in volume, and which have therefore demanded an expenditure of energy in foot-pounds before the body could assume its greater bulk. If these three effects, each in footpounds, be represented respectively by the symbols A, B, and C, and Q denote the quantity of heat applied in heatunits, then it can be written that

$$A + B + C = 778Q,$$

or

$$Q=\frac{A+B+C}{778}.$$

## EFFECT OF HEATS UPON HEAT-CARRIERS. 177

In solids and liquids the quantity C will be so small as to be negligible, so that the expression can be written

$$\mathcal{Q} = \frac{A+B}{778}.$$

In perfect gases there should be no force required to overcome the attraction of their particles and B will disappear; or, for such gases,

$$Q = \frac{A+C}{778}.$$

The above holds true, however, only within the limits of no change of state of the body or while it remains a solid, a liquid, or a gas. At the melting-point of a solid the quantity A disappears suddenly or gradually, and the addition of heat after that does not raise the temperature of the remainder of the solid or of that part which has become liquid until all has been melted. The additional heat is expended in increasing the quantity B + C. The same is true for liquids passing to vapors. These quantities require to be separately investigated for each material.

But for the permanent gases used for motive-power purposes, such as air, and for the most usual vapor, that of water, there are certain physical laws which are the result of experiment and analysis and which require to be studied. The permanent gases are the easiest to begin with and will be taken first.

112. Law of Gay-Lussac, or Charles' Law.—This may be stated: The increase of volume which a perfect gas receives when the temperature is increased 1° under a constant pressure of such gas is a fixed proportion of its initial volume at the temperature of *melting ice*; or, stated otherwise, *Equal increments of the volume of a perfect gas correspond very nearly to equal increments of its temperature as determined by* 

a mercurial thermometer, provided the pressure is kept constant. The first statement has already been anticipated in the discussion of the air-thermometer and absolute temperature (§§ 15 and 16), and the values for the increment of volume for each thermometric degree as determined by Regnault and others; viz.,  $\frac{1}{\sqrt{2}}$  or .00365 on the centigrade scale, and  $\frac{1}{493}$  or .002035 on the Fahrenheit. Expressing this law in symbols, if  $v_{a} =$  an initial volume of any permanent gas at the temperature of melting ice, and if a represent the coefficient of increase for each degree of the thermometric scale. then the volume for any temperature t will be (at) times greater than the volume at melting-ice temperature on the centigrade scale, and  $[a(t - t_o)]$  times greater on the Fahrenheit or other scale on which the reading at melting-ice temperature is not zero. This can be made general for all scales by calling t the range of temperature from melting ice as a starting-point, or

$$v = v_0(1 + at).$$

The coefficient a is practically or very nearly the same for all the permanent gases, air, oxygen, hydrogen, etc.

113. Coefficients of Expansion.—It has already been observed that the expansion of solid bodies by heat is so small a quantity within any normal range of temperature as to be of no moment in motive-power problems. The following tabular values from D. K. Clark will show the quantitative relations of certain materials. The figure is the length to be added to a unit length for each degree Fahrenheit.

Aluminium	Lead
Brass	Plaster
Bronze	Silver
Concrete	Steel
Copper	Tin* .00001163
Iron, wrought	Zinc
" cast	

### EFFECT OF HEATS UPON HEAT CARRIERS. 179

Liquids expand between 32° and 212° F., with the volume at freezing as unity:

Water	1.0466	Nitric acid	1.11
Salt solution	1.05	Oils	1.08
Mercury	1.0182	Ether and turpentine	1.07
Alcohol	1.11	HCl and $H_2SO_4$	1.06

114. Law of Mariotte, or Boyle's Law.—The law of Mariotte, discovered by him in 1640, and announced by Robert Boyle in England independently at about the same date, may be stated: The temperature of the gas remaining constant, the volumes of the same weight of gas at different pressures will be inversely as the pressures.

Near the points of liquefaction of gases by pressure, departures occur from this law which are wider the nearer that point is reached, as the diminution of volume is then more than proportional to the increase of pressure, —as should be anticipated from the conditions. Expressing the law by symbols, if  $p_0$  be an initial pressure expressed in any unit of pressure on a unit of area, and  $v_0$  the corresponding initial volume of the gas, then for any other pressures and volumes which go together it will be true that

 $p_{o}: p:: v: v_{o};$ 

or, more conveniently,

$$p_{0}v_{0} = pv = a \text{ constant},$$

provided no change of temperature or heat energy occurs by reason of processes connected with such change of volume. It follows further, that since for a given weight of gas the density will vary inversely as the volume, the pressures must vary directly as the densities, and will be directly proportional to them at the same temperatures. Or, in symbols,

$$p_{\circ}: p:: D_{\circ}: D;$$
 or,  $\frac{p}{D} = \frac{p_{\circ}}{D_{\circ}} = a$  constant.

115. Combination of Mariotte and Gay-Lussac Law. Value of Symbol R.—It becomes simple and useful to combine the foregoing two laws so as to exhibit the behavior of a weight of gas undergoing change of volume and temperature under constant pressure, or change of pressure and temperature under constant volume. Let  $p_0$ ,  $v_0$ , and  $t_0$  be respectively the pressure volume and temperature of a given weight of gas at the temperature of melting ice. Then for a different pressure,  $p_1$ , let  $v_1$  denote the corresponding volume, and  $t_1$  the range of temperature attaching to the change of pressure to  $p_1$ , and let  $p_2$ ,  $v_3$ , and  $t_2$  denote the same quantities at a different pressure,  $p_3$ , and range of temperature  $t_3$ . It follows from Mariotte's law alone that

$$p_0 v_0 \doteq p_1 v_1 = p_2 v_2.$$

But by the Gay-Lussac law the respective volumes for a range  $t_1$  and  $t_2$  belonging to the pressures  $p_1$  and  $p_2$  will be respectively

$$v_{1} = v_{0}(1 + at_{1});$$
  

$$v_{2} = v_{0}(1 + at_{2});$$
  

$$p_{1}v_{1} = p_{0}v_{0}(1 + at_{1}),$$

whence

and

$$p_2 v_2 = p_0 v_0 (\mathbf{I} + at^2).$$

Dividing one by the other, and transposing the factors  $p_i$ 

$$\frac{v_1}{v_2} = \frac{p_2(1 + at_1)}{p_1(1 + at_2)}.$$

Substituting for *a* its value in either thermometric scale  $(\frac{1}{273})$  or  $\frac{1}{493}$  and multiplying both numerator and denominator by it, we have

$$\frac{v_1}{v_2} = \frac{p_2}{p_1} \times \frac{273 + t_1}{273 + t_3},$$

٥r

$$\frac{v_1}{v_2} = \frac{p_2}{p_1} \times \frac{461 + t_1}{461 + t_2}.$$

But the last factor is the absolute temperature corresponding to the temperatures belonging to  $p_i$  and  $p_i$  respectively, so that the equations might be written, if a capital T denote the respective absolute temperatures,

$$\frac{v_1}{v_2} = \frac{p_2}{p_1} \times \frac{T_1}{T_2},$$

which may be again transformed so as to read

 $\frac{\not p_1 v_1}{T_1} = \frac{\not p_2 v_2}{T_2}, \text{ and which must equal } \frac{\not p_0 v_0}{T_0},$ 

which may be translated to say that at constant pressure the volume will vary inversely as the absolute temperature, or at constant volume the pressure will vary inversely as the absolute temperature.

It follows furthermore, that since for any permanent gas the quantity  $T_0$ , or the absolute temperature at the point of melting ice; the quantity  $v_0$ , or the volume occupied by a given weight of gas under atmospheric pressure at that temperature; and the quantity  $p_0$ , or the pressure on a unit of area corresponding to one atmosphere, are all known and evaluated, the product of them must be a constant for any known gas. It may be called R. Whence it will be true for any other conditions of pressure and volume which belong together that

$$PV = RT.$$

(Compare § 107.)

For air R = 53.354, since  $p_0 = 2116.5$  pounds per square foot;  $v_0 = \frac{I}{D_0} = \frac{I}{.080728}$ , whose denominator is the weight of a cubic foot of dry air at the sea-level and  $32^\circ$  F., and under one atmosphere of pressure called 14.7 pounds per square inch; and  $T_0$  is 493 for Fahrenheit scale. For other gases, such as

Steam, superheated	R =	104.641
Ammonia	R =	162.602
Ether	R =	107.830
Alcohol	R =	103.785

It will be apparent from inspection of the term  $\frac{\not P_0 v_0}{T_0} = R$ 

that it represents the outer work performed by a pound of gas when its temperature is raised one degree, or from  $32^{\circ}$  to  $33^{\circ}$ on the Fahrenheit scale. Let a cylinder be imagined of one square foot of area, in which fits a weightless piston loaded with a weight to represent one atmosphere or  $14.7 \times 144$ = 2116.5 pounds, and enclosing below it one cubic foot of air. Let this cubic foot be expanded by heat to become two cubic feet. The work done will be  $2116.5 \times 1 = 2116.5$ foot-pounds by one cubic foot, or

 $\frac{2116.5}{.080728} = 26217.66 \text{ foot-pounds}$ 

by one pound of air. The denominator is the weight in pounds of one cubic foot. But to double the volume would require by the Mariotte law an expenditure of  $493^{\circ}$ ; hence to expand through one degree would require but  $\frac{1}{493}$  of that required to do the work of doubling the volume. Hence the outer work entailed by the rise of one degree temperature Fahrenheit will be

$$\frac{26217.66}{493} = \frac{p_0 v_0}{T_0} = 53.354 = R.$$

Similar calculation can be made for any gas, or R can be found by the other method discussed in § 107 by using the densities.

## EFFECT OF HEATS UPON HEAT-CARRIERS. 183

116. Specific Heat at Constant Pressure and at Constant Volume.—A most important consequence is suggested by the foregoing calculations and deductions concerning the symbol R in the equation PV = RT. If the volume of the gas is prevented from increase, the work represented by R is not disposed of against outside resistances, and will remain in the gas as heat not expended in work. By definition (§ 12) the specific heat of a substance is the amount of heat necessary to raise one pound of it through one degree Fahrenheit. This quantity must obviously be different for a gas which is free to expand and overcome the work represented by R, from the quantity which the gas takes when such work is not done upon outer resistances. Gases therefore have two specific heats: the specific heat at constant pressure, which may be represented by  $C_{\mu\nu}$  and the specific heat at constant volume, represented by  $C_{v}$ . The former is always the larger, since

$$C_{p}-C_{v}=\frac{R}{778}.$$

For air Regnault's experiments give for  $C_{p}$  0.2375; for  $C_{v}$  0.1691; whence

$$\frac{C_{\phi}}{C_{v}} = \frac{2375}{1691} = 1.408.$$

In any case where a gas is heated from a temperature absolute  $T_1$  to another higher absolute temperature  $T_2$  under a constant pressure, the work done will be that of overcoming the pressure through a space represented by the difference between the volume  $v_1$  at the temperature  $T_1$  and the volume  $v_2$  which corresponds to the temperature  $T_2$ . Expressing this in symbols, the heat taken in will be, per pound of gas,

$$C_{p}(T_{2} - T_{1});$$

and the work done will be

 $p(v_2 - v_1)$ , which must equal  $R(T_2 - T_1)$ .

The internal energy in the gas must be the net difference between these two quantities, or

$$(C_p - R)(T_2 - T_1).$$

When, on the other hand, the same weight of gas (one pound) was heated at constant volume from  $T_1$  to  $T_2$ , it must be true that the heat taken in is expressed by

$$C_{v}(T_{2} - T_{1}),$$

since no external work is done, and the whole applied heat energy goes to store up internal energy. But the same amount of heat energy was applied in the two cases; so that

$$C_v(T_s - T_s)$$
 should equal  $(C_p - R)(T_s - T_s)$ ,  
or  
 $C_v = C_p - R$ ,

as has just been shown above.

It may therefore be stated that the expression  $C_v(T_a - T_i)$  expresses or measures the change of internal energy in a unit weight of gas in changing its temperature from  $T_i$  to  $T_a$  in any manner, no matter how the volume or pressure may vary during the process.  $C_v$  has been called the real specific heat, and  $C_b$  the apparent specific heat.

117. Joule's Law.—A law determined experimentally by Joule, involving the foregoing determinations and extending them, may be stated as follows: When a gas expands without doing work and without taking in or giving out heat (and therefore without changing its stock of internal energy), its temperature does not change. This was proved by immersing two closed vessels in a vessel of water. They were connected by a tube with a cock in it. One was empty, and in the other was the gas at a considerable tension by compression. When the cock was opened, the gas expanded and equalized its pressure in the two vessels, but did no external work. The water surrounding the vessels underwent no change in temperature, but the cooling upon expansion was offset by the
# EFFECT OF HEATS UPON HEAT-CARRIERS. 185

warming effect in the other vessel. Hence it was inferred that the gas had neither gained nor lost heat, and, since it had done no work, the intrinsic energy was the same at the end as at the beginning, although both pressure and volume Hence the conclusion that the inhad undergone changes. trinsic energy of a given weight of gas depends on its temperature only, and not on its pressure or volume; or, in other words, a change of pressure and volume not associated with a change of temperature leaves the internal energy un-This has an important significance in operating altered. with compressed air. Or, again, the same idea may be expressed by saying that the change of internal energy is independent of the relation of pressure to volume during a temperature change, but is dependent only upon the amount of such temperature change.

118. Graphical Representation of the Thermal Changes in a Gas.—Since the characteristic equation of a perfect gas (pv = RT) involves three factors which are variable and one constant factor, and of which variable factors one can be made an arbitrary to be assumed, it early attracted the attention of mathematicians that this equation was in the same form as that for a curve upon a surface whose points were given by their coordinates or perpendicular distances from three rectangular axes. If one factor or co-ordinate were assumed arbitrarily, the other two would give the relation between themselves on a plane surface, giving a curved plane figure; while if all three were variable the curve would be upon a surface whose section at every plane through it would be a curve.

This fact is of interest and significance in the field of speculative research, but by far the most usual cases are those in which one of the variables is assumed to be constant or to undergo no change, while the other two are varying according to the law of their relation for that particular gas. If the temperature, for instance, be assumed to be kept up by jack-

eting the working-cylinder with live steam or hot air, the changes designated by a properly drawn curve show the changes in pressure which take place as the volume is increased or diminished. This gives the form of diagram or curve which bounds the ideal indicator-diagram, taken or described by a pencil which records pressures as vertical lines, while the horizontal lines described from the engine crosshead are proportional to the volume created behind the piston by its motion from its dead-centre. By a similar process, the volume being kept constant for a given mass or weight of gas, a curve can be drawn showing the law of observed variation of pressure with temperature; or again, the pressure being kept constant, the law of variation of volume with temperature. This is a straight line, of course, whose equation is  $v_1 = v_0 + at$  from the Gay-Lussac law (§ 112).

These various lines on one or another of the coordinate planes have received special names, some of which are as follows.

119. Lines of Constant or Equal Pressure. Isopiestic Lines, or Isobars.—When the change of condition in a gas is a change of its volume without change in its pressure, and



the same assumption is made as in the foregoing paragraph, that vertical ordinates represent pressures, and horizontal abscissas represent volumes, then a horizontal line ab (Fig. 43)

# EFFECT OF HEATS UPON HEAT-CARRIERS. 187

drawn at a height above the initial line of pressures at a distance proportional to that constant pressure and of a length proportional to the increase in volume (or decrease) will represent an isopiestic line. Such a line is drawn by the pencil of a steam-engine indicator when the piston moves in the cylinder and steam enters from the boiler by evaporation of the water within it without drop of pressure.

The temperature may or it may not change during the increase of volume. The diagram is silent on this point. The work done would be obviously

Work = 
$$p(v_1 - v_0)$$
.

120. Lines of Constant or Equal Volume. Isometric Lines.—When the pressure in the cylinder is increasing by addition of heat or pressure, while the volume occupied by the gas is not altered, a vertical line will represent such changes of pressure under the same suppositions as above. This is the line traced by the pencil of the indicator at the dead-centre of the piston-stroke when the valve has opened to admit steam behind the piston, but no motion has occurred to generate a volume in the cylinder to be filled. Since there is no volume swept through by the pressure, the work is zero (Fig. 44).

121. Lines of Constant or Equal Temperature. Isothermal Lines .- By the use of special appliances (steam-jacket, hot-air jacket, and the like) it is possible to supply to the weight or mass of gas enclosed in a working-cylinder the amount of heat which it is ex $v_{\tau}$ pending in the form of work both  $p_1$ upon its own molecules in expanding, and the doing of the ex-FIG.45. ternal work. In the case of a per-

manent gas acting in this way the pressure will fall as the

volume increases (Fig. 45), and in simple and inverse ratio to such increase because

$$\frac{p_1 v_1}{T_1} = \frac{p_2 v_2}{T_2} = R = \text{a constant},$$

and the final temperature  $T_1$  was the same as the initial  $T_1$ , by the hypothesis. In other words, the external work has received all the heat supplied to the working-gas from outside, and the intrinsic energy of the gas has remained constant, or undiminished by the doing of any work.

On the other hand, for a mixture of a liquid and its vapor, as in a steam-boiler, in which the temperature is kept constant by a continuous supply of heat from a fuel or a fire, the pressure of the combination of liquid and vapor remains constant; hence the isothermal for such a case will be a straight line, like the isobar or isopiestic line of Fig. 43. This is the condition in the admission line and the back-pressure lines of the indicator-diagram.

122. Isodynamic or Iso-energic Lines.—This name is applied to lines of a thermal diagram representing changes during which the intrinsic energy remains unaltered; that is, all the heat received is transformed into external work, and produces no change in the carrier during the process. The isothermal for a gas as above is also an isodynamic line, by definition.

123. Adiabatic Lines.—When the gas which is working by expansion within a cylinder overcomes the external resistance through a path, and is yet so contained within that cylinder that it can receive no heat from an outside source, it is apparent that in such expanding it should become cooled by the giving up of some of its intrinsic energy. The cylinder may be supposed to be absolutely non-conducting; hence no heat is transferred to or from the working-medium—which was supposed to happen in the isothermal working. Rankine gave the name *adiabatic* to this change of heat condition

# EFFECT OF HEATS UPON HEAT-CARRIERS. 189

(from *a*, not, and *diabainein*, to pass through); and adiabatic lines are those which represent the relation of volume to pressure during changes which occur without transmission of heat, as such, to the medium.

The adiabatic line is usually steeper than the isothermal which has a common point with it, as can be made apparent if the gas has a considerable change of volume with tem-

perature. In Fig. 46, if the curve ii' be an isothermal and start at i to represent the expansion which takes place with a transfer of heat to it during that process, it will be apparent that the curve aa' representing expansion without that added heat should have a less pressure when a final volume is reached which is the same for

both. This will be equally true if the gas be compressed from a greater to a lesser volume. The isothermal curve must have heat withdrawn from the gas, thus diminishing its volume at the end of compression; adiabatic compression will leave in the gas the heat which corresponds to the work expended in such compression, and for the same final volume the pressure will be higher. It will be interesting in this connection to examine the table for the relative volumes of compressed air under adiabatic and isothermal compression given in Chapter XIII, § 182.

In the analytic representation of an adiabatic change it will no longer be true that pv = RT, but the equation for relation must be written

# $p_{\circ}v_{\circ}^{n} = pv^{n} = a \text{ constant};$

in which the exponent n represents either a whole number or a fraction, but is constant for any one substance and is to be



experimentally determined. The condition of true adiabatic • expansion (or compression) is rarely reached in practice, because the cylinder-walls of metal castings such as are usual must conduct heat in or out during the time in which the gas or medium is changing its volume and pressure. Such a curve, however, with its exponent experimentally determined is probably more nearly reached in the majority of cases than the curve of the isothermal change in which n is unity.

124. Isentropic Lines. Entropy.-It would be aside from the present purpose to review in detail the processes used by the great mathematicians in their masterly deductions which resulted in the mathematical quantity which they have called the "thermodynamic function" (Rankine) or the "entropy" (Clausius). In brief their reasoning may be summarized by stating that the addition of heat to a body is rendered evident by changes in pressure and volume. These simultaneous changes of infinitesimal extent give rise to an equation of differential form which expresses the relation between the ordinates and abscissæ for a given state, and which it is desired to integrate by the methods of the calculus so as to express the law of change between certain finite When the equation involves unknown functions of limits. the variable volume and pressure, and is in a general form, the expedient has been used of introducing an integrating factor. If this factor is made itself a function of the pressure and volume, the differential equation for a small increase in heat H becomes

$$\delta H = y \delta x,$$

in which y is the reciprocal of the integrating factor and  $\delta x$ is what the differential equation becomes when the equation is thus made integrable. Thence the investigation is concerned with the labor of finding out which of the functions of pressure and volume it is most useful to assign to the factor y. Subsequent research shows it to

# EFFECT OF HEATS UPON HEAT-CARRIERS. 191

be the absolute temperature, deduced from Carnot's principle (§ 213), and therefore

$$\delta x = \frac{\delta H}{T}.$$

This is usually written by substituting  $\phi$  for x,

$$\delta\phi=\frac{\delta H}{T},$$

whence

$$\delta H = T \delta \phi.$$

This is evidently a most elementary expression for an area, and is to be used in that form hereafter in this treatise.

This factor  $\phi$  was first segregated mathematically by Clausius, and received from him its accepted name, entropyfrom the Greek words en and trope, meaning a "turning into" or a transformation. Its symbol in all languages is the Greek letter  $\phi$ . While it is of signal importance in heatengine discussions, it is impracticable to form a defensible conception of the entropy as a property of heat media, since it does not reveal itself to the senses nor to usual instruments of observation. A most helpful illustration or analogue has been elaborated by Zeuner, Reeve, and others, by the suggestion that the energy resident in a pound of water to be used upon a water-motor is the product of the available height or head above the motor, multiplied by the attraction of gravitation upon the mass of the water. The head corresponds to the temperature in heat-engines, and is the measure , of the availability of the medium when our lower temperature level is fixed; the attraction of gravitation corresponds to the entropy of the heat medium, which has been called its "heat weight." We know as little about gravitation outside

of its phenomena and laws as we know about entropy, but this does not interfere with every-day applications and uses.

It is customary to take the value for the entropy factor as the difference between the value for the final stage and the initial stage of the expansion, each counted from freezing-point usually. This gives a finite value to be used as a factor, by methods to be discussed hereafter in more detail in Chapter XIV. For the present it will suffice to say that when heat is added to a permanent gas such as air,

Entropy = 
$$\int \frac{C\delta t}{T} = C$$
 hyp.  $\log \frac{T_1}{T_2}$ ,

which becomes equal to R hyp. log r when r is the ratio between the initial and final volumes or pressures or temperatures of the gas doing work by its expansion. This is made evident from the fact that the entire heat addition in such isothermal expansion appears as the external work; this external work being the expression RT hyp. log r (§ 166) can therefore be placed equal to  $T\phi$ .

In the case of steam-gas, working in a cylinder as dry saturated steam, the heat addition is that which has disappeared as latent heat; hence the entropy becomes

$$\frac{\text{Heat of vaporization of steam at } T}{T} = \phi = \text{entropy,}$$

exclusive of the heat addition made to the liquid from which the steam is formed. Hence for the condensable vapors the total entropy is made up of two parts. The difference between the entropy value of the liquid at the beginning and end of the heating process will be

$$\theta_1 - \theta_2 = C_v \int \frac{\delta t}{T_1} - C_v \int \frac{\delta t}{T_2} = C_v$$
 hyp.  $\log \frac{T_1}{T_2}$ 

which indicates a progressive increase in the heat condition

#### EFFECT OF HEATS UPON HEAT-CARRIERS.

193

from the lower temperature to the higher on the hypothesis that  $C_v$ , the specific heat of the liquid at constant volume, is the same at both ends of the range represented by the heating. (See columns 11 of § 136, and formulæ at its conclusion.) When the vapor begins to form, a part x has its state changed and receives the heat of vaporization r, or the latent heat. The sum of these is

$$\frac{x_1r_1}{T_1} + \theta_1$$

for a state corresponding to  $T_1$ , and for a state  $T_2$ ,

$$\frac{x_2r_2}{T_2} + \theta_2.$$

Hence the difference will be

$$\phi_2 - \phi_1 = \frac{x_2 r_2}{T_2} + \theta_2 - \theta_2 - \frac{x_1 r_1}{T_1},$$

$$\phi_2 - \phi_1 = \frac{x_2 r_2}{T_2} - \frac{x_1 r_1}{T_1} + C_v$$
 hyp.  $\log \frac{T_1}{T_2}$ 

under the foregoing supposition.

If in the permanent gas the temperature has to be raised from a lower temperature  $T_0$ , the entropy above that at freezing will be made up of the heat to raise from  $T_0$  to  $T_1$ , and in addition that to increase the pressure from that at  $p_0$  to that at  $p_1$ . Hence the general expression becomes for a heating process not isothermal

$$\phi - \phi_{\bullet} = C_{\flat}$$
 hyp.  $\log \frac{T}{T_{\bullet}} + (C_{\flat} - C_{\flat})$  hyp.  $\log \frac{p}{p_{\bullet}}$ .

When, on the other hand, the curve representing the relations of pressure and volume is no longer an isothermal,

or

but is an adiabatic, the condition must be met that by definition there is no longer a transfer of heat from without the medium. Hence in the equation

$$\frac{\delta H}{T} = \delta \phi$$

the quantity  $\delta H$  has become zero, so that while T remains finite the quantity  $\delta \phi$  must become zero. This means that when the volume and pressure change according to the adiabatic law, the change in entropy for such changes is zero, or the entropy is constant for such changes of condition. Important deductions from this truth will be seen to follow hereafter (Chapter XIV), but for the present it may be observed that a curve representing an adiabatic variation of pressure and volume may be called a curve of constant entropy, or an isentropic line.

An interesting deduction can be made from the foregoing If two isothermal lines represent two differing states facts. of a heat medium at different times, the change which has made them differ is a change in temperature. Each curve represents by itself all variations of pressure and volume at a constant temperature, and the substance can therefore pass from one curve to the other curve only by having a temperature change brought in sufficient to make the transfer. If. on the other hand, two adiabatic lines represent two paths of variation of pressure with volume, with constant entropy attaching to each, but variable temperature, the heat-medium can only pass from being operated on one adiabatic to being operated on the other by such a heat-energy change as shall change the entropy of the medium. Temperature addition will only increase the relation of the pressure to the volume on either curve, but will not change the path of the process from one adiabatic to the other. Representing this graphically: if *ii* and *i'i'* be two isothermals (Fig. 47) representing the

# EFFECT OF HEATS UPON HEAT-CARRIERS. 195

relations of pressure and volume of a gas in a cylinder each corresponding to its proper temperature T and T', it follows from what precedes that to have the product p'v' belonging to T' become the product pv belonging to T, the property of the gas to be altered is its temperature. If, however, the curves aa and a'a' in Fig. 48 are each an adiabatic, whose



constant entropy is respectively  $\phi$  and  $\phi'$ , the relation  $pv^n$  for one curve can only become the relation  $p'v'^n$  proper for the other by a change in entropy which will correspond to the difference in that factor for the two states of the heat medium in question.

125. Plotting of Isothermal and Adiabatic Lines.—The graphical representation of the variation of pressure and volume isothermally is quite simple when the temperature is known or assumed and the value for R for the particular gas in question has been computed from known data. For, since

$$pv = RT = \frac{p_{\circ}v_{\circ}}{T}T,$$

it appears that the curve of the isothermal is that of an equilateral hyperbola referred to the coordinate axes of zero

pressure and zero volume as asymptotes. The easiest way is to calculate the product pv, and then to find the coordinates of the vertex of the hyperbola, when p = v, by extracting the square root of that product. When the vertex has been found for the assumed value of T, other points are found by making  $2v = \frac{1}{2}p$ ,  $4v = \frac{1}{4}p$ , and so on (Fig. 49), or the curve may be drawn by any reliable hyperbolograph.

A method much used to draw the hyperbola for the curve of expansion on a pv diagram where the vertex does not come at an observed point is required for indicator-diagrams. Any point on the actual curve having been located, as B (Fig. 50),



and the two coordinate axes of zero volume OP and zero pressure OV having been established, a horizontal line is drawn at a convenient pressure height above the greatest record of the diagram. It may be at boiler-pressure, but this is not essential. From the point B draw horizontal and vertical construction lines, and from the point A draw a diagonal to the point O, the origin of coordinates; where the horizontal through B intersects the diagonal, or at the point E, erect a perpendicular EF, and complete the rectangle ABEF by this means. Then lines drawn from O and cutting EF and meeting AF will determine other rectangles, and the intersections of the lines  $p_1$  and  $v_1$ ,  $p_2$  and  $v_3$  will give in each case a point

# EFFECT OF HEATS UPON HEAT-CARRIERS.

on the curve. In indicator-diagram work the point B is usually taken at the point of release of steam at the end of the expansion, because at this point it is usually safe to assume that the steam is dry or vaporization is complete. The point C at which cut-off takes place or expansion begins can also be taken, although this is less certain and accurate, and necessarily locates a different hyperbola.

For the drawing of the adiabatic curve, the calculation must be made for the initial state with the relation of pressure and volume represented by  $p_0 v_0^n$ , in which the exponent *n* is either known or assumed. Then by the relations

$$p_0 v_0^n = p_1 v_1^m = p_2 v_2^n = a \text{ constant}$$

points on the adiabatic curve are found. It will be brought out in a following chapter that for air n is usually 1.41, while for steam it is variously held to be 1.11 or 1.06

# CHAPTER XI.

# VAPORS AS HEAT-CARRIERS. STEAM.

130. Introductory.-It has been already said in Chapter IX that condensable vapors could also be used as heatcarriers, or those for which the expression pv = RT was not true in all states. In the choice of a vapor medium there is room for a wider choice than among the permanent gases. The latter are so nearly alike in their physical qualities that the selection of the cheapest, most accessible, most innocuous, and most inexhaustible of the gases, which are the conditions which attach to air, have precluded any serious attempts to use any of the other gases. But with the vapors there is at once presented a wide variation in volatility, specific heat, vapor density, condensability, and behavior while doing the work of expansion which has attracted experiment and invention to attempt to utilize them. The vapor of water has the same convenient qualities on its practical side as are possessed by air among the gases. It is furthermore without disagreeable odor, is not inflammable nor explosive, and has the property of carrying great heat in small bulk, and of having the highest temperature at the convenient limits of pressure to be used in generators and working-cylinders. It must be shown therefore by any other vapor that it possesses advantages greater than the losses incidental to the use of steam if it is to seek to be used as a heat-carrier. In other words, the presumption is in favor of steam, and the burden of proof must lie with the rivals who may seek to displace it

(see Chapter XXI). There are, however, certain general facts and principles to be noted for all condensable vapors to which attention should be first directed before discussing the special properties of steam.

131. Saturated Vapor. Saturated Steam .- It should be a deduction from Chapter IX that in a vessel containing a given weight of a mixture of a vapor and the liquid from which the vapor is being given off by the application of heat at any given pressure, it will be impossible to change the value of the expression pv by changing the value of p without changing the proportion of liquid and vapor. If p is increased and the volume remain constant, some vapor will go back to liquid; if p is diminished, more vapor is formed. Furthermore, if heat is withdrawn from the mixture, condensation of vapor to liquid occurs; if heat is added, vaporization occurs. In other words, there is for every vaporizable liquid a temperature of vaporization (or a boiling-point) corresponding to every pressure. A vapor is said to be a saturated vapor when it is in that condition of pressure and temperature at which exists this equilibrium of tendency to vaporize and to condense. In the case of the steam in a boiler in which is the water being vaporized, the steam is Instantly, on the withdrawal of any steam into saturated. the cylinder, its place is supplied by fresh evaporation. When the throttle-valve is closed, either the generation of steam ceases, or if heat is still flowing into the water, the pressure at constant volume rises until generation is made to cease by a new equilibrium at such higher pressure. When the steam passes into a pipe at the temperature of saturation and leaves the boiler to do work in the engine, it is called dry saturated Strictly, of course, it is the space which it occupies steam. which is saturated, or which is filled with as much steam as it will hold as steam at that temperature. Any reduction of temperature from radiation or other heat-loss will cause some of the dry steam-gas to fall back to the state of water,

probably in a state of fine division or mist, or perhaps in the form of liquid hot water. Such steam is called *wet* steam; and wet is not synonymous with saturated. Heat applied to it to dry it by evaporating out the condensed water will cause it to become saturated once more.

When dry saturated steam enters its working-cylinder, and after cut-off begins to work, increasing the volume it occupies and lowering its pressure by adiabatic expansion, the drop in temperature equivalent to the work done outside will cause a similar condensation of some steam unless the necessary heat is supplied from the cylinder-walls by jacket or otherwise to prevent a drop below the condition of satura-The latent heat of vaporization must, however, be tion. given out before this condensation occurs, and as this is a considerable proportion of the total heat (§ 138), the heat of the steam is strongly effective for doing work. By careful adjustment of the supply of heat to the jackets of a steamengine, the curve of pressure and volume ratio can be made to be that of the saturation curve of steam, and the steam at the period of release from the cylinder will be dry saturated steam. It would otherwise be wet.

This matter will be further considered under paragraphs treating of cylinder-condensation and re-evaporation, and the negative specific heat of steam.

132. Superheated Vapor. Superheated Steam.—When steam or other vapor is raised by the application of additional heat to a temperature above that which belongs to its equilibrium of temperature and pressure when in contact with its liquid, it is called superheated. It is possible to superheat steam in contact with its liquid by reason of the slow transfer of heat through a large volume of gas, but as soon as convection or circulation occurs some of the liquid will be vaporized, and the state of saturation will be again established. Hence, as a rule, superheating is effected upon steam-gas which is isolated from its liquid, and in some other

chamber or vessel. The effect of superheating is to make it possible for some heat to be withdrawn from the superheated vapor before it passes to the saturation stage, after which further removal of heat results in condensation. This makes it a convenient expedient to diminish probable losses from the cylinder-condensation, hereafter to be discussed, since a range or margin above saturation-point must first be traversed before the inconveniences of active change to liquid set in.

Superheating occurs in effect when steam or other vapor passes through a narrow opening or a constriction of passage such as is caused by a partly-closed valve. On the one side is the higher potential of greater pressure, while upon the lower side is a volume too large to be filled as rapidly as it is created if the flow must be through the constricted passage. Hence a lower pressure prevails beyond the constriction, and yet no heat has been abstracted except that required to do the work represented by the friction of the vapor through the orifice. Hence the practical effect is to produce a steam in the space beyond the valve which is hotter than the temperature belonging to the pressure there-or which is, by definition, superheated; and it will behave as a superheated vapor in an engine-cylinder. The action or effect here spoken of is one of the advantages inhering in the throttling method of governing by means of a valve in the steam-pipe, and lies at the basis of a form of apparatus for measuring the amount of moisture present in a flowing current of wet steam in a pipe.

Superheated vapor may be made so hot that within the limits of its use in any machine it may behave as a permanent gas, and undergo no change of state. It may then be called steam-gas rather than a vapor. It loses some of its advantages as a heat-carrier when it is used as a permanent gas, and some practical difficulties result from its inconveniently high temperature.

133. Relations of Pressure and Temperature in Saturated Steam-vapor (Regnault).—The relation between pres-

sure volume and temperature for saturated steam and other vapors were investigated by the physicist Regnault at Paris with such thorough exhaustiveness that his results are the standards for all engineers. These researches are to be found in vol. XXVI of the "Mémoires de l'Institut de France," 1847. His method was to take the temperature of the boiling-point under varying pressures, the pressure being observed by a mercury-column, and the temperatures by mercury-thermometer. After corrections were applied and the readings reduced to the air-thermometer, the best results were plotted, a curve drawn through them, and an equation worked out whereby the relations desired could be calculated. His equation is of the form

$$\log p = a + b\alpha^n + c\beta^n,$$

in which p is the pressure in millimeters of mercury, and  $n = t - t_0$ , or is the range between the temperature at which the pressure p prevails and the lowest temperature at which the formula is true with the given values for the constants a, b, and c. Thus at a latitude of 45° the values for steam between 32° and 212° F. and in pounds per square inch

$$a = 3.025908;$$
  

$$\log b = 0.6117400;$$
  

$$\log c = 8.13204 - 10;$$
  

$$\log \alpha = 9.998181015 - 10;$$
  

$$\log \beta = 0.0038134;$$
  

$$n = t - 32;$$

while between 212° and 428° F. the quantities will be

a = 3.743976;  $\log b = 0.4120021;$   $\log c = 7.74168 - 10;$   $\log \alpha = 9.998561831 - 10;$   $\log \beta = 0.0042454;$ n = t - 212.

Fig. 51 presents to the cye a graphical representation on a small scale of the relations between temperature and pressure from the Regnault experiments, below 15 pounds pressure, and Fig. 97 hereafter will carry the relation up to 150 pounds.



134. Rankine Formula for Pressure of Saturated Steam. —An approximate formula conforming very closely to Regnault's experiments was put forward by Rankine (*Edinburgh New Philosophical Journal*, July, 1849), and claimed by him to be sufficiently accurate between  $-22^{\circ}$  F. and 446° F. It is of the form

$$\log p = A - \frac{B}{T} - \frac{C}{T^2},$$

in which T is absolute temperature on the basis of  $T = t^{\circ} + 461^{\circ}.2$ , and for pounds per square inch

$$A = 6.1007;$$
  
log  $B = 3.43642;$   
log  $C = 5.59873.$ 

For pounds per square foot A = 8.2591. The difference between the two authorities is given by the comparison in the following table:

Temperature	Pressure, in Poun	Pressure, in Pounds per Square Inch.								
Fahrenheit.	Regnault, at Latitude 45°.	Rankine Formula.								
32	0.0890	0.083								
77	0.4555	0.452								
122	1.7789	1.78								
167	5.579	5.58								
212	14.697	14.70								
257	33.711	33.71								
302	69.27	69.21								
347	129.79	129.80								
392	225.56	225.9								
428	336.26	336.3								

135. Other Formulæ for Pressure and Temperature of Saturated Steam.—Many other formulæ have been worked out for the temperature and pressure of steam, having a certain accuracy and value within their several ranges. Mallet's, ranging between 15 and 60 pounds pressure, is

$$p = \left(\frac{75+t}{111.78}\right)^{6}$$

with centigrade degrees, and in pounds per square inch. Tredgold uses 175 as the denominator instead of 111.78.

Dulong and Arago give for pressures above 60 pounds per square inch, and centigrade degrees

$$p = (0.4873 + 0.012244t)^{\circ}.$$

Zeuner's formula is

$$pv = \frac{p_0v_0}{T_0}T - Cp^n,$$

in which by substitution is found

$$pv = 50.933T - 192.50p^{\frac{1}{2}},$$

in which p is in kilograms per square meter and v is the specific volume in kilograms per cubic meter.

De Volson Wood proposed

$$pv = 96.95 T - \frac{18500}{v^{0.22}},$$

in which p is in pounds per square foot, and v the cubic feet for one pound. For pounds per square inch, and v still in cubic feet per pound,

$$pv = 0.6732 T - \frac{128.5}{v^{0.22}}.$$

Other formulæ are by Dalton, Roche, Coriolis, and others.

136. Steam Tables.—Using the accepted formulæ and experiments of Regnault, Zeuner Rankine and others have computed tables giving the pressure corresponding to any temperature or the temperature corresponding to any pressure in common use. An abstract of such a table follows, giving also certain other data concerning steam which will be found useful and convenient. The pressure is given in even figures, as counted from a vacuum, and the corresponding temperature is therefore fractional. Following the computations by Prof. C. H. Peabody (the accepted authority in American practice), the value of the Fahrenheit freezing-point is taken as 492°.7. The reader and student is referred to Peabody's complete tables for further and fuller tabular information. The data for pressures above 300 pounds absolute are not reliable wherever the specific heat has entered as a

Pressure in Pounds by Gauge.	-		20.3
Entropy of Vapor. Øs	12	2.215 2.215 1.9845 1.9845 1.9845 1.9869 1.7812 1.7812 1.7730 1.7730 1.7755 1.7755 1.7477 1.7477 1.7477 1.7477 1.7457 1.7457 1.7452 1.7452 1.775555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.77555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.775555 1.7755555 1.7755555 1.775555555555	I.0705
Entropy of Liquid, $\phi_w = \theta$	=	0 1754 1759 1759 1759 1759 1759 1759 1922 1922 1922 1922 1922 1922 1922 19	.3811
Heat Equiv. fright frequence of frequence of frequence frequence frequence frequence frequence frequence frequence frequence frequency	01	5 45 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5	76.0
Heat Equiv. of Internal Work. $r_1$	6	863 871.5 8835.5 8855.5 8755.5 87	850.0
Heat of Vaporiza- tion. B. T. U.	8	1091.7 1058.3 1058.3 1028.1 1015.3 1007.2 1000.8 979.0 979.1 975.1 965.1 965.1 965.5 956.6 956.6 956.6 956.6 956.6 956.6 956.6 956.6 956.6 956.6	932.6
Heat of Liquid. q	7	4800 4800 4800 4800 4910 4910 400 400 400 400 400 400 400 4	228.4
Total Heat, A	9	1091.7 11136.3 11136.3 11136.3 1123.5 11231.5 11240.9 1144.9 1144.9 1144.9 1144.9 1144.9 1144.9 1144.9 1144.9 1144.9 1144.9 1144.9 1144.9 1144.9 1144.9 1144.9 1145.5 1155.1 1155.1	1161.0
Weight of 1 cu. ft. in Pounds.	5	.00030 .00158 .00158 .00576 .00576 .00107 .01107 .01107 .02561 .01107 .02561 .03355 .03355 .033555 .033555 .033555 .033555 .033555 .04067 .04067 .04067 .04067 .05796 .05796 .05796 .05796 .05796 .05796 .05796 .05796 .05796 .05796 .05796 .033555 .033555 .033555 .033555 .0335555 .03355555 .033555555 .0335555555555	.08508
Volume of 1 pound in Cu. Feet.	4	3336 3346.8 334.68 334.68 173.56 73.22 73.22 73.22 73.22 73.22 24.59 26.42 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 26.42 27.79 27.	11.75
Tempera- ture, Degrees Absolute,	3	492.70 542.70 5540.97 586.97 602.32 602.32 653.95 653.95 653.95 652.68 653.95 672.70 672.70 672.70 672.70 672.70 672.70 672.70 672.70 672.70 672.70 672.70 672.70 672.70 672.70 672.70 677.02 6	719.89
Tempera- ture, Degrees Fahr.	2	32 80 1010 1110 1110 1110 1110 1110 1110	259.19
Pressure above Vacuum in Pounds per Sq. Inch.	-	00.00 0.	35

20б

Pressure in Pounds by Gauge.	-	24.3	30.3	35.3	40.3	45.3	50.3	55.3	60.3	61.3	62.3	63.3	64.3	65.3	66.3	67.3	68.3	69.3	70.3	71.3	72.3	73.3	74.3
Entropy of Vapor. φs	12	1.6657	I.6564	I.6480	I.6404	I.6339	1.6275	1.6218	I.6165	1.6156	I.6144	1.6135	1.6126	1.6116	1.6106	1.6097	1.6087	I.6078	1.6069	I.6067	I.6052	1.6043	I.6033
Entropy of Liquid. $\phi_w = \theta$	=	. 3921	.4020	.4109	1914.	.4267	.4337	.4402	.4464	.4476	.4487	.4499	.4511	.4522	-4534	.4545	.4557	.4568	-4579	.4590	.4601	.4612	.4622
Heat Equiv. of External Work. $\frac{\rho u}{778}$	0	76.7	77.2	7.77	78.2	78.6	79 0	79.4	7.9.7	79.8	79.9	79.9	80.0	80.I	80.I	80.2	80.3	80.3	80.4	80.4	80.5	80.5	80.6
Heat Equiv. of Internal Work.	6	850.3	844.8	839.7	834.9	830.7	826.5	822.7	819.I	818.4	817.6	817.0	816.3	815.5	814.9	814.2	813.4	812.8	812.I	811.5	810.8	810.2	809.5
Heat of Vapozira- tion. B. $T$ , U.	8	927.0	922.0	917.4	913.1	909.3	905.5	902.1	898.8	898.2	897.5	896.9	896.3	895.6	895.0	894.4	893.7	893.1	892.5	891.9	891.3	840.7	890.1
Heat of Liquid. q	7	236.4	243.6	250.2	256.3	261.9	267.2	272.2	276.9	277.8	278.7	279.6	280.5	281.4	282.3	283.2	284.I	285.0	285.8	286.7	287.5	288.4	289.2
Total Heat. A	9	1163.4	1165.6	1167.6	1169.4	1171.2	1172.7	1174.3	1175.7	0.0711	1176.2	1176.5	1176.8	0.7711	1177.3	1177.6	1177.8	1178.1	1178.3	1178.6	1178.8	1.79.1	1179.3
Weight of r cu. ft. in Pounds.	5	.09644	.1077	.1188	.1299	. 1409	.1519	. 1628	.1736	.1757	.1779	.1801	.1822	.1843	.1865	.1886	.1908	. 1930	.1951	. 1973	.1994	. 2016	.2037
Volume of 1 pound in Cu. Feet.	4	10.37	9.297	8.414	7.696	2.096	6.583	6.144	5.762	5.691	5.621	5.554	5.488	5.425	5.362	5.301	5.240	5.182	5.125	5.069	5.014	4.961	4.909
Tempera- ture, Degrees Absolute.	3	727.83	734.99	741.55	747.59	753.21	758.47	763.41	768.08	768.98	769.88	770.76	771.64	772.50	773.36	774.21	775.06	775.89	776.72	777-54	778.35	779.15	779.95
Tempera- ture, Degrees Fahr,	2	267.13	274.29	280.85	286.89	292.51	297.77	302.71	307.38	308.28	309.18	310.06	310.94	311.80	312.66	313.51	314.36	315.19	316.02	316.84	317.65	318.45	319.25
Pressure above Vacuum n Pounds Per Sq. Inch.	-	40	45	50	55	3	65	70	75	26	17	78	79	80	81	.82	83	84	22	86	87	88	68

Pressure in Pounds by Gauge.	-	75.0 775.3 770.3 770.3 770.3 85.0 85.0 85.0 125.0 135.0	150.0 160.0 170.0 175.0	180.0 185.0 190.0
Entropy of Vapor, \$\$\$	12	1.6027 1.6018 1.6009 1.6009 1.5992 1.5944 1.5944 1.5842 1.5842 1.5842 1.5597 1.5597	1.5581 1.5538 1.5538 1.5518 1.5408	1.5410 1.5435 1.5435 1.5426 1.5410
Entropy of Liquid. $\phi_w = \theta$	=	.4633 .4643 .4653 .4653 .4653 .4673 .4673 .4733 .4738 .4738 .4738 .4738 .4738 .4738 .4738 .4738 .4738 .47788 .47788 .47788 .47788 .47788 .47788 .47788 .47788 .47788 .477888 .477888 .4778888 .4778888 .477888888 .4778888888888	.5230 .5290 .5319 .5347 .5347	.5429 .5429 .5454
Heat Equiv. of Work.	0	800.77 800.77 80.98 80.98 80.9 80.19 80.19 80.19 80.19 80.19 80.19 80.10	83.6 83.8 83.9 84.0 84.1	84.2 84.3 84.5 84.5
Heat Equiv. of Internal Work.	6	808 808.3 808.3 805.4 805.4 805.8 805.8 805.8 7099.9 7099.9 7091.4 7001.4 7001.4 7001.4 7001.4 7001.4 7001.4 7001.4 7001.4 7001.4 70010	772.0 768.2 766.4 764.6 762.0	761.1 759.5 757.8 756.2
Heat of Vaporiza- tion. B. T. U.	8	889.0 8889.0 8887.9 8887.9 8886.7 8884.0 8867.3 8571.3 8571.3 8571.3 8557.3 8557.3 8557.3	855.6 852.0 850.3 848.6 847.0	845.3 843.8 842.2 840.7
Heat of Liquid. q	7	290.0 290.8 291.6 291.6 293.2 293.2 293.2 293.2 293.2 293.2 293.2 293.2 293.2 308.7 308.7 321.4 321.4	338.0 343.0 345.4 345.4 348.2 348.2	352.4 354.6 356.8 358.9
Total Heat. A	9	1179.6 1179.8 1180.0 1180.5 1180.5 1180.5 1185.0 1185.0 1185.0 1185.0 1188.7 1188.7	1193.6 1195.0 1195.7 1195.7 1196.4	1197.7 1198.4 1199.0 1199.6
Weight of z cu. ft. in Pounds.	5	.2058 .2080 .2080 .21121 .2114 .2114 .2114 .2114 .2114 .2589 .2589 .2589 .2589 .2589 .2578 .2711 .22711 .2278 .22711 .2278 .22711 .2278 .22778 .227778 .22778 .22778 .22778 .22778 .227778 .227778 .22778 .22778	.3635 .3841 .3841 .3945 .4049	.4257 .4359 .4359 .4461
Volume of 1 pound in Cu. Feet.	4	4.858 4.7760 4.7760 4.615 4.615 4.615 3.328 3.323 3.211 3.211 3.211	2.751 2.603 2.535 2.470 2.408	2.349 2.294 2.241 2.190
Tempera- ture, Degrees Absolute.	3	780.74 781.53 781.53 781.53 781.53 781.53 781.53 788.28 791.83 791.83 791.83 801.75 810.73 813.955 813.955	826.58 831.35 833.67 835.93 838.14	840.31 842.43 844.52 846.57
Tempera- ture, Degrees Fahr.	2	320.04 322.37 322.37 322.37 323.14 323.14 323.58 337.58 357.58 35	365.88 370.65 372.97 375.23 377.44	379.61 379.61 381.73 383.82 385.87
Pressure above Vacuum n Pounds per Sq. Inch.	-	90 91 93 93 94 94 95 11 135 11 135 150 150	165 175 180 185 190	195 200 205 210

Pressure in Pounds by Gauge.	-	200	210	225	235	245	255	265	275	285	335*	385	435	485	535	585	685	785	885	985	unity.
Entropy of Vapor.	12	I.5393	I.5363	I.5319	I.5292	I.5264	I.5239	I.5215	1.5193	1.5171	I.4923	I.4853	I.4754	1.4728	I.4663	1.4609	I.4485	I - 4393	I.4328	I.4278	sumed to be
Entropy of Liquid. $\phi_w = \theta$	=	· 5504	.5553	.5021	.5665	.5707	.5748	.5787	.5820	.5863	.58781	.6043	.6152	.6313	6119.	.6523	.6678	.6831	1869.	.7129	res, and as
Heat Equiv. of Work. $\frac{pu}{778}$	0	84.6	84.7	84.9	85.0	85.2	85.2	85.3	85.4	85.4	85.8	86.4	86.7	87.I	87.3	87.7	88.1	88.2	88.3	88.8	temperatu
Heat Equiv. of Internal Work. $r_1$	6	754.6	751.6	747.3	744.5	741.7	739.2	736.7	734.3	732.0	721.7	711.5	702.4	603.9	686.2	678.6	665.2	653.2	642.3	631.5	wn at these
Heat of Vaporiza- tion. B. T. U.	æ	839.2	836.3	832.2	829.5	826.9	824.4	822.0	819.7	817.4	807.5	797.9	789.1	781.0	773.5	766.3	753.3	741.4	730.6	720.3	fic not know
Heat of Liquid. q	7	361.0	365.1	371.0	374.7	378.4	381.9	385.3	388.6	391.9	406.3	<sub>°</sub> 419.8	432.2	443.5	454. I	464.2	482.4	498.9	514.0	528.3	ible. Speci
Total Heat. λ	9	1200.2	1201.4	1203.2	1204.2	1205.3	1206.3	1207.3	1208.3	1209.3	1213.7	1217.7	1221.3	1224.5	1227.6	1230.5	1235.7	1240.3	1244.7	1248.7	† Not relia
Weight of 1 cu. ft. pounds.	5	.4669	.4876	.5186	.5393	.5601	.5809	. 6020	.6220	.6440	.7545	.8572	9595	I.0620	I.1640	1.2660	I.4700	0170.1	I.8780	2.0820	
Volume of 1 pound in Cu. Feet.	4	2.142	2.051	I.928	I.854	I.785	1.722	1.662	1.607	I.554	I.325	1.167	1.042	0.942	0.859	067.0	0.680	0.597	0.532	0.480	350 pounds.
Tempera- ture, Degrees Absolute.	3	848.58	852.49	858.II	861.69	865.17	868.55	871.82	875.02	878.12	892.70	905.60	917.30	928.10	938.20	947.60	964.80	980.30	994.40	1007.50	bles above
Tempera- ture, Degrees Fahr.	2	387.88	391.79	397.41	400.99	404.47	407.85	411.12	414.32	417.42	432.0	444.9	456.6	467.4	477.5	486.9	50.4. I	519.6	533-7	546.8	n Buel's Ta
Pressure above Vacuum in Pounds per Sq. Inch.	-	215	225	240	250	260	270	280	290	300	350*	400	450	500	550	600	200	800	006	1000	* Frot

295 LIL 07 177

UNITE

factor, since its value at these higher pressures has not been fixed.

The columns after No. 5 have been calculated as follows:

$$\lambda = 1091.7 + 0.305(t - 32);$$

$$q = 1 + 0.00004t + 0.000009t_{2} \text{ in centigrade units,}$$

$$reduced \text{ to Fahr.};$$

$$r = \lambda - q = \text{Col. } 6 - \text{Col. } 7;$$

$$r_{1} = r - \frac{pu}{778} = \text{Col. } 8 - \text{Col. } 10;$$

$$\text{Col. } 10 = (\text{Col. } 1 \times 144) \times \text{Col. } 4 \div 778;$$

$$\text{Col. } 11 = \text{Spec. } \text{Ht.} \times \text{Hyp } \text{Log } \frac{T}{T_{0}};$$

$$\text{Col. } 12 = \frac{\text{Column } 8}{\text{Column } 3} + \text{Column } 11; \text{ or } \phi_{s} = \frac{L}{T} + \phi_{w}.$$

137. Saturated Vapor Pressures and Temperatures for Media other than Steam.—In the Comptes Rendus of the Academie des Sciences, Tome xxxvi, will be found the formulæ elaborated by Regnault to express the relations between temperature centigrade and pressure by mercury-column for other vapors such as alcohol, ether, chloroform, carbon bisulphide, and carbon tetrachloride, all of which have attracted experimenters who have wished to replace the vapor of water by another medium (see also Chapter XXI). His equations and constants are given in the following table:

Quantity.	Alcohol.	Ether.	Chloroform.	CS2	CCl4.			
	$a - ba^{n} + c\beta^{n}$ 5.4562028 $\bar{1}.99708557$ 4.9809960 $\bar{1}.9409485$ 0.0485397 t + 20 - 20, + 150°	$a + ba^{n} - c\beta^{n}$ 5.0286298 0.0145775 0.0002284 1.996877 3.1906390 t + 20 - 20°, + 120°	$\begin{array}{c} a - ba^n - c\beta^n \\ 5.2253893 \\ \overline{1.9974144} \\ 2.9531281 \\ \overline{1.9868173} \\ o.0668673 \\ t - 20 \\ + 20^\circ, + 164^\circ \end{array}$	$\begin{array}{c} a - ba^{n} - c\beta^{n} \\ 5.4011662 \\ 1.9977628 \\ 3.4405663 \\ 1.9911997 \\ 0.2857386 \\ t + 20 \\ - 20^{\circ}, + 140^{\circ} \end{array}$	$a - ba^{n} - c\beta^{n}$ 12.0962331 1.0907120 9.1375180 1.0949780 1.9649780 t+20 - 20°, + 188°			

PRESSURE OF SATURATED VAPORS.

138. Total Heat of Steam.—In the case of a hot liquid and its vapor, there will be a certain amount of heat resident in the liquid which has been required to raise it to the point at which the vapor forms at that pressure; there will be, furthermore, the heat represented by the internal work of disgregation of the particles of liquid to change its state to vapor (§ 111) and the heat which has disappeared in overcoming the external pressure. The usual expression for this sum (which is called the total heat of the vapor) is counted from the freezing-point of water, and for a unit of weight is the heat required to raise that weight of water from freezingpoint to a given temperature, and evaporate it completely into steam at that temperature. Science is indebted also to Regnault's investigations for the accepted expression for this total heat, which has the form

$$\lambda = A + Bt,$$

in which the constants in centigrade units give

$$\lambda = 606.5 + 0.305t;$$

and in Fahrenheit scales

$$\lambda = 1091.7 + 0.305(t - 32^{\circ}).$$

For the same other vapors as in the preceding paragraph, Regnault's figures for the total heat are, for

Ether ......  $\lambda = 94 + 0.45t - 0.00055556t^2$ Chloroform.....  $\lambda = 67 + 0.1375t$ CS<sub>4</sub>......  $\lambda = 90 + 0.14601t - 0.0004123t^2$ CCl<sub>4</sub>......  $\lambda = 52 + 0.14625t - 0.000172t^2$ Aceton......  $\lambda = 140.5 + 0.36644t - 0.000516t^2$ 

139. Heat of the Liquid.—If the specific heat of water be considered unity at all ranges of temperature, the heat of the

liquid water would be the same as its range above freezingpoint for each pound. At lower temperatures, the specific heat is unity. Regnault found that from 0° to 100° C. it was 1.005 and from 0° to 200° it was 1.016. Assuming an equation of the form

$$q = \mathbf{I} + At^2 + Bt^3,$$

and finding the values for the constants by aid of known observed values of q, the usually accepted equation results:

$$q = t + 0.00002t^2 + 0.000003t^3.$$

This can be used to work back to the specific heat by the methods of the calculus, since the differential of the value of q taken with respect to the temperature will be the heat required to produce this differential change, which is the specific heat; or

$$C = \frac{dq}{dt} = 1 + 0.00004t + 0.0000209t.$$

As before, the heat of the liquid for the other vapors investigated by Regnault gives values for q as follows:

# HEAT OF THE LIQUID q.

Alcohol	$0.54754t + 0.0011218t^{3} + 0.000002206t^{3}$
Ether	$0.52901t + 0.0002959t^2$
Chloroform	$0.23235t + 0.0000507t^2$
CS2	$0.23523t + 0.0000815t^2$
CC14	$0.19798t + 0.0000906t^2$
Aceton, C <sub>3</sub> H <sub>6</sub> O	$0.50643t + 0.0003965t^2$

140. Heat of Vaporization. Internal Latent Heat.— It is made apparent from the foregoing that if the heat of the liquid be subtracted from the total heat, the remainder will be the heat absorbed in the vaporization process. If this be designated by the symbol r

$$r = \lambda - q$$
.

It may be seen, however, that r is really made up of the sum of two quantities. One is the internal latent heat, or heat of disgregation, and the other is the heat equivalent to the work done by a unit liquid volume expanding into vapor volume u against a pressure p. If then  $r_1$  denote the excess of the heat in units of heat which is contained in the vapor over the heat contained in the unit of weight of the water at  $32^{\circ}$  F. from which the vapor was produced, the above equation can be written

$$\lambda = q + r_1 + \frac{pu}{778},$$

since the last term will express the heat which has been expended in increasing the volume from a smaller bulk s to a larger bulk  $\sigma$ , which we may call U, and overcoming the pressure P which must be constant during the evaporation.

An empirical formula in the French system for  $r_1$ , proposed by Zeuner, gives the following values, which are fairly approximate:

INTERNAL LATENT HEAT  $r_1$ .

Water	575.40 - 0.791 <i>t</i>
Ether	$86.54 - 0.10648t - 0.0007160t^{2}$
Chloroform	$62.44 - 0.11282t - 0.0000140t^2$
CS <sub>2</sub>	$82.79 - 0.11446t - 0.0004020t^2$
CC14	$48.57 - 0.06844t - 0.0002080t^2$
Aceton	$131.63 - 0.20184t - 0.0006280t^2$

141. Specific Volume of Hot Liquids.—For the accepted data concerning the increase of volume of the liquid which expands by heat (although much less than the expansion in change of state) the best values are those given by Hirn in the Annales de Chimie et de Physique for 1867, as the result of experiments using the liquids in question as the registering medium as in a thermometer. Usually the expansion of the liquid in connection with its vapor can be neglected in comparison with the expansion of the vapor, without detectable

error. Or, in other words, the value for  $\sigma$  is considered to be constant. Hirn's data are as follows:

SPECIFIC VOLUMES OF HOT LIQUIDS.

Water, 100° C. to 200° C. (Vol. at $4^\circ = unity.$ )	$v = \mathbf{i} + 0.00010867875t. + 0.0000030073653t^{9} + 0.00000028730422t^{3} - 0.000000000066457031t^{4}$	Logarithms. 6.0361445 — 10 4.4781862 — 10 1.4583419 — 10 8.8225409 — 20
Alcohol, 30° C. to 160° C. (Vol. at $0^\circ = unity.$ )	$v = \mathbf{I} + 0.00073892265t + 0.00001055235t^2 - 0.000000092480842t^3 + 0.00000000040413567t^4$	$\begin{array}{r} 6.8685991 \longrightarrow 10\\ 3.0233492 \longrightarrow 10\\ 2.9660517 \longrightarrow 10\\ 0.6065278 \longrightarrow 10\\ \end{array}$
Ether, 30° C. to 130° C. (Vol. at o° = unity.)	$v = \mathbf{i} + 0.0013489059^{\prime} + 0.0000065537^{\prime} + 0.00000034400756^{\prime} + 0.000000034400756^{\prime} + 0.0000000033772062^{\prime}$	$\begin{array}{rrrrr} 7.1299817 &10 \\ 4.8164866 &10 \\ 2.5377028 &10 \\ 0.5285571 &10 \end{array}$
Carbon Bisulphide, 30° C. to 160° C. (Vol. at $0^\circ = unity.$ )	$v = \mathbf{I} + 0.0011680559t + 0.0000016489598t^{2} - 0.0000000081119062t^{3} + 0.00000000060946589t^{4}$	7.0674636 — 10 4.2172103 — 10 0.9091229 — 10 9.7849494 — 20
Carbon Tetrachloride, 30° C. to 160° C. (Vol. at o' = unity.)	$v = 1 + 0.0010671883t + 0.000035651378t^{9} - 0.000000014949281t^{3} + 0.0000000085182318t^{4}$	$\begin{array}{r} 7.0282409 - 10 \\ 4.5520763 - 10 \\ 2.1746202 - 10 \\ 9.9303494 - 20 \end{array}$

142. Critical Temperature.—Computations made by the foregoing formulæ (§ 141) show that the internal latent heat of vapors  $(r_i)$  decreases as the temperature rises, since the terms containing the temperature as a factor act to diminish the value of the constant for each vapor. There must be a temperature therefore for each vapor at which  $r_i$  will become zero for that vapor, or, in other words, a temperature at which there is no internal work done in disgregating the particles of the medium, but at which it behaves as a perfect gas. The distinction between the liquid and its vapor has disappeared, and it would be correctly inferred that above this temperature, pressure alone—without a concurrent lowering of temperature—would not liquefy the vapor or gas. This temperature at which the value for  $r_i$  or the internal latent

214

 $\sigma =$ 

heat disappears has been called the critical temperature for any vapor; and it has been wisely advocated to use the term gas for a vapor above its critical temperature, while below that temperature it is a vapor.

The accepted determinations so far have been those of Avenarius (Poggendorff's Annalen, vol. 151, 1874), in which volatile liquids were heated in strong glass sealed tubes until the liquid all disappears and the tube is full of gas. His experiments, compared with the computations based on Regnault's experiments from equations deduced for the internal latent heat, give the following:

#### TABLE OF CRITICAL TEMPERATURES.

	Experiment.	Calculation.
Ether	. 196.2 C.	196.8 C.
CS,	. 276.1	274
CC1,	. 292.5	298.7
Aceton	. 246.1	230.4

The critical temperature for water as calculated from Zeuner's formula is 720° C. (1328° F.), which is beyond the present limits of experiment.

143. Increase of Entropy of a Liquid and its Vapor.— It is usual in considering liquids with their vapors to treat of a unit of weight, from which a portion x is raised from liquid to vapor. Hence I - x is the weight of liquid, and  $I \times x$ = x is the weight of vapor. If such unit of weight of liquid is raised from freezing-point to a temperature t, and the part x is evaporated at that temperature, the increase of entropy will take place in two stages, and the total increase will be their sum. The heat of the liquid portion is determinable from the Regnault experiments and data given in § 139 as denoted by q, so that when t denotes the range above centigrade 0°, the increase in entropy from that at zero represented differentially by the symbol  $\frac{dq}{T}$  can be written:

$$\theta = \int_{\circ}^{t} \frac{dq}{T} = \int_{\circ}^{t} \frac{cdt}{T} = c \text{ hyp. leg } \frac{T}{T_{\circ}},$$

as foreshadowed in § 124. In this expression c is the specific heat, considered as constant for the range in question. If it is not constant, as, for instance, was made clear by Regnault in the case with water (§ 139), the entropy of the liquid is to be calculated in steps or stages from the zero-point to that desired. Referring to Regnault's experiments, the specific heat between 0° and 5° C. is 1.0072; from 5° to 10°, 1.0044; from 10° to 15°, 1.0016. This would make the entropy for a temperature between 10° and 15°—say at 13°, or 65° F., to be made up of

1.0072 hyp. 
$$\log \frac{T_{b}}{T_{0}} + 1.0044$$
 hyp.  $\log \frac{T_{10}}{T_{b}} + 1.0016$  hyp.  $\log \frac{T_{10}}{T_{10}}$   
= 0.04663.

For other liquids the data of the tables in § 139 can be used which give values for q directly. By differentiating these equations, the resulting equation has the form  $\frac{dq}{dt}$ , which gives the specific heat at the desired temperature t, since  $\frac{dq}{dt} = c$ from the derivation of equations giving values for q, as well as by definition of the terms used. So that, if ether be taken for which (§ 139)

$$q = 0.52901t + 0.0002959t^2;$$

then

$$\theta = \int_{0}^{t} \frac{dq}{T} = \int_{0}^{t} (0.52901 + .0005919t) \frac{dt}{T},$$

which becomes

.2

$$\theta = (0.52901 + .0005919t)$$
 hyp. log T.

144. Increase of the Entropy of the Vapor.—In the case of a vapor which is formed from a liquid with which it is in contact, the heat is continually added at the constant temperature at which the vapor stands or is formed. Hence the weight x of the original unit weight receives a quantity of heat q', which is represented by the heat of vaporization r, which is the difference between the total heat  $\lambda$  and the heat of the liquid q (§§ 138, 139, and 140). Hence it follows that the increase in entropy for the weight x will be represented by

The entire increase in entropy will be therefore the sum of

 $\frac{xr}{T}$ .

 $\theta + \frac{xr}{T} = \frac{xr}{T} + \int_{0}^{t} \frac{cdt}{T},$ 

as was explained in § 124.

The convenient approximation is also to be remembered in the absence of tables or formulæ for  $\theta$ , the entropy of the liquid, whereby the specific heat is assumed to be constant; so that

$$\theta_1 - \theta_2 = c \int \frac{dt}{T} = c$$
 hyp. log  $\frac{T_1}{T_2}$ ;

whence for adiabatic relations, and  $\phi - \phi_2 = 0$ ,

$$\frac{x_1r_1}{T_1} + \theta_1 = \frac{xr}{T} + \theta$$

can be written

$$\frac{x_2 r_2}{T_2} = \frac{x_1 r_1}{T_1} + c \text{ hyp. } \log \frac{T_1}{T_2},$$

in which  $x_2$  is the unknown quantity for which the equation is to be solved.

145. Superheated Steam, Total Heat of.—Superheated steam has been already defined (§ 119). The total heat of such superheated steam is therefore that due to the increase of its temperature considered as a gas by the addition of the sensible degrees of temperature above that total heat which it had as a saturated vapor, as given in § 138. The formula for the total heat, when the sensible temperature of saturation at any pressure is t and the superheat temperature is  $t_a$ becomes for Fahrenheit units:

$$\lambda = 1091.7 + 0.305(t - 32) + c(t_2 - t).$$

The value of c, or the specific heat of steam becomes at once of significance.

146. Specific Heat of Steam.—It is obvious that there will be a difference in the specific heat of steam at constant pressure and at constant volume, as is the case with all gaseous media, but furthermore it would be expected that there would be a different specific heat for constant pressure at or near the saturation-point from that prevailing when the steam is superheated to a degree permitting considerable cooling before condensation to liquid began.

Regnault's accepted value for the specific heat of superheated steam at constant pressure is

$$c_{p} = 0.4805,$$

which is the mean of three determinations, giving

0.48111, 0.47963, 0.48080.

The specific heat of saturated steam has to be more definitely defined to secure exactness, by stating that it is the

quantity of heat which must be added to one unit o weight of steam, when the temperature is raised one degree and the pressure increased the corresponding amount while the steam remains dry and saturated under this change. It will appear, therefore, that the specific heat of a dry and saturated vapor is not exactly like either of the others, as the condition of saturation imposed compels a change of both pressure and volume to maintain the imposed equilibrium. The accepted statement for the value of the specific heat of saturated steam has therefore the form

$$C=0.305-\frac{r}{T}.$$

147. Negative Specific Heat of Saturated Steam.— If the foregoing equation be solved for C, by means of the relations  $r = \lambda - q$ , and the values for  $\lambda$  and q already given (§§ 138 and 139) for several temperatures, it will result that within usual limits of practice the specific heat C comes out negative. For example:

At	٥°	C.	or	32°	Fahr.,	С	=		1.911
" "	50	"	"	100	" "	С	=		1.461
"	100	" "	" "	212	" "	С	=		1.131
" "	150	" "	"	300	" "	С	=	—	0.879
" "	200	"	" "	392	" "	С	=		0.676

It will be apparent that the value for C is approaching a point of inversion at which it will be zero and beyond which it will become positive, as for many of the other heat media, such as ether. This point, however, is beyond present experimental knowledge. The negative value within experience means that when temperature and pressure are increased together, the steam will become superheated unless heat is abstracted by doing work. Or, in other words, a sudden expansion or drop of pressure, if accompanied also with a

drop of temperature, causes a part of the steam to be con-The heat freed by the condensation of that weight densed. which is condensed serves to keep the uncondensed part in the required state-of saturation under the changed conditions. This was shown experimentally by Hirn (Bulletin de la Société Industrielle de Mulhouse, tome 133). This is quite different from the condition discussed in § 131, in which the temperature was assumed to be maintained at the point belonging to the higher pressure, while the pressure fell. The negative specific heat of steam acts in an unjacketed and conducting cylinder to increase the cylinder condensation, since the pressure is falling and heat is being withdrawn by radiation outwardly, while the piston-work is being done at the expense of the heat brought into the cylinder.

148. Specific Heat of Superheated Steam at Constant Volume.—The specific heat of superheated steam at constant volume can be calculated by means of a ratio between the two specific heats, assumed by Zeuner to be  $\frac{4}{3}$  or 1.333, whence for various pressures in pounds per square inch

or is apparent as a variable.

149. Specific Volume of Superheated Steam.—The volume of superheated steam in metric equivalents and centigrade degrees as given in the following table presents the results of experiments by Hirn. The comparison column is deduced from an equation expressed in kilograms per square meter for the volume belonging to any pressure and temperature T, which has the form in

Metric units....  $pv = 51.3T - 188p^{\frac{1}{2}};$ and in English " ...  $pv = 93.5T - 971p^{\frac{1}{2}}.$ 

When the same equation is applied near the limit or near the condition of saturation it seems to apply fairly well.
#### VAPORS AS HEAT-CARRIERS. STEAM.

Pressure in Atmosphere.	Temperature Centigrade.	Cubic Meters per Kilogram.	
		Hirn's Experiments.	Calculated Values.
I I 3 4 4 4 5 5 5	118.5 141 200 165 200 246 162.5 205	I.74 I.85 0.697 0.4822 0.522 0.5752 0.3758 0.414	1.75 1.87 0.699 0.476 0.520 0.577 0.376 0.418

SPECIFIC VOLUME OF SUPERHEATED STEAM.

150. Specific Volume of Saturated Steam.—The volume occupied by a unit weight of saturated steam has already been given in the steam-tables presented in § 136. It will be of significance to refer to experiments to determine these values. Those of Fairbairn and Tate in England (*Phil*osophical Transactions, vol. 150, p. 185, 1860) are among the most complete. Fig. 52 represents a diagram to illustrate

their method. A and B are globular vessels containing slightly varying weights of water. They are connected by a tube containing mercury, and the whole apparatus is immersed in a bath whereby any desired temperature may be given to the globular vessels and their contents. As long as any water is in either



globe the vapor in each will have the same tension, and the mercury will stand even in the two legs. There will be a temperature, however, at which the water in that vessel which has originally the least weight of water in it will become altogether vapor, in a dry and saturated state, and, if this point can be accurately observed, the density can be found from the known weight and observed volume. Beyond this point of dryness and saturation the steam in a state of complete vaporization becomes superheated by addition of heat, and the mercury will rise in the dry leg. The pressure for saturated steam at any temperature is greater than for superheated steam at that same temperature. The difficulty and uncertainty in the experiment is due to the chances of error and uncertainty in fixing on the period of complete vaporization and the corresponding temperature.

The Tate and Fairbairn formula which they deduced to represent their work is of the form

$$V = 25.62 + \frac{49513}{P + 0.72}.$$

The term V is the volume of steam compared to that of the water which produced it, and P is the pressure in inches of mercury.

This transformed to cubic feet per pound, and with p in pounds per square inch, becomes

$$V_{1} = 0.016 \left[ 25.62 + \frac{24317.5}{P_{1} + 0.365} \right].$$

Zeuner's empirical formula is

$$D=ap^{\frac{1}{n}},$$

in which a = 0.6061 and  $\frac{1}{n} = 0.9393$ . *D* is in kilograms per cubic meter, and p is in atmospheres.

151. Condensation in Adiabatic Expansion of Steam.— It will be apparent in an adiabatic expansion in which by definition the external work is being done at the expense of the intrinsic heat energy of the steam, that with the use of superheated steam a certain amount of expansion will occur before the steam becomes saturated, and that if the expansion be carried further the steam will become moist by condensation of a part of it. The equations of § 144 when applied to an actual case with the proper data will make this clear. Let a unit weight of steam  $(x_1 = 1)$  be taken at 100

### VAPORS AS HEAT-CARRIERS. STEAM. 223

pounds pressure above vacuum and let it be superheated to a temperature of  $400^{\circ}$  F.: then let it be expanded adiabatically down to atmospheric pressure. Then in the formula

$$\frac{r_1}{T_1} + \theta_1 + 0.4805$$
 hyp.  $\log \frac{T_s}{T_1} = \frac{x_2 r_2}{T_2} + \theta_2;$ 

all data are known or to be taken from tables except  $x_s$ , the final state of steam in the same unit of weight. When, therefore,

$$\theta_1 = 0.4733$$
;  $t_1 = 327.6$ ;  $r_1 = 884$ ;  
 $\theta_2 = 0.3143$ ;  $t_2 = 213.9$ ;  $r_2 = 965.1$ ;

the equation becomes

$$\frac{884}{788.3} + 0.4733 + 0.4805 \text{ hyp. } \log \frac{860.7}{788.3} = \frac{965.1x_2}{673.7} + 0.3143,$$

and there will result

 $x_{1} = 0.923,$ 

or a little less than 8 per cent of the steam has become water, in the process of expansion, in spite of the initial superheat.

If instead of  $T_s$ , or the absolute superheat temperature, the temperature of saturation had been used, the formula and calculation would show the amount of condensation to be expected from steam which is simply dry. See also Chapter XIV, § 200 et seq.

152. Evaporation from a Feed-water Temperature.— The formulæ for total heat of steam (§ 138) give the total heat counted from freezing-point of water. When the feedwater which is pumped into the boiler of a steam-engine is at some higher temperature than this, it is apparent that the coal burned in the boiler-furnace does not have to supply as much heat per pound of water evaporated as the formula would indicate. The feed-water being assumed at t' F., the total heat required to make steam at t degrees temperature becomes for each pound of water evaporated

$$Q_1 = 1091.7 + 0.305 (t - 32) - c(t' - 32),$$

or (if the specific be called unity between t and  $32^{\circ}$  F., instead of using its more exact value)

$$Q_1' = 1091.7 + 0.305 (t - 32) - (t' - 32).$$

153. Evaporation from and at 212° F.—A very convenient, practical, and useful deduction is made from the formulæ for total heat of steam (§§ 138–144) to compare the evaporative performances of steam-boilers working under different pressures. It is apparent that more heat goes into each pound of water at the higher pressures. Hence it has been agreed to reduce all conditions of feed-water temperature and evaporative temperature and pressure to the condition of a feed-water temperature of 212°, and an evaporation of the water at that temperature into steam at atmospheric pressure, with a temperature of 212°. This has been shortened into the compact expression, "Evaporation from and at 212°."

The pressure of one atmosphere is 14.7 pounds per square inch, and at 212° F., which is the corresponding boiling temperature, the heat necessary to make water at that temperature into steam at that pressure is

$$965.7 = 966 \text{ B.T.U.}$$

If, then, from the preceding paragraph, the total heat Q required to vaporize a weight of water W be observed from a test, in which the feed-water was introduced at t' and the evaporation took place into steam at t, the total heat which went into the evaporated water was the product

#### VAPORS AS HEAT-CARRIERS. STEAM. 225

If the evaporation had taken place from and at 212°, Q would have been 966 for each pound, so that

### 966x

would have been the equivalent heat absorption if x is the corresponding weight of water evaporated at that atmospheric pressure. Equating these,

$$QW = 966x$$
 or  $x = \frac{QW}{966}$ ,

gives the pounds of water which would have been evaporated from and at 212°. This may be either the total equivalent evaporation, or the equivalent evaporation per pound of coal, or per horse-power per hour, according to the unit used for W.

154. Rankine's Factor of Evaporation .- Rankine computed a table giving values for a factor,

$$F = \frac{Q}{966},$$

wherewith to multiply the quantity W to produce the desired weight X (Rankine, "Steam-engine and other Prime Movers," pp. 255, 256). His equation for F is

$$F = 1 + \frac{0.3(t_1 - 212^\circ) + (212 - t_2)}{966},$$

in which  $t_a$  is the temperature of the feed-water, and  $t_a$  the temperature at which vaporization actually took place.

155. Theoretical Evaporation of Water per Pound of Fuel.-The formula for total heat of steam under various conditions renders it possible to predict the limits of evaporative capacity with any fuel whose calorific power is known or assumed. The pounds of water evaporated per pound of fuel burned will be the same as the quotient found by dividing the total heat at that temperature into the calorific power

(§§ 22, 58, 59). For example, while with pure carbon, with a calorific power of 14,500 heat-units, the evaporation from a feed-water temperature at  $212^{\circ}$  will be

$$\frac{14500}{966} = 15$$

pounds of water per pound of carbon, as was already shown in  $\S$  59, at higher pressures, or with cooler feed-water temperatures, the value of the divisor increases while the dividend remains constant, and hence the quotient grows smaller. The effect of this is to make the maximum theoretical evaporation per pound of fuel burned less as the pressures increase at which the steam is formed.

156. Output of a Steam-boiler in Heat-units. — The product of the pounds of water evaporated by a boiler into the total heat of the steam at that pressure, as determined from the foregoing formulæ, gives the heat-units which that boiler is delivering. These may be expressed in any unit, per hour, or per boiler horse-power, or per day, or per 1000 pounds of steam delivered to engine, or in any form. The accepted boiler horse-power unit of 30 pounds of water evaporated into steam at 70 pounds pressure from a feed-water temperature of 100° is equivalent to an evaporation of 34.488 pounds of water from and at 212°. The product,

# $34.488 \times 965.7 = 33305$ heat-units,

is the heat-units per boiler horse-power from and at 212°, according to the standard of 1885 of the American Society of Mechanical Engineers. Any other similar computation can be made from the observed results of a boiler-test.

157. Efficiency of a Steam-boiler.—The efficiency of a steam-boiler as an appliance for getting the heat-units available in the fuel into the heat-carrier or medium whereby they are to be utilized would appear to be the relation between the heat-units in the output as compared with the total heat-

### VAPORS AS HEAT-CARRIERS. STEAM.

units charged into the furnace. (See § 59.) That is, if the efficiency were unity, or one hundred per cent., each pound of fuel should evaporate a weight of water W which, multiplied by its total heat in heat-units, should give a product equal to its calorific power; or,

### calorific power = $W \times Q$ .

This is the statement of § 155 reversed. The actual evaporation, however, is not W but a smaller weight W', raised to the same total heat, Q. Hence for any boiler,

efficiency =  $\frac{W' \times Q}{W \times Q} = \frac{W'}{W} = \frac{\text{actual output in heat-units}}{\text{calorific power of the fuel}}$ 

taken per hour, or per horse-power, or per pound, as may be convenient.

A comparison of actual and theoretical output in tests of modern economical boilers will show that it may claim to be a fairly efficient apparatus for its purpose.

# CHAPTER XII.

### WORK DONE BY ELASTIC HEAT MEDIA IN HEAT-ENGINES. CYLINDER DESIGN.

160. Introductory.—In the foregoing chapters the subject of heat has been discussed first from the standpoint of its generation or liberation from a fuel or combustible; and, secondly, with respect to the effects which heat produces upon a suitable medium to convey the energy of that heat to the organ or motor which is to utilize it. This chapter will discuss the action of such heat-medium exerting an effort by reason of the elastic tension which has been imparted to it by heat to produce motion of a suitable piston in a cylinder and overcome a resistance expressed in pounds exerted through a space expressed in feet.

Attention was called to the general truth in Chapter II, § 7, that a work in foot-pounds could be represented by an area equivalent to that of a rectangle whose height or altitude was proportional to pounds on any accepted scale and whose length or base was proportional to feet. The product of the base and altitude would therefore be a product expressed in foot-pounds. It will further be recalled that for a piston-engine which has a piston-area A and a length L, the work in any time in which N strokes are made in such cylinder while a product in foot-pounds represented by

$$W = PA \times LN$$
,

which becomes expressed in horse-power per minute by making N represent the number of traverses of the piston per minute, and dividing both members by 33,000, or

$$HP = \frac{PALN}{33000}.$$

It becomes necessary now, however, to take up this work-formula in more exact detail for a fuller discussion. The thermal lines discussed in \$\$ 119–125 now have a significance.

161. Work Done with Constant Pressure in the Cylinder.—Since the product AL is equivalent to the volume of the cylinder filled once, and ALN is the volume filled during N traverses or  $\frac{N}{2}$  revolutions if the engine is double-acting, it becomes apparent that AL becomes V for one traverse, and ALN is V for N traverses. It is possible, therefore, to write

$$W = PLA = PV$$

for one traverse, provided it be clearly kept in mind that Pand A must be kept in the same unit. This is most easily done by expressing P in pounds per square foot, and A in square feet. It is just as true to use pressure in pounds per square inch p, which is equal to  $\frac{P}{144}$ , provided the area a is in square inches, and a = 144A. Then

$$PLA = \frac{R \times I_{44}A \times L}{I_{44}} = paL.$$

The length L must remain in feet, in any case, which makes this latter method liable to confuse. But it is in the form

$$Work = PV$$

that the formulæ applicable to heat-engines have so far appeared.

The resistance against which the heat-motor works is supposed to be a uniform effort, expressed in pounds to be overcome through the given path. The discussion of the flywheel as a regulator or accumulator to compensate and control irregularities of the resistance is aside from the present purpose. The resistance will be assumed to be able to be kept constant.

Such resistance can therefore be represented by a rectangle, ABCD (Fig. 53), in which the horizontal is the space s, through which the resistance is overcome in one traverse of the motor-piston, and the vertical or height is proportional to the intensity f of that resistance in pounds. In order that



this constant resistance may be overcome, the cylinder of the motor must generate an equal product or area in which the horizontal shall be the volume filled by the elastic heatmedium, and the vertical is proportional to the pressure P. That is, the work in foot-pounds W = fs = ABCD of Fig. 53 must be equal to the area PV = A'B'C'D' in Fig. 54.

It is to be observed that there is an infinite number of rectangles or other figures which have the area PV = fs. The two need not have the same altitude or base, provided only their areas are the same. This represents the simplest case which occurs in tank-pumping with small pumps without fly-

wheel, where the parts are so light as to permit their inertia to be neglected, and where no excess of energy is required from the motor to cause the engine to pass its centres at the ends of each stroke so as to reverse the motion. The effort of the elastic medium is a constant effort of the same intensity and the volume generated is that which exists at the end Instead of using the stroke as the unit, the of the stroke. work of a minute might have been chosen involving N strokes. Instead of either of these, the volume might have been made that occupied by a pound weight of the medium at the constant pressure P, and the corresponding value of fs calculated back from the value of the corresponding PV. In any case one or the other of the two factors must be assumed, and the value of the other calculated to meet the case.

162. Constant Pressure-work with Air or Permanent Gases .- The condition presented by the rectangular area for PV is not considered a desirable or economical one. The difficulty is caused by the fact that at the completion of the working-stroke the contents of the cylinder must be voided to permit the piston to return to its original position against the least possible internal resistance in the cylinder itself. Hence a volume of medium V at a pressure or tension P would be wasted at each stroke. In the case of air, if it be assumed that no temperature changes occur, and the work represented by PV was put into the working medium by the doing upon it of an external work by a compressor which is equal to that same PV, then the compressed air acts exactly like incompressible water or like a solid mass to transmit the work of the compressing motor to the air-motor cylinder. A certain weight or volume of air is displaced mechanically, and in the strictest sense the transmission is not a heat-engine transaction at all. Usually, however, temperature changes do come in.

The work represented in bringing up its tension from atmospheric pressure to its working tension is thrown away at

the exhaust, because the potential energy is not exerted which it might have given out in expanding down to atmospheric pressure again. The drop in pressure takes place outside of the cylinder. The heat expended in raising the medium to the higher pressure will be a matter of later discussion.

163. Constant Pressure-work with Steam. -- In the case in which a steam-cylinder receives steam through a pipe from a boiler during the entire stroke of the piston, the engine is said to work without expansion, or non-expansively (Fig. 1). This is true in the sense that the terminal pressure and temperature of the steam at the moment when exhaust begins are the same as at the beginning, and all the heat and potential energy in the weight of steam which fills the final volume of the cylinder is voided during the exhaust. What occurs in this case is an expansion in the boiler and not in the engine. The fire or source of heat has to furnish the amount of heat represented by the total heat of steam at the pressure p, at which it works in the cylinder for each pound of steam represented in the terminal volume  $v_1$ . The data of §§ 136 and 138 enable this calculation to be made. The rejection of so much potential energy at the end of the working-stroke, which has been imparted to the medium by the heat of the fire, and which might be utilized for the doing of external work in the engine, make this method of working less economical and efficient than methods now to be discussed.

164. Work Done by an Elastic Heat-carrier Expanding in a Cylinder. Cut-off or Degree of Expansion.— It has already been made apparent (§ 112 *et seq.*, Chapter X) that the elastic tension of a heat medium is a function of its temperature or is dependent upon it. The necessity for disposing of the working-volume of the medium at the end of the stroke, and its rejection from the heat-engine proper, would at once suggest the advisability (if it were possible to secure this result) of making the elastic heat-carrier surrender

all the heat energy which could be gotten from it before it leaves the cylinder. This implies the maximum lowering of its temperature and pressure, which is wise to demand, within the cylinder itself, and after the disconnection of the required weight of medium from its source of heat. Hence the principle is availed of which is expressed mathematically by the equation,

$$p_1v_1 = pv = RT$$

for isothermal expansion; or the expression,

$$p_1 v_1^n = p v^n = \text{constant}$$

for an adiabatic expansion. As applied in a practical way, this means that if the elastic heat-carrier be admitted from the heating-appliance to fill a small volume  $v_1$ , and then that volume is increased up to the final volume represented by the entire piston-displacement in one stroke (or v), the final or terminal pressure will be as much lower than the initial pressure as the final volume was greater than that filled by the medium while it was flowing into the cylinder from the outside reservoir of pressure. With the non-condensable media, it is therefore desirable that the terminal pressure should be that of the atmosphere surrounding the cylinder if the exhaust takes place in the open air, unless some practical considerations should give another consideration greater weight, which is hereafter to be discussed. In condensing engines (Chapter IX) a similar theory would demand that the terminal pressure might be that of the vessel into which the exhaust takes place-which latter expression can be made generally applicable, subject only to the limitations to be hereafter im-The heat-carrier thus carries out of the cylinder the posed. minimum amount of available energy.

This principle of working the heat medium so as to make it expand to a larger volume and lower pressure, and do work against the resistance in thus expanding, is secured in

practice by cutting off the admission of the medium at a designated point in the stroke of the piston. The point where admission of heat-medium and heat-units to the workingcylinder ceases is called the point of cut-off, and is expressed as a fraction of the entire piston-stroke as unity. In a cylinder of uniform section the volume filled up to the point of cut-off of the admission will bear the same relation to the final volume at the end of the stroke as the ratio of the lengths of the stroke bear to each other. Volumes and lengths can therefore be used indifferently.

The final volume of the elastic medium will be to the volume present when cut-off took place in a ratio which is the reciprocal of the fraction expressing the point of cut-off. That is, the degree of expansion, or the ratio of expansion, will be 2 for a cut-off at one half stroke, since the final volume will be twice that present when cut-off occurred. This distinction must be carefully observed lest confusion occur. In using cut-off terms, the final volume is the denominator and the cut-off volume is the numerator; in handling the ratio of expansion or the number of expansions which is usually designated by r and is a number greater than unity, the final volume is the numerator and the cut-off volume the denominator.

In handling expansions in non-conducting cylinders, where the working medium gets no heat from outside, but expends its own heat energy in doing work with the piston, its temperature may drop inconveniently in expanding down to the pressure prevailing in the space into which it exhausts. Furthermore, it will be apparent that a lowering of the final pressure must be accompanied with a less amount of forward effort at the end of the stroke than at the beginning, and hence a larger piston-area is required than for the constant value of the pressure. This means a bulkier and probably heavier engine, and more fly-wheel mass to compensate the irregular effort. It will be seen, therefore, that it may not be desirable

to carry the lowering of pressure to the practicable limit in actual cases. This further opens the question of the considerable potential energy rejected from a heat-motor with its rejected medium, because of the impossibility of capturing it for use. These will be referred to later in a different connection.

165. Work of a pv Diagram Represented by an Area. —It has been already said that the work of a piston-engine could be represented by the area of a diagram (§ 7). Let Fig. 61 represent such a pv diagram, in which v, is the



#### FIG.61.

volume filled at cut-off and  $v_2$  is the final volume, while the vertical ordinates reproduce the pressures prevailing at each point of the piston-stroke. If this is a pv diagram from an actual engine v while variable is yet known, and the problem resolves itself into finding a value for the varying p which shall be a mean value for that stroke, whereby the effort of the medium can be equated to the mean value of the resistance during the same period. The inequalities of the varying value for p in each stroke can be provided for by the flywheel, and must be so taken care of. If the mean value of p is too small, the engine will slow down until the diminished distance through which the resistance is moved restores equilibrium. If p is too large for the mean resistance, the engine accelerates its speed until the greater space per minished distance through which the greater space per minished end to the space per minished distance through until the dimension of the mean resistance, the engine accelerates its speed until the greater space per minished distance through which the resistance is moved restores equilibrium. If p is too large for the mean resistance, the engine accelerates its speed until the greater space per minished distance through which the resistance is moved restores the engine accelerates its speed until the greater space per minished distance through which the space per minished distance through which the resistance is moved restores equilibrium. If p is too large for the mean resistance, the engine accelerates its speed until the greater space per minished period.

ute for the resistance balances the excess of effort, or the internal resistances of the motor itself supply the excess of resistance. It is from the governor of the engine that a proper control of the mean effort must be expected.

The area of the pv diagram, as determined by observation or otherwise as to its bounding curves, will give a figure expressing a number of square inches or square feet. If this number be divided by the measured length, the quotient will be the height of an equivalent rectangle having the same length. This value for the mean pressure (called p) can be substituted in the formula,

$$HP = \frac{p_m LAN}{33000},$$

in which A, L, and N are taken from the actual case.

The area of the pv diagram can be found by dividing it lengthwise into conveniently short portions, and taking the area of each portion and making a summation of the fractional areas. If the number of areas be made ten, their bases being of equal length, the sum of their mean heights divided by ten (displacing the decimal point one place to the left), gives the mean height of the diagram as a whole. If a planimeter is at hand, the area is determined directly within the error of that instrument.

To apply Simpson's rule for determining an area the diagram is divided vertically by n ordinates. The first one is called  $p_o$  and the last one  $p_n$ . Then the area A is given by the formula:

$$A=\frac{1}{n}l(\frac{p_0+p_n}{2}+p_1+p_2\ldots p_{n-1}),$$

when l is the measured length. Dividing this area by the length l, the mean pressure p results; or,

$$\frac{A}{l}=pm=\frac{1}{n}\Big(\frac{p_0+p_n}{2}+p_1+p_2\cdots p_{n-1}\Big).$$

If the expulsion of the working medium used in the preceding stroke exerts a negative pressure upon the piston on its working stroke, then the pressure ordinates cannot be measured from a zero line of no pressure. The working diagram representing the effective pv area is displaced upward above the horizontal reference line of zero pressure (Fig. 62). The value of that constant back pressure  $p_{i}$  must



be subtracted from the mean forward pressure  $p_m$ , making the effective pressure  $p_e = p_m - p_s$ . Or the subtraction may be made by scaling the values for  $p_o$  to  $p_n$  from the back-pressure line instead of the zero-pressure line. The planimeter also gives  $p_e$  directly.

It is apparent that the steam-engine indicator draws a  $\rho v$  diagram from which the mean effective pressure usually designated M.E.P. is one of the primary deductions. A calibrated spring equilibrating the pressure in the cylinder against a piston of known area can be made to compel a pencil or tracing-point to draw a diagram giving the values for  $\rho$  and  $\rho$ , at each point of the stroke of the engine-piston.

166. Work of an Elastic Heat Medium Expanding Isothermally.—The foregoing discussion applies to any pv diagram bounded by any curves. If the special case be assumed of an expansion according to the isothermal law in a cylinder of highly conducting material through which heat from outside

may be supplied to the working medium as it requires it in expanding, certain simple rules of procedure derived from the calculus enable the area of the pv diagram or the mean pressure  $p_m$  to be foretold when the value of the initial pres-

sure is given, and the ratio  $\frac{v_1}{v_2}$ .

In Fig. 63 the total work represented by the diagram is the sum of the areas of the rectangle ABCD equal to  $p_i v_i$ , and the curved portion BEC bounded on its upper side by an





equilateral hyperbola BE, if the expansion-curve is an isothermal curve in which  $p_1v_1 = p_2v_2$ . The work  $W_1$  of the rectangular part is obviously  $p_1v_1$ . The work  $W_2$  of the hyperbolic part will be expressed by the differential equation,

$$W_{a} = \int_{v_{a}}^{v_{1}} p dv = p_{1} v_{1} \int_{v_{a}}^{v_{1}} \frac{dv}{v_{1}},$$

since  $p_1v_1 = pv$ , and  $p_1v_1$  is not a variable.

The integration of that expression by the methods of the calculus between the limits  $v_1$  and  $v_2$  gives

 $W_1 = p_1 v_1$  hyp. log  $v_1 - p_1 v_1$  hyp. log  $v_1$ ;

or

$$W_2 = p_1 v_1 \text{ hyp. } \log \frac{v_2}{v_1}.$$

-/-

The total work is the sum of the two portions:

$$W_{1} + W_{2} = p_{1}v_{1} + p_{1}v_{1} \text{ hyp. } \log \frac{v_{2}}{v_{1}}$$
$$= p_{1}v_{1}(1 + \text{ hyp. } \log r),$$

since the ratio of expansion r is the same as  $\frac{v_2}{v}$ .

If the foregoing expression for work is the area of the pv diagram, the mean value for  $p_m$  will be found by dividing through both members by  $v_a$ , the known length of the stroke or final volume of the cylinder. Hence

$$p_m = \frac{W}{v_2} = \frac{p_1 v_1}{v_2} (1 + \text{hyp. log } r).$$

But

$$\frac{v_1}{v_2}=\frac{1}{r}.$$

Hence, the mean pressure becomes

$$p_m = p_1 \Big( \frac{1 + \text{hyp. } \log r}{r} \Big),$$

from which the pressure to be inserted in the horse-power formula can be calculated from any assumed initial pressure in boiler or pressure reservoir, when the effects of clearance and compression are not considered, and the expansion is isothermal. If there is a back pressure  $p_i$  it must be subtracted from  $p_m$  before the latter is inserted in the horse-power formula,

$$H.P. = \frac{p_{e}LAN}{33000},$$

because  $p_m$  is the gross effective mean pressure counted from lines of zero pressure.

167. Work of an Elastic Heat Medium Expanding Adiabatically.—In the foregoing paragraph, where the final

state of the medium as respects heat energy was the same as the initial state, by the supply of the necessary heat to the expanding medium through a conducting cylinder wall by a hot jacket or otherwise, the external work was all done by the applied heat. This is obvious for the admission stage  $p_1v_1$ , and is made clear for the expansion stage by considering that the final pressure and temperature are no less than they would be if the piston had been moved from outside by some force, whereby the medium expanded doing no work. Anv work done by expanding without such addition of heat from without must be accompanied by a fall of the heat energy represented by the work done during such expansion. If the cylinder is a non-conducting and non-absorbing one for heat, and work is done during expansion, the terminal pressure ought to be less at the end of such adiabatic expansion than when the law pv = RT is true. Hence the equation of the form

 $p_1 v_1^n = p_2 v_2^n$ 

will be true, if *n* has a proper value, greater than unity. Rankine ("Steam-engine," p. 392) gives for the exponent a value  $\frac{10}{9}$  when the initial pressure is not less than one atmosphere nor more than twelve atmospheres, in a non-conducting cylinder. For a jacketed engine with pressure between 30 and 120 pounds initial pressure, and for ratios of expansion between 4 and 16, he gives a value of  $\frac{17}{16}$  for the exponent. Zeuner considers 1.0646 nearer than Rankine's value of 1.111.

The most general form of the work-equation is conveniently applied in this case,

Work = 
$$\begin{bmatrix} admission \\ work \end{bmatrix} + \begin{bmatrix} expansion \\ work \end{bmatrix} - \begin{bmatrix} back-pressure \\ work \end{bmatrix}$$
  
 $W = p_i v_1 + \int_{v_1}^{v_2} p dv - p_3 v_3;$ 

but since  $pv^n = p_1v_1^n$ , the integration of the expansion work becomes

$$W_{1} = p_{1}v_{1} \int_{v_{1}}^{v_{2}} \frac{dv}{v^{n}} = \frac{p_{1}v_{1} - p_{2}v_{2}}{n-1},$$

which can be transformed into

$$W_{\mathbf{1}} = \frac{p_{\mathbf{1}}v_{\mathbf{1}}}{n-\mathbf{1}} \left[ \mathbf{I} - \left(\frac{v_{\mathbf{1}}}{v_{\mathbf{2}}}\right)^{n-1} \right],$$

since

$$p_1 v_1^n = p_1 v_1 (v_1)^{n-1} = p_2 v_2^n = p_2 v_2 (v_2)^{n-1};$$

whence

$$p_{2}v_{2} = \frac{p_{1}v_{1}(v_{1})^{n-1}}{(v_{2})^{n-1}} = p_{1}v_{1}\left(\frac{v_{1}}{v_{2}}\right)^{n-1}.$$

This factors into the expression

$$W = \frac{p_1 v_1}{n - I} \left[ n - \left( \frac{v_1}{\tau_2} \right)^{n-1} \right],$$

when  $p_1v_1$  be added in the form of

$$p_1v_1=\frac{n-1}{n-1}(p_1v_1).$$

As before, the mean pressure is  $\frac{W}{v_2}$ , or

$$p_m = \frac{W}{v_2} = \frac{\frac{p_1 v_1}{n-1} \left[ n - \left(\frac{v_1}{v_2}\right)^{n-1} \right]}{v_2};$$

or, if  $r = \frac{v_2}{v_1}$  = ratio of expansion, then

$$p_m = \frac{p_1}{n-1} \left( \frac{n}{r} - \frac{1}{r^n} \right),$$

since

$$\frac{v_1}{v_2} = \frac{I}{r} \quad \text{and} \quad \left(\frac{v_1}{v_2}\right)^{n-1} = \left(\frac{I}{r}\right)^{n-1},$$

and

$$p_1 \frac{v_1}{v_2} \left( \frac{v}{v_3} \right)^{n-1} = p_1 \frac{\mathbf{I}}{r^n}.$$

The expression for mean pressure can be substituted for  $p_m$  in the horse-power formula for the work when expansion is adiabatic, and the desired work per minute or per stroke worked out as before, when the value for n is assumed or is known. When Rankine's value  $\frac{1}{9}$  is used for n, then

$$p_m = 9p_1 \left( \frac{10}{9r} - \frac{1}{r^{\frac{10}{9}}} \right) = p_1 \left( \frac{10}{r} - \frac{9}{r^{\frac{10}{9}}} \right).$$

# 168. Adiabatic Work in Terms of Pressures .-- Since

$$p_1 v_1^n = p_2 v_2^n$$
, then  $\frac{p_2}{p_1} = \frac{v_1^n}{v_3^n}$ 

whence by extracting the *n*th root

$$\frac{v_1}{v_2} = \left(\frac{p_2}{p_1}\right)^{\frac{1}{n}},$$

and by raising both members to the n - 1 power,

$$\left(\frac{v_1}{v_2}\right)^{n-1} = \left(\frac{p_2}{p_1}\right)^{\frac{n-1}{n}}$$

Hence the equation for work of expansion of the preceding paragraph becomes

$$W_{1} = \frac{p_{1}v_{1}}{n-1} \left[ 1 - \left(\frac{p_{2}}{p_{1}}\right)^{\frac{n-1}{n}};\right]$$

and adding the admission work  $p_1 v_1$ ,

$$W = p_1 v_1 + \frac{p_1 v_1}{n - 1} \left[ 1 - \left(\frac{p_3}{p_1}\right)^{\frac{n-1}{n}} \right],$$

which can be factored into

$$W = \frac{p_1 v_1}{n-1} \left[ n - \left(\frac{p_2}{p_1}\right)^n \right],$$

which is a general expression for the work of a stroke with admission and adiabatic expansion, and which can also be transformed to express the work of compressing adiabatically and displacing into a reservoir in air- or gas-compressors.

169. Temperature Changes in Adiabatic Expansion.— Since in adiabatic expansion

$$p_1 v_1^n = p_2 v_2^n,$$

$$\left(\frac{v_1}{v_2}\right)^n = \left(\frac{p_2}{p_1}\right).$$

Multiplying both sides by  $\frac{v_2}{v_1}$ , we have

$$\left(\frac{v_1}{v_2}\right)^{n-1} = \frac{p_2 v_2}{p_1 v_1}.$$

 $\frac{p_2v_2}{p_1v} = \frac{RT_2}{RT_1};$ 

hence

But

$$\left(\frac{v_1}{v_2}\right)^{n-1} = \frac{T_2}{T_1} = \left(\frac{1}{r}\right)^{n-1}.$$

But the previous paragraph has shown

$$\left(\frac{v_1}{v_2}\right)^{n-1} = \left(\frac{p_2}{p_1}\right)^{\frac{n-1}{n}};$$

hence

$$\left(\frac{p_2}{p_1}\right)^{\frac{n-1}{n}} = \frac{T_2}{T_1}.$$

Which can be substituted in either of the previous expressions, giving

$$W = \frac{p_1 v_1}{n - 1} \left[ n - \frac{T_2}{T_1} \right],$$

a convenient transformation for use in problems connected with compression. While this is of value as presenting general expressions for the relations of temperature and pressure in the pressure-volume discussion, a more direct method is convenient. At the state indicated by  $p_1$  the inherent heat energy will be the product of the specific heat by the absolute temperature. This can be expressed in foot-pounds for the volume  $v_1$  by multiplying the product of  $cT_1$  by the factor J = 778, and again by the number of pounds required to fill the volume  $v_1$ , which can be called l. Or,

 $E = c \times J \times T_1 \times l.$ 

At the end of the expansion, no heat having been given out or received, but all heat energy having been directed to perform external work, and the final temperature is  $T_2$ , found from the preceding relations of volume or pressure, it will be true that

$$E_{2} = c \times J \times T_{2} \times l,$$

whence the work in expansion becomes the difference in the two states of energy, or

$$E_{1} - E_{2} = W_{1} = Jc(T_{1} - T_{2}),$$

or the outer work in expansion is proportional to the difference between the initial and final absolute temperatures, as should have been foreseen.

The above relation also indicates how much heat in units must be withdrawn by artificial refrigeration in compression, or must be added in expansion between limits of  $v_1$  and  $v_2$  or  $p_1$  and  $p_2$  if the final temperature is to be kept the same as the initial temperature, as required in isothermal conditions.

170. Conclusions regarding Isothermal and Adiabatic Expansion.—Neither isothermal nor adiabatic expansion is ever exactly realized in practice, by reason of the conducting, absorbing, and radiating effect of metallic walls of the cylinder in which actual work is done. These interchanges take place so rapidly that differences in piston-speed affect, the action less than might be anticipated. True isothermal expansion is not desired where the heat-carrier is a hot medium, because at the end of expansion the gas is as hot as it was at the beginning, and this heat is voided at the exhaust with attendant waste of applied heat. What is desired is to reduce the inherent energy in the medium at exhaust to its lowest practicable value.

In the foregoing discussion, the volume  $v_1$  at the end of admission from the boiler or reservoir of energy has been the quantity assumed, and its pressure  $p_1$  given to it by heat or other source of energy. Both these quantities have been made arbitrary. If it be desired to assume the initial temperature the initial volume  $v_1$  can be taken as that of a unit of weight of the medium, and filling this volume at a calculated pressure  $p_1$  belonging to that state of the medium. The work for l pounds of the medium will be simply l times greater than that for one pound.

171. Design of Cylinders for Piston-motors.—The foregoing paragraphs lead directly to the fundamental processes of the design of a cylinder volume V which will perform a given mechanical work in foot-pounds when the mean effective pressure has been ascertained. In the general formula

 $H.P. = \frac{PLAN}{33000}$ 

l

the value for P (when usual assumptions are made as to cutoff) is given for the various media by the preceding deductions. The horse-power or foot-pounds is given as a fixed element of the problem, and the desired number of traverses of the piston is imposed as a rule by the work to be done. Hence the remaining factors to be worked out are the relations of L to A when their product LA for one stroke is known. The product LN is called the piston-speed, and is the aggregate of the piston travel in feet per minute. Values for LN as a product will make a high-speed or a lowspeed engine according as

LN = 400 to 600 ft. per minute.... low speed LN = 600 " 800 " " " … moderate speed LN = 800 " 1000 " or over, per minute... high speed.

When the value for N indicates a high or a mean or a low speed, the relation of length to diameter of cylinder is likely to be

> Stroke = diameter  $\times$  (1 $\frac{1}{2}$  or 2) for low speed "="""  $\times$  1 $\frac{1}{2}$ "" mean "" "=""  $\times$  1" " high ""

Hence from the relation  $A = \frac{\pi d^2}{4}$ , and the assumption concerning LN, a value for L and for the cylinder diameter can be worked out for a single-cylinder engine. The cylinder proportions having been fixed upon, the design of the valve-gear to give the required cut-off and the proportions of parts to resist the dynamic strains belong to another branch of engineering design apart from the present purpose. The questions concerning clearances with their losses, and the economics possible as affecting wise design, belong to the more advanced treatment of heat-engines in subsequent chapters.

These remarks concerning design apply to the single or simple engine of a typical design. But the engine may be compound or multiple-expansion; it may be rotary instead of reciprocating; the heat medium may be used in a turbine. The mechanical features of these motors have been more fully treated elsewhere than is here possible, but some brief reference is desirable.

172. The Compound or Multiple-expansion Engine.— In the compound engine the steam expands continuously after admission is cut off from the boiler in the high-pressure cylinder. There are three stages of such expansion in the triple-expansion engine, and four stages in the quadrupleexpansion. The number of cylinders is not important, but the number of steps or stages is the determining factor.

The diagram of steam effort in the Woolf or tandem-compound engine (Fig. 64) reveals the continuity of the expan-



sion in the two cylinders, and that the driving steam of the larger or low-pressure cylinder is the back pressure upon the smaller or high-pressure cylinder. The greater area of the low-pressure piston, however, secures a net forward effort. The foregoing formulæ make it plain that it is the final volume of the steam which is significant as compared with its initial volume, so that the cylinder design compels a calculation of the volume of the low-pressure cylinder to secure a required horse-power, and from accepted relations the cylinder area of the smaller is worked out. The other way and more

usual is to draw the P.V. diagram for the desired ratio of expansion, with the given initial and terminal values, and then



F1G. 66.

divide the area of that diagram, so that equal work will be done in each of the two or more cylinders (Figs. 65 and 66).

In the cross-compound or receiver engine with a cut-off in the low-pressure cylinder there will be an apparent discrepancy or break of continuity in the diagrams of effort. This disappears when the length of the high-pressure diagram is reduced in proportion to that of the low-pressure diagram in the relation of the cylinder-volumes. That is, if the cylinders are as I : 4 the length *CD* of the high-pressure diagram at any pressure level is reduced to  $\frac{1}{4}$  of that length at the same level *cd* (Fig. 67). The only loss of area is from friction or condensation or free expansion into the receiver. It is the



loss between the two diagrams which the reheater between cylinders aims to reduce.

The following table presents accepted practice with respect to a selection of the grade of expansion with fixed boiler-pressures:

When the values for T are those which belong to a pressure below 80 lbs..... use single engine for pressures between 80 and 100 lbs. "compound engine "c " " 130 " 160 " "triple " triple " above 170 lbs...... "quadruple "

Usual cylinder-ratios of practice, for usual pressures with triple engines, are:

Pressures.	Small.	Intermediate.	Large.
130	I	2.25	5
140	I	2.40	5.85
150	I	2.55	6.90
160	I	2.70	7.25
170	Quad	ruple engine pro	eferred.

For quadruple-expansion engines the usual ratios of cylinder-areas and volumes approximate I: 2: 3.78: 7.70, which may be called I: 2: 4: 8.

If the principle be adopted that the ratios of areas are to be as the fourth root of the number of expansions, the ratio of the first to the fourth will be as the cube of the fourth root. The ratio will increase as the initial pressure becomes greater; e.g., 1 : 2.2 : 4.8 : 10.6.

Mr. G. I. Rockwood has designed a compound engine with a cylinder-ratio of 7: I with the view of making heat-range equal in the two cylinders, whence the ratio of surfaces is taken account of, as well as the differences in temperature.

The subjects of the mechanisms of the compound engine, arrangement of cylinders, compounding above atmosphere, the compound locomotive, etc., will be found discussed elsewhere, to which references appear in the Appendix.

173. Advantages of the Compound or Multiple-expansion Engine.—The principle of securing expansion by the continuous working of steam in cylinders of increasing volume is to be defended by reason of the following advantages:

I. The high grade of expansion and the difference between the initial and final temperature in the steam used is secured with an admission of steam into the cylinder through a longer proportion of the stroke than in the single cylinder. It has been seen that the efficiency of the fluid used increases with the difference in the initial and final temperatures. The work of the steam reaches the crank in angles more favorable to produce rotation.

2. With the terminal temperature at exhaust fixed by the temperature possible with the means used to condense the steam, the compound principle enables higher pressures to be used in the boilers as initial pressures in the cylinder. To increase the pressures in the boilers is to carry more stored energy in a given space; to use higher pressures is to enable each cubic foot or pound of steam to carry more energy into the engine-cylinder, and the given quantity of heat raises the pressure of steam more rapidly after the steam has become a complete gas than it does at lower pressures, when a large part of the heat is absorbed in changing the molecular condition of the water.

3. By receiving the high-pressure steam from the boiler first upon a cylinder of small area, as in the compound engine, the strain upon the mechanism at the joints and moving members is less than if that same pressure had to be received at the beginning of a stroke in a cylinder, and against a piston of a large diameter. Less loss from friction also follows during the less effective angles of the stroke.

4. From the longer period of admission discussed in number one above, it follows that a more advantageous arrangement for admitting and cutting off the steam becomes possible. With the single cylinder and early cut-off in it, the openings to admit steam would have to be closed so early that it would be difficult to admit steam through wide and generous ports or passages. Such single-cylinder valve-gear with narrow areas for steam would introduce the difficulty known as wire-drawing of the steam. This is a phenomenon present when the pressure of steam is reduced by compelling it to pass through a narrow or constricted opening.

5. With high-pressure steam it is difficult, both by reason of changes of shape due to heat and by reason of the pressure itself, to make the valves controlling the admission of steam so that they shall be and remain tight. In the compound engine the steam which leaks past the valve of the first or high-pressure cylinder does not leak into the air or condenser, but into a later cylinder in the chain in which it expands and does work.

6. If by reason of doing work in expanding there is a transformation of heat into work which must be compensated by a condensation of the steam in the first cylinder, that water reheated and expanding at the lower temperature does work in the later cylinder of the chain instead of escaping unutilized through the exhaust.

7. In those forms of the compound engine in which the work of the several cylinders reaches the crank-shaft each through its own crank-pin, there is the advantage of such distribution, for this avoids the concentration for large engines of great energy on small areas, and enables designers to avoid either excessive lengths or inconvenient diameters for their crank-pins. When the crank-pin becomes of inconvenient diameter with respect to the length of the crank, the angle during which the pressure of steam is available to produce rotation of the crank is diminished.

8. The turning effort is equalized when the compound engine is arranged to have its cranks quartering. This diminishes the weight of the fly-wheel.

9. The compound engine gives an opportunity to improve the quality of the steam during the process of expansion when it is possible to use a reheater.

10. The clearance-volumes of the small-diameter cylinder carry less steam by weight than if the steam had to fill the clearance-volume of the large cylinder. The steam in these clearance-volumes is also used expansively in the later cylinder, instead of being rejected, as would be the case in the single cylinder.

11. The hottest steam is used in the cylinder of the smallest volume, causing a diminished loss from radiation and condensation due to cool external air.

12. In the compound locomotive the less terminal pres-

sure gives less violence to the escape of the exhaust which induces the draft through the fire-box. The fire is pulled about less.

13. The greatest advantage incident to the use of the principle of continuous expansion in several cylinders is that thereby the range of temperature between the initial and final states of that cylinder is less than it would have to be if the expansion were in the one cylinder only. The law of transfer of heat from one body to another is that the transfer is rapid in proportion as the difference in temperature is greater. The less the temperature between the incoming and outgoing steam in any cylinder, the less condensation occurs when the This is a particularly favorable condition hot steam enters. for the large and low-pressure cylinder, whose ends are alternately open to the comparatively low temperature of steam as it is escaping into the condenser. It is of great advantage that the high-temperature steam fresh from the boiler should not have to meet the relatively cool metal and large surface of this low-pressure cylinder.

174. Disadvantages of the Compound Engine.—When it is recalled that the low-pressure cylinder is the fundamental unit, and determines the working capacity of the compound engine, it is apparent that by introducing the other cylinders in the multiple-expansion type certain disadvantages are introduced. These are:

I. The cost of the cylinders other than the low. This may mean in tandem engines the cost of piston and cylinder with additional rod, but in cross-compound and fore-and-aft engines it means an additional cost of practically another engine with crank, connecting-rod, cross-head, and the like.

2. The weight and bulk of the additional cylinder adding to foundations and taking up valuable space.

3. The friction-loss due to the work absorbed by this extra cylinder in operating its mechanism, valve, and the like.

4. The loss by radiation of heat from the surface of the extra cylinder and valve-chest, which are surfaces exposed to the air.

5. The loss of work due to the difficulties represented by lost area in the work-diagram from friction, free expansion, condensation, and the like. The single-engine diagram, getting the same grade of expansion in the same cylinder, would not experience this.

6. The difficulty connected with regulating the power of the engine when the work varies widely, and the first cylinder has measured off a volume of steam adapted to a resistance different from that upon the engine when that volume of steam reaches the later cylinders. This is the difficulty of regulating the multiple-expansion engine, except by regulating devices operating upon each cylinder independently.

7. There has been considerable trouble in compound engines from the accumulation of water in the low-pressure cylinders, particularly when compounding above the atmosphere and using wet steam. The wide range of expansion, the lowered terminal pressure, and the large diameter of the lowpressure cylinder have made this difficulty a very troublesome one in locomotive practice.

8. In compound locomotives, the terminal pressure may not be high enough to give intensity to the draft in the stack sufficient to keep the engine steaming freely.

It is very obvious that the weight to be attached to the above objections is not considered by most designers to be great enough to overbalance the advantages which follow from the principle of compounding.

175. Design of the Rotary Engine.—In the rotary engine, a series of pistons or vanes are attached radially upon crank-arms so as to receive the pressure of the steam directly to produce rotation. It is so difficult to secure expansive working by allowing the steam admitted to the cylinder to lower its pressure while doing work, that it is not usually

attempted, and the foregoing formulæ are not applicable. The pressure from the boiler acts upon the effective area of the vane, and moves it through a space in feet (Fig. 68). The product is the foot-pounds exerted while that vane was in action. For the mechanisms and for the advantages and disadvantages of the rotary engine, see the reference



in the Appendix. A difference between the initial and final volumes of the steam in the machine itself is only to be easily secured by compounding, or the use of engines in series.

176. The Steam Turbine.—The third type of motor which is used to avail of the pressure energy of an elastic heat medium is the steam turbine. It is a transfer to the field of the elastic fluids of the idea long familiar in water-

motors which use an incompressible medium. The turbine uses the impact of a weight of fluid having a velocity due to head or equivalent pressure, and after the impulse has been utilized, a further propelling effect is sought from the reaction of the current of the fluid.

The low density of steam as compared with water makes it difficult to secure a high value for the unit of effort upon the bucket of the steam turbine; the best results along this line are secured by using a considerable number of jets of On the other hand, if it be conceded (as can be steam. proved) that the best result is obtained when the velocity of the jet is twice that of the surface receiving its impulse, or when the circumference of the wheel is moving tangentially with half the velocity of the steam at the nozzle, the wheel has to have so high a velocity that it is not easy to resist the centrifugal effort of the outer elements of the wheel itself. For example, if the steam issue from the nozzle at a pressure of 140 pounds, it has a velocity of upwards of 2000 feet per This follows because  $v = \sqrt{2gh}$  and  $h = (140 \times 10^{-5})$ second.  $144) \times 0.3148$ , the latter being the weight of a cubic foot of steam at that pressure. Solving when h = 64,000 feet, vbecomes 2030 feet per second.

This linear velocity at the circumference compels a rotative speed of many thousand revolutions per minute for the turbine wheel proper, which has to be of small diameter to withstand the centrifugal strain, and therefore a reducing train to bring the speed to limits which are convenient and usual. On the other hand, where high rotative speed is no disadvantage, as in driving of dynamo-armatures or specially designed propeller-wheels, the turbine is the most compact and lightest of motors.

The mechanical principle underlying the motors of this class is that the energy imparted to the wheel will be the difference between the moments of the living force of the mass of the fluid upon entering and leaving the wheel, mul-
tiplied by the angular velocity of the wheel. That is, if x be the tangential velocity of the jet, and u be the less tangential velocity of the buckets, the work per second will be

Work per second 
$$= M(x - u)u$$
,

when  $M = \frac{W}{g}$  is the mass passing the nozzles in one second, and  $u = \omega r$ . If the steam left the wheel without velocity relatively to the direction of its effort, the work per second per pound would be:

Work per second per pound 
$$= \frac{u^2}{g}$$
,

when the velocity of the rim is known. If the weight in pounds of steam is known which flows per second (w) and the work per second per pound is

$$U = \frac{\mathrm{I}}{g}(x - u)u,$$

then the horse-power per minute becomes

$$H.P. = \frac{wU \times 60}{33000}.$$

The outward-flow turbine (Dow type) permits the range of pressure to occur within the arm, so that at the issue-point the steam has expanded to atmospheric pressure or nearly so, leaving only energy and velocity enough to free itself from the wheel. The same is secured in Parsons and Curtis turbines by the principle of compounding, whereby successive increase in volume results in the lowering of pressure. In the De Laval turbine the expansion occurs in the nozzle itself by the changes in its cross-section.

Figs. 69*a*, 69*b*, and 70 show typical sections of steam-turbines selected from outward-flow and tangential impulse



# ELASTIC HEAT MEDIA IN HEAT-ENGINES. 259

types. The high speeds compel the greatest care in balancing and in the construction of the bucket detail. Where it can be done, the plan of mounting the axis of the turbine verti-



cally avoids the disturbance of balance from its own weight. Excellent results have been secured by the use of an annular jet around a fine central needle in a small nozzle.

# CHAPTER XIII.

# MECHANICAL COMPRESSION OF HEAT MEDIA.

180. Introductory .- It will be at once apparent that in the case of permanent gases or heat media within the usual limits of pressures, it is easily possible to invert the formulæ for expansion and so express the changes when a heat medium has outer work exerted upon it to produce those changes in its heat condition which must follow its subjection to such external force. When such changes are studied upon the pressure-volume plane the diagram of pressures is traced in reverse direction, or contrary to that of the hands of the clock in the previous right-hand diagrams. When this is done with air or gas as a medium, the machine is called an air- or a gas-compressor. The compressor is a heat forcepump, raising a weight of air to a higher heat condition by converting external work into heat. The blowing engine differs from the compressor only by having a low ratio between final and initial pressures of the medium, and usually also by being adapted to handle large volumes of air.

181. The Air-compressor, with Pressures Given.—The air-compressor problem in practice usually requires that air shall be taken into the cylinder at a pressure  $(p_1)$  of the atmosphere or nearly, and that a volume per stroke  $(v_1)$  of air at this pressure shall be compressed to a higher pressure  $(p_2)$ . This will be accomplished by reducing its volume to  $(v_2)$  corresponding to that higher pressure, when the valves leading to a receiver will be opened by the pressure in the cylinder,

and the compressed air without increase of pressure or temperature will be forced out into the receiver. If the air undergoing compression is cooled by water-jacketing or by injection of water, the compression may be isothermal. As a rule, however, by reason of the short time allowed for the compression and the slowness of transfer in air, the compression is practically adiabatic, and the air is warm or hot as it leaves the compressor. If the air is only compressed to receiver pressure, at the end of the piston traverse, the valves will not open to discharge the air, and consequently on the return traverse the compressed air in clearances will simply expand down to atmospheric pressure  $(p_2)$  like a spring and no fresh charge will be taken in. It will be apparent, therefore, that clearance volumes are of significant detriment in air compressing, and the higher the pressure above atmosphere, the worse the loss which they occasion.

The formulæ of § 167 are therefore directly applicable, provided the direction of the process be reversed, in the diagram representing the cycle. The total work of one stroke will be made up of:

Work = 
$$\left\{\begin{array}{c} \text{compression} \\ \text{work} \end{array}\right\} + \left\{\begin{array}{c} \text{displacement} \\ \text{work} \end{array}\right\} - \left\{\begin{array}{c} \text{inlet back-} \\ \text{pressure} \end{array}\right\}$$
$$W = W_c + W_d - W_i$$
$$W_c = \int_{v_a}^{v_1} p dv$$
$$= p_1 v_1 \int_{v_a}^{v_1} dv = \frac{p_1 v_1 - p_2 v_2}{v^a}$$
$$= \frac{p_1 v_1}{n - 1} \left[\left(\frac{v_1}{v_2}\right)^{n-1} - 1\right],$$

which can be transformed as in § 168 to

$$W_c = \frac{p_1 v_1}{n-1} \left[ \left( \frac{p_3}{p_1} \right)^{\frac{n-1}{n}} - \mathbf{I} \right].$$

The work of displacement

$$W = p_1 v_1 = p_1 v_1 \left(\frac{p_1}{p_1}\right)^{\frac{n-1}{n}},$$

by using the same methods as in the foregoing expansion discussion, since

$$\frac{p_2}{p_1} = \left(\frac{v_1}{v_2}\right)^n;$$

by multiplying both members by  $\frac{v_2}{v_1}$  we have

$$\frac{p_2v_2}{p_1v_1} = \left(\frac{v_1}{v_2}\right)^{n-1},$$

whence

$$p_{s}v_{s} = p_{1}v_{1}\left(\frac{v_{1}}{v_{2}}\right)^{n-1} = p_{1}v_{1}\left(\frac{p_{3}}{p_{1}}\right)^{\frac{n-1}{n}}.$$

The compressing cycle work is therefore

$$W = \frac{p_1 v_1}{n - 1} \left[ \left( \frac{p_2}{p_1} \right)^{\frac{n - 1}{n}} - 1 \right] + p_1 v_1 \left( \frac{p_2}{p_1} \right)^{\frac{n - 1}{n}} - p_1 v_1,$$

which factors into

$$W = \frac{p_1 v_1 n}{n - 1} \left[ \left( \frac{p_2}{p_1} \right)^{\frac{n-1}{n}} - 1 \right].$$

This has been made intentionally to differ from the form of the statement for expansion work (§ 167), inasmuch as in expansion the back-pressure line does not necessarily coincide with the end of the expansion line, and to introduce another pressure value not related to the rest of the factors would be to complicate the computations. In compression, however, the initial pressure is the same as the terminal pressure for the intake stroke.

182. The Air-compressor with Volumes given.—If the volume of compressed air should be given, or the volume at atmospheric pressure, the relations between pressures, volumes, and temperatures given in §§ 167 and 168 enable easy substitutions to be made. In adiabatic changes

$$\left(\frac{v_1}{v_2}\right)^{n-1} = \left(\frac{p_2}{p_1}\right)^{\frac{n-1}{n}} = \left(\frac{1}{r}\right)^{n-1} = \frac{T_2}{T_1},$$

in which r expresses the relation between the less and greater pressures, and the greater and the less volume. The relation shows how the temperatures absolute will change as external work is done upon the air, and also how much heat must be abstracted if the compression is to be kept isothermal and the air to be at the same temperature in the receiver as in the outer air. The table on page 264 gives data of interest as to the rise in temperature for air.

183. Value of the Factor n in Air-compressing.—The exponent n of an adiabatic expansion and compression of air or other non-condensable gases will be the ratio between the 'specific heat of the gas at constant volume and the specific heat at constant pressure; i.e.:

$$n=\frac{C_{p}}{C_{n}}.$$

1

For air, when  $C_{p} = .238$  and  $C_{v} = .168$ 

$$n = \frac{238}{168} = 1.41.$$

The heat required to raise a unit weight one degree at constant pressure will be obviously the greater since the expanding air is overcoming the outer pressure on it as it increases in energy but does not increase in pressure. The difference  $C_{\phi} - C_{v}$  will denote the amount of heat corresponding to overcoming the pressure  $p_{0}$  when a volume  $v_{0}$  of air at zero degrees is heated one degree. One hundred volumes of dry air at mean atmospheric pressure of 14.7v pounds per square inch and a Fahrenheit temperature of 60° (15.5 C.) when compressed without withdrawal of heat will have the temperatures centigrade given in column 2 of the following table, and the volumes given in column 3 for that pressure. If the compression is isothermal so that the temperature is kept at 60° F. or 15.5 C., the volumes will be as in column 5. (Thurston, *Journ. Frank. Inst.*, 1884.)

Pressure Absolute, Pounds per Square Inch.	Temperature Centigrade at end of Compression.	Volume of Temperature and Pressure Preceding.	Temperature Fahrenheit Corresponding.	Volume if Temperature had remained constant at 15.5° C.
 I	2	3	4	5
14.7 15 20 25 30	15.5 17.26 42.60 64.76 82.10	100.0 98.58 80.36 68.59 60.27	60 63 108 149 180	98.co 73.50 58.80 49.00
35	98.38	54.01	208	42.00
40	113.86	49.13	237	36.75
45	126.54	45.18	259	32.67
50	138.96	41.93	282	29.40
55	150.53	39.19	303	26.73
60	161.38	36.84	322	24.50
65	171.61	34.80	340	22.62
70	181.29	33.02	357	21.00
75	190.49	31.44	375	19.60
80	199.26	30.03	391	18.38
85	207.66	28.77	405	17.29
90	214.71	27.62	418	16.33
95	223.25	26.58	434	15.47
100	230.91	25.63	447	14.70
125	264.66	21.88	508	11.76
150	293.91	19.22	561	9.80
175	319.87	17.23	608	8.40
200	343.31	15.67	649	7.35
225	364.71	14.41	687	6.53
250	411.57	13.38	772	5.88
300	420.34	11.75	788	4.90
400	480.76	9.58	896	3.90
500	531.21	8.17	986	2.94
600	574.93	7.18	1065	2.45
700	603.74 %	6.44	1117	2.10
800	648.80	5.86	1200	1.84
900	680.86	5.39	1256	1.63
1000	710.49	5.00	1310	1.47
2000	929.67	3.06	1706	0.74

But it has been already seen (§§ 107 and 115) that

$$\frac{p_{o}v_{o}}{T_{o}}=\frac{p_{1}v_{1}}{T_{1}},$$

or that

$$p_1v_1 = RT_1.$$

Hence it follows (see § 116) that

$$J(C_p - C_v) = R.$$

From which, if the other quantities have been observed, the value of the mechanical equivalent can be calculated in advance of experiment. When densities are known, for any standard temperature, R can be calculated for any gas, since

$$R = \frac{p_{\circ}v_{\circ}}{T_{\circ}} = \frac{p_{\circ}}{D_{\circ}T_{\circ}},$$

because the weight of a unit cubic volume is by definition its specific gravity. (See § 107).

This enables a usual transformation of the equation for work to be made. For since

$$C_{p} - C_{v} = C_{v}(n - 1),$$
$$n - 1 = \frac{R}{JC_{v}};$$

hence (§ 167)

$$W = \frac{Jp_1v_1C_v}{R} \left( \mathbf{I} - \left(\frac{p_2}{p_1}\right)\frac{n-\mathbf{I}}{n} \right)$$

when there is no work of admission.

184. Mean Pressure in the Compressing-cylinder.—If the work of the compressing-cylinder be given by a  $p_1v_1$  product, which can be represented by an area, the mean pressure will be the height of a rectangle whose base is the final vol-

ume. Hence the mean pressure will result if the equation for W be divided by  $v_1$ . This makes (§ 180)

Mean effective pressure 
$$= \frac{p_n n}{n-1} \left[ \left( \frac{p_n}{p_n} \right)^{\frac{n-1}{n}} - 1 \right].$$

If the compressor is a steam-machine, the mean effective pressure in the steam-cylinder must be enough greater than this to overcome the frictional resistances at bearings, guides, stuffing-boxes, etc., and to overcome the friction in the cylinders from packing-rings, valves, and the like, and the fly-wheel must be able to equalize effort and resistance by its stored energy when these are unequal at different parts of the stroke.

185. Isothermal Compression.—The formula for isothermal expansion (§ 166) and for mean pressure for such expansion are the same for compression, with proper changes in the letters for volumes and pressures. The formula becomes

$$W = p_{1}v_{2} + \int p dv = p_{1}v_{1} + p_{1}v_{1} \operatorname{Nap.} \log \frac{v_{1}}{v_{1}}$$
$$= p_{1}v_{1} \left[ I + \operatorname{Nap.} \log \frac{v_{1}}{v_{2}} \right],$$

and the mean pressure as before is found by dividing by the length or volume  $v_1$ ; or

M.E.P. = 
$$p_1 \left[ \mathbf{I} + \operatorname{Nap.} \log \frac{v_1}{v_2} \right]$$
.

When this is compared with the work and M.E.P. in adiabatic compression, it will be found that isothermal compression requires less work than adiabatic compression between the same pressures, but a less volume is displaced into the receiver because of the reduction of volume resulting from the abstraction of the heat of the compression, which is made to disappear by the cooling and is lost. That is, if Fig. 75 represents by its curve of compression *ia* the path of the

pressure-volume relation in adiabatic compression, and by its curve is the path of isothermal compression, there is a waste of power in adiabatic compression represented by the shaded area isa as compared with isothermal, when both compressions start from atmospheric pressure and temperature at c. If the air cools down from the higher temperature belonging to the adiabatic point a to the atmospheric pressure in pipes and reservoirs so as to have a volume represented by cs instead



F1G.75.

of ea, the adiabatic compression will suffer a further loss when the air comes to expand from the volume es back to atmospheric pressure in a proper air-engine (Chapter XVIII). The expansion, if adiabatic and starting from s, will end at a point d, while, if isothermal, would return to i. Hence the area between the bounding curves sd and ai will represent the waste of power if the compression were adiabatic as well as the expansion. If the compression were isothermal, the loss would be only the area *isd*. If the expansion could be also isothermal, there would be no loss in the reversible process outside of pipe friction (see further, Chapter XVIII).

186. Effect of Clearance in Compressing-cylinders.—It has been already said (§ 181) that any air remaining behind in a compressing-cylinder, between piston-head and valves, will expand on the return or inlet stroke, preventing early opening of the inlet valves or any flow of air into the cylinder, until

the pressure of that imprisoned air falls below that outside which acts on the inlet values to open them. The effect of this expanding air is to help the working stroke at the start, by acting as a cushion or spring, but the harmful effect is to increase the size of cylinder required for a certain net output of air. The expansion of this imprisoned air is safely called adiabatic, and the work which it does (if it is worth while to find it) is to be found for the weight or volume as given in the expansion value for W (§§ 167 and 168). The increase in the size of cylinder required is to be found by plotting the curve of such expansion work on a diagram (Fig. 76), and increasing the volume by that percentage of itself which is given



FIG.76.

by the ratio of the entire length of the diagram between verticals ec to the length cd of the diagram between the terminals of the adiabatics.

The mean effective pressure is of course reduced by the effect of the clearance volume of air. This will be in the proportion of the effective length between the feet of the adiabatics to the total length between perpendiculars. Otherwise, the formula for mean effective pressure may be applied directly in calculating the work to be done in horse-power if the actual volume of air be used, taken after the inlet-valves have opened, instead of the full piston-displacement.

187. Volume of the Compressing-cylinder.—If the problem be given to design a cylinder to give  $V_s$  cubic feet of air at a pressure of  $p_s$  pounds per square inch (or per square foot) after compression, it will first be necessary to find the corresponding absolute temperature  $T_s$  corresponding to that pressure, from the foregoing equations. Then the volume  $V_1$  at atmospheric pressure and temperature can be found from the relation

$$\frac{p_{\mathfrak{s}}V_{\mathfrak{s}}}{T_{\mathfrak{s}}} = \frac{p_{\mathfrak{s}}V_{\mathfrak{s}}}{T_{\mathfrak{s}}}.$$

Then if clearance effect be neglected, and the piston makes 2n traverses per minute for n revolutions in that same time, the cylinder volume v, will be

$$v_1 = \frac{V_1}{2n}$$
 cubic feet.

If there be a clearance expressed in terms of piston-displacement by the fraction  $\frac{I}{c}$ , the air in the clearance volume expanding down from  $p_2$  to  $p_1$  will occupy a volume which will be

$$\frac{\mathrm{I}}{c} \left(\frac{p}{p_{1}}\right)^{\frac{1}{n}}$$

of that piston-displacement. The denominator 2n should be therefore multiplied by the factor

$$\mathbf{I} + \frac{\mathbf{I}}{c} - \frac{\mathbf{I}}{c} \left(\frac{p_2}{p_1}\right)^{\frac{1}{n}}$$

of itself to allow for this clearance loss. Furthermore, the inlet-valves do not open until the pressure in the cylinder is less than  $p_1$  and friction through them keeps it less than  $p_1$  on the aspirating stroke; and similarly, the delivery-valves

do not open until  $p_2$  is exceeded, and their friction makes the pressure of displacement in the cylinder greater than  $p_2$ . These losses compel the real volume to exceed the calculated volume by an amount for which experience is the only guide.

188. Cooling of Compressing-cylinder.—The relation between pressures and absolute temperatures in compressing

$$\frac{T_2}{T_1} = \left(\frac{p_2}{p_1}\right)^{\frac{n-1}{n}}$$

enables the rise or range of temperature to be calculated when the pressures are given. Hence if it be desired to cool the compressing-cylinder by water-jacketing or to cool the air by injection of water, the pounds of water required are easily calculated. If  $t_a$  is the range of temperature for the air, and  $t_w$  is the range to be permitted to the water, then the law of transfer gives

 $I \times C_v \times t_a = w \times I \times t_w$ 

for each pound of air, when w is the desired weight of water with a specific heat of unity.

. Water-jacketing does not cool the air much, since air is cooled by contact only, and this is not easily managed unless the air is in thin films. Injection of water is effective for cooling the air, but in many cases the presence of water-mist in the compressed air is an objection on account of its freezing when the air is used expansively in the compressed-air motor. If the air be assumed to be saturated with all the steam-vapor it can carry, the effect of the steam-vapor is probably inappreciable on the work of the air. The exponent of the equation may be slightly affected, but this is all.

189. Compressing in Two or More Stages. Compound Compressors.—It early suggested itself to designers of compressors that if the compound principle were applied to compressing they would reap certain advantages belonging to the principle as applied to the steam-engine. The air taken

at lower pressure and larger volume into a large cylinder and delivered from it to a smaller one would allow an intercooler between the two cylinders to be advantageously arranged to cool the air and diminish the volume of the small cylinder, while the entire volume of the small cylinder was available for the second stage of the compression, instead of forcing this into that part of the stroke of the one cylinder at which the diminishing crank-angle reduced the piston to a slower velocity. The intercooler, however, has a manifest advantage, because it usually happens that a storage of air in reservoirs occurs in which the temperature of the air drops down to or near that of the incoming atmospheric air. Here the work of compression can be reduced by the division into two stages, by making it approach to isothermal compres-The air is taken in at  $p_1$  and is compressed in the first sion. cylinder to  $p_2'$ , and in the reservoir at  $p_2'$  it is cooled back to  $T_1$ , or nearly so, at which it entered the first cylinder. The second cylinder draws the air at a pressure  $p_a'$  and compresses it to the final  $p_{a}$ . This is represented graphically for a three-stage compression by Fig. 77. By the first cooling



the volume is diminished from the adiabatic point x to the isothermal point i. The second compression adiabatic in the second cylinder would bring the pressure and volume to y; by the second intercooler it is reduced in temperature, and

# The halout sarver over pressimilians area is by 3 stage confirming the stage wade by stage HEAT AND HEAT-ENGINES.

therefore in volume, to j. The final compression carries the pressure up to the volume-line through z, whereas k would have been the isothermal point. Hence the loss drops to that represented by the hatched area instead of being the full area outside of the isothermal curve cijk.

What is desired in two-stage compression is to make such a division of the compressing work as shall make it a minimum. If the first stage compress from  $p_1$  to  $p_2'$  and the work be called  $W_1$ , the equation of § 181 is

$$W_{1} = p_{1}v_{1}\frac{n}{n-1}\left[\left(\frac{p'_{2}}{p_{1}}\right)^{\frac{n-1}{n}} - 1\right],$$

for one pound of air, neglecting clearance loss.

The work of compressing from  $p_1'$  to  $p_2$  is

$$W_{2} = p_{2}' v_{3}' \frac{n}{n-1} \left[ \left( \frac{p_{2}}{p_{2}'} \right)^{\frac{n-1}{n}} - 1 \right].$$

But if the air be cooled back to the temperature  $T_1$  in the intercooler between the cylinders, this last work becomes

$$W_{\mathbf{a}}' = p_{\mathbf{a}} v_{\mathbf{a}} \frac{n}{n-1} \left[ \left( \frac{p_{\mathbf{a}}}{p_{\mathbf{a}}'} \right)^{\frac{n-1}{n}} - 1 \right].$$

Hence the total work in the two cylinders is their sum; or,

$$W = W_{1} + W_{2}' = p_{1}v_{1}\frac{n}{n-1}\left[\left(\frac{p_{2}'}{p_{1}}\right)^{\frac{n-1}{n}} + \left(\frac{p_{2}}{p_{2}'}\right)^{\frac{n-1}{n}} - 2\right].$$

This value for W will be a minimum when

$$\left(\frac{p_2'}{p_1}\right)^{\frac{n-1}{n}} + \left(\frac{p_2}{p_2'}\right)^{\frac{n-1}{n}}$$

is a minimum. When  $p_1$  and  $p_2$  are known, this expression is of the form  $\frac{x}{a} + \frac{b}{x}$ , which can be differentiated, and when

the first differential coefficient is put equal to zero, the value for x corresponding to such minimum  $= \sqrt{ab}$ . Hence the minimum value for the work occurs when

$$p_2' = \mathbf{1} p_1 p_2.$$

When the air is supplied to both cylinders at the temperature  $T_1$  their respective volumes should be inversely as the absolute values of the pressures  $p_1$  and  $p'_2$ .

When high pressure is sought, a similar reasoning would point to using three stages or four. The smaller diameter of the higher pressure cylinders enables greater strength to be secured with less proportionate increase in weight, besides the diminution of the motor work, resulting from cooling the air in transit. The intercooler is usually a receiver with a coil of pipe within it, around which the air passes.

190. Fluid Compressors.—By combining the use of a displacing-piston with the use of a displacing fluid in the compressing-cylinder, or by using a fluid alone on which the air or gas undergoing compression was without physical or chemical effect, designers have been able to diminish the evil effects of clearance. The liquid used may be water or oil. It fills all dead space behind the piston up to the valves, which are placed above the liquid, and therefore the expulsion or displacement of air is practically complete. The pumps must not operate at too high a speed with these fluid pistons, which must not be allowed to churn or spatter. If water is used, it grows warm and begins to form vapor, and requires renewal.

191. Conclusions and Remarks.—It will have been made apparent that in compressing air, as the volumes diminish, the pressures increase more rapidly. Air at very high tension, therefore, is not heated so hot in proportion to the stored energy in it as at the lower pressures. It is the loss of the heat of compression in receivers, pipes, conduits, and the like which withdraws energy from compressed air after it is





stored in it by the compressing process, which forces compressed air to lower effectiveness as a medium of transmitting energy, unless the air is heated again just before using, which can be cheaply done. The cooler the intaken air, the greater the weight per cubic foot and the greater the mass or weight of air handled by a machine of a given size. Further, the greater energy is a given machine capable of imparting to the air. At high mountain altitudes the efficiency of a compressor is less than at sea-level. If the air can be used directly as compressed, the heat energy stored in it is of more moment than the pressure without the heat. If the air is not used expansively in the air-motor, energy stored in it is wasted at the exhaust. If the air is used expansively, its condition as to heat is lowered, and the energy expended in doing useful work. If pressure is raised without heat-rise, then in working expansively its heat standard is lowered below the normal, and it has to be regenerated.

The operation of the air-engine, or compressed-air motor, and the storage losses, will be discussed in Chapter XVIII. Fig. 78 will serve as a type for two-stage tandem steam aircompressors.

# CHAPTER XIV.

# TEMPERATURE-ENTROPY DIAGRAMS FOR HEAT-ENGINES.

195. Introductory.—It will have been observed that the formulæ and diagrams of the foregoing chapters have been diagrams of work in terms of co-related pressures and volumes, and similar to the diagram traced by the pencil of the steam-engine indicator.

It has long been a conception of the master thinkers on the mutual relations of pressure, volume, and temperature for any medium, that these factors might be regarded as the coordinates, taken with respect to three rectangular co-ordinate axes, of points upon a surface, which they have called the thermodynamic surface for any medium undergoing such changes of pressure, volume, and temperature as were represented analytically by the equations of the mathematical treatment. If the axis of x be the line representing volumes, and the axis of  $\gamma$  represent pressures, the axis of z will be the axis of temperatures. The pv diagram is therefore drawn on a surface parallel to the plane fixed by the axes of p and v, either with disregard of temperatures or with the temperature assumed constant. The distance from the plane through the axes of p and v is the value of the temperature at the pressure assumed for the initial or final pressure. In all the foregoing discussion the variations of temperature have been deduced analytically from the pv variations at assumed points. It would be an interesting deduction if it should result that the exponent of an expansion curve should prove to be the consequence of the distortion of the pv sur-

TEMPERATURE-ENTROPY DIAGRAMS.

face when temperature alters with variations of pressure and volume. The projection of pv surfaces will be by lines parallel to the temperature axis.

The projection parallel to the volume axis on the plane through the t and v axes of the pv diagram when the latter is distorted as required by the temperature change in adiabatic expansion or compression gives lines or areas on the pt surface, which, however, are of no practical service. The actual cycle of a heat-motor always demands the addition to the working substance or heat medium of a quantity of heat energy which may or may not take the form of increased temperature. The *pvt* thermodynamic surface is adapted primarily for the study of phenomena involving no change of energy from without, but only transformations in which the unit weight has the same intrinsic total energy but undergoes only variation in the factors. What is desired is a scheme of graphical representation, whereby the expense of heat in the form of temperature or other form of heat energy can be represented by an area, the product of two factors, which shall be so connected to the pv diagram that the heat expenditure or return which accompanies the cycle of a piston-motor can be readily examined, or the heat work of different motors and media examined and compared, even as the pressure work is studied for design when a capacity in footpounds is desired. In gas-engines, or such as have the heatenergy liberated by combustion in the motor-cylinder directly, the temperature phenomena are more significant than the phenomena of the indicator-card in studying efficiencies. While it is also true that certain areas of work expressed in foot-pounds by the pv diagram can be translated into heatunits by the division by J = 778, the foot-pounds corresponding to one heat-unit, this can only be done with isothermal expansion of the permanent or true gases and is not exact for isothermal work of vapors or mixtures.

196. The Temperature-entropy Diagram.-It will be

recalled, however, from the discussion of thermal lines and the significance of the entropy, that when a heat medium is undergoing the operations usual to such media under the isothermal conditions, with pv a constant product, and the temperature T is not allowed to vary when the pressure or volume vary inversely together, there is a quantity which should vary when increased heat energy is imparted. If this quantity be called the entropy (§ 124), and a quantity of heat in units be added which would raise the absolute temperature through  $T_a - T_i$  degrees, the total increase in entropy for the quantity of heat energy added will be expressed by



Hence when a quantity Q of heat-units is being added to the medium at a temperature T, the energy which is being added can be expressed by the product

Heat energy added =  $T\phi$ .

In this the temperature is that at which the medium is receiving the energy but growing no hotter under the process as it is conducted at the fixed temperature of that source of heat which is supplying heat energy; and the entropy is that which belongs to the body after the increase of entropy ceases. It is the final or maximum state of the entropy, at the point of highest heat energy then under consideration.

A diagram, therefore, on which the absolute temperatures shall be the vertical ordinates and the entropy factor shall be the horizontal abscissæ will have an area enclosed between the bounding co-ordinates and the curves embodying their relations at intermediate points, which will present graphically to the eye at once the magnitude of the heat

energy supplied under differing conditions and with different heat media.

When it is remembered that the adiabatic change of volume is that in which no change in entropy occurs, or the entropy is constant, it will appear that the changes in heat energy in adiabatic expansion or compression find convenient analogies in the descent of a weight of water Wthrough a height measured from the sea-level of absolute zero down to a second level lower than the first, but still having a value greater than zero (cf. § 124). The available energy of the weight is thus

 $W(h_1 - h_2) = \text{available foot-pounds.}$ 

By analogy, if the constant entropy during adiabatic expansion descend from an initial height  $T_1$ , to a final height  $T_2$  on the absolute scale,

 $\phi(T_1 - T_2)$  = available energy in heat-units,

if a pound of the medium is under consideration.

Interesting extensions of this will be noted hereafter. It is further to be noted that the same ignorance as to the real meaning of weight or the attraction of the earth for bodies to it prevails for W in the hydraulic analogy as exists for the quantity  $\phi$  in the heat energy diagrams.

197. Temperature-entropy Diagram for an Ideal Heatengine.—An ideal heat-engine, as will be shown in a succeeding chapter, is one in which a given mass or weight of a heat medium is acted upon by heat to produce work, and returns after the completion of one cycle of operations to its initial state, the heat being supplied at a given constant temperature, and withdrawn or rejected at another constant temperature. The difference between the two quantities measures the work done in a perfect engine. The heat is therefore necessarily

supplied and withdrawn under the isothermal law for constant temperature, with change in entropy; the expenditure of energy on expansion is most effectively done by adiabatic expansion, and the rise to initial state of entropy is also to be done without change of such entropy, or by a second adiabatic. The pv diagram will therefore show a pair of adiabatic curves (Fig. 79) connected at their extremities by a pair of isothermals. To express this set of relations on the temperature-entropy diagram, with T ordinates and entropy



abscissæ, the isothermal line of increasing energy starts from the upper end of the T ordinate corresponding to the temperature (Fig. 80). The top horizontal line 1, 2, has a length representing the increase of entropy during that isothermal process. At 2 the adiabatic must begin. The expansion along an adiabatic is accompanied by no change in entropy, but by a drop in absolute temperature to the point 3 corresponding to  $T_{1}$ . At 3 the withdrawal of heat and a lowering of entropy occurs till the point 4 is reached, where the adiabatic begins, with constant entropy and increase of temperature from  $T_{1}$  back to  $T_{1}$ , closing the cycle. The heat which could not be utilized but was rejected is the area of the lower unshaded rectangle represented by  $T_{s}(\phi_{1} - \phi_{1})$ , a quantity which is obviously reduced as  $T_{a}$  is made smaller, and be-

comes zero when  $T_i$  is zero. The relation between the entire energy supplied or received by the medium

area 1256 = 
$$T_1(\phi_2 - \phi_1)$$
,

and the work done

area 1234 = 
$$(T_1 - T_2)(\phi_2 - \phi_1)$$
,

will be the efficiency of the cycle, or

Efficiency = 
$$\frac{(T_1 - T_2)(\phi_2 - \phi_1)}{T_1(\phi_2 - \phi_1)} = \frac{T_1 - T_2}{T_1} = 1 - \frac{T_2}{T_1}$$

a result to be otherwise deduced hereafter.

If the passage from 1 to 2 take place at 100 pounds pressure of steam absolute, corresponding to a latent heat of 882 thermal units, and an absolute temperature of 788 degrees, then the entropy counted from 32°, or freezing-point of water, should be

$$\frac{882}{788} = 1.117,$$

for one pound of such water, and gives the length of the line  $\phi_2 - \phi_1$ .

If the unit of heat medium was a permanent gas, then the heat added during an expansion from  $v_1$  to  $v_2$  will be the same as the work of such isothermal expansion, which was found (§ 166) to be in foot-pounds

$$w_{1} = p_{1}v_{1} \text{ Nap. } \log \frac{v_{2}}{v_{1}}$$
$$= p_{1}v_{1} \text{ Nap. } \log r$$
$$= /RT \text{ Nap. } \log r.$$

If this value in foot-pounds be divided by J, it becomes heatunits, and if the increase in energy be divided by T, at which

that increase took place, the quotient is the final value for  $\phi$ ; or (§ 124),

$$\phi = R$$
 Nap. log  $r$ .

It is a matter of indifference at what distance from the point 6 the origin or zero of entropy be taken; or, in other words, what value of  $T_0$  be taken as a datum. Temperature will of course be taken from absolute zero, if the value of heat rejected has any significance. Usually, however, it will be only the differences in temperature and in entropy which are required.

198. Deductions from the Temperature-entropy Diagram.—The use of the temperature-entropy diagram permits a direct and obvious deduction of certain facts and principles, also deducible from the pv equations but less simply.

(1) When heat passes from one body to another, the entropy of the system is increased. This follows because heat passes downward only from a warmer to a colder body (never automatically the other way); and if the heat-area transferred from the hotter and equal to the heat-area received by the lower have a higher and longer temperature-ordinate, the other area with lower and shorter temperature-ordinate must have a greater entropy value to give equality of area.

(2) Clausius announced the generalization that the entropy of the world tends to a maximum. This follows from the previous principle, since all transfers are downward unless mechanical force is introduced at the expenditure of heat to make them otherwise.

(3) The entropy imparted by adding heat so as to change the state of the heat medium from that belonging to one adiabatic to that belonging to another adiabatic is the same by whatever path the passage takes place. The diagram shows that the distance between the two parallel lines representing the adiabatics is everywhere the same (cf. § 124).

(4) The heat absorbed or given out by a heat medium in passing from one state to another is given by the area between

#### TEMPERATURE-ENTROPY DIAGRAMS.

the curve which represents the change of state and two adiabatics, one drawn through each extremity of this curve.

(5) If a series of equidistant isothermals be drawn between two adiabatics, they will cut off equal areas; or isothermals equidistant in temperature divide the heat into equal parts.

(6) If two bodies differ sufficiently in heat energy, a part of that excess of energy in the hotter body can be transformed into mechanical work by a proper heat-engine, and the remainder transferred to the cooler body. The test that all available heat energy has been transferred is that the entropy of the system has not been increased by a mere transfer as given in (I). If there has been such a transfer, the lost work is proportional to that increase in entropy.

(7) The temperature condition of a medium which is to operate adiabatically in a heat-engine is a measure of its availability, since the lower temperature limit is fixed by that of the coldest available body. The area of the diagram increases as  $T_1$  increases, when  $T_2$  is fixed by the temperature of water available for condensation. Hence:

(8) Where a given heat-energy is under consideration, increase of entropy is concurrent with a loss of availability of that energy.

(9) If the conditions of the preceding paragraph (197) be applied to one pound of steam, within very small variations of pressure, and consequently a small corresponding range of temperature, the height of the figure on the pv plane becomes also very small, or may differ from a rectangle by only an inappreciable quantity. If the symbol v denote the volume of the one pound of steam, the area on the pv diagram will be  $(p_1 - p_2)v$ . The area on the  $T\phi$  diagram will be  $(T_1 - T_2)\phi$ , the temperatures belonging to the pressures of the pv diagram. Hence

$$(p_1 - p_2)v = (T_1 - T_2)\phi$$
, or  $\phi = v \frac{p_1 - p_2}{T_1 - T_2}$ ,

giving, when the relation of pressures and temperatures are given by a table, a method for calculating the value of  $\phi$ .

(10) Since the heat energy which disappears on making a liquid at a necessary temperature and pressure into a gas at that pressure and temperature is an isothermal absorption of heat, the so-called latent heat can be expressed by the equation  $L = T\phi$ , since the entropy is the quotient of the applied heat divided by the temperature at which it was applied. Hence from section (9)

$$L = Tv \frac{p_1 - p_2}{T_1 - T_2}.$$

199. Entropy-temperature Diagram Applied to a Perfect Steam-engine, with Complete Expansion.—The perfect engine and the diagram of § 197 assumed the water to be at the boiling-point, so that in forming steam at the temperature  $T_1$  there was only the latent heat to be added. The more usual case is that at which the water is condensed after expansion to a temperature  $T_2$  by an isothermal process, and is returned as water at that temperature to the boiler as the source of heat. The water therefore requires to be heated from  $T_2$  to  $T_1$  as feed-water and then to be made steam and to receive entropy at the higher temperature.

For any temperature T, the entropy counted from an assumed origin at  $T_{a}$  will be

Entropy = 
$$\int_{T_0}^{T} \frac{dH}{T}$$
,

which, if the specific heat of water be considered as constant and equal to unity (§ 143) for the limits in question, transforms into the equation

Entropy 
$$= \int_{T_0}^{T} \frac{dT}{T} =$$
 Hyp. log  $T -$  Hyp. log  $T_{\circ}$ .

284

d.H. cat

## TEMPERATURE-ENTROPY DIAGRAMS.

the temperature T being for any state intermediate between  $T_1$  and  $T_2$ . The first element of the diagram will therefore be a logarithmic curve through the points a and e (Fig. 81)





which have for their temperature-ordinate  $T_i$  and  $T_i$ , respectively, and for their horizontal abscissæ

 $\phi_a = \text{Hyp. log } T_2 - \text{Hyp. log } T_0$ ,

and for e,

$$\phi_e = \text{Hyp. log } T_1 - \text{Hyp. log } T_e.$$

This will give the distance

 $wx = \phi_e - \phi_a = \text{Hyp. log } T_1 - \text{Hyp. log } T_2.$ 

It is not significant where the origin of entropy be taken, although in the figure the usual convention is observed, of calling the entropy of water at  $32^{\circ}$  F., zero. The weight of one pound of water is the mass of heat medium in question;  $T_1$  corresponds to  $103^{\circ}$  F., or the temperature at one pound absolute pressure, and  $T_2$  corresponds to  $373^{\circ}$  F., or the temperature corresponding to 180 pounds absolute.  $T_1$  is therefore 834 and  $T_2 = 562$ . At the point *e* steam forms isothermally, and the length  $ef = \frac{L}{T_1}$ , if the entire pound of

water passes into steam. If a percentage x only becomes steam, the length will not be *ef*, but will equal  $\frac{xL_1}{T_1}$ , less than that belonging to complete vaporization. At f the cut-off takes place, and adiabatic expansion without change of entropy reduces the temperature down to  $T_2$ , when the exhaust opens and the entropy is reduced by the isothermal condensation process, at  $T_2$  constant, which brings the cycle to the starting-point.

Examining now the heat interchanges:

Area waex = heat taken in to heat feed-water to boiling-point;

- " xefy = heat taken in during evaporation;
- " wacy = heat rejected at exhaust;
- " *aefca* = work done.

The rectangle *xefy* is the analogue to the area in the previous paragraph, where the proportion of utilized heat to the heat applied was given by the ratio  $\frac{T_1 - T_2}{T_2}$ . The area to the left of this rectangle is the heat taken in during warming of the cool feed-water, and the utilized part *abe* bears a less ratio to the whole heat supplied, or the heat is used less efficiently. This is because the heat is not supplied at a constant temperature  $T_1$ , but at a temperature gradually changing from the lower to the higher value. That is, while this engine does more work and receives more heat than the engine of the previous paragraph, the work it does requires an amount of heat more than larger in proportion.

200. Amount of Condensation in Adiabatic Expansion. —The temperature-entropy diagram can easily be extended so as to give graphically the proportion of steam and water in an adiabatic process of expansion at any stage. If a curve cfbe drawn from c (Fig. 82), whose points are found by drawing horizontals (isothermals) from the logarithmic curve ab, each

such horizontal being equal to the value of  $\frac{L}{T}$  for that particular value of T, a curve will result concave outward, because the entropy will increase as evaporation takes place at a lower value for T. Hence if af be equal to  $\frac{L_2}{T_2}$ , and the steam were entirely dry when it had cooled by expansion down to  $T_2$ , the heat disposed of during condensation would have been

F1G.82.

qfaw. But it was less than this actually, or the area pdaw. Hence there must have been some part of the unit weight of water already condensed before the temperature  $T_2$  was reached, or the length

> $\frac{ad}{af} = x$ , the percentage of steam, and  $\frac{df}{af} = 1 - x$ , the percentage of water.

Similarly, any horizontal line  $\frac{L}{T}$  between the curves *ab* and *cf* will be divided by the adiabatic *cd* into segments giving the proportion of steam at that temperature. For example, at the point *i*,  $x = \frac{li}{lk}$ .

On the compression curve of the pv cycle, it will be apparent that the condensation should be stopped at a point e on the line fa if by compression of the heat medium it is to be brought to the temperature  $T_1$  as water ready to evaporate. In other words, if adiabatic compression is to be used to restore the medium to the condition  $T_b$ , the process must begin when  $\frac{ae}{af}$  represents a proportion of steam still uncondensed, and at any point of the adiabatic compression eb the dryness is  $\frac{lj}{lk}$ .

Finally, if the entire pound of steam is not dry vapor when the expansion begins, but only a proportion x. Let the point g give the proportion of complete vaporization which has taken place, so that

$$bg = \frac{xL_1}{T_1},$$
$$x = \frac{bg}{bc}.$$

The perpendicular through g now gives the line of complete vapor adiabatic expansion, and the segments to the right as before are water. At the exhaust period,  $x = \frac{ah}{af}$ , and the

proportion of water is  $\frac{hf}{af}$ .

201. Temperature-entropy Diagram when the Expansion is Incomplete.—If the steam or heat medium expands down to the temperature and pressure represented by the exhaust at  $T_i$ , it must follow that at the end of the pistontraverse there is little or no forward effort acting upon it. This tends towards irregular motion, which must be counteracted by stored kinetic energy in fly-wheel or the reciprocating masses of the mechanism, or else the effort must be main-

#### TEMPERATURE-ENTROPY DIAGRAMS.

tained by causing the motor-pressure to drop to  $T_2$  only after the stroke has been completed. This is a practical condition which prevails very widely, and will result in changing the heat-diagram by a loss of availability along the lower line. In Fig. 83 let the expansion take place from the point of

cut-off c adiabatically until a temperature is reached at the end of the piston-traverse corresponding  $u^{m}$ to the point c' in the figure, at which pressure and temperature (above  $T_{*}$ ) the exhaust opens and



available heat is swept out by a non-adiabatic expansion and condensation, resulting in a fall both in entropy and temperature until the line af is reached proper for  $T_2$ , whence the return stroke da brings the substance back to the startingpoint.

The curve from c' to d represents the change at the end of the stroke, before the piston reverses its motion, and is a curve of constant volume, while varying in pressure and temperature from the withdrawal of heat energy by condensation from contact with some cooler body. It is described by Any point on it will be found at the intersection of points. the temperature ordinate for T with the line drawn from the curve ab, which has a length representing the percentage of steam in the mixture at that temperature. The length le is: to be to the length lk as the original volume xV' (in which V' is the volume of one pound of saturated steam at the temperature corresponding to the point c', but which must have moisture in it represented by c'n, so that  $x = \frac{mc'}{mn}$  is to the volume belonging to the assumed temperature T. Or, in other words.

$$le: lk:: xV': V, \text{ or } le = \frac{xV'}{V}lk.$$

The loss of available energy as compared with complete expansion is the area bounded by the lines c'g and dg and the curve c'eg. In the scale used in Fig. 83, the drop in temperature represented by the line cc' is from the pressure of 180 pounds to 3 pounds pressure.

202. Temperature-entropy Diagram when there is no Expansion.—If the steam follows at full pressure to the end of the piston-traverse, and is there released at full pressure to exhaust without any adiabatic expansion, there is no length



FIG.84.

cc' in the diagram, but the curve of constant volume of saturated steam as temperature is lowered starts from the corner c (Fig. 84). Points on the curve are found as before, since  $xV = V_1$ , and hence

$$le: lk:: V: V_1$$
, or  $le = \frac{V_1}{V} lk$ .

The area of lost work is the area cgd, which is greater than in the preceding case, the conditions being assumed the same, or  $T_1$  as  $834^\circ$  and  $T_2$  as  $603^\circ$  absolute. The line da, as before, shows the change in state or the condensation occurring as the piston returns.

203. Temperature-entropy Diagram when Steam is Superheated.—If the specific heat of steam undergoing a process of heating beyond the saturation point be represented by the factor 0.480 (§ 146), then the entropy will be increased after the point c is reached by an amount which will exceed that at  $T_1$  by the quantity

$$\phi_{i} = 0.480 \int_{T_{1}}^{T'} \frac{dT}{T} = 0.480 \text{ (Hyp. log } T' - \text{Hyp. log } T_{1} \text{).}$$

# TEMPERATURE-ENTROPY DIAGRAMS.

The effect of this upon the diagram is to add a curve plotted by points as given for a series of values of T' up to the maximum temperature used. The curve 3-7 is such a logarithmic

curve (Fig. 85), and the point 7 indicates that maximum temperature. At this point, if adiabatic expansion sets in, the line 7-4 is described with complete expansion. The heat taken in is increased by 3798, while the work done is increased by 5374 as the result of the superheating. It will appear that even if the superheating be considerable (200° in the scale selected) the proportionate increase is

small, as compared with the total expenditure. In other words, so much of the heat is taken in at the temperature of saturation that the subsequent raising of temperature, even to a considerable degree, offers small theoretical advantage. It offers a practical advantage, however, as will be shown hereafter (§ 229. See also § 232). The temperature may drop in expanding down to a point on 3-4, where the adiabatic line would cross the saturation curve before condensation begins. Up to this point the steam has been superheated. If the steam were to be dry at the end of expansion down to  $T_2$  then the curve 3-7 would have to be prolonged until it met the temperature ordinate through 4.

204. Plotting of Entropy-temperature Curves for Water and Steam.—For the convenient use of the entropy-temperature diagram, the logarithmic curves for the relation of temperature to entropy may be conveniently plotted on cross-section paper, and on the scale preferred for the heat diagrams, and then used directly between the desired limits in drawing in the curves of heating of water and in the heating of the steam-gas. As drawn in Fig. 86, the horizontal distance between the two curves gives the change in entropy which takes place when water at any temperature is changing into

steam at the same temperature  $\left(\frac{L}{T}\right)$ . The numerical values start at zero at 32° F., and are for one pound weight. The specific heat of water increases as the temperatures increase, it will be remembered (§ 139).



This pair of curves is also of great convenience in drawing in the curve of saturation for an adiabatic expansion in terms of pressure and volume. If the curve BCD (Fig. 87) represent a curve plotted from the tables for saturated steam, let it be required to draw the adiabatic through B. Let C be any point on the saturation curve whose pressure is given, and for which tables give the corresponding temperature. From the point b on the entropy curve drop a perpendicular (a line of constant entropy) to meet the line pc drawn through the temperature point corresponding to C. This will give the
point c'. Then the point C' on the adiabatic curve will lie at a distance NC' from the line of no volume given by the relation:

Other points are similarly found. If the initial volume in cubic feet were the result of vaporization of less than one



pound of water, or the percentage of steam was less than 100 at the beginning, then the curve of vaporization of such a mixture, as represented by  $\frac{ME}{MB}$  per cent of steam and  $\frac{EB}{MB}$  percentage of water could be found by dividing the space *ob* in Fig. 86 in that proportion, and using the ratio given by the line *ec''*. Points on the adiabatic through *E* would be found by making

This same diagram can be used to find the curve cf in the foregoing sections.

It will be apparent from the slope of the entropy curves that for each range of temperature there is a certain adiabatic for which the initial and final figures are the same. If the steam contains more than 50 per cent of water within the range given, it will become drier by expansion; if less than this, it will become wetter.

205. Transfer of the Indicator-diagram to the Temperature-entropy Diagram.—The foregoing paragraphs have made clear the methods to be used with any actual case in transferring the pv points on the curve traced by a steamengine indicator-pencil to the temperature-entropy diagramplane. The theoretical diagram is first drawn, giving the ideal condition of complete vaporization, with the expansion curve that of saturation, and with cut-off located with respect to the line of zero-volume, thus neglecting clearance. The corresponding ideal temperature-entropy diagram is then drawn, with values for  $T_1$  and  $T_2$  corresponding to the given pressures, and the entropy values laid off according to the observed data as taken from tables. The actual engine-diagram will lie within the theoretical one in both cases, by reason of the losses in pressure and temperature caused by the necessity of operating engines in air cooler than the medium, and for other causes to be discussed in a following chapter. Hence it is the problem to locate points within the theoretical pv diagram at the corresponding points within the theoretical te diagram. The vertical distances above the zero of temperature on the te diagram are taken from steam tables which give the temperature corresponding to the pressure on the pv curve. To locate the upper end of these pressure-temperature ordinates on the entropy scale, the principle is used that corresponding points in each actual diagram divide the horizontal lines of the theroretical diagrams in the same proportion. That is, if X in Fig. 88 be a point in the actual indicator-diagram, a horizontal AB is drawn through X on the pv theoretical diagram, and also a line abthrough the point on the *te* diagram which is at the distance from the line of zero temperature required for the pressure corresponding to X on the other. Then divide ab in the same proportion as the point X divides the line AB, which determines the desired point x. It will be apparent that if the volume of the liquid be not considered, the percentage of

#### TEMPERATURE-ENTROPY DIAGRAMS.

liquid evaporated when X denotes its condition will be in the same ratio to AB, denoting complete evaporation, as the heat required for this evaporation will be to the heat required for such complete evaporation. Or,

## AX:AB::ax:ab.

This can also be worked out from entropy tables or from the diagram of § 204. All the points of the indicator-diagram can thus be located, and an area enclosed representing the heat energy attaching to the work in foot-pounds of each pound of steam used, and its departures from the ideal con-



sumption measure the efficiency of its operation. Detailed examples will be referred to hereafter when certain other points have been discussed. Its exact application involves that certain desirable refinements should be made more clear.

# CHAPTER XV.

# THE IDEAL CYCLE HEAT-ENGINE.

**210.** Introductory.—In the discussions of the preceding chapters certain principles have been assumed by implication, to which it is desirable to refer now more in detail.

It has been made obvious by the heat diagrams of the preceding chapter that heat energy is made available for mechanical work by the existence of a difference in heat level between bodies. Just as no work could be done by waterpower if all water were at a dead-level of the seas, so no mechanical effect could be produced, however great the amount of actual heat energy, if all bodies were at a dead-level of temperature. Hence it is desirable to separate  $T_1$  and  $T_2$  by as great an interval as possible, in heat-engines.

Secondly, the lowest available temperature will be fixed by the temperature pertaining to that climate or latitude which attaches to the best cooling medium there. This is usually water, by reason of its high specific heat, and it rarely can be counted as having for the year round a temperature as low as 50° F. in the temperate zone. Hence, it will be impossible to convert the whole of any heat supply into work, because the temperature  $T_2$  thus fixed is so far above the absolute zero of temperatures that a considerable quantity of heat must always be unavailable, and will be swept out by the exhaust.

Thirdly, if the highest temperature be a temperature  $T_1$ , and the lowest practicable temperature be  $T_2$ , it is obvious that any heat taken in below  $T_1$  will have less availability for

- Charles With the stand and the stand

THE IDEAL CYCLE HEAT-ENGINE.

conversion into work than if it had been taken in at  $T_1$ , or will be less effective. Similarly, it will entail a loss if any heat is rejected above a temperature which corresponds to  $T_2$ .

Fourthly, complete expansion will be more efficient than incomplete expansion, and should be so managed that there are no losses from eddies or internal movement in the medium such as will occur with a free expansion or one which is imperfectly resisted by the external resistance being overcome.

It was upon the basis of these assumptions and deductions that Sadi Carnot in 1824 proposed the classic conception of a heat-engine whose heat medium should traverse a succession of pv relations between two fixed limits of temperature, and return to its initial state after each traverse. The complete path he called a *cycle*. He applied it first to a permanent gas, used as a heat medium. The Carnot cycle, and the first and second laws of thermodynamics, need to be noted.

211. The First Law of Thermodynamics.—The science of thermodynamics means by definition the science of heat energy. Its first and fundamental law has already been enunciated (§ 9), that heat and mechanical energy are mutually convertible; and that heat requires for its production the expenditure of a definite number of units of work, or by the expenditure of heat a definite number of units of work can be done. It is obvious that back of this law lies the fundamental conception of the conservation of energy, which may be stated: "Energy cannot be created nor can it be annihilated by any physical processes which the mind can conceive."

212. The Second Law of Thermodynamics.—What is known as the second law of thermodynamics has been variously enunciated by the great masters who have studied it. The axiom of Clausius may be treated as a first section of the second law: "Heat cannot pass of itself from a colder body

to a hotter one," meaning that of two bodies, that to which heat energy passes is always the colder one, unless mechanical energy comes in from without. This is otherwise expressed by saying that "A self-acting machine cannot convey heat from one body to another at a higher temperature."

Rankine's statement of the second law may be combined with the foregoing: " If the absolute temperature of any uniformly hot substance be divided into any number of equal parts, the effect of each of those parts in causing mechanical work is equal." That is, provided the work of transfer is done in the most efficient way, the equal intervals into which any range of temperature may be divided are equally effective when heat is allowed to pass through all the intervals from the top to the bottom of the range. This is graphically obvious from the temperature-entropy diagram of Fig. 80. It assumes, therefore, in it the conception of the absolute scale, and that Carnot's cycle is used in effecting the transfers of heat into work.

213. Carnot's Cycle.—Carnot's cycle is the realization of the expansion, compression, and heating and cooling of a perfect gas under conditions which § 197 has shown to be those of maximum efficiency. The heating and cooling must be done at a constant temperature, and therefore these changes of pressure and volume in the working cylinder must be by the isothermal law to secure maximum effect. The expansion must be done without additional heat supply and without loss externally; it must therefore be adiabatic. The compression similarly must be without change in entropy, but only cause a change from the temperature  $T_2$  back to  $T_1$ ; the compression must therefore be adiabatic. The conditions, therefore, imposed by the Carnot cycle are those presented in Fig. 89. The cylinder and piston must have no heat capacity, nor friction. The bottom of the cylinder is a perfect con-The element A is a heat-source of great capacity at ductor. a temperature  $T_{1}$ , and the element C is a condenser of great

### THE IDEAL CYCLE HEAT-ENGINE.

capacity maintained at  $T_2$ . Both the source of heat and the cold body are so capacious that no change in  $T_1$  or  $T_2$  can occur while the pound of gas behind the piston is heated by contact with the heater, and cooled by contact with C. B is a non-conducting cylinder-cover, for use when the perfect gas is expanding adiabatically and without influence of heat and



cold. The relations of pressure-volume for the various stages are given by the subscripts on the diagram. The specific heat at constant pressure will be denoted by  $C_{p}$  and the ratio between the initial and final volumes  $\frac{V_{c}}{V_{d}}$ , which must be the same as the ratio  $\frac{V_{b}}{V_{a}}$ , will be denoted by the factor r, or the ratio of the expansion.

There will be four steps or stages. The student-reader is advised to compare the procedure given in \$\$ 197–198:

(a) Apply the heater A. The piston rises; the unit weight of gas expands isothermally at  $T_1$ . The heat energy taken in is

$$H_1 = CT_1$$
 hyp. log  $r$ ,

which all goes to increase entropy.

(b) Heater A is removed, cover B is applied, and the piston moves out at the expense of its temperature, without change of entropy, until the temperature falls to  $T_a$  by such expansion against external resistance.

(c) Take away cover B and apply cool body or condenser C at  $T_2$ . No change will take place, because the expansion is complete, unless the piston be pushed back. But if the piston is retracted the smallest tendency to an increase of temperature above  $T_2$  is at once met by a flow of energy into the condenser. The gas loses entropy down to the stage represented by  $T_2$ , and the amount rejected to the condenser will be the difference between the entropy as  $T_1$  and  $T_2$ , or

$$H_1 = CT_2$$
 hyp. log r.

(d) Remove the condenser C and replace B when the point d is reached. The determination of this point has already been touched upon and found graphically (§ 199). The piston is now still further forced in and back until the gas has its initial volume  $V_a$ , and if the point d was rightly chosen it has also the temperature  $T_1$  at which it started because the compression has been adiabatic, and the cycle has been completed. For the relations of  $V_b$  and  $V_c$  to produce the desired final temperature  $T_a$ , refer to § 168, which will give

$$\frac{T_1}{T_2} = \left(\frac{V_c}{V_b}\right)^{n-1} \text{ and } \frac{T_1}{T_2} = \left(\frac{V_d}{V_a}\right)^{n-1}.$$

according as the location of b or d is desired.

It will appear, therefore, that the Carnot cycle gives an external work in foot-pounds which will be 778 times the difference between the heat rejected and the heat received, or, for the complete cycle,

Work = 
$$778C(T_1 - T_2)$$
 hyp. log r.

which is 778 times the area included in the diagram of curves (Fig. 89), all transfers having been made at maximum efficiency.

#### THE IDEAL CYCLE HEAT-ENGINE.

214. Carnot's Cycle Reversed.—In the foregoing conception, the curves have been described by starting at a and following round the cycle clockwise, as it were. If, however, the start be made from a and the curves described in the reverse order, the condition of affairs is that in which mechanical energy is converted into heat, or Carnot's cycle is reversed. What happens then will be:

(e) The cover B being in place, the piston is drawn to the right till the point d is reached. The adiabatic ad is traced, and the gas cools down to  $T_{2}$ .

(f) Cover B is removed, and condenser C is applied. The piston is drawn out still further to the right, but as the gas is in contact with C at the temperature  $T_2$  it cannot fall below that temperature in expanding, and heat flows from the condenser according to the isothermal law, to the amount

$$H_{s} = C_{*}T_{v} \text{hyp. log } r.$$

(g) The point c being reached, the condenser is detached, the non-conducting cover B is replaced, and by external mechanical energy the piston is forced back to b. The compression being adiabatic, the temperature rises to  $T_1$ , without rejection of heat in the process.

(*h*) Further compression back to initial volume with cover B removed, and the heater A applied. Heat flows into A because the compression must be isothermal, the curve ba is described and the heat which passes into A will be

$$H_{\star} = C_{\star}T_{\rm l}$$
 hyp. log r.

It will appear from a comparison of  $H_1$  and  $H_4$  and of  $H_2$ and  $H_3$  that these are equal, or the same amount has been put back into A by the reversed process as was taken out in the direct cycle, and the same amount was taken out of C in the reverse process which was rejected into it on the direct cycle.

A cycle capable of being operated in either direction is called a *reversible cycle*.

302

215. Carnot's Criterion of Reversibility .- It is not difficult to show that the efficiency of the reversible engine is a Let it be conceived that there are two heatmaximum. engines working between the same limits  $T_{1}$  and  $T_{2}$ , one nonreversible operating by the direct cycle, to be designated by D, and the other a reversible engine operating on the reverse cycle R. Suppose both to be capable of being connected to the same heater A and the same condenser C and to withdraw and apply heat as they operate. Let them be supposed equally frictionless, and that they are connected together so that D drives R, as a steam-engine drives an aircompressor, without loss. Then if the two machines were equally efficient, the heat withdrawn from A to drive D would be restored by the pumping action of R, and the heat added to C by D would be withdrawn by R. The result would be an indefinite continuance of the action, without addition of outside heat or mechanical energy. If, however, R is more efficient than D, and puts back into A more heat than D has withdrawn from it in order to drive R, then it will follow that the cold body from which R derives its heat is transferring heat to a warmer body, which is contrary to all experience, and to the enunciation of that experience in the second law of thermodynamics. But D is any engine working between the same limits of  $T_1$  and  $T_2$ . Hence no engine can be more efficient than the reversible one. But may not the direct engine D be less efficient than the reversible engine? This is met by assuming both engines to be reversible, and following the same reasoning. It is similarly proved that neither can be more efficient than the other: whence:

(1) The reversible heat-engine has the maximum efficiency when the limits  $T_1$  and  $T_2$  are given.

(2) All reversible heat-engines working between the same limits of temperatures are equally efficient; that is, the efficiency in the thermodynamic sense is independent of the heat medium.

This second form of enunciation has been preferred by

some for one of the statements of the second law of thermodynamics.

**216.** Efficiency in the Carnot Cycle.—Remembering that the efficiency of any machine is the ratio which the total available work bears to the work actually realized, the efficiency of a Carnot engine will be:

 $\frac{\text{Heat utilized}}{\text{Heat applied}} = \frac{C(T_1 - T_2) \text{ hyp. } \log r}{CT_1 \text{ hyp. } \log r} = \frac{T_1 - T_2}{T_1} = I - \frac{T_2}{T_1}.$ 

But the foregoing discussion has shown that no reversible heat-engine can be more efficient than another working between the same temperature limits. Hence the above expression for efficiency is that of maximum possible efficiency, or is the measure of perfect efficiency for all engines receiving and rejecting heat under the conditions assumed by Carnot.

Most heat-engines, with the exception of the gas-engine, operate under this assumption. In the steam-engine, for instance, the capacity of the cylinder up to cut-off is filled by vaporization at a constant pressure and temperature, and the condensation or exhaust is at a lower constant pressure and temperature; the expansion and compression are adiabatic, as assumed by the Carnot requirements. The difficulty is, however, that the actual engine does not and cannot reach the ideal efficiency for reasons to be made apparent in the next chapter, which are concerned with the actual construction of the steam-engine and are not capable of being reduced to nonexperimental statements.

It will be observed in discussing the conclusion:

Efficiency = 
$$\frac{T_1 - T_2}{T_1} = I - \frac{T_2}{T_1}$$
.

(1) The efficiency increases with higher temperatures (and pressures) for the heat medium as it enters.

(2) The lower temperature being fixed by available cooling bodies for condensers, the efficiency can never reach unity while  $T_2$  has to be so large. Figs. 90 and 91 show a plotting





of such efficiencies with  $T_2$  chosen as 212° F. in Fig. 90 and with  $T_2$  as 125° for Fig. 91.

(3) The effect of condensing the steam is to lower  $T_{s}$  and of compounding cylinders is to make it easier to raise  $T_{1}$  (§§ 172-174).

(4) The efficiency does not include pressure or specific heat or other physical properties of the medium, but is dependent on temperature limits alone.

(5) Air as a heat medium, allowing a higher value for  $T_1$  before the pressure becomes troublesome, is a more efficient heat medium than steam where this difficulty occurs. There must be some other things than heat efficiency to consider.

(6) The low efficiency of the steam-engine thermally is not a reflection upon its effectiveness as a means of transforming the *available* energy of a fuel into mechanical energy. The mechanical efficiency is not to be confused with the thermal efficiency. This latter is limited by the greatness of the minimum value for  $T_2$ .

217. Rankine and Clausius Cycles.-The Carnot cycle for the steam-engine involves the condition, which is not usually realizable, that the heat medium is raised in temperature by compression. Rankine introduced a cycle and elaborated formulæ for its efficiency in which the succession of curves are of an ideal indicator-diagram. The isothermal is horizontal for the period of admission; the expansion is either an adjabatic or a saturation curve; the isothermal for the back-pressure line is either at the level of complete expansion or below it; and finally the effect of the water-volume in the steam and any effect of entrapped steam used as a cushion in compression are neglected. This cycle, like the Carnot, is approachable, but not attainable in practice. It offers the advantage that in the design and test of an actual engine it may be compared with an ideal one which may be called a purely thermodynamic machine of similar construction and like limits of pressure, temperature, and degree of expansion.

A cycle by Clausius is the Carnot cycle without compression, but with complete expansion down to the back-pressure line. It permits the measure of the loss incurred when the Rankine cycle is used without such complete expansion.

218. Theoretical Weight of Heat Medium for a given Work.—An interesting practical deduction from the Carnot equation for efficiency is easily made. Since

$$\frac{T_1 - T_2}{T_1} = \frac{\text{Heat utilized}}{\text{Heat applied}},$$

the second member can be reduced to foot-pounds by multiplying both terms by 778. Hence

$$\frac{T_1 - T_2}{T_1} = \frac{\text{Work utilized in foot-pounds}}{778Q_1},$$

in which  $Q_1$  is the product of the weight of heat medium into the heat which it has absorbed in reaching the temperature  $T_1$ . In the case of steam, this heat will be the heat of vaporization, or the latent heat, or the product  $T_{\phi}$ , when the feedwater at the temperature corresponding to the pressure  $T_1$  is made into steam at that pressure. In § 139 this was designated by r, and is found by subtracting the heat of the liquid (q) from the total heat  $(\lambda)$ . Hence it is only necessary to substitute for the work term the number of foot-pounds of work corresponding to a horse-power per hour ( $60 \times 33,000 =$ 1,980,000), and for  $Q_1$  a factor made up of the unknown weight of heat medium sought multiplied by its heat of vaporization at the temperature  $T_1$ . That is, if M denote the desired weight of heat medium,

$$Q_1 = Mr_1$$
.

Whence

$$\frac{T_1 - T_2}{T_1} = \frac{1980000}{778Mr_1},$$

whence

$$M = \frac{T_1}{T_1 - T_2} \times \frac{2545}{r}.$$

It is interesting to note that the weight of heat medium decreases as the heat of vaporization increases, and that the latter is the measure of the amount of work which will be done by a unit of weight of the medium. The factor 2545 is interesting as presenting the number of units of heat to be converted per hour into work for each horse-power.

A table of efficiencies and theoretical water-consumption per horse-power may be computed on proper assumptions for condensing and non-condensing engines as follows :

Gauge Pressure	Condensing.		Non-condensing.		
above Atmosphere. Initial.	Efficiency. $\frac{T_1 - T_2}{T_1}$	$\begin{array}{c c} \text{fficiency.} \\ \hline T_1 - T_2 \\ \hline T_1 \end{array} \end{array} \begin{array}{c} \text{Pounds of Steam} \\ \text{per H. P. per} \\ \text{Hour.} \end{array}$		Pounds of Steam per H. P. per Hour.	
15	0.189	14.3	0.053	50.9	
30	0.215	12.8	0.084	32.8	
60	0.249	11.4	0.124	22.9	
100	0.278	10.5	0.157	18.4	
150	0.302	9.8	0.186	16.0	
200	0.320	9.5	0.207	14.6	
300	0.347	9.0	0.238	13.1	

WATER CONSUMPTION AND EFFICIENCY.

The temperature  $t_2$  is 212° F. for non-condensing engines, and for the condensing engines it was made 115°, corresponding to 1.5 pounds pressure.

In engines using a permanent gas like air, which has no heat of vaporization, as in the case of vapors, the factor r is replaced by latent heat of expansion, which is the product of the entropy by the temperature.

The same result can be secured from the temperatureentropy diagram directly. Assuming the diagram of Fig. 80,

which presents the Carnot cycle of maximum efficiency, it is apparent that the temperature-entropy area in heat-units can be made the area in foot-pounds by multiplying both members by 778. That is,

Area in heat-units 
$$= (\phi_2 - \phi_1)(T_1 - T_2).$$

Area of work in foot-pounds =  $778(\phi_2 - \phi_1)(T_1 - T_2)$ .

But the factor  $\phi_1 - \phi_1$  is the change in entropy at  $T_1$  in passing from water at  $T_1$  to steam at  $T_2$ , which is  $\frac{r_1}{T_1}$  for one pound of fluid and becomes  $\frac{Mr_1}{T_1}$  if an unknown weight is to do the work imposed by giving a value to the foot-pounds of the first member. Hence

Water per H.P. per hour =  $778 \frac{Mr_1}{T_1} (T_1 - T_2)$ .

Whence

$$M = 2545 \frac{T_1}{r_1(T_1 - T_2)},$$

as before.

In the case of a permanent gas, the value for  $(\phi_2 - \phi_1)$  for an isothermal expansion was found to be

R hyp. log r.

Whence the equations become

Work of one H.P. per hour = 778MR hyp. log  $r(T_1 - T_2)$ ,

whence

$$M = \frac{2545}{R \text{ hyp. } \log r(T_1 - T_2)},$$

in which r is the ratio of the final to the initial volumes in the expansion process.

# THE IDEAL CYCLE HEAT-ENGINE.

**219.** Recapitulation.—The Carnot cycle being the cycle within which must lie the performance of actual engines, and to which they should approximate as closely as possible to make the actual value of M small and to make the expenditure of fuel to raise it to  $T_1$  as small as possible, it becomes of interest to examine the causes of difference between the ideal and the real engine, topics which form the next chapter. But it should not be overlooked as a fundamental departure from actual conditions, that the Carnot cycle for the steam-engine demands three impossibilities:

(1) That the body of water in the boiler be always at the temperature  $T_1$  no matter what the exigencies of feeding, or what feed-water temperature be available, and that there be no drop of temperature in supplying the cylinder.

(2) That all heat be rejected from the cylinder at the lower temperature,  $T_{a}$ , and not by a process of gradual cooling. That is, the steam in giving up its heat shall be at the temperature of the condenser; if it were, it would not give it up.

(3) That all heat delivered to the medium shall be carried down from  $T_1$  to  $T_2$  purely adiabatically, without being diverted by radiation or contact or other methods of transfer, in spite of the conducting qualities of the structural materials used, in spite of eddies in the steam itself, and in spite of possible free or unresisted expansion, "drop" into the lower pressure of condensing appliances, receiver, and the like.

Finally, the thermal and not the mechanical character of the efficiency equation needs to be emphasized, and its application only to any one medium to which it is for the moment applied. A study of the temperature-entropy diagram, however, for a Carnot cycle, shows that when the medium changes and another is used which has a different entropy value at  $T_1$ , the efficiency ratio changes in the same proportion (another way of saying that the thermal efficiency depends on the temperature ratio alone); but the Carnot equation does not say that the same weight of different media will

310

be required with a same temperature range, nor that all media have to be used at the same range, nor that the heat to be expended to raise all media to  $T_1$  is the same, nor the extent of condensing appliances to cool these different media to  $T_2$ . This belongs to a different department of the subject, and will be treated in Chapter XXI.

# CHAPTER XVI.

# THE CYCLE OF THE ACTUAL STEAM-ENGINE.

220. Introductory.—It has already been said that the actual engine must depart from the Carnot ideal because—

(1) Heat is not received from the furnace at a constant high temperature  $T_1$ .

(2) Heat is not rejected at a constant lower temperature  $T_{2}$ .

(3) All the steam-heat energy is not devoted to work.

221. Elements of Departure of the Actual Cycle from the Ideal Carnot Cycle.—But besides these, and belonging to a class which the engine-designer can control in part, are other sources of loss or ineffectiveness, to which attention must be called. Among these are:

(4) Loss of pressure and temperature from friction and radiation and conduction in the steam-pipe between the boiler and the engine.

(5) For this cause  $T_1$  at the engine is not the same as at the boiler. The steam is therefore not dry, but carries a mist of watery particles resulting from condensation, and the entropy value is not that belonging to dry steam at  $T_1$ .

(6) In the engine itself, at throttle-valve, governor-valve (if any), and at the ports of the valve or valves by which distribution of steam is effected into and out of the cylinder, a loss of pressure occurs by the process known as "wire-drawing" from friction and the work of overcoming it.

(7) Condensation, and entropy-drop by contact of the hot

incoming steam with a cylinder-head and one side of the piston, and the steam-passages to that end of the cylinder, which have just ceased a contact with steam at the lower temperature  $T_s$ . The exhaust steam has cooled these surfaces off and swept out the heat with itself, and initial condensation covers these cooler surfaces with dew. This is an entropy-leakage of which theory can take account with difficulty, and which yet affects greatly the value of M (§ 218).

(8) Even if the cylinder-walls and cover were absolutely non-conducting and non-diathermanous, a condensation of steam will occur after cut-off and during the process which is alleged to be adiabatic. The conversion of heat into work must result under non-isothermal conditions in the condensation of a certain percentage of steam to water, or (unless steamjacketed) the actual curve of the indicator-card will fall within the curve of saturation for steam as laid out from tabular values (§ 200). It happens, however, usually, that as this condensed percentage of moisture lying on the cylinder bottom or in the form of dew on the metallic surfaces is reduced in pressure by the increase in cylinder volume during expansion, the point is reached at which the equalization of temperature and boiling-point for water is also reached. When this occurs, if the cylinder-walls will furnish the necessary heat energy to supply entropy to this water, it will absorb the heat of vaporization r which it requires at this lowered pressure, and the steam formed will raise the pressure ordinate on the indicator-diagram, and the cylinder metal has been cooled still further. Here again the theoretical diagram gives no hint of this entropy reaction, but the incoming steam has to supply the new heat called for by an increase in the loss discussed under (7). The heat supplied to the steam by this re-evaporation of condensation is swept out at exhaust and is lost.

(9) At the end of expansion the exhaust opens, and the release occurs to a condenser or to the atmosphere. It has

# THE CYCLE OF THE ACTUAL STEAM-ENGINE. 313

been already noted that in steam-engines it is not usual to secure complete expansion (§ 201) because the forward effort becomes ineffective at the end of the stroke. If the valvegear is automatically adjusted by variation in the load, without change in steam-pressure, it may easily happen that the pressure at the release is rarely or never that of the back-pressure or exhaust line. If above that point, there is the loss from non-adiabatic expansion on the temperature-entropy diagram (§ 201), and the exhaust sweeps heat out unutilized. If the terminal pressure at release is less than that representing the back-pressure, the expansion curve has crossed the back-pressure line, forming a loop at this end of the diagram. The fly-wheel must therefore be making the engine overcome its own friction, and be doing a little pumping action in the cylinder; while the contents of the exhaust-passages will evince a tendency to reverse their outward direction, at a cost of mechanical energy, and the expanding steam loses by free or unresisted expansion.

(10) During exhaust the pressure attaching to the actual  $T_a$  of the condenser or the atmosphere may not prevail in the cylinder, by reason of friction or wire-drawing of the exhaust outflow from valves, passages, and piping connections.

(11) During exhaust at or near  $T_2$  the cylinder-walls and piston-head are radiating heat to the exhausting volume of saturated steam, containing also perhaps a mist of water unevaporated. This is a different heat from that which the heat medium is giving up, but which must be supplied at the next stroke by the incoming steam [see (7)].

(12) The exhaust-valve and port probably close before the end of the return stroke, entrapping some steam and compressing it adiabatically in the main, raising its pressure and temperature as the volume diminishes. If prudently done, the pressure may rise to the initial pressure. It is usually done by the excessive living force of the reciprocating parts which would otherwise be wasted, and the elastic steam-cush-

ion serves to lessen the flexing effect on the crank-pin which would otherwise receive it. The heat due to this compression is regained for the cylinder-walls, although under absolutely ideal conditions the heat represented by the energy of the reciprocating parts would not have been wasted upon them in the first place, but should all have been absorbed in useful work on the crank-pin. If compression is carried too far, a loop forms on the top of the compression curve, with free expansion losses, excess of pumping action, and arrest of steam-flow into the cylinder.

(13) The clearance space left between the piston and the cylinder-head at each end, to prevent impact, to lessen trouble from water, and to give a volume in which forward pressure may establish itself at dead-centres, adds a volume to the actual piston displacement caused by the stroke. The valve-passages add a further necessary waste volume, which must be filled with steam at full pressure and temperature at each stroke, and which is exhausted (less the compression or cushion steam) without having done as much work as if the expanding volume had been smaller. The heat to make this wasted volume of steam is lost.

(14) It is only in condensing engines that the exhausted steam after condensation is pumped back into the boiler at  $T_2$ . When the engine exhausts into the atmosphere whose temperature is  $T_2$  it is apparent that there is a jolt in the heat cycle, representing the difference usual between the temperature of the exhaust-steam and the temperature at which the feed-water can be usually presented to the boiler. If the feed-water is preheated by a heat-supply outside of the boiler-furnace, and other than a wasted heat, this must be allowed for.

(15) The ideal cycle assumes that the unit weight of medium is raised from  $T_i$  to  $T_1$  by an adiabatic compression. In actual conditions there is a gain in entropy in the gradual

## THE CYCLE OF THE ACTUAL STEAM-ENGINE. 315.

heating by the fire from  $T_2$  to  $T_1$ , and a loss because this gain is not all made at  $T_1$ .

(16) During the cushion-compression heat is transferred to the medium by the mechanical work, and some of this increase in heat condition is transferred to the metal of pistonhead, cylinder-head, walls, and passages.

(17) The loss of heat represented by the equivalent of the mechanical energy consumed wastefully in the friction of the engine mechanisms, which is caused by the size and weights of the parts, packing-friction, valve-friction, and the like, which are independent of the load or work done.

(18) Any additional friction (usually small in amount) chargeable to the load of the engine in augmenting its friction when running with no load.

The above list enumerates the points in which every actual engine is likely to differ from every other actual engine, and the losses which for this reason are incapable of being included under a generalization, and are to be experimentally determined for each engine or each type of engine. For this reason they have been called *extra-thermodynamic* losses, or internal wastes. It is the object of the engineer or designer to reduce these losses as far as possible in new constructions, and in making guarantees as to performance he should be able to evaluate their proportion to the whole expenditure of energy. It will be convenient for their further study to group the principal sources of heat loss into the following headings:

- I. Loss by wire-drawing.
- II. " " clearance.
- III. " " condensation, initial.
- IV. " " during expansion.
- V. " " re-evaporation.
- VI. " " incomplete expansion.
- VII. " "unnecessary back-pressure, or imperfect vacuum.

The other losses are usually met by an allowance in cylinder volume to overcome them, and by that increase in cylinder volume their effect is introduced into the groups above, and need not be accounted for a second time. It is safe to say that at the end of the nineteenth century the thermal wastes are not far from 20 per cent, and the dynamic losses are less than 10 per cert.

222. Progress in Steam-engine Efficiency.—The early historic engines of Savery and Newcomen in England suffered greatly from heat-wastes, by reason of their using the working-cylinder barrel as a place within which to condense the steam after the stroke. James Watt's invention of the separate condenser in 1769 was a most important step toward reducing condensation. The following diagram, Fig. 92, has



been prepared to present to the eye the improvements of the last one hundred and fifty years, showing at the left the reduction of thermal wastes by devices to be discussed presently, and at the right hand the corresponding increase in

# THE CYCLE OF THE ACTUAL STEAM-ENGINE. 317

performance per hundred pounds of pure carbon burned. This latter is given in millions of foot-pounds of work per 100 pounds of pure carbon.

The elements which seem to have had most influence in this result may be said to be:

I. The separate condenser.

- 2. The higher temperature and pressure limit.
- 3. The steam-jacket.
- 4. The multiple-expansion principle.
- 5. Better mechanical construction.
- 6. Higher piston speed.
- 7. Increasing size of units.

223. Ideal and Actual Efficiency Compared.—The elements which affect actual efficiency are numerous, and hence care is necessary in making comparisons to select fair figures. Certain of the losses, being practically fixed in amount and not dependent upon cylinder volume, will be much greater a proportion or percentage in a small engine than in a large one, and will be greater when the large engine is running below its rated power or at best effect. An observed result, with a 200-H.P. engine at 100 pounds boiler-pressure, with a back-pressure of 5 pounds above vacuum in its condenser, gave results at various ratios of expansion which are given in Fig. 93, on which the Rankine ideal water consumptions have also been plotted, and a curve for the friction and radiation losses.

The thermal units per H.P. are taken as 1000 for each pound of water.

If pressures belonging to the temperatures  $T_1$  be made to vary, curves similar to those in Fig. 94 will result. These belong also to the simple condensing engine of average size, and larger engines will do better, but small ones not so well.

The effect of increasing the ratio of expansion by the expedient of expanding continuously through two or three cyl-





# THE CYCLE OF THE ACTUAL STEAM-ENGINE. 319

inders is made apparent by Fig. 95. The curves A are those for the smaller cylinder of a 9- and 16- and 24-inch diameter triple engine, with 36-inch stroke, working as a simple en-



gine. The curves B are derived when the small cylinder and intermediate are used to form a compound engine; the curves C represent the triple engine, with the corresponding ratios of expansion possible. The dotted lines give unjacketed conditions; the full line shows results with cylinders jacketed.

The table on page 320 also gives water consumptions from test and experiment.

224. Methods of Reducing Internal Condensation.—It will be apparent that the compound or multiple-expansion engine should offer the advantage of diminished wastes from condensation, when it is remembered that the largest cylinder in the series is the unit cylinder, which determines the horsepower of the engine and must be present whatever system of

		1 72			
Ъ	e	ſ	е	ſ	
Type of Engine.	Feed-water per Indicated Horse-power per Hour.				
- , , , , , , , , , , , , , , , , , , ,	Non-condensing.		Condensing.		Cent Gained by Con-
Name.	Probable Limits.	Assumed for Compari- son.	Probable Limits.	Assumed for Compari- son.	densing,
Simple high-speed Simple low-speed Compound high-speed. Compound low-speed Triple high-speed Triple low-speed	Lbs. 35 to 26 32 to 24 30 to 22 	Lbs. 33 29 26 * 24	Lbs. 25 to 19 24 to 18 24 to 16 20 to 1234 23 to 14 18 to 1234	Lbs. 22 20 20 18 17 16	33 31 23 25 29

\* The terms "high-speed" and "low-speed," it is believed, refer to the number of revolutions per minute, and not to the piston-travel. Low-speed engines are Corliss engines and the like, with releasing cut-offs, and have a rotative speed usually less than 120 revolutions per minute.

expansion is used. This is because in the horse-power formula PLAN refers to a pressure over an area, or a pvresult, in which the volume is always the volume at the end of the completed stroke. What has been done is therefore to add certain smaller cylinders between the boiler and the largest low-pressure cylinder, among which the temperature range is distributed, each taking a fraction of the range. Reactions between the cylinder-metal and the hot medium within it are active in proportion as the difference in their temperatures is large. By diminishing the temperature range in each, the expansion in each cylinder approaches the adiabatic law, and heat is saved.

Secondly, compounding utilizes in part at least, in the later cylinders, the steam vaporized by the metal wall reactions in the early cylinders. Some heat is thus recovered which would have been wasted in the simple engine.

Thirdly, the succession of the cylinders permits a regenerating of the quality of the steam by reheating between cylinders.

## THE CYCLE OF THE ACTUAL STEAM-ENGINE. 321

Fourthly, the compound engine favors a high value for  $T_1$  and hence a high range in availability, and a high efficiency value or a low value for M (§ 188) when  $T_2$  is fixed by limitation.

The compound or multiple-expansion principle has many and other advantages (see § 173). These are sufficient, however, to more than offset the losses caused by the succession of cylinders, the losses in passing from one to another, and, where fuel cost or the size of the plant will warrant it, to neutralize the increased cost of the additional cylinders and mechanism. For the specific object of reducing condensation in the steam-cylinder, the steam-jacket, and the use of superheated steam, are to be particularly discussed.

225. The Steam-jacket. - The steam-jacket was first devised and applied by James Watt, "to keep the cylinder as hot as the steam which enters it." Constructively, it is an annular space surrounding the cylinder-barrel and chambered spaces in the cylinder-heads into which steam hot from the boiler shall be kept actively circulating. Such boiler-steam shall continually put back into the metal of the working barrel the heat swept out at the exhaust from evaporation during the expansion and from contact with the relatively cool exhaust-steam. It is intended, therefore, that internal initial condensation shall be made less because the working charge of steam finds the cylinder hotter when it enters it than when such jacket is not present nor in action. Furthermore, during expansion after cut-off, the barrel-jacket will furnish the heat for any re-evaporation, or shall heat the cylinder-metal again after it has furnished the heat energy represented by such re-evaporation of water either the result of adiabatic expansion or present as remains of initial condensation. Evaporation of water mechanically entrained may also occur to cool the metal walls.

The structural difficulties which must be met in casting and using a cylinder with hollow walls (particularly when the

length is considerable) have been elsewhere considered ("Power Plants," p. 291, § 162). The unequal expansion is likely to make one wall crack; or if made in separate cylinders, the inner fitting as a liner within the jacket, the expense of fitting and the joint at the end are difficulties.

In comment on the steam-jacket it may be said:

(1) The heat which the jacket supplies to the cylindermetal is surrendered at the cost of its own condensation. Hence the net gain from jacketing is the algebraic sum of a loss and a gain.

(2) The heat-supply to prevent initial condensation is mainly from the heads, and from the piston if this latter is also jacketed, because the barrel surface only becomes equal to the head surface when the piston has travelled a distance equal to one quarter of the cylinder diameter.

(3) After cut-off and during expansion the jacket would appear to be supplying a heat-flow to the gradually cooling steam which tends to transform the expansion curve from an adiabatic towards an isothermal, and furnish an entropy change opposed to maximum efficiency in Carnot's cycle.

(4) The hot live-steam jacket, keeping the average temperature of the cylinder higher than when the latter is not jacketed, will increase the loss by exterior radiation, unless at the same time increased precautions are taken by use of lagging and non-conductors of heat to diminish this action both at heads and at the barrel.

(5) The effective action of the steam-jacket demands that the walls of the "liner" or barrel proper should be highly conductive of heat. Transfer of heat by contact and conduction is very rapid, but cannot be truly instantaneous. Hence it would appear that jackets are more effective when their time of action on the working steam is lengthened, and when the weight of the working steam is less in proportion to the quantity of heat in units present in the jacket. The first statement is confirmed by the generally observed fact that an

### THE CYCLE OF THE ACTUAL STEAM-ENGINE. 323

engine of slow rotative speed derives more benefit from jacketing than quick-acting engines; and the other statement is confirmed by the fact that the greater the ratio of expansion, or the earlier the cut-off in the single cylinder or in the compound, the greater the gain from jacketing. The time of most effective action in heating is that from cut-off on one stroke to the beginning of admission at the next. Hence long-stroke engines gain less by jacket action than short-stroke engines with the same ratio of expansion.

(6) The gain from the jacket is proportionally less in multiple-expansion engines than in single-cylinder engines in which high expansion is attempted. This follows because the less the amount or tendency to condensing action the less good the jacket can do. The divided temperature range in the compound or multiple series diminishes the actual condensation, and the increased cylinder surface increases loss of heat in the jackets themselves. Marine tests have shown a gain from jacketing the larger and cooler low-pressure cylinder of a compound engine, but no gain from jacketing the high-pressure cylinder.

(7) If the condition of high grade of expansion should happen to concur with a supply of steam initially wet, the jacket during expansion will evaporate more water than was initially condensed against the walls. Condensation of steam in the jacket being a wasteful method of evaporating this water in the working barrel, the steam-jacket may cost more than it saves. In other words, with dry steam the jacket saves; with wet steam, the jacket condensation may offset the gain; when the boiler primes, the jacket is likely to be a loss.

(8) Hence if the steam is superheated, there is no occasion for a steam-jacket.

226. Conditions and Action of an Effective Steamjacket.—Circulation of the hot steam from the boiler is the prime condition of effectiveness in a steam-jacket. As the water is condensed in the jackets it should be removed by

traps or by gravity back to the boiler. The plan of passing the steam through the jackets of a main engine to operate the cylinder of an auxiliary engine like an independent air-pump has much to commend it. The plan of jacketing so that the steam from the jackets enters the valve-chambers is also a good one, provided the supply to the valves is kept thoroughly dry. Hot water in jackets is fatal to economy. The conductivity of water for heat is very low, and a thin film of water will seriously impair the transfer of heat to the metal behind it. In fact, this peculiarity of a water-film or dew on the inside of the cylinder often seriously disturbs the normal or anticipated action of the jacket from without. The vertical cylinder might be expected to free itself of a water-film better than a horizontal one. Jacketing of pistons has not been found to work well.

227. Gain from the Use of the Steam-jacket.-The gain fom the use of the steam-jacket in economy of fuel is a matter to be experimentally found for each engine and each set of conditions. It may be a quantity varying from zero to 15 per cent, rarely reaching 20 per cent. The expenditure of steam in the jackets is likely to be over 5 per cent in single engines and about 10 per cent in compcunds, and 15 per cent or less in triples if all cylinders are jacketed. The gain from the use of jackets results from the fact that for every pound condensed in the jackets some greater quantity is saved in the cylinders. In the case of initially poor engines the net gain from jacketing may reach 20 or 25 per cent. With well-designed engines, such as are met in marine practice, the gain or economy is not likely to exceed 10 per cent of the total feed-water evaporated. It belongs to the finance of the problem to decide whether the cost of the extra construction is justified by the decrease in running cost which follows from it.

The jacket results in a notable convenience in starting

# THE CYCLE OF THE ACTUAL STEAM-ENGINE. 325.

engines, since the barrel and all parts of the cylinder can be warmed up in advance of the actual starting of the engine. This avoids annoyance from condensation of water, and from any seizing of fitted parts by difference of temperature.

228. Non-conducting Cylinders.-It has also been sought by certain skilful designers to mitigate the evils of internal condensation waste by making the cylinder-wall to possess such a non-diathermanous character that no reactions should take place between the steam and the metal. These objects have been aimed at either by a lining within the metallic cylinder, or by treating the metallic surface exposed to steam. The practical difficulties of a glazed or enamelled surface have arisen from the unequal coefficients of expansion of the body of the metal and the non-conducting coating, whereby the surface cracks and disintegrates. The difficulties caused by abrasion have to be overcome in the other system. These ideas, if a successful method could be found for carrying them out, would bring the actual engine up to the ideal conditions so far as internal wastes were concerned.

229. Superheating, to prevent Cylinder Condensation. -The temperature-entropy diagram in § 203 has made it apparent that it was possible to add heat to the incoming steam to such a degree that all the cooling which it must have to ). undergo in expansion should not be able to bring it down to the point of saturation, when it is just ready to condense to a mist on further cooling. It is obvious then that the initial condensation upon entry into the cylinder can be prevented by superheating to a less degree, and the losses thus avoided or reduced. For example, let it be assumed that such initial steam come in in a saturated state with a total heat of 1250 thermal units per pound, and that cylinder condensation under these conditions would cause a loss of 20 per cent, or that  $1250 \times .20 = 250$  British thermal units disappeared into the metal walls of the cylinder by such condensation. There

must therefore be brought in by the steam, if its specific heat be called 0.480, an amount of heat represented by

$$250 = 0.480t^{\circ}$$

or the range above the working temperature of saturation for each pound becomes

$$t = \frac{250}{480} = 520^{\circ}$$
 F.,

which is practically unattainable for reasons shortly to be treated. The same result could have been reached by the graphic process.

On the other hand, moderate superheating, of  $100^{\circ}$  to  $150^{\circ}$  F. above working pressure, is sufficient to reduce initial condensation greatly, if not to eliminate it, and when the steam is dry and the cylinder-walls are hot at the point of cut-off the evils from condensation and evaporation during expansion are mitigated. The two sets of curves shown in Figs. 96 and 97, derived from the Regnault experiments, make it plain that as the temperature increases there is a wider margin or range for a change of condition at the upper ranges than at the lower. Or in other words, the similarity of the curves shows how much more cooling has to be done at the higher levels to produce the same change which at the lower points will occur so easily.

The exceeding rapidity with which cooling takes place in the thin film of metal when acted on from within makes it also particularly rapid in responding to the heat effect of extrahot steam coming in as a superheated gas at admission. It is for this reason that superheating has an advantage over jacketing. The jacket supplies heat not only at admission, but also during the exhaust stroke, when it is wasting it, to atmosphere or to the condenser. Superheating supplies heat only where it is required, if the initial condensation only is to be considered.

The effects of superheating the steam are:

(1) To raise  $T_1$  in the efficiency formula, without such increase in  $p_1$  as to give rise to practical difficulty. This increases thermal efficiency.



FIG. 96.

(2) To diminish the density of the steam-gas. Hence a less weight goes to an initial volume introduced into the cylinder with a given period of admission.

(3) The steam has more of the reluctance to part with its heat which is the property of a gas as distinguished from a vapor which is ready to transfer its heat to solid objects by condensation upon them. Saturated or wet steam condenses freely; steam-gas is difficult to cool except by intimate contact with all parts of it, as is the case with air and other gases.

230. Methods of Superheating.—There are three general principles underlying the attainment of superheat in steam.



The first ha; already been referred to (§ 132), where two masses of steam are supposed to be separated by a throttling orifice, and flow to take place from the higher pressure into the lower pressure volume. All the heat which was in the steam at the higher pressure is in the mass at the lower pressure, and this latter must therefore have more heat than is due
## THE CYCLE OF THE ACTUAL STEAM-ENGINE. 329

to its pressure or is superheated in consequence. That is, if the difference  $T_1 - T_2$  of their total heats be one degree, then

$$(T_1 - T_2)0.480 = I_1$$

or there will be a surplus of heat represented by

$$\frac{I}{.480} = 2.08$$

degrees for each thermal unit difference of their total heats at the different pressures.

This method of superheating by wire-drawing occurs in the throttling engine; such as the locomotive, and with throttling governors on stationary engines. It is not available, however, when maximum output of energy is required.

The second method is by an admixture of highly superheated steam (usually secured by the third method) with the ordinary or saturated steam. This method of mixture has been called "adheating," or the "combined steam" process; also Wethered's system. The claimed advantage was the control of the degree of superheat by the proportions of highly superheated steam to be mixed with normal steam as the load might vary.

The third and most usual method is the direct method of heating all the steam by passing it through pipes or coils on its way from boiler to engine, such pipes being kept at high temperature by waste-heat from the furnace-gases. This result is secured in many ways:

(1) Superheating coils in the flues or at the base of the chimney (Fig. 98).

(2) Superheating in the boiler, by having a part of the heating surface above the water-line, and forcing the steam into contact with such superheating surface. Corliss and Manning boilers exhibit this method; also the common upright boiler, and the steam-chimney of the marine boiler.

(3) Superheating by surrounding the cylinder with fluegases. This is a very old plan, but troublesome.



FIG. 98.

(4) In multiple-cylinder engine-practice the use of coils of steam at high or boiler pressure, in receivers through which the lower pressure steam passes on its way from cylinder to cylinder. This is called " reheating."

231. Objections to Superheating.—European engineers have paid more attention to superheating the steam than American engineers have. The reasons for this have been the practical difficulties in the way. These are:

(1) The low specific heat of steam-gas causes the superheating coil to become highly heated in the furnace-gases. Hence these coils oxidize or burn out and give way.

(2) The range of temperature and expansion in superheating coils or tubes makes it difficult and costly to keep joints tight.

## THE CYCLE OF THE ACTUAL STEAM-ENGINE. 331

(3) The high temperature of the steam compels the use of metallic packings and non-oxidizable lubricants, to withstand the heat. Fibrous packings and non-mineral lubricants are impossible.

232. Gain or Economy by Superheating.-The actual gain from superheating in any case should be a matter of experimental determination, as in the case of the steam-jacket. It is furthermore complicated by the cost of renewing the direct superheater at frequent intervals, and the repairs to it. Neglecting this element, however, and speaking generally, it seems safe to say that a superheat of from 15° to 20° F. will effect an important gain in reducing wastes, and a superheat of 100° F. will practically extinguish initial condensation. With compound engines a superheat of 100° produces an average gain of 20 per cent of the fuel used with saturated steam That is, the algebraic sum of the gain and the heat alone. expended to produce the superheat will always be a positive quantity, because the return will be from twice to ten times the expenditure, taking the average of recorded tests.

233. Loss by Clearance.—There must be linear clearance between the piston and the two cylinder-heads, and a clearance volume in the passages below the values which control inlet and exit of working steam. If no compression is used or desirable, a volume of steam is taken from the boiler at each stroke and wasted, and the mean pressure is less than it would be if a smaller volume were expanding after cut-off.

The clearance volume in any actual case is found from drawings, or better by pouring in water behind the piston on its dead-centre until the clearance volume is filled. The observed weight or volume of such water gives a volume in cubic inches or cubic feet to be added to the real piston-displacement for each stroke to give the actual weight or volume fed to the cylinder per stroke.

In representing the clearance on the pv or indicator diagram, it is only necessary to prolong the diagram at its admis-

sion end by a length which shall give to the admission area the same percentage of increase in area as the clearance volume adds to the piston-displacement. (See also § 186).



1 10.100.

That is, if C (Fig. 100) denote the clearance volume, expressed as a fraction or percentage of the piston-displacement volume, which latter will be the product of the area A into the length of stroke L, then

or

C = fAL, $f = \frac{C}{AT}.$ 

Therefore a length of diagram is to be added to the admission area of the indicator-card which shall be

$$fL = \frac{C}{A},$$

and the line of zero clearance drawn through a point outside the line of furthest stroke as far beyond that point as is given by the ratio  $\frac{C}{A}$ . In the diagram

$$LK = NA = f(AL)$$
, since  $\frac{LK}{KI} = \frac{C}{A}$ .

## THE CYCLE OF THE ACTUAL STEAM-ENGINE. 333

Neglecting clearance, with admission AB on the P.V. diagram, the apparent cut-off is

$$\frac{AB}{KI} = \frac{\mathbf{I}}{r},$$

and the apparent ratio of expansion is

$$\frac{KI}{AB} = r.$$

But the real admission volume is NB, and the final volume LI; whence

$$\frac{\mathbf{I}}{r_{\bullet}} = \frac{NB}{LI} = \frac{AB+f}{KI+f} = \frac{\frac{1}{r}+f}{\frac{1}{1+f}},$$

and

$$r = \frac{LI}{NB} = \frac{1+f}{\frac{1}{r}+f} = \frac{r+fr}{1+fr},$$

so that the increase of expenditure of fluid and hence of heat becomes

$$\frac{NB}{AB} = 1 + fr,$$

while the absolute mean pressure is less than it would be if the clearance volume were not also filled with expanding steam in the proportion

$$p'_m = p_m - f(p_1 - p_m).$$

If the values of the clearance volume are not known or conveniently measurable, the line of zero volume and no clearance can be drawn with close approximation from the actual card, upon the assumption that for a short distance the compression line departs so little from an equilateral hy-

perbola that it may be called one. Then if two symmetrical points are chosen on the curve (Fig. 101) and a line drawn through them to the line of zero pressures, which it will cut



FIG.101.

at some point e, and prolonged also beyond c, it will cut the line of zero volumes as far beyond c as the point e is beyond d. Making cf = de, the line OY through f is the line of zero volumes, or the line of clearance zero. This comes because, by similar right-angled triangles,  $pv = p_iv_i$ , only when O is determined in this way. A determination of the location of the point O by two points on the expansion curve is less accurate because the curve may diverge from the equilateral hyperbola, and any errors in such diagonal line are multiplied in locating the point O.

234. Probable Amounts of Clearance.—Small engines may have the linear clearance as low as one eighth of an inch; larger engines may have as much as one-half inch. The longer the stroke relatively to the diameter, the less the percentage of clearance represented by a linear unit of clearance. Short-stroke high-rotative-speed engines therefore empty the greatest clearance volumes.

Corliss valve-gearing causes the least volume between valves and cylinder-bore, and the same is true for those designs which have the valves in the cylinder-heads. Valves of

### THE CYCLE OF THE ACTUAL STEAM-ENGINE. 335

the poppet type and piston-valves compel a considerable clearance volume and attendant loss. A value for f as low as  $2\frac{1}{2}$  per cent is as low as is usually obtained; it ought not to exceed 7 per cent; if it goes above 10 per cent it is excessive.

235. Clearance Losses Diminished by Compression.-The effect of a preclosure of the exhaust-valve before the end of the exhaust-stroke is to entrap steam between the piston and the cylinder-head, and to raise its pressure by compressing it into the clearance volume, which it may fill completely. The work of such compression is a negative work so far as the useful work of the engine is concerned, and is done by the fly-wheel at the expense of energy stored in it. It is mechanically advantageous, however, as furnishing a gradually increasing cushion effect against the reciprocating parts to arrest them, and to put them under the strain of tension or compression to which the next working stroke is to subject them. The temperature-entropy diagram shows the point at which this compression should begin if adiabatic compression of the entrapped steam-vapor is to raise the pressure to that corresponding to  $T_1$ . (See § 200.)

236. Calculation of Mean Effective Pressure when Clearance and Compression are Considered.—The ac-



FIG.102.

cepted method for calculating mean effective pressure when the diagram of the indicator shows both clearance and com-

pression is an extension of principles already laid down. If L in Fig. 102 is the length of the stroke, l the length of the admission line, x the period of the exhaust-stroke after compression begins, c the clearance length proportional to the clearance volume, while the capital letters A, B, C, and D represent the areas on which they are placed, and the pressures are respectively  $p_1$  at admission,  $p_b$  during exhaust, and  $p_c$  at the end of compression, we shall have the total area of the enclosing figure from §§ 164–167:

Area of 
$$ABCD = p_1(l+c)(1 + \text{hyp.}\log\frac{L+c}{l+c})$$
.

But by similar reasoning the area of the parts B, C, and D will be given by the equations

$$B = p_b(L - x);$$
  

$$C = p_c c \left( 1 + \text{hyp.} \log \frac{x + c}{c} \right)$$
  

$$= p_b(x + c) \left( 1 + \text{hyp.} \log \frac{x + c}{c} \right);$$
  

$$D = (p_1 - p_c)c = p_1 c - p_b(x + c).$$

Hence the area of the net-work diagram A will be

Area of 
$$A = ABCD - (B + C + D)$$
  

$$= p_1(l+c)\left(1 + \text{hyp.}\log\frac{L+c}{l+c}\right)$$

$$-\left[p_b(L-x) + p_b(x+c)\left(1 + \text{hyp.}\log\frac{x+c}{l+c}\right) + p_1c - p_b(x+c)\right]$$

$$= p_1(l+c)\left(1 + \text{hyp.}\log\frac{L+c}{l+c}\right)$$

$$- p_b\left[(L-x) + (x+c)\text{ hyp.}\log\frac{x+c}{c}\right] - p_1c.$$

### THE CYCLE OF THE ACTUAL STEAM-ENGINE. 337

Hence, since the mean effective pressure will be the result of dividing the area of the work-diagram by its length, we have

Mean effective pressure 
$$=$$
  $\frac{\text{area of } A}{L}$ .

237. Friction in Steam-pipes.—When the volume of steam required by the engine is known per unit of time, experience shows that loss of pressure and temperature from friction or wire-drawing will be inappreciable if the cross-section of pipes or passages is so made that the linear velocity of the steam shall not exceed 100 feet per second. Length is not without effect, but for short distances, and where engine and boiler are close together, the velocity may be increased.

238. Loss of Pressure and Temperature from Cooling in Pipes.—When steam is moving in pipes which are adequately clothed with non-conducting coverings there is no doubt a loss by eddies and by a higher velocity at the beginning than at the end, due to the long travel. Experiments, however, on any considerable or adequate scale are lacking to enable this difference to be more than guessed at, under the wide variation of condition as to exposure and effectiveness of covering. Designers usually allow for a loss of 5 per cent of pressure in long runs of over 250 feet, and allow variations from this allowance by climate and season and deterioration of the insulation to be met by changing the pressure at the source of heat.

239. Efficiencies Experimentally Determined in Terms of Thermal Units.—The calculation of § 218 showed that

$$\frac{33000}{77^8} = 42.164$$

thermal units per minute per horse-power would be required by an ideal engine.

If an actual engine be tested and found to consume n

pounds of water per horse-power per hour, it will be obvious that the thermal units consumed by that engine per horsepower will be the product of the weight n into the specific heat unity into the range of temperature used by the engine. This range will be the difference between the total heat of the steam at the temperature used and the temperature of the feed-water as supplied to the boiler. Hence

Efficiency = 
$$\frac{42.4164 \times 60}{n \times (\lambda - t)}$$
,

when  $\lambda$  is the total heat at  $T_1$ , and t is the temperature of the feed-water. Usually the boiler is combined with the engine, and the efficiency is thus taken together. In the case, however, where it is desirable to separate them, the calorific power of the fuel being known, and the total heat above feed-water temperature being given, it will be obvious that the product (total heat — feed-water heat)  $\times$  (pounds of water so heated) should be equal in theory to that calorific power. The efficiency of the boiler should be the ratio:

$$Efficiency = \frac{Actual \text{ pounds evaporated per pound of fuel}}{Theoretical evaporation per pound of that fuel}.$$

Then the efficiency with the theoretical cycle having been calculated between the limits  $T_1$  and  $T_2$ , or the theoretical water consumption, the actual water consumption is compared with the theoretical, the latter being taken as 100 per cent; then

Efficiency of engine =  $\frac{\text{Actual water per H. P. per hour}}{\text{Theoretical water per H. P. her hour}}$ .

The combined efficiency is the product of the two efficiencies in percentage.

This method is fairer than the comparison with unity of perfection in the Carnot cycle. The difficulty with the steamengine is that the fuel-temperature of 2000° F. in the furnace

## THE CYCLE OF THE ACTUAL STEAM-ENGINE. 339

gives as yet only a 400° temperature of the heat medium for physical reasons. While the limits imposed by temperature are such as yet as to keep theoretical limits of efficiency far beyond our present practice, and induce earnest research either after media which shall not be subject to these limitations, or to extend the limits, yet on the other hand it is unfortunate not to be able to appreciate how excellent our heatengines are when the perfection realizable within these limits is taken into the calculation.

# CHAPTER XVII.

## THERMAL ANALYSIS OF HEAT-ENGINES.

240. Introductory.—It has been repeatedly emphasized in previous chapters that the character of the reactions causing loss of heat and efficiency, and the action of the appliances devised to mitigate these losses, were matters demanding experimental investigation for each particular engine. Skilful designers however must have general principles to use, and their skill will consist in the wise application of these to the problem then in hand. But the ultimate criterion even in duplicate engines must be the actual test and the analysis of the results.

The testing of engines and the interpretation of the data of such tests have long been matters interesting the foremost grade of practitioners, and form a field too wide to be entered on here except in a summary way. The use of the indicator and the deductions from its diagram with respect to distribution, value for mean effective pressure, and horse-power must be studied elsewhere. This chapter will discuss only the deduction of water per horse-power, the Hirn analysis, and the temperature-entropy diagram as giving the distribution of the heat energy.

241. Pounds of Heat Medium per Horse-power Calculated Theoretically from an Indicator-diagram. — The steam used in a steam-engine weighs the same as the water furnished to the boiler (less wastes) when observed over a long enough interval. The heat delivered to the engine will be proportional to the weight of steam which it consumes.

Hence the most satisfactory test is to weigh the water used by the engine by catching it in a surface condenser. Where this cannot be done, and often also where it is possible, it is desirable to determine, from the indicator-card of data on the pvplane, what weight of water the diagram corresponds to. In Fig. 103, let L be the length of the stroke in feet; A the area



of the piston in square inches, so that  $\frac{A}{144}$  is the area in square feet; N = number of strokes per minute; l the percentage of the stroke completed at the point of cut-off, if the water rate is to be computed for that point, or at the release, if the rate is to be there computed; c the percentage which clearance volume bears to piston-displacement, and hence the same relation to the stroke length; w the weight per cubic foot of steam at the pressure at which the water rate is to be calculated, and w' the weight belonging to the pressure at the end of any compression that there may be. Then

Cubic feet per stroke 
$$= L \left(\frac{l+c}{100}\right) \frac{A}{144}$$
.

The clearance volume will be  $=\frac{LcA}{144 \times 100}$ .

The weight of steam in pounds per stroke will be the cubic feet times w, or

$$W_{1} = L\left(\frac{l+c}{100}\right)\frac{A}{144}w,$$

and the weight in the clearance volume  $w_{1}$  will be

$$w_{2} = \frac{LAcw'}{14400}.$$

The total weight per stroke will be the difference between  $W_1$  and  $w_2$ , or

$$W_{1} - w_{2} = L\left(\frac{lAw + cAw}{14400}\right) - \frac{LAcw'}{14400}$$
$$= \frac{LA}{14400}[(l+c)w - (cw')].$$

This becomes weight of water per hour by multiplying by 60N, or

$$W = \frac{60LAN}{14400} [(l+c)w - (cw')].$$

In this result all data are on the indicator-diagram, or are from tables and observations. To reduce this to weight of water per horse-power per hour, both members are to be divided by the equality

$$\text{H.P.} = \frac{PLAN}{33000},$$

in which P is the mean effective pressure from the diagram. Hence

$$\frac{W}{\text{H.P.}} = \frac{\frac{60LAN}{14400} [(l+c)w - (cw')]}{\frac{PLAN}{33000}} = \frac{137.50}{P} [(l+c)w - (cw')].$$

For compound or multiple engines P will be the mean pressure reduced to the low-pressure cylinder volume, assuming all work to be done in that cylinder.

This equation repeats the statement of § 236. If the pressure in the clearance is carried by compression so that w' = w, then

 $\frac{W}{\mathrm{H.P.}} = \frac{137.50}{P} (lw).$ 

If, however, there is no compression, and w' = zero, then the consumption per horse-power is

$$\frac{137.50}{P}(l+c)w.$$

The difference between the water supplied to the engine and the value for W from the card is known as "water not accounted for by the indicator" which has been expended in the initial condensations, leakages, etc., which constitute the losses hitherto discussed.

The above values for w refer only to points chosen between cut-off and release. The results at these two terminal points are likely to differ. The amount of their difference is a rough gauge of the amount of re-evaporation in the cylinder. The indicator will imply the greatest weight at release for this reason.

242. Hirn's Analysis.—The thermal analysis most in use in America and Europe was first proposed and elaborated by the great Alsatian engineer G. A. Hirn, and applied by his distinguished pupil and colaborer Octave Hallauer. In the form most used it bears the impress of later study by Prof. V. Dwelshauvers-Déry of Liège, Belgium. The first step in applying it is to select a representative indicator-card, whose curves on the pv surface shall give the normal performance of the engine over a considerable time, and representing practically constant conditions. A weight of steam M in pounds

is supplied to the cylinder per stroke (or per 100 strokes if desired) occupying the volume up to the point of average cutoff by diagram, which will be denoted by  $V_1$ . The closure of the exhaust-valve on the previous stroke has entrapped a volume  $V_0$  or a weight  $M_0$  of steam and water mixture in the clearance volume ( $V_0$ ). The quantity M may be called the cylinder-feed; the quantity  $M_0$  may be called cushion-steam and is found by selecting on the average card the earliest point at which the valve is known to be closed on the exhauststroke, calculating the volume from this abscissa, and adding the clearance volume. The weight for this pressure and this volume is found from tables. It is assumed that the steam is dry and saturated at the compression-point.

The weight M is of course most satisfactorily found by measurement directly from a surface condenser where this is possible; if not convenient, the feed to the boiler should be the same as the feed to the cylinder if no other apparatus is supplied by the boiler, such as pumps, jackets, injectors, leakage, and the like. To make the case general, it should be assumed that the steam is wet, or that a percentage x is vaporized, while I - x remains as water. Hence the volume of one pound of the mixture, if u represents the increase in volume of the water when it becomes steam and  $\sigma$  is the volume of the liquid water,

$$v = xu + \sigma$$
,

and for M pounds this will be

$$Mv = V = M(xu + \sigma).$$

If, then, the subscript letters represent the various points at which volumes are noted on Fig. 104, and the corresponding states of the mixture, we have

> $V_{o} = M_{o}(x_{o}u_{o} + \sigma) \quad \text{for admission;}$   $V_{o} + V_{1} = (M + M_{o})(x_{1}u_{1} + \sigma) \quad \text{`` cut-off;}$   $V_{o} + V_{s} = (M + M_{o})(x_{2}u_{2} + \sigma) \quad \text{`` release;}$  $V_{o} + V_{s} = M_{o}(x_{s}u_{s} + \sigma) \quad \text{`` compression.}$

Assuming evaporation complete at compression makes this last equation present  $x_i$  as unity, and therefore

$$M_{\circ} = \frac{V_{\circ} + V_{\circ}}{u_{\circ} + \sigma}.$$

But  $u_1 + o$  will be the volume of one pound of completely evaporated steam at the point of compression  $V_1$ , and this volume will be the reciprocal of the weight w' of one cubic foot at that pressure from tabular values. Hence

$$M_{0} = (V_{0} + V_{3})w'.$$

This value for  $M_0$  can be inserted in the equations above, and the values for  $x_0$ ,  $x_1$ , and  $x_2$  calculated for admission, cut-off, and release, respectively.

In the second place, the heat brought into the cylinder by



FIG.104.

M pounds of steam will be

M(q + xr) = Q,

when q is the heat of the liquid and r is the latent heat of vaporization for the percentage x which has been vaporized.

If the steam is superheated, then Q becomes

 $Q_s = M[\lambda + .480(t_s - t)]$ 

if  $t_s$  is the temperature of the superheat and .480 is the specific heat of steam at constant pressure.

But it is necessary to separate the entire heat energy into those fractions which correspond to outer or external work, and those which represent intrinsic heat energy, which can be otherwise disposed of than in doing such external work. If the heat equivalent be called H, then

$$\begin{split} H_{\mathfrak{o}} &= M_{\mathfrak{o}}(q_{\mathfrak{o}} + x_{\mathfrak{o}}\rho_{\mathfrak{o}}) & \text{for admission;} \\ H_{\mathfrak{i}} &= (M_{\mathfrak{o}} + M)(q_{\mathfrak{i}} + x_{\mathfrak{i}}\rho_{\mathfrak{i}}) & \text{``cut-off;} \\ H_{\mathfrak{o}} &= (M_{\mathfrak{o}} + M)(q_{\mathfrak{o}} + x_{\mathfrak{o}}\rho_{\mathfrak{o}}) & \text{``release;} \\ H_{\mathfrak{o}} &= (M_{\mathfrak{o}} + M)(q_{\mathfrak{o}} + x_{\mathfrak{o}}\rho_{\mathfrak{o}}) & \text{``compression.} \end{split}$$

The symbol  $\rho$  replaces r because the factor must contain only the heat equivalent for the *internal* work of vaporization of one pound, and not that corresponding to both internal and external work of vaporization.

In the third place, it becomes apparent that when the steam entered, bringing Q units of heat, it found already the clearance volume filled with a steam whose energy was  $H_{o}$ . At the end of admission when cut-off takes place, an external work in foot-pounds W has been done, whose heat equivalent is  $\frac{W}{778}$ , or AW, and there remains an intrinsic energy  $H_1$  in addition to any transfer to the cylinder-walls of heat which has disappeared in initial condensation or otherwise. Hence

$$Q + H_0 = A W_a + H_1 + Q_a,$$

or

$$Q_a = Q + H_a - H_1 - A W_a$$

if  $Q_a$  denote such lost heat during admission.

During the expansion period external work  $W_b$  is done, and at release an intrinsic energy  $H_a$  remains. Whether  $H_a$ or  $H_i$  will be numerically the larger must depend on whether the walls by jacket or otherwise supply heat to the working-

cylinder-feed steam or are withdrawing it. In any case, calling the transfer  $Q_b$  and assuming that it denotes an absorption, the intrinsic energy at cut-off must balance the work, the loss from condensation, and leave the remainder  $H_s$  of energy to be present at release. Hence

 $H_{1} = H_{2} + AW_{b} + Q_{b},$  $Q_{b} = H_{1} - H_{2} - AW_{b}.$ 

During the third period, or exhaust. the engine is pumping out the exhaust steam, or is doing a negative work  $W_c$ , and at the end of exhaust, or when compression begins, there must remain an intrinsic energy represented by  $H_i$ . If the heat of the liquid water resulting from the condensation in a condensing engine be represented by  $q_i$ , which is the hot-well temperature with a surface condenser, then a quantity of heat represented by  $Mq_i$  is carried into the condenser. If G pounds of condensing water are used to effect this condensation, and delivered at injection temperature  $q_i$  are raised to the outflow temperature  $q_k$ , then an amount of heat disappears in this process of cooling which will be represented by  $G(q_k - q_i)$ . If a jet condenser is used,  $t_i$  of hot-well and condenser outflow  $t_k$ will be the same. The loss to the walls being denoted by  $Q_c$ , the heat energy  $H_i$  must balance:

or

or

$$H_{3} = H_{2} + Mq_{4} + G(q_{k} - q_{i}) + Q_{c} - AW_{c},$$

$$Q_{c} = H_{2} - H_{3} - Mq_{4} - G(q_{k} - q_{i}) + AW_{c}.$$

TT I TT I CI

If the release leads the ends of the stroke, some of the expulsion work will be done by the working fluid. If this happens,  $W_e$  will be the difference between the lengths of these two parts of the stroke in which the exhaust is done by the driving steam of the stroke, and the length of the expulsion done by the steam of the following stroke.

During the fourth or compression period a work  $W_d$  is done by the engine. Any losses  $Q_d$  must leave the energy represented by  $H_0$  at the end of the compression, so that

$$H_{s} = H_{o} - AW_{d} + Q_{d},$$

or

$$Q_d = H_s - H_o + AW_d.$$

Finally, there is whatever expenditure of heat is represented by the jackets of cylinders, receivers, and the like. Let *m* represent the weight of water collected per stroke (or per 100 strokes), with x' its percentage of dryness, r' its heat of vaporization, and q' its heat of liquid, while q'' is the heat of the liquid withdrawn as water from the jackets; then if  $Q_j$ be the heat so supplied to the jackets,

$$Q_i = m(x'r' + q' - q'').$$

It is obvious on the other hand that the quantity Q supplied to the engine must be great enough to do the following:

(a) do the external work W, which will be

$$W = W_a + W_b - W_c - W_d,$$

or the work corresponding to the entire net area of the indicator-card;

(b) supply the heat carried into the condenser and away by the injection

$$Mq_{4} + G(q_{k} - q_{i});$$

(c) meet all the losses by radiation, condensation, or otherwise; the summation of all the losses

$$Q_e = Q_a + Q_b + Q_c + Q_d.$$

To help out the quantity Q, the jacket heat  $Q_j$  must be supplied in addition, and it may be treated as if it were also supplied per stroke as an addition to the working fluid. Hence

$$Q + Q_j = AW + Mq_* + G(q_k - q_i) + Q_e,$$

from which it follows that, by addition of equations,

$$\mathcal{Q}_e = \mathcal{Q}_a + \mathcal{Q}_b + \mathcal{Q}_c + \mathcal{Q}_d + \mathcal{Q}_j,$$

and also

$$= Q + Q_j - Mq_* - G(q_k - q_i) - AW,$$

all of which latter quantities are capable of experimental observation in a properly arranged engine-test, and should check with the summation of the losses in each part of the cycle.

243. Application of Hirn's Analysis.—If a thermal analysis is to be applied to an engine-test, the foregoing equations have shown the quantities which are to be observed and recorded. For the determination of Q = M(xr + q) the weight of cylinder-feed per stroke observed from the condenser is to be multiplied by the percentage of dry steam present in the cylinder-feed, and this must be determined by a calorimeter so located as to give the indication of quality which is prevalent in the cylinder. This is not always easy, and offers scope both for skill and for care.

The data concerning the cylinder must involve not only length and diameter, but also the points of cut-off, release, and compression from both head end and crank end, the clearance volumes at both ends, and the piston-displacements at both ends. These latter quantities are rarely or never the same for both ends, because the connecting-rod introduces an irregularity of path of the piston by its angular motion, and the piston-rod fills a part of the clearance volume at one end and not at the other. It is usual to take the half-sum of the volumes in working out numerical values.

Then from the average diagram the absolute pressures are ascertained by measurement, adding to them the barometerreading on the day of the test so as to locate the atmospheric line in its proper place above a true vacuum. These pressures being observed for cut-off, release, compression, and for the point on the compression at which the inlet-valve opens for admission on both crank end and head end, it is convenient to tabulate the corresponding values for q, r,  $\rho$ , and uderived from tables; and similarly to work out the value of  $\frac{W}{778}$  for each section of the card from the mean pressure prev-

alent when  $W_a$ ,  $W_b$ ,  $W_c$ , and  $W_d$  respectively is being performed. The mean pressure into the area, both in squareinch units, multiplied by the length in feet through which that effort is exerted, gives a value for W in foot-pounds, which is reduced to the equivalent in heat-units by dividing by 778, since  $A = \frac{I}{\overline{I}}$ . The volumes in cubic feet are then

calculated for  $V_0$ ,  $V_1$ ,  $V_2$ , and  $V_3$  for both head and crank ends.

The longer the duration of the test, the less the chances for error, and the more insignificant its percentage. This is particularly true of the weight of steam per stroke:

 $M = \frac{\text{Total weight of steam used in the test}}{2 \times \text{number of revolutions during that period}},$ 

and also for the weight of condensing water per stroke, which will be

$$G = \frac{\text{Total weight of condensing water during period of test}}{2 \times \text{number of revolutions during that period}}.$$

The temperatures of the condensed steam in the hot-well, and of the injection before and after use in the condenser,

have to be observed with sufficient frequency to represent average conditions.

These data having been prepared, M and  $M_{\circ}$  are calculated; the values for x, H, and Q with their several subscript values are worked out from tables.

The work per stroke having been found in foot-pounds from the pv indicator-card and reduced to heat-units for the foregoing calculations by dividing by 778, the horsepower will be found by multiplying the heat-unit work by the factor 778 and dividing by the foot-pounds in one horsepower for the same period. If, as is usual, the work in heatunits *per hour* is the result of the calculation, then

$$\text{H.P.} = \frac{778 \times W \times 2Rpm \times 60}{60 \times 33000},$$

when W is the heat-unit work for one stroke. Then it is obvious that the steam per horse-power is the quotient resulting from dividing the total weight of steam used by the number of horse-power developed during that same period.

The quantity Q is, however, the principal object sought, and when found for one revolution can be expressed per minute or per hour or per horse-power as desired.

The table on page 352 will show an illustrative analysis involving the foregoing details.

244. Limitations of Hirn's Analysis.—If the engine is a non-condensing one, the quantities depending on the condenser will vanish. But since it is true that

$$Q_{i} = Q + Q_{i} - Mq_{i} - G(Q_{k} - Q_{i}) - AW,$$

the equation of the previous paragraph for  $Q_c$  may be written

$$Q_c = H_s - H_s - Q + Q_j - Q_c + A(W + W_c)$$

by substitution.

## THERMAL ANALYSIS-DATA AND RESULTS PER 100 REVOLUTIONS.

	Quantities.	Symbols.	Formulæ.
1. 2. 3. 4. 5.6. 7.8. 9.	Steam entering working cylinder, pounds. Steam at admission, pounds Steam used by calorimeter, pounds Heat of condensed steam Condensed water, pounds Heat given to condensing water Heat supplied to engine Sensible heat at admission	M M <sub>0</sub>       	$100 (V_c + V_0) + v_0$ $Mq_g$ $G(q_k - q_i)$ $M(xr + q)$ $M_0q_0$
10.	Internal heat at admission	$H_0'$	$100 \frac{\nu_c + \nu_0}{\nu_0} \rho_0$
11.	Sensible heat at cut-off	$H_1$	$(M+M_0)q_1$
12.	Internal heat at cut-off	$H_{1}'$	$\frac{V_c + V_1}{2} \rho_1$
13.	Sensible heat at release	$H_2$	$(M + M_0) q_2$
14.	Internal heat at release	H2'	$\frac{V_c + V_s}{m_s} \rho_s$
15.	Sensible heat, beginning of compression.	H <sub>3</sub>	M <sub>0</sub> q <sub>3</sub>
16.	Internal heat, beginning of compression.	H <b>3'</b>	$100 \frac{V_c + V_3}{v_2} \rho_3$
17. 18. 19. 20. 21. 22. 23.	Cylinder loss during admission. Cylinder loss during expansion. Cylinder loss during exhaust. Cylinder loss during compression. Heat discharged, and work. Jacket. Jacket.	Qa Qb Qc Qd B D D'	$\begin{array}{l} Q + H_0 + H_0' - H_1 - H_1' - AW_a \\ H_1 + H_1' - H_2 - H_2' - AW_b \\ H_2 + H_2' - H_3 - H_3' - K - K' - AW_c \\ H_3 + H_3' - H_0 - H_0' - AW_d \\ K + K' + AW \\ Q - B \\ Q_a + Q_b + Q_c + Q_d \end{array}$
24.	Quality of steam entering	x	per calorimeterper cent.
25.	Quality of steam at cut-off	<i>x</i> 2	$100 \frac{V_c V_1}{(M+M_0)v_1} \dots \dots \dots \dots \dots \dots \dots \dots \dots$
26.	Quality of steam at release	<i>x</i> 2	$100 \frac{V_c + V_2}{(M + M_0)v_2} \dots \dots \dots \dots $
27.	Quality of steam at compression,		$100 \frac{V+V_3}{M_0 7/2}$
28.	Quality of steam at admission	$x_0$	per calorimeter
29.	Quality of steam in exhaust	xs	$\left(\frac{X+X}{M-M_x}-q_5\right)+r_5\cdots$
30.	Heat lost, admission	a b	$Q_a + Q$
32.	Heat rejected, exhaust	c d	
33.	Heat utilized. work	w	$\frac{W}{W}$ + 0
35. 36. 37. 38. 39.	Heat lost, radiation Ratio, radiation to work Ratio, cylinder condensation to work Thermodynamic efficiency. Actual efficiency. Efficiency compared with ideal.	$\begin{bmatrix} R \\ \vdots \\ E \\ E_1 \\ E^2 \end{bmatrix}$	$\begin{array}{l} 77^{\circ}\\ \text{Radiation} + Q. & \text{``}\\ R + vv & \\ a + vv & \\ (t-t_3) + (460 + t) & \text{per cent.}\\ AW + Q. & \text{``}\\ E_1 + E_2 & \text{``}\\ \end{array}$
40.	isinclency compared with idealititititi	-	] = , . =

Special symbols,  $V_c$  = volume clearance, t = measured temperature. Subscript 5 applies to exhaust, *i* to injection, *k* to discharge, *g* to air-pump discharge.  $A = \frac{\tau}{778}$ . Correct for steam used by calorimeter, when necessary.

The usual custom is to assume that the steam at the end of compression, or just when the inlet opens, is quite dry and saturated, or that  $x_0$  is unity. It has been already said that the condition of the steam corresponding to  $x_0$  at the beginning of compression or the end of exhaust was considered to be that of dry steam; hence while the presence of any considerable quantity of water in the clearance volume is unlikely, it is not entirely justifiable to assume that the steam is dry. The difficulty of ascertaining the truth of this fundamental assumption has made many feel a dissatisfaction with the calculated results, and furthermore it will be apparent that the errors of observation and computation in the successive equations for Q are cumulative in their effect upon the final value for  $Q_0$ , and may make a large percentage of its value.

245. Thermal Analysis by Temperature-entropy Diagram.—The methods given for a transfer from the pv diagram to a T.E. diagram in § 205 require to be extended when clearance and compression volumes are to be considered. But the inspection of the T.E. diagram resulting from such a transfer will give the thermal analysis more clearly than the analytic method by Hirn and Dwelshauvers, although of course when correctly done the results in both should agree.

The method followed here was first advanced by Boulvin, and has been further elaborated by Prof. Reeve.

The steps for the transfer will involve much of the same procedure as above:

(1) The drawing or selection of an average and representtive indicator-card on the pv plane.

(2) The indicated horse-power is to be worked out, and the total feed-water supplied to the cylinder during the test. From this is derived—

(3) The water rate per horse-power per hour. The rate per stroke fed to the cylinder will be the total water consumption divided by twice the number of revolutions per hour.

(4) What is needed, however, is the reciprocal of (3) or

the number of strokes needed to make up a pound of the cylinder feed. In large engines this may be a fraction less than unity; in small engines it will be a whole number, and perhaps a large one.

(5) Find the weight of cushion-steam as in Hirn's analysis. Find first the clearance volume, add the volume given by the indicator-card when the exhaust-valves close, and multiply this by the volume resulting from the calculation in (4). This volume at the compression pressure can be reduced to weight from steam-tables. With multiple-cylinder engines this should be done separately for each cylinder.

Checking these with the methods followed in § 243, it will appear that (3) corresponds to M and that (5) corresponds to  $M_0$ . The next steps will be the proper graphical plotting of the pv card, that the proper entropy values may be measured from it. The object sought is to pass from the pistondisplacements given by the indicator to the volumes of heat medium supplied to the cylinder, the temperature of such volume being that in each case which belongs to that pressure.

(6) Construct a diagram (Fig. 105) which shall represent by the curve MN the saturation curve for one pound of



FIG.105.

steam measured for complete vaporization from a zero line OP, and having the height of the point M above the line ON

355

correspond to the absolute pressure in the boiler above the line of perfect vacuum on the same scale as the indicator-card or proportional to it, so that N would correspond to complete expansion, or to the pressure corresponding to the limit value of  $T_{n}$  as may be preferred. The vertical OP would be the point to measure the cylinder-feed volumes if there were no clearance and no cushion-steam in such volume or in the receivers undergoing expansion and compression at each stroke, and therefore affecting the actual volume of cylinder-feed. Since this cushioning weight is varying in volume as the pressure varies in the cylinder, the line to be drawn to the left of OP to represent this increase in actual volume due to clearance will not be a straight line, but will be an adiabatic for the clearance volume  $V_{\bullet}$  between the limits of the back pressure and the admission pressure. The methods for drawing adiabatic curves have been given elsewhere (§§ 123 and 125). A curve AB results in Fig. 105 which is as far to the left of the axis OP as the varying volume of the expanding cushionsteam adds to the volume of the cylinder-feed at any pres-The horizontal lengths between the curves AB and MNsure. at any pressure give the total volume of steam in the cylinder at that pressure, which will be the sum of the volumes of cushion-steam and cylinder-feed steam, assuming vaporization complete. Hence if the cushion-steam does not show the volume to be expected, this will mean that some of it has been condensed to meet demands for heat from the working volume, for which heat something should give account:

(7) If, then, horizontal lines intercepted between the curves AB and MN measure the sum of the cushion-steam in clearances and the cylinder-feed, a curve must be capable of being drawn between AB and MN which shall intercept the volume of the cushion-steam from the curve AB at each pressure, and which shall establish the zero line of piston-displacements, which are the units of the indicator-diagram.

This is done by measuring from AB to the right at a sufficient number of horizontal distances a length which shall be the product of the clearance volume into the number of strokes per pound of cylinder-feed (4). The dotted curve CD results in Fig. 105, and would appear to be the axis curve from which horizontal lines of the indicator-diagram were to be measured for each pressure, if the indicator-card had given pressures corresponding to volumes of cylinder-feed steam instead of volumes of piston-displacement only.

(8) Hence if from CD as an axis of volumes the indicatorcard from the actual engine be laid down, taking vertical distances as measured from the line of perfect vacuum, and laying off the horizontal distances from the curve CD at the same height, a diagram of cylinder-feed volumes *indeca* results (Fig. 106). It will usually be within the saturation curve MN, be-



#### FIG.106,

cause the volumes are made less than the theoretical by the condensations which measure the heat losses. The only case where the actual could pass beyond the saturation curve would be where superheating was practised.

(9) The diagram of volumes for the cylinder-feed or M can now be transferred to the theoretical temperature-entropy diagram by the principle laid down in § 205, that horizontal lines on the pv theoretical diagram and the T.E. theoretical diagram are divided proportionally by the points of the

actual diagram. The height of the line AB above the horizontal axis of entropy measures the temperature corresponding to the boiler-pressure; the point C is distant from the temperature axis a distance which is the entropy counted from an assumed zero, and the line CD is the increase in the entropy during complete vaporization at the temperature  $T_1$ . The line FG belongs to  $T_2$ , and its length is the measure of the decrease in entropy belonging to the feed-water temperature. The line OC is the logarithmic curve representing the gradually heating cylinder-feed, with temperature and entropy increasing together. The plotting of the diagram from Fig. 106 may cause it to appear on the T.E. diagram somewhat like Fig. 107.





246. Losses Revealed by the Temperature-entropy Diagram —(1) The line *in*, representing the period of admission in the actual engine, will not be as long as CD if the steam carries any moisture. The relation  $\frac{CH}{CD}$  is that given by the calorimeter, and is the proportion of dryness at admission.

(2) The drop from C to n indicates a fall of temperature. This is the result of friction and loss of pressure through too small ports or throttling passages.

(3) If it were the case that there were no wire-drawing nor any initial condensation before cut-off, the entropy line should move to D, and the heat-unit supply should have been greater than it is by the sum of the areas nicH + HDKLn. If niCH be charged to wire-drawing, the rest is the result of the condensation before cut-off, or initial condensation. The determination of the point H or n by calorimeter is to this extent unreliable and unsatisfactory, since the initial condensation will mask the other condensation, because greater in amount.

(4) The expansion curve between H and L on the pv diagram becomes the curve *nud* on the T.E. diagram. If the expansion were truly adiabatic from cut-off, it would descend on the line nL, which is the isentropic line; but since condensation usually continues after cut-off, the curve falls behind the line nL, until abstraction of heat ceases. This occurs where the line nL crosses the expansion line.

(5) Re-evaporation sets in, and a gain in entropy follows from the heating action of the walls. It is here that any action caused by the jackets would also appear.

(6) At d the exhaust opens. If expansion had been complete within the cylinder, d should have been on the temperature level given by the line FG. The expansion at exhaust is into the exhaust-pipe, instead of against the external resistance. The curve of constant volume dc (§§ 201, 202) is drawn, with the attendant loss of area below it.

(7) At c the back-pressure line begins. If c is not on the line FG, it indicates that either the vacuum is not as good as it might be in the condenser, or that the back-pressure in non-condensing engines is unduly high.

(8) At a the exhaust closes, and an area *ast* of work is done on the cylinder-feed which is a loss.

(9) When the point t is passed, the gain in heat is the result of a warming by the cylinder-walls. The two together may balance each other, although usually the sum is a loss. If the compression of the cushion-steam were just so adjusted that it would fill the clearance volume with cushion-steam at

boiler-pressure, and if the compression were truly adiabatic, the curve atri would be the logarithmic curve OC. If the compression is insufficient, making *ast* greater than *tri*, the difference measures the net loss.

Hence it will appear that the differences between the area of the actual and the theoretical heat-diagram measure the losses for the whole cycle, and the lost areas under each phase measure the values corresponding to  $Q_a$ ,  $Q_b$ ,  $Q_c$ , and  $Q_d$  in the preceding analytical method.

When the engine is steam-jacketed and an allowance is to be made for the consumption of steam in the jackets, so that their net effect may be observed, the usual plan is to construct a diagram to the right of the  $\phi_2$  ordinate, having the same  $T_2$  value as the working steam from the boiler, but having a horizontal or entropy length as much less than that of the working steam as the weight of steam per stroke in the jackets is less than the working-steam weight per stroke. This enables the heat-unit area to be compared directly. The jacket-steam parts with its heat energy by contact with the cooler metallic surfaces, as the working steam parts with its heat in non-expansive working when it flows out to the condenser. The lower temperature limit is that of the water condensed in the jacket and removed by traps.

247. Reeves' Entropy-temperature Diagram Chart. —Prof. Reeves arranged in 1897 a most convenient chart for the application of the foregoing principles. Following Boulvin, he divides a large sheet into four quadrants, allotting the lower ordinates below the central horizontal line to pressures, and the ordinates above the central horizontal to entropy. From the central intersection of the horizontal and vertical axes, abscissæ to the right are volumes, and to the left are temperatures. This divides the chart so that, as appears in the diagram (Fig. 108), the four angles give each a diagram in terms of the double unit. In the pressure-temperature segment are drawn a number of different adiabatics for differ-

ent weights of cushion-steam, and in the temperature-entropy segment are the curves of entropy for water and for steam similar to Fig. 106. If then the metamorphosed indicatordiagram be drawn on the p.v. segment with the line AB of Fig. 106 inserted in its proper location, it will be apparent that simple projection of points first upon the proper line in the volume-temperature segment and thence into the T.E. segment will locate the points of the desired experimental T.E.

ENTROPY	ENTROPY
TEMPERATURE	, AOLAWE
PRESSURE	PRESSURE
TEMPERATURE	VOLUME

#### FIG.108.

diagram. The diagram also presents other data which are intended to make its application more easy.

248. Conclusion.—It is to be emphasized anew that these thermal analyses are based on the knowledge as to the quality of the steam with respect to dryness within the cylinder at portions of the stroke, and can be no more accurate than the observations or the assumptions concerning this quality. It is furthermore not always easy to determine with exactness the point of cut-off with single-valve engines, and hence to fix the volume  $V_0 + V_1$  for the computations. Hence the conservative attitude towards them is that all tests and experiments should be so directed as to be made available when these disputable facts shall have been settled by an accumulation of knowledge concerning them, rather than that dogmatic assertions can be now made concerning the results of such analysis. These results may be called suggestive rather than conclusive.

# CHAPTER XVIII.

### COMPRESSED-AIR ENGINES.

**250.** Introductory.—The foregoing chapters have been mainly concerned with the use of steam as a heat medium, because it is in the first place the most used of all such media, and is the most accessible of the vapor class. Next to steam as a heat medium, the accessibility and harmlessness of air puts it as the most to be preferred of media of the permanent-gas class, treating it as a permanent medium at the usual range of temperatures and pressures.

Before passing to the study of air as a medium to which energy is imparted by the action of heat from combustion, as in the caloric or hot-air engine and in the gas-engine, it will be convenient to refer to a class of air-engines, using air as a motor fluid to which a degree of energy has been imparted by mechanical means so as to raise its capacity for doing work to a level higher than that exhibited by the ordinary atmos-The air-compressor (Chapter XIII) is constructed to phere. raise the entropy of air above its atmospheric condition, in isothermal aspiration, and to raise its temperature by adiabatic In so doing a quantity of energy is stored in compression. each pound of air so compressed which is available for work in a piston-motor similar to the steam-engine. The compressed-air engine receives from the reservoir a charge of available energy just as the steam-engine receives its charge from the boiler. A mechanical pressure is exerted against the piston at constant pressure isothermally up to cut-off, with a drop in entropy till cut-off is reached, after which adiabatic

expansion should drop the temperature in a complete expansion back to where the cycle began. It will be obvious, therefore, that if both compressor and air-motor were perfect and frictionless, the latter could drive the former and together they would make the reversible combination conceived by Carnot. In practice, however, the air-machine is to do some outside work at a point more or less remote from the compressor. The latter has therefore to receive a heat or other energy from some source, transform that energy to the form in which it exists in the compressed air, and permit that stored energy to be transmitted to the remote point, there to be released. It is the convenience and safety of the transmission and storage of energy by compressed air that has made it so important and widespread a feature of modern engineering. Storage of great energy in small bulk and with little weight in strong tanks is the element of strength for compressed air for street-car service or where the motor cannot be conveniently continuously connected to the delivery of the compressor. The convenient return of the exhaust to the atmosphere is in many places an advantage, as underground or in submarine work; and the harmlessness of the air in case of accident, breakage, leakage, and the like, are often valid claims for the use of such air-engines.

Compressed air may be used in air-engines, receiving it from receivers or direct from the compressing cylinders, in three general ways. There can be no condensation with air, so that the lowest pressure level to which it can fall is that of the atmosphere. When it does so, all the mechanical energy is withdrawn from it, and the engine is said to work with complete expansion. The objection to complete expansion is the low terminal effort towards the end of the stroke, which may not be enough to overcome the friction of the motor itself. Hence the second method is that of partial or incomplete expansion where there is a pressure acting at the moment when the exhaust opens. The energy resident in the

air which exhausts is thus lost, but a smaller cylinder will serve to give a given horse-power, because the mean forward pressure is greater, and a lighter fly-wheel will secure a given degree of regularity in speed.

The third method is to deliver air to the cylinder at full pressure, to work without reduction of pressure, and to exhaust a cylinder full of air at the receiver pressure at each stroke. Here the air works without expansion. These three types will be discussed, and the losses in transmitting energy to a distance.

251. Loss of Energy in Transmitting Air through Pipes.—The most considerable loss in well-planned systems will be the loss down the temperature scale by radiation and conduction in the long pipe-line. It does not pay, as a rule, to protect the pipes to mitigate this loss, and furthermore the cooling processes at the compressor are planned to carry away excess of temperature for the sake of lessening the compressor work. As the air cools, however, its volume lessens, or its pressure, or both together, so that the velocity of flow through the long pipe should in theory be increasing slightly from the beginning to the end. Furthermore, to cause a flow of the compressed air in the pipe from the compressor end toward the motor there will require to be a difference in This may be called  $(p_1 - p_2)$  and is a quantity to pressure. be assumed by the designer of the pipe transmission. To allow it to be 10 pounds difference is a large value, and would only be justified where the temporary character and small importance of the work made economy of plant-cost of more importance than running or working economy. From 3 to 5 pounds loss in transmissions up to 10,000 feet would not be considered bad practice. It will be apparent, therefore, that length and diameter of pipe will enter the formula, and the density or degree of compression to which the air is brought at the upper or compression end; there must be also an experimental coefficient to embody the actually observed effect

of the condition of the pipe, inside, upon the air flowing through it. The slower the linear flow per unit of time the less effect will the pipe have upon the differences of pressure. Hence it appears that all the factors entering into any formula are likely to be varied by the influence of the others which enter it, making any but an empirical formula a somewhat uncertain dependence.

252. The D'Arcy Formula for Compressed Air.—The original formula of D'Arcy for flow of water in hydraulic distributions has been modified to apply to an elastic medium like air, and in its most accepted form appears:

$$D = \frac{c\sqrt{d^{\circ}}}{\sqrt{l}} \times \sqrt{\frac{p_1 - p_2}{zw_1}}.$$

In this D is the cubic feet of air in cubic feet per minute discharged at the pressure  $p_i$  at the end of the pipe-line when the latter has a length in feet denoted by l and a diameter in inches denoted by d. Therefore the factor  $p_1 - p_2$  will be the permitted drop in pressure from the compressor pressure  $p_1$  to secure the demanded final pressure  $p_2$  at the air-engine. The factor  $w_1$  will be the weight in pounds per cubic foot of this compressed air entering the pipe at the compressor or the reciprocal of the volume occupied by one pound at the pressure  $p_1$ . Since the weight of a cubic foot of air at 62° F. and atmospheric pressure is .0761 pounds, the weight at any other pressure  $p_1$  will be

$$W_{1} = .0761 \left( 1 + \frac{\dot{P}_{1}}{14.7} \right),$$

in which  $p_1$  is in gauge pressure in pounds per square inch. This appears more conveniently

$$W_1 = .0761(1 + 0.068p_1).$$

Values for the factor  $c \sqrt{d^5}$  have been worked out as follows:
#### COMPRESSED-AIR ENGINES.

Diameter of Pipe.							$c\sqrt{d^5}$			Diameter of Pipe.						c√d5										
I	inch	•				• •						4	45.	3	9	inc	hes	5.		• •	•	•••	•		•	14872
2	" "	•		•		•••		•	• •			29	97.	0	10	6	6				•	•••	•		•	19480
3	" "	•		•		•••						87	6.	0	ΙI	4	6			•		• •		• •	•	<b>2</b> 4800
4	" "	•									I	85	б.	0	12	(	6			• •	•	•••		• •	•	30926
5	" "	•	• ,•			••					3	29	98.	0	I 3	•	6			•				• •		37898
б	" "	•		•		•••					5	27	73.	0	14	(	6						•	•••	•	45690
7	" "	•		•		• •					7	81	7.	0	15	•	6			•		•••	•			54462
8	"	•				••					10	98	38.	0	16		6			•	• •	•••	•			64102

The values for the expression  $c \sqrt{d^{5}}$  in the above table will require to be increased if any unusual conditions as to multiplicity of bends are to be met or the constrictions caused by valves with complicated passages. One bend at right angles has been considered to offer the resistance of one length of pipe of the same calibre. It is here that the judgment of the engineer must come in until exhaustive experiment shall have given reliable figures.

Another experimental formula of considerable acceptance is the result of the practice at the Mont Cenis tunnel excavations. If n denote the velocity in feet per second, d the diameter of the pipe in inches, and l the length in feet,

 $p_{1} - p_{2} = 0.00936 \frac{n^{2}l}{d},$ 

when  $p_1$  and  $p_2$  are the pressures in pounds per square inch at the beginning and end of the pipe.

253. Compressed Air-engine with Complete Expansion.—This is the preferred plan, because the air in expanding from the pressure  $p_s$  at which it enters the air-cylinder to the pressure of the atmosphere  $p_s$  at which it goes out, leaves the cylinder without carrying with it any available pressure energy. As in the case of the compressor, the work of the engine will be made up of

$$W_{s} = \begin{cases} p_{s}v_{s}, \dots, admission work \\ + \int_{v_{3}}^{v_{4}} pdv, \dots expansion work \\ - p_{4}v_{4}, \dots, back-pressure work \end{cases}$$

or

$$W_{s} = p_{s}v_{*} + \frac{p_{s}v_{s}}{n-1} \left\{ 1 - \left(\frac{p_{s}}{p_{s}}\right)^{\frac{n-1}{n}} \right\} - p_{s}v_{s}\left(\frac{p_{s}}{p_{s}}\right)^{\frac{n-1}{n}}$$
$$= p_{s}v_{s}\frac{n}{n-1} \left\{ 1 - \left(\frac{p_{s}}{p_{s}}\right)^{\frac{n-1}{n}} \right\},$$

in terms of the initial volumes and pressures for one pound of air received, or if the terminal pressures and volumes be preferred,

$$\bar{W}_{s} = p_{s} v_{s} \frac{n}{n-1} \left\{ \left( \frac{p_{s}}{p_{s}} \right)^{\frac{n-1}{n}} - 1 \right\},$$

from which the mean effective is derived by dividing through by the final volume  $v_4$ , giving

M.E.P. = 
$$p_{\frac{n}{n-1}} \left\{ \left( \frac{p_3}{p_4} \right)^{\frac{n-1}{n}} - 1 \right\}.$$

In this *n* is the ratio 1.41 between the specific heats, since  $C_p = 1.41C_v$ . The work for *M* pounds of air would be *M* times greater. The expansion is considered to be adiabatic, as was the compression.

254. Compressed Air-engine at Full Pressure without Cut-off.—This is a very usual case where the conditions must not permit of the down-drop of temperature in the adiabatic expansion. The air enters full stroke at  $p_s$  and fills a volume  $V_{.}$ , the latter representing M times the volume of one pound at the pressure  $p_s$ , when M pounds are expended per unit of time. There is therefore no internal temperature change,

but an isothermal entropy increase during the stroke, and at exhaust the pressure drops to  $p_4$  and the temperature from  $T_s$ to  $T_4$  at the free expansion into the open air, with the loss represented by the product  $778(T_s - T_4)$ . In other words, the air is used as an inelastic fluid like water to displace the working piston, and no increase in intrinsic energy resulting from the compression is withdrawn from it in the air-engine. It leaves the latter with just as much as it had when it entered it.

The work of such an air-engine will be the difference between the initial and final pressures into the volume  $V_s$  occupied by the M pounds of air; or

$$W_{4} = V_{3}(p_{3} - p_{4}),$$

but

$$p_{\mathbf{v}} = MRT_{\mathbf{s}};$$

hence

$$W_{\bullet} = MRT_{\bullet}\left(I - \frac{p_{\bullet}}{p_{\bullet}}\right)$$
$$= 778M(C_{p} - C_{v})T_{\bullet}\left(I - \frac{p_{\bullet}}{p_{\bullet}}\right),$$

since by definition  $C_{p} - C_{v} = \frac{R}{778}$  (§§ 116 and 183).

To compare this with the work of complete expansion, the expression for the work of one pound is transformed by the relations

$$C_v(n-1)=\frac{R}{778}.$$

Hence, since  $p_{s}V_{s} = RT_{s}$ , and

$$\left(\frac{p_4}{p_3}\right)^{\frac{n-1}{n}} = \frac{T_4}{T_3},$$

the expression

$$W_{s} = p_{s} V_{s} \frac{n}{n-1} \left[ 1 - \left(\frac{p}{p_{s}}\right)^{\frac{n-1}{n}} \right]$$

can be written

$$W_{\rm s} = 778 C_{\rm p} T_{\rm s} \left( {\rm I} - \frac{T_{\rm s}}{T_{\rm s}} \right)$$

for one pound of air; or for M pounds

$$W_{3} = 778 M C_{p} (T_{3} - T_{4}).$$

This expression also gives the temperature range for any assigned work given in pressure relations, with complete expansion. The work at full pressure may therefore be conveniently equated to an expression of the above form in which an unknown temperature  $T_x$  shall replace the final temperature  $T_4$  in this last equation. That is,

$$W_{4} = 778M(C_{p} \cdot C_{v})(T_{3} - T_{4}) = 778MC_{p}(T_{3} - T_{x})$$

which will express that final temperature giving the same work in a complete expansion as was given by the full-pressure condition. Solving for  $T_x$  it becomes

$$T_{\mathbf{x}} = \left[\frac{\mathbf{I}}{n} + \frac{n-\mathbf{I}}{n} \cdot \frac{p_{\mathbf{x}}}{p_{\mathbf{x}}}\right] T_{\mathbf{x}},$$

whence the ratio between  $T_s$  and  $T_x$  becomes when the numerical value for n is inserted:

$$\frac{T_x}{T_s} = 0.71 + 0.29 \frac{p_4}{p_s}.$$

 $T_x$  is a temperature having no experimental or actual value; but from it the relations of the work done by complete expansion and full pressure for any values of the ratio  $\frac{p_4}{p_3}$  can be worked out.

## COMPRESSED-AIR ENGINES.

255. Compressed-air Engine with Incomplete Expansion.—The third case is perhaps the most usual, where air is received at a pressure  $p_*$ , volume  $V_*$ , and temperature  $T_*$  up to cut-off; is expanded adiabatically down to conditions  $p_*$ ,  $V'_4$ , and  $T'_4$  above the exhaust conditions represented by  $p_4$ ,  $V_4$ , and  $T_4$ . The air expands freely from  $p'_4$  down to  $p_4$ , doing no external work, but there has been some lowering of the initial pressure in doing work during the partial expansion. As before,

$$W_{\bullet} = \begin{cases} p_{\bullet}V_{\bullet} & \text{admission work} \\ + 778MC_{\bullet}(T_{\bullet} - T_{\bullet}') & \text{expansion work} \\ - p_{\bullet}V_{\bullet}' & \text{back-pressure resistance.} \end{cases}$$

Following the same plan as in the preceding case, and substituting an ideal temperature  $T_x$  in an equation of the form given with complete expansion which shall give the same work at full expansion as is given in the actual case of incomplete expansion, the above expression for  $W_{\bullet}$  will be placed equal to the ideal expression, and solved for  $T_x$ . That is,

$$W_{s} = p_{s}V_{s} + 778MC_{v}(T_{s} - T_{4}') - p_{4}V_{4}' = 778MC(T_{s} - T_{x}).$$

But since

$$V_{s} = 778 M(C_{p} - C_{v}) \frac{T_{s}}{p_{s}},$$

and

$$V_{\bullet}' = 778M(C_{p} - C_{v})\frac{T_{\bullet}'}{p_{\bullet}'},$$

this becomes when divided through by 778M

$$(C_{p}-C_{v})T_{s}+C_{v}(T_{s}-T_{4}')-(C_{p}-C_{v})T_{4}'\frac{p_{4}}{p_{4}'}=C_{p}(T_{s}-T_{z}).$$

whence by performing operations,

$$C_v T'_{*} + (C_p - C_v) T'_{*} \frac{p_{*}}{p'_{*}} = C p T_x,$$

which gives

 $\frac{T_x}{T_{4'}} = \frac{Cv}{C_p} + \frac{Cp - Cv}{Cp} \frac{p_4}{p_{4'}} = \frac{1}{n} + \frac{n-1}{n} \frac{p_4}{p_{4'}} = 0.71 + 0.29 \frac{p_4}{p_{4'}},$ 

which is the same ratio as found for the non-expansive working. Hence for both cases

$$W_{4} = 778MC_{p}(T_{3} - T_{x}) = 778MCpT_{s}\left(1 - \frac{T_{x}}{T_{s}}\right),$$

and

$$W_{\rm s} = 778 M C_{\rm p} T_{\rm s} \Big( \mathbf{I} - \frac{T_{\rm s}}{T_{\rm s}'} \frac{T_{\rm s}'}{T_{\rm s}} \Big).$$

The values of  $T_x$  can be found for any relation of  $p_4$  and  $p'_4$  from the foregoing identical formulæ.

256. Compressed-air Engine with Isothermal Expansion.—This is a very unusual case, because it means heating the working air so as to have the same terminal temperature as at the entry, by some hot jacket or similar device. It is conceivable, however, if the high temperature of exhaust were to be thought desirable.

The work per stroke will be:

$$W_{\star} = \begin{cases} p_{\star}v_{\star} \dots \dots \text{ admission work,} \\ \int_{v_{0}}^{v_{4}} p dv \dots \text{ expansion work,} \\ -p_{\star}v_{\star}' \dots \dots \text{ back-pressure work,} \end{cases}$$

when expansion is incomplete, and

$$W_{*} = \begin{cases} p_{*}v_{*}, \dots, \text{admission work,} \\ \int_{v_{4}}^{v_{v_{5}}} p dv \dots \text{expansion work,} \\ - p_{4}v_{4}', \dots, \text{back-pressure work,} \end{cases}$$

when expansion is complete. Hence.

$$W_{\tau} = p_{s}v_{s} \left[ I + \text{hyp. } \log \frac{v_{s}}{v_{4}'} - \frac{p_{4}}{p_{4}'} \right],$$

and

$$W_{s} = p_{s}v_{s}$$
 hyp.  $\log \frac{v_{4}}{v_{s}} = p_{s}v_{s}$  hyp.  $\log r$ ,

when r is the ratio of expansion, or the ratio between the volumes at cut-off and at release. With complete expansion the terminal pressure  $p_4'$  at end of expansion equals the back-

pressure 
$$p_4$$
, or  $\frac{p_4}{p_4'} = 1$ .

257. Volume of the Cylinder of a Compressed Airengine.—The design of an air-engine cylinder usually presents itself with the air-pressures given, the ratio of pressures at beginning and end, and the foot-pounds or horse-power of work to be done. Hence the formula of §§ 168 and 181 is directly available. If the known horse-power reduced to footpounds is divided by 2n, when n is the number of revolutions per minute, the quotient will be the work to be done in one stroke. Substituting this for W, and solving for  $v_4$ , the necessary final volume of cylinder is found, neglecting clearance loss. The final volume will be the product of the two factors area  $\times$  stroke, which must be proportioned to each other according to any determining conditions as to either.

Or, the mean pressure value (§§ 184, 253) can be substituted in the equation

$$H.P. = \frac{PLAN}{33000}$$

for the factor P, and the equation solved for LA. Clearance will increase the cylinder volume according to the data of 233-236.

258. Compound Compressed-air Engine.—The use of a non-condensing type of engine is forced upon the designer of

an air-engine. Hence when large powers are to be stored in small bulk the use of high pressures is made necessary, and,

with a fixed lower pressure limit, a large ratio between  $\frac{v_4}{v_*}$ .

To secure this high degree of expansion or early cut-off in a single cylinder forces the use of disadvantageous crank-angles for the admission pressures, making, therefore, unsatisfactory working of the engine from the great range of pressures over the area of the piston. This evil is much mitigated by the use of the multiple-expansion system, using cylinders of progressive areas or volumes as the pressures fall during expansion, and enabling each cylinder to have a longer and more advantageous admission (§§ 172-174). The difficulties from cylinder condensation, which are of such moment in the steam-engine, are of less moment in the air-engine and may be disregarded, although there is an interchange of heat with the metal walls and the working fluid. Hence the work of the entire expansion from  $p_s$  to  $p_s$  is divided equally between the two, three, or four cylinders of the series by laying down a diagram having an area equal to the whole work under the assumed degree of expansion supposed to take place in one cylinder, and then dividing this area of work into halves, thirds, or quarters, and giving to each cylinder in the series a volume proportioned to the pressures within which it works.

The compound or multiple system permits a reheating between the cylinders if desired, whereby unpleasantly low terminal temperatures may be mitigated and the expansion be brought nearer to the greater work of the isothermal curve of pressures and volumes. That is, if there be two cylinders, and the terminal pressure and temperature in the first cylinder be  $p'_4$  and  $T'_4$ . Hence

$$W_{s} = 778 Cp(T_{s} - T_{4}') = 778 Cp T_{s} \left[ I - \left( \frac{p_{4}'}{p_{s}} \right)^{\frac{n}{4}} \right].$$

21 – T

If in an intermediate receiver, by any source of heat, the expanded air is raised again to  $T_s$ , the terminal temperature will become  $T_s''$  and the work in the second cylinder will be

$$W_{10} = 778 Cp(T_{s} - T_{4}'') = 778 Cp T_{s} \left[ I - \left(\frac{p_{4}}{p_{4}'}\right)^{n} \right],$$

so that the sum of the two effects will be

$$W_{\rm s} + W_{\rm 10} = 778 C p T_{\rm s} \left[ 2 - \left(\frac{p_{\rm s}'}{p}\right)^{\frac{n-1}{n}} - \left(\frac{p_{\rm s}}{p_{\rm s}'}\right)^{\frac{n-1}{n}} \right].$$

The work will be a maximum when the last two terms are a minimum. This occurs when

$$p_{*}'=\sqrt{p_{*}p_{*}},$$

as was the case with the compound compressor (§ 189). The question, however, is not yet answered by experiment, whether the loss in clearances and free expansion drop be-



tween the cylinders, when added to the interest cost of the smaller cylinders, offsets the mechanical gain from the use of the additional cylinders. In street-car motors, where two cylinders are wanted in any event to prevent stalling on

centres, the compound method offers great advantages. It will be interesting to compare the diagram of the advantage from intercooling in compression of air (Fig. 109) with the increase of volume resulting from interheating between cylinders which causes an adiabatic expansion in the air-engine to approximate more closely to the isothermal condition.

259. Combined Efficiency of Compressor and Airengine.—Since the compressed-air engine can only be operated in connection with a compressor which has antecedently raised the pressure and temperature level of the air, it becomes of moment to compare the work of the two machines in the light of the foregoing discussion, so as to reveal the directions for effort to make the air-engine return in mechanical energy all the energy put into the compressor by the prime source of power. Since the temperatures are the significant factors, the work of the compressor will be transformed from the expression in § 169 by the method followed in § 254, whence

$$W_1 = 778C_p(T_2 - T_i)$$

The work of the air-engine will be

$$W_{s} = 778C_{p}(T_{s} - T_{4}).$$

The efficiency, being the quotient of the delivered work by the applied work, becomes

$$E = \frac{W_{s}}{W_{1}} = \frac{778C_{p}(T_{s} - T_{4})}{778C_{p}(T_{1} - T_{2})} = \frac{T_{s}\left(I - \frac{T_{4}}{T_{s}}\right)}{T_{s}\left(I - \frac{T_{1}}{T_{2}}\right)},$$

which can be transformed into pressure relations by writing

$$E = \frac{T_{s}\left(1 - \left(\frac{p}{p_{s}}\right)^{\frac{n-1}{n}}\right)}{T_{s}\left(1 - \left(\frac{p}{p_{s}}\right)^{\frac{n-1}{n}}\right)}.$$

COMPRESSED-AIR ENGINES.

375

If the compressor and air-engine operate with about the same ratio or range of pressures, the ratio of the bracketed factors is not far from unity. This makes it appear that the nearer the temperature of inlet into the air-engine approaches the temperature of the delivery from the compressor, the nearer will the efficiency become unity. Hence the wisdom of preheating the air for the air-engine, if the latter is at any distance from the motor so as to have lost any of its higher temperature  $T_2$ .

It must not be forgotten, however, that it is not mechanically possible to reach an efficiency of unity, even with preheating at the air-engine, if the work of the engine part of the compressing plant be taken as the starting-point. If the compressor return to the air 80 per cent of the work put into the compressor, and the air-engine deliver 80 per cent of the work which it received, the double transmission and transformation returns at the air-engine as its net work only 80 per cent of 80 per cent of the steam-cylinder work, or only 64 per cent, even with complete expansion, unless the efficiency of the air-engine can be made greater than unity by adding extra heat energy at the point where the engine works.

If  $T_s$  is the temperature of the atmosphere at the airengine, it would be an advantage to lower  $T_s$  by cooling or otherwise. This confirms the advantage from isothermal compression or two-stage compression when the loss of energy in the cooling water is of less moment than the other compensating gains.

260. Heat Range in the Air-engine Cylinder.—The expression for the work of the air-engine,

$$W_{s} = 778C_{p}(T_{s} - T_{s}) = 778C_{p}T_{s}\left[1 - \left(\frac{p_{s}}{p_{s}}\right)^{\frac{n-1}{n}}\right],$$

leads at once to the conclusion that if the air enter the airengine at atmospheric temperatures—between 60° and 68° F.

—it will leave it at very low temperatures if there is any considerable range of pressures. The following table gives values for  $T_4$  absolute and Fahrenheit calculated from the relation

$$\frac{T_{\star}}{T_{s}} = \left(\frac{p_{\star}}{p_{s}}\right)^{\frac{n-1}{n}},$$

assuming

$\frac{f_3}{f_4}$ .	Final Absolute Temperature $t_4$ .	Final Fahrenheit $t_4$ .	<u><u>†</u>3</u> . <u></u> /4	Final Absolute Temperature $t_4$ .	Final Fahrenheit t4.
2	431.4	- 28	9	278.9	- 180.5
3	383.5	- 75.9	10	270.5	- 188.9
4	352.8	- 106.6	11	263.1	- 196.3
5	330.7	- 128.7	12	256.6	- 202.9
6	313.7	- 145.7	13	250.7	- 208.7
7	299.98	- 159.4	14	245.3	- 214.1
8	288.5	- 170.9	15	240.5	- 218.9

 $T_3 = 459.4 + 68^\circ$ .

These values for the temperature of the exhausted air lead to the consideration and feasibility of mechanical refrigeration, which will be considered in a subsequent chapter, and also to the signal advantage of preheating the air before it enters the air-engine. It further makes clear the objection to the presence of moisture in the air used, because such moisture becomes snow or ice in the exhaust-passages and clogs them.

**261.** Preheating the Air for the Air-engine.—Large-scale experiments with compressed-air plants without preheating of the air at the motor show an efficiency ranging from less than 30 per cent up to about 40 per cent. Preheating may reduce the losses to something over 20 per cent only, realizing an efficiency between 70 and 80 per cent. That is, to heat the air to a temperature of 480° F. at the motor will result in an increase of efficiency of 30 per cent.

Methods of heating the air involve either some form of stove, or the use of hot water under pressure. The stove

## COMPRESSED-AIR ENGINES.

plan in its simplest form is to force the compressed air through an air-tight vessel in which anthracite coal or charcoal is kept incandescent by the union of the carbon and the oxygen of the compressed air. The trouble with this arises from the ash and dust of the fuel going forward through the engine. For the small compressed-air motors of Paris, a stove of cast iron lined with fire-clay is heated by a gas-jet or a small coke fire. A coil of pipes in a fire forms another type. The fuel consumption is so small as to be scarcely noticeable, or about 0.2 of a pound of fuel per horse-power per hour. Seventy per cent of the available heat in the fuel went into the air, raising its temperature from 170° to 300° F. above the temperature in the conducting pipe.

A form of preheater which has been used for street-car service causes the compressed air to pass through a pressuretank filled with superheated water at  $330^{\circ}$  F. This avoids

carrying live fire on the car. The water carries more heat per unit of weight than any other body, and the air, taking up some water mechanically, causes it to become vapor in the cylinder, adding to the propelling effect. This is the feature of the Mekarsky system. Other plans inject hot water in jets into



the air storage reservoir. It will be apparent that preheating raises the value of  $T_s$  to that of  $T_s$  in the formula of § 259 and tends towards an efficiency of unity. Fig. 110 shows a cut of such preheater using oil.

262. Temperature-entropy Diagram for Compressedair Engine.—While the air-engine acts like the non-condensing steam-engine in one sense, yet it is only possible to treat it satisfactorily in connection with the compressor, of which it is the complement (§§ 263 and 264), since the cycle is not closed otherwise. If, for example, the perfect-expansion pv

diagram be chosen (Fig. 115), the admission of air at constant pressure from the receiver ab is not an isothermal at the temperature  $T_i$  because the pressure is not maintained by adding heat to the reservoir; but if the latter is of finite volume, the pressure is maintained by the inlet-supply from the compressor. Hence the line on the temperature-entropy diagram (Fig. 116) will be a line of constant pressure descending by a logarithmic curve from the point b to a for



which the upper limit  $(T_b \text{ or } T_i)$  is the temperature of the air leaving the compressor, and the lower limit is the temperature  $(T_a \text{ or } T_i)$  at which after cooling by radiation the air enters into the cylinder of the air-engine. Hence the relation of the co-ordinates will be

$$\phi = C_{\rho} \text{ hyp. } \log \frac{T_{\delta}}{T_{a}}$$

At the point a the air begins to expand in the air-engine proper (it will be observed that the line ab really belongs in the compressor process), and by hypothesis such expansion

## COMPRESSED-AIR ENGINES.

is adiabatic, and is accompanied by a drop in temperature without entropy change, giving the line *ad*, corresponding to the expansion-line *bc* on the *pv* diagram. In the absence of preheating (§ 261)  $T_d$  is much lower than the atmospheric temperature with usual points of cut-off in the air-engine, so that  $T_d$  gives a point *d* (§ 260) lower than the air into which the exhaust escapes. Hence a constant pressure-curve *dc* is required to return the exhausted cold air to the normal atmospheric condition, and its equation will be

$$\phi = C_{\phi} \text{ hyp. } \log \frac{T_{c}}{T_{d}}.$$

It will be apparent that the adiabatic compression of the aircompressor will be required to close such a diagram by a compression from  $T_c$  up to  $T_b$  from which the process began. If, however, the process be an incomplete expansion, as in the dotted pv diagram of Fig. 2, or without any expansion whatever, as in Fig. 1, the temperature-entropy diagram will appear like the left-hand part of Fig. 117 for the first case, and the right-hand part for the second.



The greater relative area of rejection of heat in these latter cases is the measure of their less economy as com-

pared with the full-expansion class, provided that the greater capacity of the working cylinder for a given power by reason of the lower mean pressure is not an offset in part to the greater heat-rejection per stroke.

263. Temperature-entropy Diagram for the Air-compressor.—The compressing cylinder cd being full of air at atmospheric pressure  $T_1$  (Fig. 118), the return of the piston



FIG.118.

compresses air adiabatically up temperature along the vertical ordinate cb (Fig. 116), without change of entropy to the pressure and temperature belonging to  $T_{1}$ . Then the valves of the receiver open in the actual case and the air passes atconstant pressure by slow discharge of its heat energy down the curve of constant pressure to the condition as to temperature which belongs to surrounding objects. This is the line ba of Fig. 118, and may logically attach itself to either the compressor or the air-engine. Strictly, of course, it must be supposed to occur in the compressor-cylinder, after the adiabatic compression is complete to the pressure  $p_{2}$ . Then. in the absence of any adiabatic expansion and drop down temperature, the diagram should close by an entropy change at constant temperature  $T_a = T_c$  so as to be capable of compression again to the point b.

If the cooling is not permitted at the constant pressure  $p_a$  of the receiver, then the increase of entropy value does not occur, and the diagram becomes the straight isometric *cb*, first up, and then down. This represents a cycle of pure

adiabatic type, with full storage and restoration of the heat energy of the compression, so that the air finishes with the same energy that it began with, and acts like a spring. No effective outside work has been done, however, because no energy has been expended.  $Td\phi$  has a zero value.

If, on the other hand, the air reached the air-engine at  $T_b$  by an isothermal heating process, the point *a* would lie on a horizontal through *b*, and the adiabatic expansion through the temperature-range represented by ad = cb would bring the final temperature to that of the intaken air, and the exhaust in escaping would retain sufficient energy to return by a constant pressure-curve up again to *b*, if it were not cooled by outside means. In practice, of course, the exhausting air is cooled by contact with the atmospheric air, and this potential energy is lost.

264. Temperature-entropy Diagram for the Combined Air-compressor and Air-engine.--A much more valuable conception and application of the heat diagram results, therefore, from the consideration that the compressor and the engine which it drives are one apparatus, the exhaust from the air-engine forming the aspiration volume of the compressor, and the discharge from the latter forming the admission volume for the stroke of the air-engine. The compressor always works with complete expansion; the airengine must be of the same capacity and work with complete expansion down to the intake-pressure. The object is to have no loss in transmission, and the external work done by the air-engine should be the same as that done by the steamengine cylinder of the compressor. Then the constant pressure-line and the adiabatic at the higher entropy belong to the air-engine, and the lower constant pressure-line and the adiabatic at the lower entropy are the complementary parts of the compressor cycle. The atmospheric ocean is the receiver for the air exhausted from the air-engine, and delivers it without change of state to the compressor-inlet.

The extent to which the actual combination departs from this ideal complete cycle made up of their partial diagrams measures the heat losses of efficiency, by reason of the failure of the entropies to equalize, or because a temperature loss or





FIG.120,

a pressure loss by cooling and radiation has compelled an expenditure of energy at the compressor greater than that exhibited by the air-engine.



Let it be supposed, for example, that the pv diagram (Fig. 119) is the card from the compressor, and Fig. 120 is

#### COMPRESSED-AIR ENGINES.

the adiabatic card from the complementary air-engine. The compression of the air is adiabatic, and after passing through pipes and storage its volume at the air-engine is reduced, as is made clear by the superposition of the two cards (Fig. 121). The shaded area lying between the two adiabatics is the loss of work as revealed by the pv representation of it. The temperature-entropy diagram in Fig. 122 deduced from the two foregoing paragraphs and resulting from their superposition shows that the heat energy furnished by the compressor is the area baNR, and the energy rejected by the air-engine is represented by the unshaded area cdNR. Hence the available or utilizable energy should be their difference, or the shaded area badc.

The effect of preheating if carried so far as to raise the point a to the same temperature-level as b is made evident by an increase in the area denoting energy supplied, enabling a greater degree of adiabatic expansion if the same temperature-level d is fixed, or a higher value for d can be permitted, provided the designer is willing to increase the area of rejected energy for the same work in the air-engine cylinder. Τf now, on the other hand, the compression were isothermal, and the air by the abundant use of cooling water were not allowed to rise in temperature, the temperature entropy diagram will be a line through c parallel to the entropy axis, since  $T_s = T_s$ , and the receiver is supposed to be large enough not to have its temperature raised by the displacement of the compressed air into it. This means, then, that the cooling water has carried away with it (perhaps to waste) a quantity of heat energy equal to the work of the compression, and the compressed-air receiver has taken up the work of displacement by molecular movement and eddies in the air itself. When, then, the air-engine receives its air at atmospheric temperature from such an isothermal compression, and uses it in complete adiabatic expansion, the air

must drop down temperature on expansion by an amount which would cool that weight of cooling water back to its original temperature if it could be kept for this purpose. If the water has been wasted, then the universe at large has received the heat from the cooling water, and has to supply that which warms the exhaust-air up to  $T_1$  again. The heat of the fuel burned to compress the air in the first place is wastefully used in this process, when referred to the power developed at the air-engine.

Or, again, if the expansion at the air-engine were made isothermal by heating the air as it was working as well as before admission, making  $T_s = T_4$ , the temperature-entropy diagram becomes a line also, and the heat to be supplied will be that which will be the area of the finite diagram which would have been generated with true adiabatic expansion.

These observations lead to the generalization which might have been to essen in advance, that compressed air or other elastic media are only effective storage media for mechanical energy, and act like a spring, provided that means are taken on the expansion to replace the heat conditions in inverse order which attended the compression. Or in other words, air acts as water or other incompressible fluid transmission would to transmit the energy of the steam or other motor, if pains are taken to prevent either uncompensated rise or fall of temperature while in use as a medium ; and in this case friction in pipes, valves, and bends would be the only source of loss.

Finally, if heat is supplied to the air-engine by preheaters, such heat, adding to that received from the compressor, adds an area to the temperature-entropy diagram which helps to compensate for the losses of energy which will appear in actual conditions.

265. Concluding Summary.—It must not be overlooked that the air-engine and the air-compressor are not heat-engines in the sense in which this treatise uses this term. They do

## COMPRESSED-AIR ENGINES.

not create a mechanical energy or liberate it from a reservoir of stored heat energy. The mechanical energy being created or liberated so as to be available, these appliances store and restore that mechanical energy. Their claim for consideration is based upon the fact that the relations of pressure volume and temperature are so interrelated by natural laws that the principles underlying the compressor and compressed-air engine must conform to those broader and more fundamental ones which the science of thermodynamics must consider as its own. The special field of compressed-air engineering bears, however, to the general subject of motive-power engineering the same relation which is borne by the electric dynamo and motor in its parallel department: the energy having been liberated or made available, each is a convenient and satisfactory method of transmitting that energy to desired points and utilizing it there. The economic advantages of large-scale installations for the generation of mechanical energy are reaped by either system, and the choice of that which is to be preferred must often be guided by considerations outside of the purview of pure theory.

## CHAPTER XIX.

## HOT-AIR ENGINES.

**266.** Introductory.—In the preceding chapter a class of engines using cool or cold air has been discussed, in which the propelling energy to drive the piston was given by raising the pressure of air as a medium by means of mechanical energy previously available. This chapter is to discuss air-engines in which the pressure to drive the piston is given to the air as a heat medium, by increasing its temperature and entropy directly by the application of heat to it. They may or may not include also the conception of a compression of that air, but the rise of its temperature is the primary feature.

The relatively low specific heat of air:

at constant volume0.16847,	$(C_v)$
and at constant pressure0.23751,	$(C_p)$

together with the reluctance with which heat is transferred to it, except by contact in thin films or small subdivided masses, not only limit the size and weight of these engines to relatively low powers, but, by making the storage process inconvenient between the source of heat and the engine, the boiler and its appendages, have been thrown out which form so considerable a feature of the steam-engine and constitute one of its dangers. The usual underlying principle is the heating and cooling of 386 the air for each stroke between the limits of  $p_1$  and  $p_1$  in the cylinder itself, or in small chambers without it, or both. Carnot's principle applies most closely to such engines, because the same weight of air is often used over and over again in a strictly closed cycle. The term "caloric" engine is a sort of trade name applied by John Ericsson in 1833 to his engines of this sort, and is properly going out of use.

267. Types of Hot-Air Engine.—The fact that air as a heat medium is also a supporter of combustion, and the high temperature directly realizable from such combustion, has attracted designers to the use of engines in which the heat energy should be directly liberated in the working cylinder. Such engines will be called *internal-combustion* engines, the furnace being practically within the cylinder or in communication with it. The engine works rather with the products of combustion than with air as a medium, and for this reason such engines are sometimes called "products of combustion" engines. The fuel may be solid, liquid, or gaseous (Chapter V). The importance of the gas-engine will command a subsequent chapter for itself; the oil-engine makes the fuel gaseous before it is consumed, and is in the gas-engine class.

The alternate plan is to have the furnace exterior to the working cylinder, heating the working medium by transfer through a metal wall. This is the more usual type where the fuel is solid, and these form the hot-air engine properly so called.

A second classification of type must be made which shall include in one class those engines which operate their cycle upon the same mass or weight of air continuously, only taking in a fresh charge to replace leakage losses or to increase the mass in use. This type might be called the closed-cycle type. The other class in this division would be the open-cycle type, where at each stroke a new charge is drawn in from the atmosphere

and, after being heated and expanded, is exhausted again into the atmosphere, as occurs in the non-condensing steam-engine. The first class can evidently be operated independent of atmospheric pressure, or with an initial tension selected at pleasure.

Air-engines will again differ according as they use or do not use the principle of the "regenerator" to absorb heat on the outflow of the air, and to restore such entrapped heat to the incoming cooler air.

Finally, engines of the closed-cycle type may differ by having the temperature change in the air take place at constant pressure or at constant volume. Each type is identified with the name of some designer or engineer. It will be apparent that the closed-cycle hot-air engines operate on the lines of the Carnot cycle, as the steam-engine can only be made to do by making the feed-pump or air-pump an integral part of the series of organs.

268. Regenerator for Hot-air Engine .- The desirability of an appliance within a heat-engine itself which could absorb heat on its way to rejection at T, and give it up to the air on its way to become heated up to  $T_{n}$  was early realized by students of the Carnot theorem. If it could be made to work, such an appliance could replace some of the necessity for adiabatic expansion and compression (particularly the undesirable latter). The first to apply the idea was Robert Stirling (1816 and 1827), and Ericsson used it in 1833 and thereafter. The ideal plan would be to have a chamber of such thermal capacity, and such absence of self-conductivity, that the air entering it at  $T_{2}$  at its cool end should be heated to  $T_1$  by the time it had reached the other or hot end; and such heat as was thus absorbed should have been imparted to the chamber by the flow of the hot air entering in the reverse direction at a temperature  $\mathcal{T}_{i}$  so as to leave the chamber at the cooler end at  $T_{a}$ . This hypothesis is of a distinctly reversible

process, but fails of course from the actual conduction and radiation, and from the necessarily limited capacity for heat of a regenerator of practicable size and weight.

These regenerators as applied to hot-air engines are either wire-gauze nettings or thin brass plates on edge for small engines, or are coils or grids of copper wire for larger ones. The Ericsson hot-air ship of 1853 had a wire regenerator whose aggregate length of wire exceeded fifty miles. The weight of material used in the regenerator in British practice seems to have been about forty times the weight of air used per stroke. The waste from practical causes seems to have ranged from one tenth to one twentieth of the heat alternately withdrawn and restored per stroke. The closed-coil feedwater heater using exhaust-steam embodies this regenerator idea.

It must not be overlooked that the action of the ideal regenerator has nothing to do with the taking in and rejection of heat by the engine for the purpose of doing work with that heat. The regenerator becomes thus an integral part of the engine, and is to be so considered.

269. Hot-air Engine with Temperature Changes at Constant Volume. Stirling's Engine.—The engine designed by Robert Stirling (1816) and improved by James Stirling (1827) is one of the simplest of the closed-cycle external-furnace type, and embodies regenerator and Carnot cycle. It is shown in ideal section in Fig. 125.

The working cylinder is B, with its piston connected to a beam and so to the rotative mechanism. A passage or pipe connects the working cylinder with the larger chamber in which the heat changes occur. D is a displacing piston or plunger made of a sheet-metal casing filled with a non-conducting material like plaster or brick-dust. The furnace-fire surrounds the hemispherical cast-iron vessel at the bottom,

but is prevented from reaching above the diameter. In the upper part at C are coils of small copper pipe in which circulates cooling water forming the refrigerator. Between the



points A and C is the regenerator E of thin plates. The displacing plunger D does not fit the casing, but an inner lining of it, which lining is perforated at the bottom. The working air is thus forced to pass through the regenerator on its way to and from the working cylinder. The displacing plunger D is so adjusted as to its phase of movement that the up-stroke shall occur when the working piston in B is down or nearly so, and the descent of D shall take place when B is

near the beginning of its idle or descending stroke. engine is single-acting unless made with double cylinders. The cycle presented on the *pv* diagram is therefore shown by Fig. 126.

(I) The air at  $T_1$  from the action of the regenerator receives heat at that temperature from the furnace. It expands isothermally along *ab*, doing work through the piston *B*. The heat taken in per pound of air will be  $C_pT_1$  hyp. log *r*, in which *r* is the



ratio between the initial and final volumes of the air. The increase in entropy during that isothermal expansion will be

$$\phi_1 - \phi_1 = R$$
 hyp. log  $r$ .

(2) The air returns without change of its volume through the refrigerator from the  $T_1$  end to the  $T_2$  end. The pressure fails along *bc* proportionally to the fall in temperature. The heat stored in the regenerator plates is  $C_v (T_1 - T_2)$ .

(3) The ascent of the displacing plunger compresses the air along *cd*, reducing its volume, but withdrawing any heat by the passage over the coils of the refrigerating surface in *DC*. Heat is rejected to the cooling water to the amount of  $C_p T_s$ , hyp. log *r*. The entropy change should be the same as in the expansion, but in reverse direction.

(4) The air, passing again through the regenerator from the  $T_a$  end to the hot end, is heated to  $T_a$  isothermally at constant volume along da, and the heat taken up by the air should be that furnished to the regenerator on the other transit of the air, or  $C_v$   $(T_1 - T_2)$ .

270. Temperature - entropy Diagram for a Stirling Hot - air Engine.—If the regenerator were ideally perfect, and replaced the adiabatic expansions and compressions per-

391 The

fectly, the temperature-entropy diagram would be the rectangle whose width was (Fig. 127)

 $\phi_1 - \phi_1 = R$  hyp. log r

and whose length was

 $T_{1} - T_{2}$ ,

and whose area

$$(\phi_{\mathbf{2}} - \phi_{\mathbf{i}}) (T_{\mathbf{1}} - T_{\mathbf{2}})$$

would give the mechanical energy per pound of air per stroke. The relation of this quantity to the applied heat,

 $(\phi_1 - \phi_1)T_1$ 

would be the efficiency. The rejected heat would be

 $(\phi_2 - \phi_1)T_2.$ 

But while the regenerator gives when perfect in action a temperature-entropy area equal to that of the Carnot cycle since,

$$\frac{CT_1 \text{ hyp. } \log r - CT_2 \text{ hyp. } \log r}{CT_1 \text{ hyp. } \log r} = \frac{T_1 - T_2}{T_1},$$

the diagram is not of precisely the same form, because there will be a gradual decrease in entropy during the cooling, and a



gradual increase during the heating process. Hence the diagram will take the form of Fig. 128. The curve *bc* replace.

the isentropic drop in temperature, and the curve da represents the corresponding rise. If the regenerator is perfect, these two curves will be similar, because each transfer in one direction is the same as the transfer between the same temperature limits in the other. The value for the abscissa at any temperature T will be

# $\phi = C_v$ hyp. log T

when the transfer is at constant volume, as in the case under consideration. For the other class the specific heat will be that at constant pressure.

The area *pbcq* shows the heat taken in by the regenerator, and the area *madn* shows the heat given out to the air.

Taking the actual experimental data for a Stirling airengine used many years ago in a foundry at Dundee, and quoted from the Institute of Civil Engineers of Great Britain, some interesting conclusions may be drawn. The observed quantities were

$T_{1} = 1111$	$p_1 = 240$	d = 16 inches
$T_{2} = 611$	r = 1.25	l = 4 feet
	Rpm = 28	

Volume of cylinder

at admission and end of exhaust = 1.709at end of expansion and beginning of exhaust = 2.119

Expenditure of heat in heating the air, or latent heat of expansion,

 $H_1 = P_1 \phi = R$  hyp. log  $r \times P_1 = 11.647 \times 1111 = 12942$ 

Waste heat in regenerator,

$$mK_v(T_1 - T_2) = 13 \times 500 = 6500$$
  
m is called from  $\frac{1}{10}$  to  $\frac{1}{20}$ 

Total heat expended per pound per stroke

Rejected heat,  $H_2 = T_2 \phi = 11.647 \times 611 = .7119$ Mechanical energy per stroke per pound,

$$\phi(T_1 - T_2) = 11.647 \times 500 = 5823$$

Efficiency of fluid,

$$\frac{\text{Mechanical energy}}{\text{Heat applied}} = \frac{5823}{19443} = 0.3$$

Volume of piston displacement per stroke,

 $\frac{2.119}{2} = 1.06$  cubic feet.

Mean effective pressure,

 $\frac{\text{Mechanical energy}}{\text{Volume of displacement}} = \frac{5823}{1.06} = 5437 \text{ lbs. per square foot ;}$ = 35.75 " " inch.

The horse-power,

$$\frac{37.75 \times 200 \times 4 \times 28 \times 2}{33000} = 51 +$$

The relatively small capacity for its volume of cylinder and the relatively low mean pressure for the high initial are features to be observed. The engine referred to has long been regarded as a classic, but it was abandoned from the difficulty of maintaining the heating-chamber. Usually it was run at a lower temperature and pressure, and developed an average of 20 H.P.

Laubereau's engine is a more modern form of the Stirling.

271. Hot-air Engine with Temperature Changes at Constant Pressure. Ericsson's Engine.—The hot-air engine of 1852-3 designed for a 2200-ton sea-going vessel by John Ericsson has much the same classic and historic interest as the Stirling engine. The engine was calculated to be of 600 H.P., but actually ran at about 300. There were four cylinders, each 14 feet in diameter and having 6 feet stroke, causing

#### HOT-AIR ENGINES.

nine revolutions per minute. The air entered at about 380° F. It burned 8 tons of coal per twenty-four hours, which is 1.1 pounds per H.P. per hour if the larger figure is taken, and 2.2 pounds if the smaller figure is correct. Its bulk and weight were its defects. In 1854 it was replaced by a steam-engine. In 1860 Ericsson brought out his early design of horizontal small motor, and later (1880) the latest form adapted for house-pumping was produced. Fig. 129 shows the Ericsson



F1G. 129

FIG. 130.

pumper in perspective, and Fig. 130 in section. The fire of coal or gas is below the longer cylinder d, which again is waterjacketed at the upper end, xx. In tank-pumping engines the pumped water circulates through the jacket. A is the hollow displacing piston, and B is the working piston proper. The displacer is coupled to the bell-crank beam K, and so to the crank, while the beam proper is linked directly to the crank.

Hence the two pistons are practically quartering. Fig. 131 shows a reproduction of an actual pv diagram, and Fig. 132 the theoretical curves. The straightness of the isothermal



lines shows the variation of pressure to be slight compared with the change of volume.

The temperature-entropy curve diagram for the Ericsson engine will be the same as for the Stirling (Fig. 128, § 270), except that the coefficient will be  $C_{\beta}$  for the logarithmic curves, instead of  $C_{v}$ .

The Rider hot-air pumping-engine separates the hot and cold cylinders, and places a regenerator H between. The Ericsson pumper does not use a regenerator (Fig. 133).

272. Other Forms of Hot-Air Engine. — The engineers and designers of the continent of Europe have made more trials

397

with hot-air engines than have been made in America, but the limited extent to which even successful forms have been introduced have made their engines but little more than names. Richard Unger combined a separate compressing cylinder for



FIG. 133.

raising initial tension, with the plan of lowering the initial volume of such air by injecting cool water into it. Some of this water heated by the compression becomes steam. The hot products of combustion from the furnace mix with part of the cooled compressed air, and thence go to the valve-chest of the engine.

The Stirling-Laubereau engine had the working piston acted on at high heats by the air used, and a certain volume of air fills clearance volumes which underwent heat changes without doing work by its expansion. Lehmann's hot-air engine combined the low piston temperature secured by Ericsson, and avoids unnecessary heating and cooling of a part of the air at each revolution,

The plan of separate compression and the use of hightension air in a closed cycle are features of the Woodbury-Merrill engine of American origin. Other American designers have been Shaw, Roper, Wilcox. Other foreign types are represented by Franchot, Siemens, Robinson, Bailey.

Special interest, however, attaches to a principle put forth as early as 1851 by Dr. Joule, which leads to the operation of internal-combustion engines, to be later discussed.

273. Hot-air Engines with Separate Compressing Cylinder.—It is necessary to add to the organs of a hot-air cycle-engine a pump which shall draw in air from the atmospheric supply without, and deliver it to the working cylinder if the cycle is to be an open one. This aspirating pump is usually also a compressing pump, driven from the working shaft, and hence absorbing a certain amount of the energy developed by the heating of the air. The energy required for compression is usually restored completely by the increased energy of the working stroke, but of course extra weight is needed in the fly-wheel to redistribute this restored energy.

This separate pump is a prime requisite of products of combustion engines, and is present also in others.

The ideal indicator-diagram of such an engine on the pv plane will have a form such as Fig. 134.

The pump-piston starting at the point represented by dabove the vacuum line a distance corresponding to atmospheric pressure draws in a volume  $V_0 = Hd$ , representing that of one pound. By the return or compressing stroke of the pump the air is first compressed adiabatically along da, and when the pressure of the receiving chamber (the furnace of a products-ofcombustion engine) is reached, the valves to it open and the compressed charge enters. The pressure is practically constant because the working cylinder is withdrawing air during this

displacement process, provided the heating chamber is of sufficient volume, but the heat is not supplied isothermally as in previous cases.

The working cylinder draws hot air at constant pressure from the receiver or furnace to an extent represented by



the line Kb, when cut-off occurs and adiabatic expansion down the line bc, until atmospheric pressure is reached if the expansion is complete, when the exhaust opens to the atmosphere and the line cd is the return stroke. Such an engine is like the combination of air-compressor and air-engine, or steamengine without condensation, whose diagram is closed by the compression of the boiler-feed pump. The net work is the shaded area, the white or plain part being the work of the compressing pump. Using as subscripts the notation of Fig 134, the area of the feed-pump work diagram will be KadH, which will be the sum of

$$NdaM + KaMO - HdNO.$$
  

$$a = C_{v}(T_{4} - T_{0}) + P_{4}V_{4} - P_{0}V_{0}$$
  

$$= C_{v}(T_{4} - T_{0}) + R(T_{4} - T_{0})$$
  

$$= C_{v}(T_{4} - T_{0}) + (C_{p} - C_{v})(T_{4} - T_{0})$$
  

$$= C_{p}(T_{4} - T_{0}).$$

The area for the working-cylinder pv diagram will be similarly found to be *KbcH*, if the same scale of volumes be used as for the pump, which will become

$$A = C_{\ell}(T_2 - T_2).$$

The difference, or net work, will be

$$A - a = C_{p}(T_{1} - T_{2} - T_{4} + T_{0}).$$

The heat expended in the receiver is expended in raising the temperature of the air from that caused by the adiabatic compression  $T_4$  to the temperature  $T_1$ . Calling it Q, as the pressure is constant,

$$Q = C_p \left( T_1 - T_4 \right).$$

 $T_1$  is known as the receiver temperature, and  $T_4$  can be calculated when  $T_0$  is atmospheric temperature by the adiabatic formulæ (§ 154).

The heat rejected is given out to the atmosphere during any cooling from  $T_{i}$  (at which the air exhausts) down to  $T_{o}$ , the atmospheric temperature.  $T_{i}$  is similarly found from the  $T_{i}$ value by the adiabatic formula (§ 154). Hence the efficiency is

$$E = \frac{A-a}{Q} = \frac{T_1 - T_2 - T_4 + T_0}{T_1 - T_4} = 1 - \frac{T_2 - T_0}{T_1 - T_4}$$

Since the volume of the feed-pump should be to the volume of the working cylinder in the relation of the temperatures at the points a and b, the pressures being constant, and these volumes should bear also the same relation at d and at c, the equality can be written

$$\frac{V}{v} = m = \frac{T_1}{T_4} = \frac{T_2}{T_0},$$

by which relations the equation of efficiency transforms into

$$E = I - \frac{T_2 - T_0}{T_1 - T_4} = \frac{T_1 - T_2}{T_1} = \frac{T_4 - T_0}{T_4}$$
when working with complete expansion. The latter expression shows the value of increased compression by the feed-pump, and of high pressure in the receiver to which the  $T_4$  corresponds. The first expression shows the value of having the expansion go down to the temperature  $T_6$  if possible, when the efficiency would become unity, as would be expected. This means, however, that the compressing pump must be more nearly equal to the working-cylinder volume than is convenient or practicable.

274. Temperature - entropy Diagram of a Hot-air Engine Changing Temperatures Non-isothermally.—The Stirling and Ericsson engines changed temperatures at constant temperatures; the foregoing type changes temperatures at constant pressure, but the temperature is changing during the heating process. If, therefore, the pv diagram be as shown in Fig. 132 or 134, the *te* diagram will appear as in Fig. 135. The



adiabatic change from d to a from the compression of the feedpump is followed by the logarithmic change of entropy caused

by the heating process; such change, being at constant pressure, will produce a curve whose abscissa at any point will be

$$\phi = C_{\phi}$$
 (hyp. log  $T$ -hyp. log  $T_{a}$ )

when the temperature T is given. Then from b to c will be the adiabatic expansion in the working cylinder, and c to d the cooling under constant volume during the exhaust process back to the point in the temperature range where compression begins by the pump. The ratio  $\frac{Ta}{Tb}$ , which is  $\frac{Na}{Rb}$ , should be the same as the ratio  $\frac{Ka}{Kb}$  on the pv diagram, and is the ratio m between the pump and working cylinder which it supplies The efficiency will be

$$\frac{\text{area } abcd}{\text{area } abRN} = \frac{\phi(T_a - T_d)}{\phi T_a} = \frac{\phi(T_b - T_c)}{T_b},$$

which is less than the perfect engine would offer which took in and rejected all the heat at the same extreme limits of temperature. In proportion as the curves *ab* and *cd* approach straight lines, by as much does the area of the mechanically utilized work approach the area of the perfect engine diagram.

275. Joule's Equivalent Hot-air Engine with Closed Cycle.—While the foregoing designs are of present practical interest, it may be desirable to say that Dr. Joule proposed a closed-cycle engine, involving the same transformations in 1851. While the engine was never built, yet its reverse lies at the basis of certain types of refrigerating machine, and its cycle would be the equivalent closed cycle to that of an actual products-of-combustion engine. Fig. 136 shows a diagrammatic scheme of such a closed-cycle engine. C is the piston of the compressing-pump, on the same rod with M, the piston in the working cylinder. H is the furnace-chamber at  $T_1$ , and C is the receiver with cooling water circulating in its tubes to maintain it at  $T_2$ . If these were large enough, the pressures in

### HOT-AIR ENGINES.

them would not vary. The air compressed by C to  $T_a$  passes through the value v and is further heated to  $T_1$ , and expands through u to drive M. On expanding into the cool-chamber C the temperature drops to  $T_c$  by adiabatic expansion, and from  $T_c$  to  $T_d$  by logarithmic cooling, as above explained. The only changes necessary to transform Joule's engine into



FIG.136.

an internal-combustion engine in principle are those involved in making the chamber H the furnace-chamber, with provisions for introducing the fuel into it as required. The chamber Ccan also be the outside air into which the working cylinder exhausts and from which C shall take in its supply at  $T_0$  at each stroke.

276. Internal Combustion Hot-air Engine Using Solid Fuel.—The introduction of the gas-engine and the oil-engine, and the perfecting of the processes for gasifying fuel in producers (Chapter V), have resulted in giving to the engines of the earlier inventors an interest which is merely historic, in their attempts to heat the working air by passing it through fire of solid fuel (Fig. 137). The furnace was placed in a chamber strong enough to withstand the pressure  $p_{i}$ . The compressingpump *B* forced air below the ash-pit up through the fire, where

it was expanded by heat and by combination with carbon. Being admitted to the working cylinder, against the piston A, it was exhausted into the chimney-stack. The furnace had to be charged with fresh fuel through a combination of double-



F1G. 137.

doors on the air-lock principle, *D*. The foreign names identified with this type of engine are those of Sir George Cayley and of Wenham (1873) and Duckett in England, and Dr. Avenier de la Gree in France. The American engines have been those of Shaw, Roper, and Wilcox. The difficulties have been those caused by flue-dust and grit in the cylinders; the rapid destruction of working surfaces and valves by the intense heat, and the difficulties of lubrication. They were also more bulky than the closed-cycle engine in proportion to the power developed. If it were desirable to follow their working, the foregoing principles can be applied, using for initial volume not that of one pound of air, but the volume produced by supplying one pound of air to the furnace, as given by the data of Chapter IV.

277. Concluding Summary.—The hot-air engine in small sizes is more economical than the steam-engine of the same capacity. In larger sizes it has about the same economy as the less economical steam-engine, measured in coal consumed per horse-power. It has the advantage of avoiding the steamboiler as a magazine or reservoir of energy which may be liberated by accident so suddenly as to be explosive. It can be run by less skilled and expensive labor and no steam-runner's license is demanded. It is safe and odorless.

The objections to the hot-air engine are the greater bulk and greater weight for the same power than is required with the steam-engine; the low mean pressure with high initial pressure, which latter compels great strength of structure; the deterioration of heating-surfaces exposed to high heats and consequent oxidation; the difficulties of packing and lubricating at high temperatures; the difficulty of regulation closely to varying resistance.

If there is any danger to the present supremacy of the steam-engine, it will be in relatively small plants that a hotair engine can be a substitute; the gas or internal-combustion engine is more to be feared than the hot-air engine proper.

# CHAPTER XX.

## INTERNAL-COMBUSTION ENGINES.

### THE GAS AND THE OIL ENGINE.

280. Introductory-Historical.-The first suggestion of an engine exploding a mixture of gas and air behind a piston belongs to a considerable antiquity, when gunpowder was also similarly considered by Huyghens as early as 1680. The first English patent dates back to 1794 (Robert Street). The Lenoir engine of Paris in 1860; the Hugon engine of 1865. with water injection; the Otto and Langen (Cologne, 1867), while great advances upon the early types are only of historic interest since the introduction in 1876 of the "Otto Silent" gas-engine and the cycle represented by this class. The idea of compressing the gas-charge before explosion was brought forward as early as 1801; early names in English practice are those of Barnett (1838) and Sir C. W. Siemens (1862). French engineers have been Million (1861) and Beau de Rochas (1862), who proposed the four-stroke cycle, now known by Dr. Otto's name. The Dugald Clerk engine (1880) and the Atkinson (1885) are types involving features not common to all which have been recently brought forward under a great variety of trade or proprietary names.

It will be seen that the introduction of a combustible gas into a mass of air required to burn it, and the ignition of the gas in the air within a confined volume, results in an expansion of that air which will exert a pv pressure, which can be made to do work by means of piston and engine mechanism. The

gas engine is therefore a hot-air engine of the internal-furnace class and works upon an open cycle, since it draws in a fresh charge of gas-fuel and air at each working stroke, and rejects the products of the combustion with the exhaust. It is also a "products of combustion" engine, but using a fuel without grit or ash. Oil-engines, gasefying the oil and mixing it with air, belong to this same class, requiring only proper provisions for pumping and vaporizing the oil-fuel.

The fuel-engine cycle (§§ 273-75) is the usual and typical



FIG. 140a

hot-air gas-engine cycle. Chemical considerations must be borne in mind for their effect in modifying both the theory and action of the gas-engine.

281. Lenoir Gas-engine of 1860.—The cylinder of this early engine was a water-jacketed steam-engine cylinder (Fig. 140). During the first part of the outgoing stroke air and gas

in proper proportions of I of gas to about 12 or 14 of air air were drawn into the cylinder by aspiration. The inlets being closed, the mixture was fired by a spark from a





Ruhmkorff induction-coil. The increase of volume following the explosive ignition increased the pressure at about half stroke, which fell till the end was reached, when the expulsion of the products of combustion took place on the return of the piston. Fig. 141 shows a typical pv diagram. It took 95



FIG. 141.

cubic feet of gas per horse-power per hour (which is more than four times the present requirement), and the high temperature and the noise were objectionable. The platinum points of the

sparking electrodes were also liable to become clogged with lampblack or soot deposit. A large amount of the available power was lost in the impact effect, whose heat was absorbed and wasted by the jacket.

282. Hugon's Gas-engine of 1865. — Hugon's improvement on the Lenoir type followed from the injection of water with the gas and air mixture. The vaporization of this injection absorbed some heat and gave it out in the work of expanding, although the expansive force was diminished. The distribution of the effort made the moving parts suffer less and diminished repair expenses, and made the engine more durable, especially at packed surfaces, such as piston surfaces, stuffingboxes, etc. Gas-jets were used to fire the charge.

A form of engine known as Bischoff's is the only survivor of the purely explosive non-compression type, and burns 120 cubic feet of gas per H.P. per hour.

283. Otto and Langen Atmospheric or Free-piston Gas-engine of 1867 .- To avoid the loss from impact effect, when positive connection to the crank-shaft forced the piston to yield but gradually to the sudden increase of volume of the charge, Otto and Langen, in Germany, and Barsanti and Matteucci, in Italy, proposed to have the vertical cylinder of some height, and the piston-rod to rise without effect on the crank-shaft during the stroke caused by the gas ignition. The piston yielded like a projectile and rose to the top of its The sudden expansion of the gas-mixture cools it traverse. also suddenly, and as its tension falls below the atmospheric tension, the pressure of the atmosphere acts to force the piston back downward. The piston-rod is connected to the shaft by a rack and pinion-gear, operated by a pawl and ratchet-wheel, so that the pawl clicks idly on the up-stroke, but the rack and pinion transmit the atmospheric effect on the down-stroke (Fig. 142). This engine was obviously noisy and irregular. It consumed, however, about 30 to 40 cubic feet of gas per H.P.



FIG. 142.

410

HEAT AND HEAT-ENGINES.

hour, and was manifestly a distinct gain on its predecessors. Ignition was effected by an outside gas-flame.

284. Brayton Gas-engine or Ready Motor of 1873 .- A gas-engine forming a type by itself was brought out and introduced to a limited extent in eastern America in which a mixture of gas and air drawn into a pump-cylinder on its aspirating stroke was compressed by the return stroke into a reservoir under a pressure of about 70 pounds per square inch. From this reservoir it was allowed to flow to the working cylinder during perhaps one-half of the outgoing stroke of the piston. The mixture was ignited in the working cylinder by a flame, the back-flow of flame to the reservoir being prevented by wiregauze at the inlet. The mixture thus simply increased in volume but without rise in pressure, since the connection with the reservoir was still open, and followed the piston up to cut-off at half stroke. The rest of the stroke was operated by the expansive energy of the gas-mixture, and on the return stroke the contents of the cylinder were exhausted. Such an engine had no explosive ignition, but the slow inflammation took place as fast as the mixture was admitted and was continuous during such admission. The pump-piston had the same cross-section as the working cylinder in the beam form of engine, but onehalf the stroke. In steeple-engines the two pistons had the same stroke, but half the area was given to the compressing piston.

The principle of slow inflammation is wasteful with a water-jacketed cylinder, since a loss of energy or increased gasconsumption results from the necessity of sustaining pressure and temperature. The terminal or exhaust temperature of the gases was high from this cause, as well as the mean temperature. The efficiency as measured by the work done by I cubic foot of air with the Brayton engine was, however, 0.36, as compared with 0.21 given by the previous types, having no compression and working by explosion. It was displaced, however, by the superior economy of the Beau de Rochas or Otto

four-phase cycle, whose efficiency was measured by 0.45 for a cubic foot of air used under the same assumed conditions.

285. Four-phase Cycle of Beau de Rochas.—What is generally called the Otto cycle was first suggested in a French patent of 1862 by Alphonse Beau de Rochas, who also advocated the advantages of previous compression of the combustible mixture, and proposed to do away with the separate compressing pump by making only one stroke in four to be the 'working stroke in a single-acting engine. The Beau de Rochas or Otto cycle involves:

1. Aspiration of the mixture of gas and air in proper proportions during an out-going stroke of the piston (1-2 in Fig. 143).

2. Compression of the mixture by the return of the piston (2-3-4). This compression fills a comparatively large clearance volume behind the piston, which must be so adjusted to the displacement by the piston that there shall be no danger of such elevation of temperature from the compression as to ignite the mixture as the result of compression alone.

3. The piston being at or near its inner dead point (4), the compressed mixture is ignited by some acceptable and reliable device, at which the pressure rises at once (4-5) and exerts its outward effort to drive the piston forward. Expansion is followed by gradual lowering of pressure during this working stroke (5-6-7).

4. The products of combustion are discharged into the open air through the exhaust-valve by the return of the piston to its inner dead centre (8-1). The cycle then repeats itself.

It is apparent that a heavy fly-wheel must be used to equalize the motion of the crank-shaft, having energy enough stored in it by the working stroke to overcome the resistance during the time of the other three strokes, and cause also the piston to perform the acts of the cycle in the cylinder. High rotative speed is therefore an advantage. Furthermore, a

413

high initial pressure and temperature are desired, with a low terminal value for both, so as to secure a high mean value. Rapid inflammation is therefore desired, and the methods of ignition become important.





0

### FIG. 143.

286. Otto Silent Gas-engine of 1876.—The propositions of the French patent were not embodied in industrial form until Dr. Otto reinvented the cycle and, as the result of much experimental study, brought out the prototype of all the

modern gas-engines, to which he gave the trade-name of "Silent," to distinguish it from his earlier noisy type.

The engine was single-acting, of trunk design to secure compactness. The cylinder and valve-casing were water-jacketed. The valve-gear was operated by a shaft driven from the main-engine shaft at half its rate. Cams opened the valves at proper intervals. Regulation of effort was caused by making the inlet-cam miss its stroke when a centrifugal governor driven from the main shaft was turning too fast. Hence this type of engine has become known popularly as the "hit-or-miss" gas-engine. The mixture was ignited in early forms by a flame. The clearance volume was about one half the cylinder volume. (Fig. 144.)



#### F1G. 144.

Under the Otto patents many modifications were introduced, such as to use two cylinders driving the same crankshaft, one of which should be two phases ahead of the other, and thus diminish the interval between working strokes. The cylinders have been placed vertically instead of horizontally; different igniting devices have been used; the front or idle side of the piston has been used as the aspirating and compressing side; double-acting types have been used with ignitions on both sides, occurring alternately. Since the

expiration of the Otto basal patents, many new forms and names have come forward, both in England and America.

287. Dugald Clerk Gas-engine of 1880.—The twinning of the cylinders to secure an impulse every revolution makes a costly engine by reason of the expense of the two mechanisms. The most satisfactory plan is to separate the aspirating and



FIG. 145.

compressing operations from the other two doing the former work in the separate pump-cylinder. In the Clerk engine this arrangement is secured. At the back end of the working cylinder is placed the clearance volume, which is a conical or trumpet-shaped space, communicating through a lift-valve with the compressing cylinder. The pump or displacer crank leads the working crank by 90°. The exhaust-ports from the working cylinder are at the front or outer end of the bore, and are

.

uncovered by the working piston as it nears the outer end of The displacing piston is then returning, comits traverse. pressing the charge aspirated on its outer stroke, and the flow of fresh mixture into the clearance drives the expanded products of combustion in front of it, expelling the previous charge through the exhaust-ports. The expanding trumpet-shape by lowering the velocity of the new charge lessens the likelihood of wasteful mixture of the new and old mixtures. Any union which does take place is a gain from preheating the new charge, and thereby cooling the old. The return of the motorpiston compresses the new mixture, which is ignited by a flame as the crank passes its dead-centre at each revolution. Fig. 145 shows the Clerk engine in section, A being the working cylinder, C its piston, G the conical clearance volume, and E the exhaust-ports.

288. Atkinson Differential or Cycle Engine of 1885.-The peculiar features of this engine are the unusual linkage between the pistons and the crank-shaft, whereby the pistons can be made to act as their own valves, and whereby a greater expansion is attainable than with fixed clearance volumes to be filled with gas-mixture. The engine has appeared in two forms. In that selected in Figs. 146 and 147 there are two trunk-pistons, linked to the crank-pin by the two curved beams The latter are borne on the two massive beam-centres, whose location to each other is so chosen as to force the pistons out of symmetry or phase as the crank passes the four cardinal points as indicated in Fig. 147. In the first position, with the crank at the extreme left, the pistons are close together. An automatic lift-valve admits a charge of gas and air between them as they separate by the quarter revolution of the crank to the position 2. This movement, and the further movement toward position 3, closes the admission- and the exhaust-port, and as the pistons move toward each other, compression of the charge takes place. The compression being completed in

position 3, the charge is fired and the pistons separate, performing the working stroke, expanding the mixture by the increase of volume. The exhaust-port is uncovered and discharge begins when the pistons reach position 4, at which time the left-hand piston is moving rapidly to the right, while the left one is nearly stationary. The four usual operations of



FIG. 146a.

the cycle are provided for in the single cylinder, and an impulse occurs under full load at every revolution. The unusual character of the Atkinson linkage limited it to experimental sizes and low speeds and powers, and the design modified from it never attained any commercial importance for business reasons.



Fig. 146b.





Fig. 148 shows the cycle or single-piston engine of Atkinson. The connecting-rod does not drive the crank directly, but



FIG. 148.

a toggle-lever, pivoted at the centre as appears in Fig. 149. The connecting rod to the crank is T shaped, bearing at its lower



FIG. 149.

end the short transverse portion which forms the arms of the T. The piston-rod couples to the further end of this trans-

420

verse member, and the toggle-lever is jointed to it at the It will appear from this ingenious arrangement that the end. piston will make two strokes in each direction for one revolution of the crank, and that these will not be of the same length. The first outstroke or intake stroke will be longer than the return or compressing stroke, so that a compression volume The explosion then occurs followed by the longest is left. outstroke, giving the greatest expansion volume. Then the longest stroke of all takes place, from furthest out to furthest in, sweeping out all products of combustion. The toggle-lever causes the doubling of the strokes, since it swings through an arc only, and must do this twice in one revolution. The position of the cross-arm of the T as the toggle-lever swings is what gives varying length to the piston traverse.

289. Classification of Gas-engines.—The foregoing paragraphs have made it apparent, therefore, that there are two general classes of gas-engine.

Class I. Those making no useof compression;

Class II. Those employing compression.

The first class contains the purely explosive types and presents the two sub-classes :

(a) Explosion drives the power stroke;

(b) Explosion lifts the piston freely, and the return is the working stroke.

Class II contains the modern efficient engines and may be divided into:

(a) Compression effected in working cylinder;

(b) Compression effected in a separate or pump-cylinder.

They may again be grouped into two sections according to the working of the expanding heat medium :

(c) Ignition occurs at constant volume, followed by a sudden rise of pressure;

(d) Ignition occurs at constant pressure from a reservoir; the gas mixture burns slowly as volume increases.

The Otto engine belongs in groups (a) and (c), the Clerk engine in groups (b) and (c). The Brayton engine is the only example of group (d) and it is also in group (b).

290. Methods of Igniting the Gas-charge. — Gasengines may again be grouped into four classes upon their mechanical side according as they vary in the method used to set fire to the mixture of gas and air which has been drawn into the cylinder by the aspirating stroke. The methods practised by different designers for this purpose may be grouped as follows:

(1) Electrical methods;

(2) Flame methods;

(3) Incandescence methods;

(4) Compression of the charge.

The first plan is an early one. A pair of naked electrodes allow a spark or an arc to pass between them at the time when they are exposed to the gaseous mixture by the withdrawal of a slide, or the spark passes as a contact is broken between two poles exposed in the clearance. The breakage of continuity is timed by the motion of the valve-gear.

This plan avoids the inconvenience of opening the cylinder cavity by valve-movement when that cavity is under greater pressure than prevails without it, and a consequent tendency to leakage and unpleasant odor. The difficulties are those belonging to electric methods in unaccustomed hands, the clogging of the electrodes by lamp-black deposit, and the annoyance in finding the cause when ignition fails. The best electric igniters have the contacts wipe over each other so as to be kept cleansed by the scraping action.

The second plan is also an old one. It was used in the Barnett engine (1838) in a typical form (Fig. 155), depending on what may be called the air-lock principle. An external flame A set fire to a stream of gas entering the hollow cock chamber from below when the opening I was turned toward

such outer flame. The rotation of the cock through 90° clockwise in the plan brings the flame in contact with the explosion



Fig. 155.

port 2 and fires the charge, blowing out the enclosed flame, of course, in the process. It is relighted by the reverse motion of the cock. The intermittent contact of the flame and the

explosion port can be secured by a sliding valve, which carries the igniting flame first to the exterior flame and then draws it back into line with the port. This plan requires the presence of sufficient air to ignite the gas-flame in the valve-chamber. A plan introduced by Clerk of using the normal mixture of gas and air for the igniting flame has much increased the rapidity at which ignitions can occur. In the Brayton engine the flame was continuous on the upper or inner side of the gauze through which the mixture streamed.

The third class of igniters uses either a short coil of incandescent wire kept hot by a current of electricity of sufficient potential running through it, whose incandescence can serve to ignite the mixture when a slide is withdrawn from in front of the coil or the latter is moved into line with the explosion port; or else the mixture is fired by passing part of it through a tube or grating, which is heated to incandescence by a separate flame or by the heat of the explosion of the previous strokes. The tube may be of wrought iron or of some ceramic material, or (as in Clerk's plan) a measured stream of gas at each stroke can be admitted to heat a cage of platinum plates, which cage, being borne by a slide, is presented white hot opposite the ignition port at the proper time by the motion of the slide.

The fourth plan is one particularly applicable to oil-vapor engines, but capable also of igniting with a gas-mixture. It depends on raising the temperature of the gas-mixture by compression in a non-conducting clearance-volume to such a temperature that chemical combination is possible at that pressure and temperature, and occurs without external igniting appliances. This is of course in the incandescence class, only the temperature of the clearance-volume does not have to be so high by reason of the heat in the mixture due to the compression. This principle is used in the Hornsby-Akroyd and the Diesel engine.

A class of igniting methods might be made of certain suggestions proposing the use of spongy platinum, or the use of spontaneously igniting compounds such as phosphoretted hydrogen. They have not been reduced to successful practice, however.

The objections to the flame methods are the danger from extinction of an exterior flame by draught or otherwise, and the odor and leakage which seem inseparable from it. The electrical methods are uncertain and troublesome.

291. Indicator Diagrams from the Gas-engine.—The foregoing types will give each his peculiar indicator diagram of effort on the pv plane. Figs. 156 and 157 show the non-compressive type of engine, the former a Lenoir and the latter an Otto and Langen.

Figs. 158 and 159 show the motor cylinder and compressing pump of the Brayton engine.

Figs. 160 and 161 show typical diagrams from Otto and Clerk engines.

The lower lines in Fig. 160 show the aspirating and exhaust lines of the first and fourth parts of the cycle. For a Clerk engine, with separate displacing cylinder, a diagram such as Fig. 162 will be taken from that separate cylinder.

The interest attaching to the first four is at present only historic. With respect to the latter or Otto cycle diagrams it is to be noticed that the pressure does not rise to its maximum instantly, or while the engine is at its dead-centre, nor is it dangerously great in amount. The strain on the engine mechanism is no more exacting than that which comes upon an engine using steam of high pressure. It must be observed, however, that there is no considerable duration of that maximum pressure, but the drop due to expansion sets in at once. In other words, there is no way of increasing the power of a gas-engine by any process analogous to following the piston during a considerable part of the stroke with full boiler pres-















sure, which is possible with the steam-engine, if the valvegear is constructed so as to allow it. It appears, further, that the quicker the complete inflammation of the mixture, or the less the increase of volume during ignition, the higher the initial pressure, and the greater the mean forward effort. It will be noted, furthermore, that it will be but rarely 4 that expansion can be carried down to atmospheric pressure. It will usually be incomplete, 4 entailing loss of available energy (§§ 201 and 255). The mean pressure must be such in the 5 single-cylinder Otto engine as shall be proper for . over four times the average horse-power, since 5 the working stroke must not only do the external work of that stroke, but must also store in the 5 fly-wheel an amount of energy for the external work of the next suceeding three traverses of the 6 piston, and overcome the resistances in the engine itself in the compressing stroke. 5

Since the maximum pressures are caused by the flaming of the gas in the air, it becomes of interest to study the temperatures to be expected.

The questions, then, on which experimental knowledge must be sought will be the rapidity 1.5 of flame propagation and the relation of pressures to actual temperatures.

292. Some Phenomena of Ignition in the Gas-engine.— The volume of air required for the combustion of a gas of given composition has already been calculated (§§ 24–27), as well as the theoretical temperature of a flaming substance when its calorific power is known, the weight or volume and specific heat of the products of combustion being known or assumed (§§ 28, 61, and 68). In a gas ignition the weight of combustible per cubic foot is not large, but the time taken for its combustion

FIG. 162.

is very short. Hence the reasoning of § 61 should be applicable, and a high temperature should be secured.

The pressure behind the piston having been observed by the indicator, the temperature corresponding can be calculated from the Gay-Lussac law, as the volume is constant (§ 112). The calculation need only be checked by the fact that there is a slight contraction of volume resulting from the combination of the combustible gas and air as two bodies into one chemical mixture. With ordinary street gas, and the minimum dilution with air, this contraction will be less than four per cent, and diminishes with the dilution. Hence it is usually safe enough to calculate temperatures without allowance for this contraction.

But complete combination does not occur at once, nor are theoretical pressures and temperatures attained. Physicists appear to agree that nearly one half of the heat present in the mixture of inflammable gas is kept back, and is prevented from causing the increase in pressure to be expected from it. Standard experiments made by Dugald Clerk have given the following results with English illuminating-gas (Oldham):

		Vol. Air.	Pounds per sq. in. Gauge Pressure.	
No.	Vol. Gas.		Observed Pressure.	Calculated Pressure.
I	I	14	40.0	89.5
2	I	13	51.5	96.0
4	ī	II	61.0	112.0
5	I	9	78.0	134.0
6	I	7	87.0	168.0
7	I	6	90.0	192.0

The theories which have been advanced to explain this suppression of heat are at least three. Hirn's explanation was that at these high temperatures the cylinder walls and waterjacket absorbed heat so rapidly that at a certain point the abstraction of heat was faster than its liberation by the burning

of the gas. The objection to this theory is that the suppression of heat does not seem to depend on the cylinder surface nor on the efficiency of the jacket. Bunsen's theory is that at high temperatures the phenomenon of chemical combination cannot occur readily, and that a high enough temperature may be reached to dissociate or break up combinations already made or making. Hence, if the combination cannot exist at any high temperature, the mixture will remain made up of the free constituents, which will come together only as the temperature falls. The fact of dissociation has been proved by physicists; its applicability to the gas-engine is still partly in question by reason of the fact that suppression of heat does not seem to increase in proportion as the temperature increases.

The third and most interesting theory is that advanced by Mallard and Le Chatellier, that at the higher temperatures the specific heats of the constituents and of the products of combustion increase. That is, if, as seems to be the case, the specific heats of oxygen and nitrogen double at or near  $3600^{\circ}$  F., the heat is completely evolved in the flame combustion, but twice as much heat is taken care of in heating these absorptive gases. This has the same difficulty as the dissociation theory; a greater proportion of heat should be evolved at the lower temperatures, which is not always the fact.

The soundness of the dissociation theory seems to be suggested by what is known as the "after-burning." The expansion should fall below the adiabatic line with a good waterjacket, since heat should be withdrawn and the pressure thereby lowered. The actual curve is nearly adiabatic or above it, suggesting an addition of heat during expansion, which of course must come from the combustion of gas in the charge which was not ignited at the beginning of the stroke. Such gas is not burned with the same economy as the explosion proportion, and liberates less heat per unit of weight. It fattens the indicator-card, however.

Dr. Otto's claim and theory for his silent engine was that the dilution of the fresh charge with the products of combustion of the previous one, and their arrangement in a species of stratification, caused a slower propagation of the flame, and moreover caused a cushioned effort of the expanded charge against the piston. Later experiments have thrown considerable doubt over the validity of these contentions.

203. Usual Mixtures of Gas and Air .- The gas being the expensive element in the mixture of gas and air drawn into the cylinder, it would appear that to increase the proportion of air in a given cylinder volume was to increase the economy. This is only true, however, when the power of the cylinder is the fixed element, provided the diluted mixture does not lose pressure per square inch in a more rapid proportion. That is, it may be necessary to increase the cylinder volume more rapidly to secure a given power, and so draw in more gas than if the proportion of gas were increased in a cylinder of given volume. It is desirable, furthermore, that in a cooled cylinder the water in the jacket shall not lower the average temperature and pressure too rapidly. Hence the most efficient mixture becomes a matter for experimental determination. The mixture must further be one in which the flame propagation or the time of ignition of the mixture shall bear the desired relation to the speed of the engine, or the period of the single working stroke of the four-phase cycle. The accepted data are again those of Mr. Dugald Clerk, from experiment, as follows:

No.	Volume Gas.	Volumes Air.	Maximum Gauge Pressure, lbs. per sq. in.	Time of Explosion, Seconds.	Absolute Fahr. Temperature of Explosion from Observed Pressure.
2	I	13	52	0.28	1934°
4	I	11	63	0.18	2309
5	J	9	69	0.13	2525
6	I	7	89	0.07	3236
7		5	96	0.05	3484

Mixtures more dilute than 14 or 15 of air to one of gas fail to ignite. Six volumes of air furnish just about the required oxygen for complete combustion. The time of explosion can be shortened by adapting the shape of the vessel to more rapid propagation of the flame, or by igniting by the injection of a flame into the combustible mixture.

When the capacity of the mixture for resisting the cooling effect of the walls is considered, or its ability to keep up its pressure until a part of the stroke is completed, the best mixture is found between  $\frac{1}{12}$  or  $\frac{1}{14}$ , or about one of gas to thirteen of air.

294. Thermodynamic Efficiency of the Otto Engine considered as a Carnot Engine.—If it be assumed that the heat caused by the explosive ignition of the gas in air is all imparted to the air at that temperature of explosion (T), and that by the compression either in pump or cylinder the temperature has been brought up to  $(T_c)$ , the heat supplied to the cycle will be supplied at the constant volume  $v_c$  prevailing at the end of such compression, and will be

$$H_1 = C_v (T - T_c).$$

If the condition be assumed which is the most usual, that the final volume after expansion is the same as that at atmospheric pressure before compression was begun, then the heat necessary to bring the mixture back to its original state may be abstracted also at constant volume; hence if  $T_a$  be the final temperature at exhaust, and  $T_a$  the atmospheric temperature before compression, the heat discharged will be

$$H_{\mathbf{y}} = C_{\mathbf{y}}(T_{\mathbf{y}} - T_{\mathbf{a}}).$$

Hence the Carnot efficiency will be

$$\frac{H_1 - H_2}{H_1} = \frac{C_v(T - T_c) - C_v(T_s - T_a)}{C_v(T - T_c)}$$
$$= 1 - \frac{T_s - T_a}{T - T_c}.$$

The two curves of temperature range being adiabatic, and the volume range being the same,

$$\frac{T_a}{T} = \frac{T_a}{T_c}.$$

Hence

$$E = \mathbf{I} - \frac{T_2}{T} = \mathbf{I} - \frac{T_a}{T_c}$$
$$= \mathbf{I} - \left(\frac{v_c}{v_o}\right)^{n-1},$$

when  $v_0$  is the final volume at the end of the stroke. This says, in other words, that the efficiency is greater as the ratio between the initial and final volumes of the compressing



stroke grows less, or the greater the compression. The exponent n is the ratio between specific heats of air. Fig. 163 shows the perfect diagram corresponding to this design.

The fact that the theoretical efficiency can be increased by increasing the degree of compression, which would not be true in practice to the same degree, shows the danger of applying Carnot's reasoning to cases to which it is not properly applicable.

295. Temperature-entropy Diagram for the Gas-engine —The discussion of Joule's air-engine in § 274, where the heat medium receives its heat and increase of entropy at an increasing temperature, has opened the way to the discussion



of the temperature-entropy diagram for the gas-engine. In its theoretical form, when operated with compression either in a separate cylinder or in the working cylinder, the adiabatic compression of the charge raises the temperature from d to a without increase of entropy. The ignition of the combustible gas at increasing temperature causes the entropy to rise according to the law

 $\phi = C_v$  hyp.  $\log \frac{T}{T_a}$ .

The expansion during the working stroke supposed to be adiabatic would drop the temperature down to that represented by the point c on the temperature-ordinate, at which the exhaust may be conceived to open. Then the curve cdis a drop in entropy and temperature at the constant pressure of the exhausting products of combustion, to close the cycle and bring back the condition of temperature and entropy belonging to the mixture as drawn into the compressing cylinder.

The difference between the gas-engine cycle and the theoretical Carnot cycle is made clear by observing that for the ideal Carnot cycle the line ad should have been carried up to meet a horizontal line through b which represents the maximum temperature attained; the entropy should increase at constant temperature. Secondly, the adiabatic expansion should lower the temperature till it descends along bc to meet a horizontal through the point d; the rejection must take place at the constant lower temperature. The relation of the shaded area to the total  $T\phi$  area might thus be called the *possible* efficiency, while the ratio between the rectangle given by the lines through b and d as compared with the total area whose base is NR and whose height is bR might be called the ideal efficiency.

In drawing a temperature-entropy diagram for an actual engine from its indicator-diagram on the pv ordinates, the relation is used (§ 124) that the work done with isothermal expansion in foot-pounds should be equal to 778 times the heat-units supplied. With permanent gases this work will be expressed by

$$RT$$
 hyp. log  $r = RT$  hyp. log  $\frac{v_s}{v_1}$ ,

when the 778 is divided out to reduce it to heat-units. But the work will also be

 $T(\phi_1 - \phi_1),$ 

whence the entropy change equivalent to the actual change will become

$$\phi = R$$
 hyp.  $\log \frac{v_2}{v_1}$ 

by dividing both members by T.

This can be written

$$\phi = (C_{p} - C_{v}) \text{ hyp. } \log \frac{T_{s}}{T_{1}}$$
$$. = C_{p} \text{ hyp. } \log \frac{T_{s}}{T_{1}} - C_{v} \text{ hyp. } \log \frac{T_{s}}{T_{1}}.$$

It follows, therefore, that points on the indicator-diagram may be transferred to the temperature-entropy diagram by the graphical expedient of drawing a line of constant pressure through one point of a pv curve, and a line of constant volume through another (Fig. 165). These two construction



lines will intersect at a pv point which will have a corresponding temperature T, established by the constant relation PV = RT. Then if in the left-hand part of Fig. 165 the points 1, 2, and 3 be the selected and resulting points, the lines  $T_1$ ,  $T_2$ , and  $T_3$  will indicate the corresponding isothermal

lines. Then the constant pressure curve I-3 will have a relation between co-ordinates

$$C_{p}$$
 hyp.  $\log \frac{T_{s}}{T_{s}} = C_{p}$  hyp.  $\log \frac{v_{s}}{v_{s}}$ .

since, the pressure being constant, the temperature will vary as the volume. The constant volume curve 3-2 will have a relation between co-ordinates given by the expression

$$-C_v$$
 hyp.  $\log \frac{T_v}{\overline{T_v}}$ 

By the expedient of multiplying both terms of the fraction by  $-\frac{T_a^a}{T_a^{a}}$ , this becomes

+ 
$$C_v$$
 hyp. log  $\frac{T_2}{T_3}$ ,

which (because the volume is constant, which again makes the pressure proportionate to the temperature) may be written

$$C_v$$
 hyp.  $\log \frac{p_2}{p_1}$ ,

since the line through the point I is a constant pressure line and hence  $p_s = p_1$ . Hence the equation for the entropy becomes transformed from

$$\phi = C_{\rho}$$
 hyp.  $\log \frac{T_{a}}{T_{1}} - C_{\nu}$  hyp.  $\log \frac{T_{a}}{T_{1}}$ 

into the expression

$$\phi = C_{\rho}$$
 hyp.  $\log \frac{v_{a}}{v_{1}} + C_{v}$  hyp.  $\log \frac{p_{a}}{p_{1}}$ 

which can be used to transfer points on one diagram to the other, provided proper values are found for the quantities  $C_{\phi}$  and  $C_{v}$  for the mixture of air and gas during compression,
and for the products of combustion after ignition and during expansion. Mr. Geo. Richmond by a process of approximation has proposed values as follows:

C.	-	Ş	.246	on	the	compression	curve
C <sub>F</sub>		l	.26	" "	" "	expansion	"
C		Ş	. 176	" "	"	compression	" "
$v_v$	_	l	. 189	"	" "	expansion	" "

Following this method, the  $\rho v$  diagram at the left of Fig. 166 gives the straight line 1-5 on the T.E. curve to correspond to the practically adiabatic compression line 1-5



FIG. 166.

on the pv diagram. From 5 to b is the increase of temperature and entropy at constant volume, corresponding to the ignition rise in pressure from 5 to b on the indicatordiagram resulting from the ignition. Points 6, 7, 8, 9, and 10 on the indicator-diagram are found by the equation above; and from 10 back to 1, to close the diagram, a constant pressure curve corresponds to the drop in entropy and temperature incident to the exhaust, to reach the condition when compression is to begin anew. The calculation made by Mr. Richmond is given in the table on page 438.\*

<sup>\*</sup> School of Mines Quarterly, Columbia University, vol. XVIII. Jan. 1897, p. 146.

Point.	PV	$\frac{T_2}{T_1}$	$.176 \log P + .246 \log V$	$\phi_1 - \phi_2$
1 2 3 4 5	475 545 600 661 706	1.000 1.147 1.263 1.391 1.486	6094 6149 6159 6154 6095	55 IO — 5 — 59
			.189 $\log P$ + .260 $\log V$	
6 7 8 9	1391 1404 1438 1460 1428 1300	2.928 2.957 3.027 3.073 3.006 2.800	6943 7045 7183 7268 7313 7308	854 102 138 85 45 5

The table makes it appear that the changes in entropy from I to 5 or during the compression are so small that the curve is practically isentropic (§ 124) or adiabatic, for the scale used at any rate. This is doubtless to be explained by the compensatory action of cylinder-walls which are warmer than the mixture at the beginning of the stroke and cooler at the end. On the expansion curve, while the great rise in entropy corresponds to the ignition stage at b, yet the positive value (while a diminishing one) for the succeeding points means doubtless that the gas continues to burn with a delayed combustion till near the end of the stroke. The action of the cooling water-jacket no doubt masks also to some extent the real value of the heat added by this "afterburning" process.

The temperature-entropy diagram can also be made to show the gain in thermal efficiency resulting from the extension of the expansion down to atmospheric pressure. If the supposed theoretical diagram be again referred to, and the expansion be carried down to the lower temperature 5 (Fig. 167), instead of having the exhaust open at 3 before the pressure falls to atmosphere, then the point 5 is to be joined to 4

by a curve of equal pressure. This will be a lower or more gently sloping line than the curve 4-3, and the triangular area 5-4-3 will represent the thermal gain over the condition of incomplete expansion. It must not be overlooked, however, here as elsewhere, that this attempt to secure complete • expansion is followed by wide variations in the propelling energy on the piston, and the bad effect of the irregularity



of motion may be of greater consequence than the thermal gain.

Furthermore, the temperature-entropy diagram may be used to make clear the effect of the water-jacket in the gasengine. If the action of the water-jacket removes both temperature and entropy during the expansion, so that when the exhaust opens the state of the mixture is represented by a point located at 6 instead of at 3, then the triangle 2-3-6 (Fig. 168) shows the quantity of heat so disposed of. The effect of the jacket thus appears to be to diminish the heat swept away by the exhaust by the quantity represented by the area under the line 3-6, which would be exhausted with the products of combustion if there were no jacket. The sup-

pression of the jacket-loss would not result in its conversion into work. The jacket would act to bring the expansion line lower than an adiabatic on the pv plane. If, however, the phenomenon of retarded combustion be in action, the expansion pressure would be increased; and while perhaps a less temperature would be attained, a greater value for the entropy change might be made to result. That is, if, instead of having the maximum temperature represented by 2 reached by the ignition (Fig. 169), a temperature of 7 only



is reached by the ignition at the beginning of the working stroke, then the retarded combustion traces a path such as I-7-8 during the expansion whose latter part only is adiabatic. If the area of heat represented by the area whose upper boundary is I-7-8 is the same as that bounded by the line I-7-2, then the combustion is completed before the exhaust opens and no waste of gas occurs. If less, then the retarded combustion has been so noticeable as to cause a waste of unburned gas.

296. Compound Gas-engines.—It will have been observable from most of the indicator-diagrams of gas-engines that

the exhaust opens while a considerable pressure remains upon the piston. This may be as much as 30 to 40 pounds above the atmosphere at the beginning, and the coughing noise of such exhaust is a great objection to this type of engine for many locations, apart from the apparent waste of available energy.

The problem may be stated generally, by saying that it is desired to expand the compressed charge during the working stroke to a volume greater than that which the charge occupied before compression. This cannot be done in the single cylinder of the Otto cycle-engine, and the attempts to secure continuous expansion in more than one cvlinder have not been successful as yet. In some twocylinder engines one has had a larger volume than the other, either by different areas or different length of stroke, but the two cylinders have received their charge simultaneously and not in succession as a continuous process. Clerk has suggested that in small engines it is to be questioned whether an increase in the expansion beyond the volume of the charge before compression may not so far reduce the volume of mixture dealt with at each stroke as to increase the relative loss of heat to the jacketed cylinder-walls to a point where the gain from greater expansion will be more than neutralized. In larger engines dealing with larger volumes of gas and with their slower transfer of heat to metal walls, the gain from successful compounding will be realized when further investigation shall have revealed some principles as yet not mastered.

207. The Oil-engine, using Kerosene or Non-volatile Oils.—It will be at once apparent that if the object in the gas-engine is to burn the fuel supplying heat directly in the working cylinder, this same object can also be secured by injecting a liquid fuel in a finely divided state, or a state of vesicular vapor, mixed with the air which it requires for its combustion. Hence it was early proposed and tried to use

44I

petroleum and its derivative oils, so as to make this type of motor available where municipal or private gas companies were not at hand, or where the manufacture of gas by producer methods was not convenient or practicable. The first practical petroleum engine was that of Julius Hock of Vienna (1870), and the early Brayton engines of 1873 were planned for oil. If the more volatile derivatives of petroleum are used, such as naphtha or gasoline, a current of air passing over or through them will absorb hydrocarbons to such an extent as to become an illuminating-gas, and can be used as such in an engine  $(\S 47)$ . But, as a rule, the dangers connected with the use of these lighter oils, and particularly with their storage in any quantity, have precluded their use on any large scale. On the other hand, the use of crude petroleum is attended with difficulty from the presence of its heavier and less inflammable constituents, whereby it becomes difficult to burn it completely and to ignite it promptly. There are troublesome residues also, which leave a deposit in the cylinder (§ 49). In many places, furthermore, the use of crude oil is prohibited by ordinance by reason of its offensive odor, and from the danger connected with the presence in it of its volatile elements. Hence the usual oil-engine burns oil of the grade known as burning oil, or kerosene (§ 43), which is safe and efficient.

The use of a liquid fuel suggests that it should be first finely subdivided or made into a spray or mist by the action of a current of compressed air, and then afterwards the true vaporization of the liquid oil shall take place by heat. In certain successful oil-engines, however, the spraying process is omitted, and the oil injected in its liquid state. Oilengines may therefore be classified into groups:

1. The oil is atomized or sprayed, and then vaporized.

2. The oil enters the working cylinder as a liquid, and is there vaporized.

3. The oil is vaporized in a separate vessel, from which it passes to the working cylinder as a gas.

As in the case of gas-engines, the methods for igniting the mixture of air and oil-vapor will distinguish oil-engines from each other.

The mixture may be fired by (1) an electric spark; (2) by passing through an incandescent tube: (3) by heat of the internal surfaces, combined with the heat of compression.

The Priestman engine will serve as a type of the first group; the Hornsby-Akroyd of the second; and of the third group the best known examples are the British designs of Crossley and of Fielding and Platt.

In the Priestman engine the air-supply is passed through a heating-chamber, which is surrounded by the hot exhaustgases. If the latter are at 600° F., the chamber will be at nearly 300° F. The oil is injected into this chamber by a small jet of air, and changes from spray to oil-vapor by evaporation, and passes into the cylinder upon the aspirating stroke. The compression of the preheated air brings it to a high temperature, above that to be met in the gas-engine, thus lowering the weight of charge present in the engine at each stroke, and reducing the average available pressure. The high temperature renders the mixture liable also to premature The presence of the charge in the vaporizing ignitions. chamber in the event of a back explosion from the working cylinder constitutes a menace to the safety of the whole The necessity for keeping the vaporizing chamber machine. hot by means of exhaust-gases makes it necessary to use some oil at every stroke, even at light loads, so that governing forms a difficulty with the design, and the consumption of oil is not proportionately diminished as the load diminishes.

In the Hornsby-Akroyd engine the vaporizer is a castiron non-jacketed chamber behind the working cylinder, to which it is connected by a narrow neck. The heat due to each ignition keeps this chamber hot enough so that oil

injected into it is vaporized, and the completion of the compression stroke, forcing in a charge of fresh air from without, raises the mixture to the point of ignition, and it ignites without outside means to effect it. The vaporizer is heated by gas or by a blast oil-lamp outside of it to start the engine. Governing is effected by causing the oil-pump to send its charge back into the suction by a by-pass, instead of into the vaporizer, but, as in the previous case, the vaporizer must not be allowed to cool off too much at light loads, else ignition fails.

This type suffers also from the lower average pressure than is secured with gas, because the mixture of oil, gas, and air is less likely to be thorough, and an excess of air is therefore usual to secure perfect combustion. The engine must furthermore be massive to meet the possibility and likelihood of double charges, when for any cause an ignition has been missed on one stroke, and twice the normal quantity of oil is fired at the next ignition.

In the third group the typical engine has the oil and a small volume of air injected into a heated vaporizer consisting of tubes or passages kept hot by waste heat from the blastlamp which heats the ignition-tube. A second volume of air, heated before it enters, joins the oil in the vaporizer and completes the vaporization. The main charge of air for the mixture is not preheated, but enters through a separate valve, mixing with the oil-vapor and being ignited by an incandescent tube. The use of cool air permits higher compression, and hence higher mean pressures, with the attendant advantages. The exterior lamp with its heat and noise are objections, however, and the simplicity of the Hornsby-Akroyd design has much to commend it.

298. The Oil-engine using Gasoline or Light Volatile Oils.—The difficulties from legal restrictions and city ordinances attaching to the storage and use of the volatile oils have been already referred to in a preceding paragraph.

Their lightness in weight, and the lightness of the fuel-supply in tanks for a given traverse, have made this type popular on the continent of Europe for motor-carriages or automobile use. By reason of the volatile character of the liquid fuel, it is only necessary to force air through and over it, for the former to take up hydrocarbon vapor in quantities to make an ignitible gas. The mixture is easily ignited by passing it through incandescent tubes heated by a shunt oil-circuit which supplies a lamp beneath them, burning with a Bunsen flame. Electric igniters are not used for motor-carriages by reason of the weight of the necessary battery.

The best known gasoline-motor in Europe is the Daimler. The usual form has two cylinders, closed at both ends. The back ends behind the pistons operate on the usual Otto cycle, the front ends acting as air-pumps, so that an additional pressure of a few pounds is secured before ignition with a surcharge of air from the front ends. The compressed air from the front effects the carbonization of the working charge, and also operates the lamp of the ignition-tubes. These are two platinum tubes. The two cylinders incline to each other at an angle of about 30°, with their connecting-rods acting on a common crank-pin. In motor-carriages the main shaft runs at a constant speed and in one direction, so that speed changes and reversing is effected by gears and clutches.

The naphtha-engine, as used extensively in launches, is not a direct-combustion engine, but uses the volatile liquid in a closed vapor cycle as steam is used in the condensing engine. This will be referred to under "Vapor-engines."

299. The Diesel Petroleum-motor.—A most interesting development of the principles of the heat-engine has been made in Germany during the years 1893–97 by a Mr. Rudolf Diesel. The fundamental peculiarity of his engine lies in the same lines as those of the Hornsby-Akroyd. The idea is to compress the air to a point at which its temperature due to the compression (§ 182) shall be above the point of ignition of the fuel to be used. If the latter is petroleum, crude or

refined, a measured quantity of it as controlled by a governor is injected into the highly heated air. It enters as a vapor by being sprayed by air from a small auxiliary pump, and by being forced also through a close-mesh wire gauze. If the compression has been carried (as is expected) to a pressure of 500 pounds per square inch or over, the finely divided oil ignites, and supplies to the expanding air the heat equivalent to the work it is doing in expanding, realizing (to the extent that it secures this result) the ideal Carnot theorem of having the heat supplied isothermally during expansion or at the constant highest temperature of the cycle instead of having the supply occur along a line of falling temperature. It would be obviously possible to supply fuel enough to do all the work of the stroke without drop of temperature, but this would consume more oil in the first place, and in the second place would leave the gases when ready to exhaust at a temperature unnecessarily and wastefully high. Hence the charge of oil is proportioned so as to keep up the expanding gases to  $T_1$ during a part only of the stroke, which results in there being always an excess of air so as to secure complete combustion. When the oil-charge is completely burned at an early period of the working stroke and can furnish no more heat to the expanding air, cooling begins by the adiabatic expansion, which then sets in, and which continues till the end of the stroke, leaving the gases to exhaust at a lower temperature, and without causing so much heat to pass out by way of the The latter are retained, however, for the sake of jackets. uniformity of temperature in valves and pistons. A new charge is again drawn in on an aspirating stroke, and compressed on the return stroke as in the Otto cycle.

The injection of the fuel *after* compression is complete eliminates the danger of premature ignition and explosion; governing is also much simplified; and what is more important than all, a practically perfect combustion is secured, without carbon loss in smoke or in lamp-black deposit.

Starting is effected by a few strokes by a hand oil-pump,

to throw a preliminary fuel-supply into the casing of the fuel-valve; from a storage of compressed air at high tension from a previous run a charge of cold air is admitted by a starting-valve to the working cylinder, sufficient to turn the fly-wheel through two revolutions, or past one compressing stroke. This is done with the valve-cams out of gear, but at the close of the first revolution the cams are thrown into gear automatically, and the engine will then start off. The high temperatures used enable this engine to work on low-grade oils, or even upon powdered solid fuel, as well as with kerosene, alcohol, or gas. Governing is done by by-passing the charge or injection from the oil-pump, which is proportioned for the maximum supply to be required.

By applying the temperature-entropy diagram to the cycle of the Diesel motor, it will be apparent that when the proper practical conditions are secured for it, it approaches more nearly to the ideal Carnot conception than any of the preceding motors, and therefore the ratio of heat utilized to heat supplied or its efficiency should be by so much greater as this approach is more close. Tests show an efficiency of 38 per cent for the Diesel engine, as compared with 25 to 30 in ordinary gas engines. Fig. 170 illustrates the engine in section, and Fig. 171 is a reproduction of one of its cards.

300. Performance and Economy of Direct-combustion Engines.—Any comparison or critical discussion of different types of direct-combustion engine when stated in consumption of fuel per H.P. must be unsatisfactory and unreliable to the extent that the heat-units per unit of fuel, or from the analysis of the fuel, are unknown or unstated. The figures following are therefore given only as guides, and as points in a reconnaissance survey, by reason of the lack of such determining data, and because also the sizes of the engine are not given. Large engines burn less gas per H.P. than small ones.

With the ordinary city illuminating-gas to be met in Great Britain and the United States an average ranging from 20 to



F13.171.

448

24 cubic feet per indicated horse-power may be expected, which corresponds to a net, or brake, horse-power consumption of 24 to 30 cubic feet per hour. Record consumptions run as low as  $13\frac{1}{2}$  to 15 cubic feet per I.H.P. per hour, or 18 to 20 cubic feet per brake horse-power.

The largest gas-engines of Europe and probably in the world are of 400 H.P.; the highest number of revolutions per minute is 400.

When gas can be secured from producers of the Dowson or Taylor or other economical type the lower calorific power per cubic foot increases the consumption in cubic feet, but not the consumption per pound of coal or of carbon. For example, in a town in Connecticut where electric lighting is supplied by gas-engines operating on producer-gas the gas has only 153 B.T.U. per cubic foot, and 99 cubic feet are required by brake horse-power per hour. This corresponds, however, to a consumption of 1.075 pounds of carbon per brake horse-power per hour. English and Continental records are 1.31 to 1.34 pounds of coal per I.H.P. per hour on small engines, and an opinion has been expressed that with engines of over 100 H.P. the consumption should drop to one pound.

With oil of the grade of kerosene the consumption in pounds per I.H.P. per hour ranges from 0.75 to 1.25, corresponding to a consumption per brake horse-power ranging from 0.82 to 1.68 pounds. The Diesel motor has an authenticated record of 240 grams of kerosene oil per brake horsepower per hour, equivalent to 0.531 pound, which, when reduced on the basis of a price of  $2\frac{1}{2}$  to 3 cents per gallon for fuel-oil, results in a calculated consumption of 15 cents' worth of such oil per horse-power per hour in engines of 100 H.P.

301. Advantages of the Gas- or Oil-engine.—The principle of direct combustion, or the liberation of the heat energy directly in the working cylinder, as contrasted with the indirect method of imparting this heat energy to the heat

medium in a separate vessel, offers some inherent advantages; and certain others attach to the methods used to avail of this principle or are incidental to it. That is, there are some advantages attaching intrinsically to the use of gas or oil as a source of heat energy (\$ 42-56) apart from the principle of direct combustion as a means of utilizing that energy.

Attaching to the direct-combustion principle may be noted:

(1) The direct utilization of heat energy to drive the piston in a single apparatus.

(2) Resulting from this an economy of combustible per horse-power per hour because heat is not wasted in a furnace or chimney, or in doing work upon a heat medium which is not utilized in the engine.

(3) No fuel is consumed wastefully to start up the motor, nor is any wasted after the engine stops. The losses in banking fires under a boiler which runs intermittently are avoided, and the losses of fuel in the grates from cleaning and when the run is over.

(4) The engine is ready to start on the instant, without delay caused by getting up steam or starting the fire.

(5) By direct use of gas or oil in engines the advantages of storage of energy are reaped. Gas can be made when convenient, and stored in holders for use after working-hours or when the generating-plant is not running.

(6) Incident to this is the advantage of subdividing power units in a large plant, each of which may receive its supply of motor energy through pipes without loss, and which can be run independently of each other as to time, speed, capacity, and the like, as long as the store of gas or oil holds out.

(7) Storage of energy in the form of gas under pressure enables great power to be stored in small bulk and with small weight, to be expended in motors as required. The automobile and the experimental flying-machine avail of this

feature. So also might street-cars where electricity or compressed air is not available or preferable.

(8) The absence of the boiler and its furnace and chimney make the plant compact when the gas generation and holders are provided for elsewhere. The oil-engine is portable from the same causes, and convenient for temporary erection.

(9) The absence of the boiler (when not offset by the presence of the producer or the gas-holder) lowers the insurance risk, and the owner avoids the expense of licensed attendants upon the steam-generating plant. At least this is the case where local legislation is in force on these points, as in most cities.

(10) The absence of the boiler, with its furnace and chimney, avoids the repair and maintenance expenses which attach to these features of a power plant, as well as the labor to operate them, and their first cost.

The gas- or oil-engine furthermore attaches to itself the advantages of mechanical stoking and of oil or gas used as fuel. Such are:

(11) Combustion practically perfect and smokeless.

(12) No human labor for handling fuel into the heat apparatus nor for disposing of the ashes, with attendant cost.

(13) No dust nor sparks nor soot, except at the central gas-generator plant. With oil there is none anywhere.

302. Disadvantages of the Gas- or Oil-engine.—As in the foregoing paragraph, some of the following objections are inherent, and others attach only to certain solutions of the problem. An engine is excellent to the extent that it avoids these difficulties.

(1) Gas-engines are usually single-acting, if not acting on only one stroke in four. This makes them more bulky than the double-acting steam-engine using the same mean pressure.

(2) It is difficult to command a high mean pressure.

(3) The effort is irregular, and hence a disproportionately heavy fly-wheel is demanded to secure steadiness.

143 844

1 ...

(4) Where governing is done by missing a charge, the speed must vary widely. Many types do not govern well nor closely.

(5) Most require an auxiliary of some sort to start them from rest.

(6) There is no way of increasing the power of the engine beyond the maximum for which it is proportioned, to meet short demands for greater power.

(7) It is not usually arranged to run in both directions, or is not easily reversible.

(8) An unpleasant odor of partly burned or of unconsumed gas belongs to many examples. Leakage seems unavoidable.

(9) The high tension of the contents of the cylinder at the end of expansion makes the exhaust noisy, or like a succession of coughs, and there is a loss of heat in such hot gases.

(10) The water-jacket around the cylinder is necessary to keep it and the values cool enough to be tight and prevent deformation by heat and wasting from oxidation. The heat which goes into this water-jacket would otherwise go into the exhaust (§ 295), and could not be saved except at expense in other ways; but the engine must be supplied with the water for this jacket, and with provisions for the water to cool if it is too valuable to be wasted.

(11) If the water-jacket is ineffective, and often where it works well, the lubrication of the hot-piston is difficult. Packings should be avoided, or should be metallic when they are required.

(12) Explosions of some violence occur in the exhaustpipe. The fire laws of New York compel the metallic exhaust-pipe to be carried to free air, and not merely to enter a brick flue leading to the air. Explosions in such flues would be disastrous. The explosion is due to a charge which is not ignited in the cylinder.

(13) Lamp-black deposits, the result of imperfect combustion, clog and defile the working parts, valves, ports, and

453

the like. This deposit is very troublesome between the points of spark-igniters. The difficulty can only be avoided by having the contacts self-cleansing by sliding upon each other.

303. Conclusion.—The gas-engine has been much more studied in England and the Continent than in the United States. In most places it is cheaper to burn city gas in gasengines to operate dynamos to generate electric current for incandescent lighting than it is to burn the gas directly in chandeliers. Where fuel-gas can be made in producers this plan is much the cheaper. In many cities the insurance rate upon the producer plant makes its cost prohibitory. The gas-engine (or oil-engine) is the rival which the steam-engine is to anticipate in the next few years, for small sizes in any case, and possibly for units of considerable size also.

Fig. 173 shows the successive positions of the usual form of slide-valve in Otto gas-engines, and should be studied in connection with Fig. 144 on page 414.



## CHAPTER XXI.

## VAPOR-ENGINES.

305. Introductory.—It has been already noted (Chapter IX) that any other convenient heat media could be used to carry the heat energy from the furnace or source of heat and make it available for doing of mechanical work in the enginecylinder, if there were reasons why steam or air should not be preferred. It was further suggested, however, that there were practical reasons why the effort to use other media had not as yet been approved by commercial success. The object of this chapter is to go more fully into this question with respect to a selected series of heat-carriers, and to show the physical and theoretical basis for the disapproval of their claims for recognition for these uses, except perhaps in a few special cases.

Water and air being the only heat media found in a natural state in unlimited quantities, all the others are manufactured products or compounds which must be purchased. Hence they must be worked in a closed cycle, and not rejected to the atmosphere from which they cannot be regained. They will therefore be operated in condensing engines, and will be used as vapors to be condensed from the gaseous to the liquid state after working in their cylinder. The heat will be applied to convert them into gases, becoming latent in the process of increasing their entropy. This heat will be given out in adiabatic expansion in part, and in part to the condensing appliance, as discussed in §§ 195 and 218 *et seq.* of Chapters XIV and XV, and the cycle will be

VAPOR-ENGINES.

closed by pumping the liquid back into the generator to be raised in temperature and entropy to the high initial condition again.

The attraction to the more volatile vapors of certain liquids comes about from the facts of their physical constitution, whereby, either by reason of a lower specific heat or for molecular reasons, they are raised to a higher tension, as registered by a pressure-gauge, by a smaller amount of heat than is the case when heat is applied to water to make it into steam. If gauge pressure meant heat energy also, then there would be no question as to the thermal superiority of these more volatile media. It will be the object of the succeeding paragraphs to show how insignificant or negative these thermal advantages usually are.

The problem of the use of volatile vapors may be approached from several different points of view. It may be first examined from the assumption that the competing vapor is to be worked within the same temperature limits as the accepted steam-engine, disregarding the inconvenient pressures which result, and the relation of work done to heat supplied can be deduced under these conditions.

Or, secondly, the problem of keeping the pressures within normal limits may be made the determining one, and the temperatures adjusted to the condition of strength of cylinders and other parts which must resist pressure strain.

Or, thirdly, a set of conditions advantageous to the use of the vapors may be assumed, and the computations directed to show whether the resulting quantity of the heat medium by weight or the size of the cylinder by volume is more advantageous or economical of fuel than in the case of the steamcylinder.

306. Formulæ for the Work of a Vapor.—The accepted formulæ for the work of a vapor which expands isothermally with change of entropy at the constant temperature  $T_1$ , as represented by the line AB in Fig. 175; then expands adia-

batically along the curve *BC* to a final pressure *CG*, or  $p_2$ ; drops to a back-pressure *GH*, or  $p_3$ , and is then worked back by isothermal compression and finally by adiabatic compression to the origin *A*, has been deduced by Rankine, Clausius, and others from differential equations, and appears in three



forms. If the cubic foot is used as the unit, then the work of one stroke in foot-pounds will be:

Work = 
$$JC_p D_1 \left\{ T_1 - T_s \left( I + \text{hyp. } \log \frac{T_1}{T_s} \right) \right\}$$
  
+  $L_1 \left( \frac{T_1 - T_2}{T_1} \right) + r(p_2 - p_3),$ 

in which J = 778, the mechanical equivalent of one B.T.U.; C = the specific heat, at constant pressure, taken at its mean value between  $T_1$  and  $T_2$ , if it is variable;

- $D_1$  = weight in pounds of one cubic foot of the vapor at the temperature  $T_1$ ;
- $T_1$  and  $T_2$  = absolute temperatures corresponding to the pressure values used;
  - $L_1$  = the latent heat of evaporation of a cubic foot of the vapor at the temperature  $T_1$ ;

 $p_s$  and  $p_s$  = the pressures at the end of adiabatic expansion and in the condenser, respectively;

> r = the ratio of expansion to reduce the temperature of the vapor from  $T_1$  to  $T_2$ . This is given by Rankine in the equation

$$r = \frac{AB}{EC} = \frac{T_{2}}{L_{2}} \Big( 778D_{1} \text{ hyp. } \log \frac{T_{1}}{T_{2}} + \frac{L_{1}}{T_{1}} \Big),$$

in which  $L_2$  = latent heat of evaporation of a cubic foot of vapor at the final temperature  $T_2$ .

With complete expansion, so that  $p_2$  equals  $p_3$ , the last term disappears, or the area will be

Work = 
$$JCD_1 \left\{ T_1 - T_2 \left( 1 + \text{hyp.} \log \frac{T_1}{T_2} \right) \right\} + L_1 \frac{T_1 - T_2}{T_1}$$
.

If it be preferred to discuss the problem from the point of view of a *pound* of the vapor instead of a cubic foot, the expression for the work may be used in the more convenient of the two forms deduced by Rankine; that is, the formula may be, when  $p_a$  is equal to  $p_a$ :

Work = 
$$ABCD = 778 \left\{ T_1 - T_2 \left( 1 + \text{hyp.} \log \frac{T_1}{T_2} \right) \right\} + \frac{T_1 - T_2}{T_1} L_1,$$

in which  $L_1$  is the latent heat of evaporation of one pound of vapor at the temperature  $T_1$  and is given by a formula

$$L_1 = a + bT_1,$$

or

$$L_1 = a + bT_1 + cT_1^2$$

in which both b and c may have a negative value.

When there is a difference between the pressures  $p_i$  and  $p_j$  the formula may be transformed into

Work = 
$$ABCHK = a$$
 hyp.  $\log \frac{T_1}{T_2} - b(T_1 - T_2) + rv_1(p_2 - p_3),$ 

in which  $v_i$  is the volume occupied by one pound of the vapor at the pressure corresponding to  $T_i$ . Instead of  $rv_i$ , the quantity  $v_i$  could be used, or the final expanded volume which is r times the initial volume admitted.

The next step in the problem is the demand upon the physicist or laboratory experimenter for the values of the factors or constants which enter the formulæ.

307. Experimental Data for a Problem in Vapors as Heat Media.-The data of density, pressure corresponding to temperature, latent heat at different temperatures, and specific heat for the vapors, have in most cases been reduced to formulæ with constants to be substituted, and these constants or factors are to be multiplied by the variable or arbitrary It will be necessary, therefore, to assume a temperature. temperature range between the limits of which the vapor is to be worked. The investigation, along these lines, whose completeness has made it almost a classic among American researches in this field is identified with the names of Messrs. Henry L. Gantt and D. H. Maury, and was first made in 1883-84. It was later revised by Prof. De Volson Wood. It will therefore be convenient to use the same assumptions and data which they have followed as respects temperature and the like, so as to follow a similar procedure.

If the standard steam-pressure range be taken as a starting-point to determine the temperature range, it may be taken as between 125 pounds per square inch and 10 pounds per square inch—absolute pressures counted from vacuum as a zero. This gives the temperature range

> $t_1 = 172^\circ \text{C.} = 342^\circ \text{Fahr.} = 802^\circ \text{ abs. Fahr.};$  $t_2 = 90^\circ \text{C.} = 194^\circ \text{Fahr.} = 655^\circ \text{ abs. Fahr.}$

The Rankine formula for pressures with temperatures given is (§ 134)

$$\log p = A - \frac{B}{T} - \frac{C}{T^*},$$

in which A, B, and C are constants having the following values:

	A	log B	log C
Steam Alcohol Carbon disulphide Chloroform Ammonia	8.28203 8.68170 7.4263 4.3807 8.4079	3.441474 3.4721707 3.3274293 [This <i>B</i> is 3.288394 negative] 3.341632	5.583973 5.4354446 5.1344146 6.1899631

Making the substitutions, the following values for the pressures result:

	∮1 Lbs. q.Ft.	1/2 Lbs. per Sq. Ft.
Steam	17408	1469
Alcohol	36450	3279
Carbon disulphide	36745	7269
Chloroform	24871	5432
Ammonia	468700	113100
Ether	55350	1440

The specific heat at constant pressure for any temperature t for such vapors is given by a formula of the form (§ 139)

 $C_t = A + 2Bt + 3Ct^2.$ 

The constants will be for the various vapors, if t is the temperature in degrees F.:

	Ъ	c	đ
Steam Alcohol Carbon disulphide Chloroform Ammonia	0.99957333 0.50954300 0.2323140 0.2305470	0.000002222 0.00056407 0.00004555 0.00002817	0.0000000926 0.000000617284 0.0000000000 0.00000000

Substituting the corresponding values, the mean value of  $C_4$  between  $T_1$  and  $T_2$  becomes

Steam.	Alcohol.	Carb. Dis.	Chloroform.	Ammonia.
$C_p = I$	0.954	0.257	0.245	1.229

The general formula for the weight of a cubic meter of a saturated vapor of the class under consideration (§ 141) is given by the formula

$$D_1 = \frac{\mathrm{I}}{v_1} = \frac{p_1 \delta}{36.2 \sqrt{T_1}},$$

in which  $\delta$  is the density of the vapor referred to that of air, and has been observed for the vapors in question to be:

	δ	$D_1$	$D_2$
Water	0.6219	5.07	0.467
Alcohol	1.5819	25.18	2.74
Ether	2.5573	78.66	14.47
Bisulphide of carbon	2.6258	45.37	9.98
Chloroform	4.1244	57.84	11.13

when the calculations are made for  $D_1$  and  $D_2$  by substituting in the formula. Or the following method may be used.

The latent heats of evaporation per kilogram (§ 140) at any temperature t is given by a formula of the form

 $r=a-bt-ct^{2},$ 

in which a, b, and c are constants having the following values (reduced to British units from the corresponding metric values determined by Regnault):

	a	Ъ	c
Steam	1121.7	0.6946	0.00002222
Alcohol	524.07	0.92211	- 0.000679
Carbon disulphide	164.57	0.0716	0.0002746
Chloroform	123.6	0.093	0.000282
Ammonia	555.5	0.613	0.000219

By substitution of the values of the constants a series of values for  $t_1$  and  $t_2$  result and which give the tabular values for  $L_1$  and  $L_2$  (the latent heat per pound) when these are multiplied by the weights per pound and by the symbol 778 or J to reduce heat-units to foot-pounds. Hence

	۲ <sub>1</sub>	r <sub>2</sub>	L <sub>1</sub>	L <sub>2</sub>
	(Thermal Units.)	(Thermal Units.)	(Foot-pounds.)	(Foot-pounds.)
Steam	873.59	978 • 44	679653	761226
Alcohol	288.19	370 • 73	224216	288428
Carbon disulphide	108.07	140 • 34	84077	109188
Chloroform	58.92	94 • 94	45 <sup>8</sup> 43	73867
Ammonia	320.54	428 • 34	2493 <sup>8</sup> 3	333246

The weight of one cubic foot of saturated vapor is the ratio of the latent heats per pound (L) to the latent heats per cubic foot (l), or

$$w = \frac{l}{L}.$$

The latent heats per cubic foot in foot-pounds are:

	Ζ1	
Steam	186905	20553
Alcohol	381359	43791
Carbon disulphide	259844	64970
Chloroform	136930	53358
Ammonia	2954108	873561

Combining these with the values for L above,

	(Weight in 1 cu. ft.)	(Weight in 1 cu. ft.)
Steam	0.275	0.027
Alcohol	1.701	0.151
Carbon disulphide	3.091	0.595
Chloroform	2.978	0.722
Ammonia	11.842	2.621

308. Efficiency of a Volatile Vapor between given Temperature Limits. — The simplest case will be the hypothesis of Carnot, that all heat is imparted at the high temperature  $t_1$  and withdrawn at the lower; the expansion and the compression adiabatic. To make the case general, suppose the heat  $L_1$  to produce a volume  $v_1$  which is not the unit volume whose weight is  $D_1$ . Then the work of expansion will become

$$W = JCD_1v_1 \left\{ T_1 - T_2 \left( 1 + \text{hyp.} \log \frac{T_1}{T_2} \right) \right\} + \frac{T_1 - T_2}{T_1} L_1 + v_2 p_2,$$

and the work of compression will be

$$W' = JCD_1v_1\left\{T_1 - T_2\left(1 + \text{hyp.}\log\frac{T_1}{T_2}\right)\right\} + p_2v_2.$$

The effective work will therefore be what the previous discussions of Chapters XIV to XIX would have led to expect, or

$$(T_1 - T_2) \times \frac{L_1}{T_1} = (T_1 - T_2) \times (\phi_2 - \phi_1).$$

Substituting in these equations their values, the following tabular solution results:

Heat Medium.	Work of Expansion, Foot-pounds.	Work of Compression, Foot-pounds.	Difference Effective Work.	Heat used.	Efficiency, Per Cent.
Water Alcohol Ether Bisulphide of carbon. Chloroform Ammonia	50 <b>323</b> 61043 115000 64538 71843 72222	15932 26652 80609 30147 37455 37831	34391 34391 34391 34391 34391 34391 34391 34391	186905 186905 186905 186905 186905 186905	18.4 18.4 18.4 18.4 18.4 18.4

In discussing the above it will be noted:

(1) That the thermal efficiency of all the media when operated within the same limits of temperature is the same.

This might have been foreseen, since the formula indicates that the efficiency is independent of the medium used.





meter of water at  $T_1$  degrees absolute is less than that required to evaporate the other vapors at that temperature. Note the values for  $L_1$ .

(3) Note also the values for  $L_2$ . The water in expanding

has given up more of its heat in doing work down to the temperature  $T_2$  than has been given by the others. In other words, water has done the same amount of effective work as the others, and has left a less quantity of heat to be taken care of by the condensing water.

(4) The pressure of the vapor of water at the temperature  $T_1$  is much less than that of the other vapors. Hence the others require much more massive castings and greater strength in all parts to withstand the strain than are needed for the steam-engine, and yet they do no more effective work in the same range. This pressure range for the same temperature range is shown most clearly in the plotted diagram (Fig. 176), which shows equal work areas, but with very different values for  $p_1$  and  $v_q$ .

(5) The same diagram shows also the inconvenient losses from excessive back-pressures with the vapors other than water, which back-pressures, as above, can only be mitigated by a use of inconvenient volumes of condensing water at a low temperature, as will be referred to hereafter.

(6) The component works of expansion and compression differ very widely, while having a constant total difference. The discussion is therefore inconclusive in so far as any effect of varying interchange of heat with the cylinder-walls may be introduced by these differing states of the medium, in its cycle.

(7) The diversity in pressure range for the same temperature range turns the thoughts to the possibility of a species of compounding with two media in series. This will be referred to again.

309. Efficiency of a Volatile Vapor between given Pressure Limits.—The difficulties of the preceding propositions with respect to pressure make it desirable to examine the action of volatile vapors when the convenient pressures which would prevail in an ordinary engine are set as the limits, and the temperature limits are determined by these

#### VAPOR-ENGINES.

limiting pressures. It will result that while the same formulæ will apply as in the previous paragraphs, the quantities will differ because of the different values for the temperatures. Let the same initial temperature be chosen corresponding to 120 pounds pressure for steam, and the terminal pressure correspond to that in a condenser kept at 10 pounds above vacuum. Making the computations as before gives the following tabular result:

Vapor.	<i>t</i> <sub>1</sub>	<i>t</i> <sub>2</sub>	ťs		$T_2$	T <sub>3</sub>
$\begin{array}{c} H_{2}OC_{2}H_{6}OC_{2}H_{6}OC_{5}C_{5}C_{1}C_{1}C_{1}C_{1}C_{1}C_{1}C_{1}C_{1$	341.60 286.34 275.34 295.34 66.34 66.34 231.34	194.00 158.34 94.34 125.34 41.66 39.34 141.34	$   \begin{array}{r}     104 \\     104 \\     104 \\     104 \\     104 \\     39 \cdot 34 \\     104 \\ $	802.26 747.00 736.00 756.00 527.00 527.00 692.00	654.66 619.00 565.00 586.00 419.00 500.00 602.00	564.66 564.66 564.66 564.66 564.66 500.00 564.66
Vapor.	<i>t</i> 1	12	t∕a	L	L2	С
$\begin{array}{c} H_{2}OC_{2}H_{6}OC_{2}H_{6}OC_{2}C_{2}H_{6}OC_{2}C_{2}C_{2}C_{2}C_{1}C_{1}C_{1}C_{2}C_{2}C_{2}C_{2}C_{2}C_{2}C_{2}C_{2$	17408 17408 17408 17408 17408 17408 17408 17408	1469 1469 1469 1469 1469 1469 10406 1469	152 375 1717 920 33020 10406 2530	186905 199649 135730 114109 166700 166700 146542	20553 20992 15586 18786 17726 10648	1.000 0.859 0.249 0.242 1.000 1.000 0.579
	Lbs. Vapor to produce Hour betw and 10 lbs.	r necessary 1 H. P. per veen 120 lbs. Pressure.				
Vapor.	.И	W	Н	E	И	7
$\begin{array}{c} H_{2}O\\ C_{2}H_{6}O\\ CS_{2}\\ CHCl_{3}\\ NH_{3}\\ C_{4}H_{10}O\\ \end{array}$	1.000 1.193 1.484 1.135 -0.204 1.033 4.877	49084 57222 35109 37617 -254827 8579 29108	237739 311249 182255 186359 	20.64% 18.38 19.27 20.13 165.00 2.87 12.84	11 30 89 78	-44 -48 -24 -15 

The figure of 165 for the ammonia vapor is the result of the unpractical assumption which makes the condenser pressure greater than that of the boiler. Hence a second engine worked by the condenser will be required to operate the engine imagined, and the figure belongs to the supplementary engine. The second ammonia line belongs to the supposititious case of an engine operated with condensing water at  $39^{\circ}$  F. This is not obtainable except by climatic accident or by use of mechanical refrigeration.

It will therefore appear from the above:

(1) The rival for steam in theoretical efficiency is chloroform only, which requires nearly eight times the weight of



medium per horse-power per hour and must be operated in a cylinder of one and one-quarter times the volume—both tending to obliterate the small gain.

(2) This comparison is distinctly unfair to the vapors other than steam, and makes them show at a disadvantage.

This is made clear by plotting the work-diagram for the vapors as in Fig. 177. Both ether and bisulphide of carbon are expanded below the line of back-pressure, or more than completely.

310. Effect on Efficiency of Volatile Vapors from Ad. justing Final Pressure and Expansion Ratio.-If the backpressure be fixed by a convenient adjustment of the condensing water in amount or temperature, a more favorable proportioning of the ratio of expansion may be made for certain of the vapors, so as to have their final pressures so adjusted to the initial pressure, which has been fixed as in the preceding case, that no loop occurs. This alters the final volume of the expanded vapor, or it may be effected by letting the final pressure be increased by such a quantity as will obliterate the loop. Keeping then the same initial pressures, but increasing the finals  $(p_2)$ , the work will vary slightly, without a variation in the heat expenditure, and a change of thermal efficiency will follow. The values in metric units as presented by Gantt and Maury for this case give:

Medium.	<i>†</i> 1	<i>₱</i> 2	W	Н	E	Cylinder Volume.
Water Alcohol Ether Carbon bisulphide Chloroform	84518 84518 84518 84518 84518 84518	7043 7358 17190 15844 10214	267705 262614 162869 162875 219200	1330639 1465207 1094722 878729 1136084	20.12 17.92 14.88 18.53 19.29	1 1.035 .845 .756 .944

This table shows steam to have an advantage in thermal efficiency and in weight per horse-power per hour over all the vapors, but not in cylinder volume; it should also be remembered that the less efficiencies in this case as compared with that of the preceding paragraph are to be offset against the losses from the higher values for r in that case. Such losses

are probably the result of condensation at the higher ratios, and of friction. Fig. 177 shows the change in diagram which results when the foregoing changes of condition are imposed and a more effective adjustment of condition is made.

311. Effect on Efficiency of Certain Vapors by an Increase in the Pressure Range.—Combining the results of the last paragraph with the computations of § 307, so that the temperature limits of a condensing engine are used without a complete expansion down to the condenser temperature with the attendant heat-losses from the cylinder-walls, another set of values are derived. This may be done first with conditions assumed most favorable to the steam-engine, as in § 308, and then with respect to getting more favorable conditions for some or all of the other vapors, as in § 309.

The first alternative will be applied as in § 307, with initial temperatures of  $172^{\circ}$  C., final temperatures of  $90^{\circ}$  C., and a condenser temperature of  $40^{\circ}$  C. or  $105^{\circ}$  F., which is as low as can be conveniently secured for the year round in the temperate zone. For this case the final results are:

Medium.	Work.	Heat.	Efficiency.	Kilograms per H. P. per Hour.	Cylinder Volume.
Water	267705	1330639	20.12	5.19	I
Alcohol	525086	2894904	18.14	13.13	.488
Ether	751821	4447823	16.90	28.64	.232
Carbon disulphide	360878	1798275	20.07	34.41	.314
Chloroform	376517	2002139	18.81	42.06	.396

If the second alternative be chosen, and the conditions so adjusted to the qualities and properties of the vapors as to reproduce under this assumption the same back-pressure values as were used in § 309, then the final results are further improved for the volatile vapors as given in the following table:

VAPOR-ENGINES.





The indicator-diagram for this set of conditions is shown in Fig. 178 and presents the same peculiarities as to excessively high pressures for the other media than steam, to which

LBS, PER SQUA	RE INCH.	MEAN	BACK-PRE	SSURE 14.7 LBS			1.t. 01 001 1
Substance used as a Heat Mcdium.	Specific Heat in Liquid	Temperatur Fahrenheit sures per a of	c in Degrees at pres- square inch	British Thermal Unus necessary to be expended in order to generate	Efficiency or Frac- tion of Heat ex- pended per col. 5 which can be real.	Coal per hour per I. H. P., assuming the boiler to utilize 8000 heat-units per pound of coal-cy-	Probable Coal per hour per H. P., in- cluding allowance of A for cylinder condensation for saturated varors
	Condition.	roo lbs.	14.7 lbs.	from "temp, of feed" equal to that given in column 4.	ized as useful work in an engine.	inder condensa- tion neglected—in pounds.	and zero for super- heated vaporsin pounds.
-	2	e	4	ъ	9	2	8
Steam	00 <b>.</b> 1	328	212	1002	0.14	2.30	3.10
Ammonia, saturated	0.99	56	- 27	632	0.15	2.15	2.88
" superheated	0.99	282	80	940	0.13	2.48	2.48
Ether	0.55	215	95	195	0.15	2.15	2.88
Carbon bisulphide	0.24	248	115	163	0.17	. 1.99	2.68

THEORETICAL ECONOMY OF VARIOUS VAPORS VSED AS HEAT MEDIA IN A GIVEN ENGINE AT FIXED CUT-OFF, THE EXPANSION BEING SUFFICIENT TO CAUSE A FALL OF PRESSURE FROM 100 TO 14.7

reference has already been made. The table shows the direction in which efficiencies superior to that of steam are to be sought but if this thoroughfare is closed, then the volatile vapors must be recommended for reasons other than their superior thermal efficiency or their economy in fuel per horsepower per hour.

In comment on the figures it should be added that condensation during expansion or initial condensation (§ 224) would increase the weight of vapor, except where it was used in a superheated state.

If the steam is to be used without condensation, as in ordinary non-condensing engines expanding down to atmospheric pressure only, then the other media show to a little better advantage. The table on page 470 computed by Prof. D. S. Jacobus presents the data belonging to this assumption:

The conclusion safely to be drawn from this table is that if the comparison made with steam under a condition least favorable to its economy shows so little margin of advantage over the other vapors, there must be great advantages for them yet to be revealed if they are to be considered for largescale work.

312. Usual Vapor Media. Their Disadvantages.— The foregoing paragraphs have enumerated the most frequently tried of the volatile vapor media. A list which should not omit some available ones would be perhaps hard to make. It should include, however:

Ammonia	Gasoline
Chloroform (CHCl <sub>3</sub> )	Alcohol $(C_2H_6O)$
Naphtha (C <sub>6</sub> H <sub>14</sub> - C <sub>8</sub> H <sub>18</sub> )	Tetrachloride of carbon (CCl <sub>4</sub> )

These have been tried or proposed separately, or in combination with steam, or even with each other.

The advantages to be urged for them are those consequent upon the lowered intensity of the source of heat to change

them into vapors with considerable tension. It therefore becomes possible to use a species of retort of small weight and bulk, within which a small weight of the medium can be injected at each stroke, to be at once volatilized and raised in tension, and to be worked in the working cylinder. This cannot well be done with steam, because the high temperature of such a "spray-boiler" for steam would result in its rapid corrosion and failure from deterioration of structure. There is therefore no reservoir of accumulated heat energy as in a steam-boiler, and its weight and bulk are avoided. Working pressure is promptly secured.

On the other hand, the disadvantages of these vapors, beside those already enumerated in the preceding calculations, are those which result from their comparison with steam.

(1) They have to be bought and paid for.

(2) They require to be operated as condensing engines, and demand a large body of cooling water.

(3) Some are inflammable, and their vapor mixed with air is explosive.

(4) Some are irrespirable, or produce unpleasant effects if inhaled, upon the human frame.

(5) Some have an odor, pungent or even offensive.

(6) Leakage must therefore be prevented at stuffing-boxes and elsewhere, by the use of a double-chambered construction, which is costly and troublesome.

(7) Some act corrosively upon metals, either alone or in combination with air or water.

An interesting computation under the second objection has been made which shows that with most of the vapors, to maintain a back-pressure of one atmosphere only, an amount of water is required which is one half of that which would maintain a 27-inch vacuum with steam. So that, in cities where condensing water is metered and taxed at a rate of 1.50 per thousand cubic feet required, the vapor-engine requires an expense for water equal to that for its fuel.
Unless the saving in fuel more than offsets this increased water cost, or unless the vapor-engine is to be run in places where condensing water is available without cost, the steam will show commercially at an advantage.

313. Naphtha and Gasoline-engines. - The use of naphtha in small launches instead of steam has been of considerable extent and interest in recent naval and pleasureboat practice. Liquid naphtha stored in bulkhead tanks in the hull of the boat is used as fuel when mixed with air to heat a retort within which the pure naphtha liquid is vaporized, expanded, and brought to a high tension by the external heat. The vapor operates then in the engine, and is exhausted into a keel condenser, a coil of pipes outside the hull, and along the garboard strakes under the water. The machine starts by giving a few strokes to a hand air-pump to generate the naphtha-gas in the furnace, and by injecting by a second pump a small charge into the retort As soon as the pressure generated in the retort will drive the engine to compress the air for the furnace-gas, the compression of the air and the injection of liquid naphtha become automatic, and the process becomes continuous. The valves on the two naphtha circuits control pressure and therefore speed. The fuelnaphtha is the only supply which becomes exhausted, as the motor fluid operates in a closed circuit. The naphtha motor weighs but 100 pounds per horse-power in the smaller sizes, down to 75 pounds per horse power in the larger, which is to be offset against the combined weight of engine with its boiler and contents in the steam-yacht. The objection is the difficulty from having no reserve of energy in store on which to draw under unfavorable conditions of wind or waves. Fig. 179 shows a section of a naphtha-launch engine.

Yarrow & Co. state that the volume of vapor with naphtha in their launches produces  $\frac{9}{5}$  the volume which would be given by steam at atmospheric pressure. A 36-foot launch with 8-foot beam, weighing with its machinery and fuel-supply one

ton, will run 8 miles per hour in still water and can carry fuel for 200 miles if necessary. One and one half gallons per hour, or one third gallon per horse-power per hour, will be



consumed in the furnace, and allowance for leakage and waste must be added.

314 Binary Vapor-engines.—The experimenters with vapors however, have usually preferred to retain the steamgenerator or boiler as a means for the convenient transfer of heat to the volatile vapor they were to use as a motor fluid. This principle has been used with the ether-engine, the ammonia-engine, and the bisulphide-of-carbon engine. The scheme is illustrated in Fig. 180 as applied to a bisulphide engine. S is the ordinary steam-boiler supplying heat through the pipe P to the generator AB. Condensed steam

### VAPOR-ENGINES.

from this generator is returned by a small feed-pump p. Within the generator AB is the closed chamber C holding the volatile liquid, ammonia, ether, or whatever. The heat of the steam-jacket vaporizes the volatile motor fluid, which passes through the pipe E to the motor-cylinder F. Exhausting thence into the surface condenser G with its provi-



sions for circulating water through pipes or tubes within it to bring the motor-vapor back to a liquid, the latter is returned to C by the feed-pump h. The two circuits are closed and distinct from each other. No additional charge of either fluid is required except to replace leakage losses.

The other form of the binary plan is to add a vapor motor-cylinder to the steam motor-cylinder and have the two cylinders drive the shaft as in the compound steamengine. The difference, however, is that the exhaust from the less volatile medium is made to pass through tubes or between thin plate surfaces on whose other side is the more volatile fluid. The tube or plate surface is a condenser for the hotter fluid, and the boiler for the more volatile one. The vapor is heated by the heat from the exhaust-steam of the first cylinder, and acquires tension to act to drive the piston in the vapor-cylinder. From this vapor-cylinder the vapor must pass to a condenser with abundance of cold circulating water, to be from thence pumped back into the generator to be used anew in circuit. This is the method used by Du Trembley (1842) with ether, and by Ellis (1872) with carbon bisulphide.

By the first plan no advantage is reaped from a saving of furnace-losses in the boiler; by the second plan, if the steamengine were a wasteful one, some advantage might follow from utilizing its wastes to evaporate the second fluid. If it had no wastes, there should not be heat enough available after exhaust to make the subsequent cylinder worth while, and a loss in transfer of heat is unavoidable, since the imparting body must be hotter than the recipient. Nearly 3000 horse-power were aggregated in vessels on the Mediterranean service using Du Trembley's ether-engines before the introduction of the compound steam-engine, but no care could prevent escape of the vapor, and fire and other disasters followed.

315. Wellington Series Vapor Motor.-In the spring of 1897 announcement was made that the late Mr. Arthur M. Wellington of New York had been giving earnest study previous to his death in 1895 to the problem of extending the Du Trembley principle to the working of several motors in series with successively more easily vaporizable media as the lower end was neared. Starting with steam as having the greatest absorptive capacity for heat in the first cylinder, the exhaust was to pass into a special chamber of thin plate cells, within which it should be cooled in the process of giving its heat to the next medium, which was to be found on the other side of the separating metal walls of the chamber. The cellular chamber was therefore a boiler or heater for the second medium, while a condenser for the first. The second cylinder, operating with the second medium, exhausted into a second condenser-heater for the third medium, and so on to the last medium, which was condensed by cold water when the descent down temperature had gone as far as it

#### VAPOR ENGINES.

was practicable to carry it. The fundamental idea is to work each medium within the limits of temperature range for which it is best adapted, and to transfer the heat from medium to medium by most effective contact methods of transfer. The principle is that of compounding by temperature but not by pressure, since the media are isolated in separate circuits, and do not act as back-pressures to those preceding it. The cylinder volumes will be proportioned for the pressure range belonging to the temperature range within which the medium works.



Fig. 194 will illustrate such a series engine both in the continuous system for one or a few media and in the successive system for a large number of media of varying properties.

Mr. Wellington also designed and patented efficient transferring appliances for the transfer of heat between the media, but his engine has never been built beyond an experimental stage. It is open to the practical disadvantages of the media which it uses, and it is further fair to call attention to the difficulties which the series principle involves.

The object of the series plan is analogous to that of. compounding below the low-pressure cylinder in the steamengine. To enable the designer to use a warmer temperature or a less volume of condensing water or a less bulk of condenser, the second medium is intercalated between the medium of higher heat potential and the condenser. The purpose is to diminish the inconveniences attaching to considerable transfers of heat in a short interval of time. On the other hand, as the *number* of transfers is increased, it must be remembered that there is a loss at each step in practice, because in order that the transfer may take place in reasonable time, or with reasonable surface and weights of metal, there has to be a difference of temperature between the hotter and cooler body. This is found in successive refrigerative processes to be conveniently allowed to reach 35°. Hence there is increased loss as the number of such transfers is increased. Furthermore, Fig. 181 shows the temperature-entropy diagram of a four-series engine in which the line 15–16 is fixed by the coolest available condensing water, and the area of heat rejected from the media above it gives the area of heat energy available for each successive medium. The shaded areas are separated by vertical spaces which represent the losses in transfer, and each rectangle is made wider as the succession moves down temperature, because with less value for T the factor  $\phi$  should be greater to produce a given area. While each medium is assumed to act in a Carnot cycle, yet an enveloping line which would give a summation of the areas would inclose a less area than if the hottest medium had been used alone within the same tem-The Carnot standard maximum efficiency. perature limits. assumes the entropy change to take place at the highest and lowest temperatures respectively. Hence while the seriesprinciple is defensible in theory, its practical difficulties as to size, weight, and cost of transfer apparatus usually more than offset the possible advantage.

VAPOR-ENGINES.

An interesting combination of the series principle has been suggested wherein a gas-engine and a steam-engine are operated, so that the rejected heat from the gas-engine shall

be used to make steam for the second cylinder. It is a question whether the gas-engine rejects heat enough to make this a practically utilizable combination when the steam cylinder is to be of any size. It would form an interesting computation for which there is no present opportunity.

The commercial obstacle to  $\overline{\circ | N}$ the series principle must not

be overlooked. The bulk and weight of the series of cylinders and condensers makes an interest cost for the plant which causes a serious inroad into its possible fuel economy. The Wellington series was proposed as far back as 1872, in the Transactions of the Polytechnic Club of New York City, by Mr. T. D. Stetson.

316. Ammonia-vapor-engines. — Ammonia is employed usually like the bisulphide of carbon by steam vaporization in a closed circuit. It can, however, be used in a sort of absorption circuit, by causing the expanded ammonia-gas to meet a spray of ammoniacal water which, when cool, will absorb the ammonia-vapor. The latter can be separated as a gas on moderate heating, and can be condensed by cooling, or by cooling and compression, for use over again. This latter principle is rather along the line of the convenient storage of energy than that of the availability of ammonia as a heat medium. Where ammonia has been tried as a medium for naval uses it has been found to offer no advantages over steam.

317. Combined-vapor-engines. Æro-steam Engines.-In all the foregoing discussion of volatile heat media which



have to be purchased in the market the necessity for condensation is rigorous, and the consequent presence of the necessary cooling water. Where the facilities for condensation cannot be had it has been proposed to combine air and steam, and lift the efficiency of the latter by mixing with it the air, whose efficiency is calculated as greater than that of This has been done in two general ways. Air under steam. pressure from a pump has been forced into the steam-pipe, so that the cylinder-charge was of nearly equal proportions of steam and air (Mont-Storm's "Cloud " Engine, 1850-1881), or the more satisfactory plan may be followed of drawing hot air and gases from the flues and injecting them into the steamspace of the boiler (Warsop's and Wethered's methods). The effect of the hot air is to raise the temperature of the mixture without a corresponding rise in pressure, producing the equivalent of a superheating of the steam and lessening cylinder condensation (§§ 132 and 229). Some loss of heat in the chimney-gases is also prevented, but the presence of corrosives in the products of combustion with most fuels, made active by the reactions with hydrogen and at high temperatures, is likely to attack the metal of the engine.

The improved economy of modern steam-engines, using the higher steam-pressures and the principle of continuous expansion, have enabled as good results to be secured with steam alone as with the aero-steam combination as it has been used.

318. Storage of Energy in Liquefied Vapors.—The use, as motor fluids, of elastic media which can be compressed to liquids by mechanical means furnishes a compact and effective way of storing such energy for transport. Carbonic acid has been so used since 1823, and the use of what is called liquid air is now proposed. It must be remembered, however, that there is to be derived from the expansion of such mechanically compressed gases only the energy which was stored in them, less the heat withdrawn in cooling them to their state of stationary temperature in accord with their surroundings.

#### VAPOR-ENGINES.

Unless reheated when used, their expansion and vaporization withdraws heat from their surroundings to an inconvenient extent, and in the case of carbonic acid or other gases which have a cost outside of the labor and fuel cost of compression, they are of significance only where expense is of less moment than some other object attained by their use. Compressed air at high tensions will usually meet these requirements more satisfactorily than the liquefied gases.

319. Conclusion.—It has been the intention that the reader and student shall derive from this chapter the conclusion that the vapor of water is the most effective of the various heat media when a balance is struck with respect to its advantages in competition with the others, unless certain extraordinary conditions are imposed as to weight or some other feature. It was intended that from the chapter on the gas- or oil-engine the conclusion should be derived that the use of these motors will extend more and more into fields now occupied by steam. Hence the gas- and the steam-engine are the two most important motive-power factors where available energy from falling water is not at hand by electrical transmission or otherwise.

With the completion of this chapter the subject of heat and heat-engines as laid out by the author for study and discussion is completed. It is intended that this treatment should be regarded only as the beginnings of the subject, and as leading to the mathematical discussion of thermodynamics as a deductive science from its differential equations. For such treatment the reader is referred to other treatises. The concluding chapters are convenient addenda having an obvious connection with the principal purpose of the book.

# CHAPTER XXII.

## MECHANICAL REFRIGERATION.

325. Introductory.-In the preceding chapters the object sought has been to liberate heat energy from fuel or other sources of heat, and to utilize this energy for industrial purposes in the form of mechanical work. The purpose of the present chapter is to consider the converse of this. Having a store or supply of heat energy either in the form of sensible or observable heat-units, or in the derived form of mechanical energy, it is sought to dispose of that energy in both forms. so that for equalization of heat condition a draft shall be made upon the store of heat energy in objects or places under their usual conditions. The result of this draft or lowering of the heat condition of an object or a place is what is generally recognized as the production of cold. It has been most aptly called a process of "heat-pumping." By the expenditure of mechanical energy upon a convenient and well-chosen heat medium its condition as to temperature alone, or as to both temperature and entropy is lowered towards that represented by the absolute zero of temperature, just as the level of water in a vessel is lowered by expending through a pump the energy necessary to draw water out of it.

The process of expanding a heat medium in an engine from a high temperature  $T_1$  to a lower one  $T_2$  is a process of mechanical refrigeration. It is, however, only when this process is so located on the temperature scale that the drop down the scale begins at the normal temperatures and proceeds below the usual limits for the climate and the zone

where it takes place that the term refrigeration is properly used. This will suggest, however, the methods which are used in refrigerating cycles.

While in heat-engine practice the medium to be used is chosen with a view to its heat-carrying capacity, in refrigeration it will be chosen with a view to its willingness to surrender its heat energy to surrounding objects. The vapors have therefore signal significance as media in heat-pumping.

326. Analogy between the Heat-engine and the Icemachine.—The foregoing analogy may be made more apparent by the use of an illustrative diagram (Fig. 185). Let the small cylinder on the left be the compressing or feed-water-





pumping cylinder of a heat-engine plant. If it be a steamengine, the current will pass clockwise or upward to the left from C through P to B, which is the heater (or boiler). In the boiler its temperature is lifted from  $T_2$  to  $T_1$ . Thence it passes to the working cylinder A, where it operates by its expansive energy to drive the piston, and is cooled by the supposedly adiabatic expansion to  $T_2$ , or the temperature in the cooler or condenser (C), which withdraws any heat which might be generated by the species of compression of the medium on the return or exhaust stroke of the working piston. The compressing pump P draws from the cooler or condenser and completes the circuit.

When the same or a different medium is operated as a refrigerating circuit the compressing piston in *P* receives mechanical energy, compressing the medium and raising its temperature an amount proportional to the work expended in compressing it. The current moves contraclockwise, or from the compressor downward to the cooler C. Here the heat from the compression is withdrawn by a circulation of cooling water and is rejected with that cooling water, so that the compressed medium leaves the condenser at the temperature  $T_{\bullet}$ . From the cooler the medium passes to the working or expansion cylinder A, where it does work against an exterior resistance (usually that of compressing the medium in P in part), and by such adiabatic expansion is cooled below the temperature  $T_{2}$  of the condensing water, and to a degree far enough below the surrounding objects to be anxious to withdraw heat from them. From A the cooled and expanded medium passes to the organ B, which is a heater so far as the medium is concerned, while it appears as the place or material to be refrigerated. That is, it supplies its heat to bring up the medium to its own heat condition, and in so doing is cooled itself. From this refrigerating chamber or heater of the medium the medium passes back to the compressor and repeats the cycle.

It is apparent, therefore, that in the heat-engine there is heat supplied from without at the heater B in the beginning of the cycle, and withdrawn at the cooler C at the end; in the refrigerating cycle heat is withdrawn at the cooler C at the beginning of the cycle, and therefore surrounding objects must supply heat at the heater B to the medium at the end of the cycle to close it.

327. Refrigeration for Ice-making or for Cooling-chambers. Brines.—The heat withdrawn from the surroundings

of the heater B in the preceding paragraph, to warm the medium while being themselves cooled by such transfer, is most easily transferred from a liquid to the medium enclosed in coils of pipes. This liquid requires to be one which shall not be too liable itself to freeze by the cooling process, and is therefore a solution of such alkaline salts in water as shall have its solidifying point lowered. It is therefore generically known as "brine." A solution of Liverpool salt in wellwater, of a degree of concentration such that it weighs 73 pounds per cubic foot or has a specific gravity of 1.17, will not sensibly thicken or congeal at zero Fahrenheit. American salt brines of the same gravity congeal at nearly 20° F. Chloride of calcium solution or chloride of magnesium can be used instead of brine. The latter remains fluid at 5° F.

When artificial ice is the object of the process there are two usual methods which are followed. The cooled brine surrounds thin metal cans within which is enclosed the distilled water to be frozen in one system, which is therefore called the "can" method; or the cooled brine or ammonia itself in coils circulates between hollow plates, perhaps 10 feet by 14 feet in area, on the outside of which the ice forms in the water-tank. This latter is called the plate method. In the can system blocks weighing 300 pounds will be frozen in from 50 to 60 hours; in the plate system the ice forms 14 inches thick over their area in from 9 to 14 days. The can system is more usual for ice-venders, since the supply of iceblocks is continuous, but the product of the plate system costs less, although the plant costs more.

When cold-storage chambers or cooling-chambers in factories are to be kept at low temperatures for the sake of their contents, the cooled medium can be circulated in coils of pipes about the walls of the chambers, or a cooled brine may be similarly circulated. The present practice tends towards direct expansion except in special cases, as likely to maintain a more uniform mean temperature in the different parts of the

coils. Or, again, air which is cooled by passing over and through a brine coil may be circulated in the chamber by means of fans. Such air will deposit its moisture in the form of snow upon the metal of the coils, and a dry cool air only will reach the stored material, and condensation thereon will be lessened or avoided. Where no brine is used the system is called a "direct expansion" system.

328. Media for Use in Refrigerating-machines. Advantages and Disadvantages.—A refrigerating medium may properly be expected to meet as many as possible of the following requirements:

(1) If it is a vapor, it must be volatile at low temperatures, but at pressures not too far below that of atmosphere.

(2) At high temperatures it must not reach high pressures.

(3) It must be stable in its composition, so as not to alter by the frequent evaporations which it must undergo.

Whether a vapor or a permanent gas:

(4) It must have no effect on metals convenient for use in machine-making.

(5) It must be without effect on convenient lubricants such as will have to be used in cylinders.

(6) It must be non-inflammable if leakage occurs.

(7) It must be non-explosive.

(8) It should be without serious physiological effect on workers around the machinery.

(9) It should not be too costly to buy.

The discussion of vapors as heat media has presented several of the volatile vapors adapted for use as heat-carriers ( $\S$  107-109 and  $\S$  312). For the uses of the process of withdrawal of heat, while some of the same media will serve, there are other special ones which have been tried. The list includes:

(I) Water-vapor.

(2) Air.

(3) Ether alone.

(4) Ether mixed with SO<sub>2</sub> (Du Motay binary fluid).

(5) Anhydrous sulphurous acid or sulphur dioxide (SO.).

(6) Mixture of No. 5 with carbonic acid  $(CO_s)$ , "Pictet fluid."

(7) Ammonia (NH<sub>s</sub>).

(8) Chymogene or other volatile derivatives of petroleum.

Ether is practically no longer in use, because the compressing cylinder has to have a volume six times that required for the sulphur dioxide and seventeen times that for an ammonia-machine. This follows from the density of the ether-vapor. It has also to be worked under less than atmospheric pressure, since its tension at  $27^{\circ}$  F. is 2 or 3 pounds per square inch, and the tendency of air to leak into the machine oxidizes the ether to a less volatile compound. Ether is also inflammable and acts on the lubricants to dissolve them. Such machines as used in India appear to have made 6 pounds of ice per pound of fuel consumed.

Sulphur dioxide is a liquid at  $14^{\circ}$  F., and at  $60^{\circ}$  to  $65^{\circ}$  F. has a tension of 3 to 4 atmospheres. It is without effect on grease used as a lubricant, and acts like one itself to keep metallic surfaces from contact. It is not inflammable and is stable, but is irrespirable. When moisture gets to it, the active acid is formed, which corrodes metals.

Carbonic acid  $(CO_3)$  used alone requires so high a range of pressures (800 pounds per square inch on the compressing side and 300 pounds on the suction side) that it is not practicable. The mixtures of Pictet and Du Motay have been displaced in America by the ammonia systems, on account of the convenience and cheapness of the medium and because capital has been attracted to invest itself in the manufacture of this type of machinery.

The petroleum-vapors are explosive and dangerous to use, and such machines are only experimental as yet.

The water-vapor machine uses a cheap and harmless medium, but the cylinders have to be enormous if the vapor operates in a compression cycle. In this case a vacuum-chamber

is required, in which by a pump a vacuum-pressure of about one tenth of a pound per square inch is maintained. A part of the water or brine injected into this chamber vaporizes, and the remainder is chilled in proportion to the latent heat extracted from it for the vaporizing of the first portion. The watervapor thus produced may be handled in two ways. It mav be passed into a surface condenser, the condensed liquid pumped out to waste, and the remaining vapor compressed from one tenth of a pound to one and one half pounds, to be worked as a superheated gas in a cycle similar to those to be discussed presently; or the absorption principle may be fol- . lowed as in the ammonia-machines shortly to be discussed, so that the water-vapor from the vaporization in the vacuumchamber is absorbed by sulphuric acid in a distilling apparatus. From the acid, which has a great affinity for water, the vapor is expelled by gentle heat, and after condensation is removed by the air-pump which maintains the vacuum. For ice-making conditions the volume of water-vapor would have to be 150 times that of ammonia. The machine is not in use in America to any extent.

The air- and the ammonia-machines are those of principal importance. The air-machine is principally used on shipboard, where pungent vapors from any leakage would be objectionable, and particularly in confined or ill-ventilated places.

329. Refrigerating-machines using Air as a Medium.— The discussion of the air-engine using air at ordinary temperature at admission and expanding it adiabatically (§ 260) should have made it clear that by the use of high grades of expansion the final temperature of the air will be very low. It will be recalled that

$$\left(\frac{v_1}{v_2}\right)^{n-1} = \left(\frac{p_2}{p_1}\right)^{\frac{n-1}{n}} = \frac{T_2}{T_1},$$

in which for air n = 1.41, the ratio of the specific heats of

air. So that if the air be taken in at 68° F., and expanded so that the ratio  $\frac{p_a}{p_1}$  has the values given in the following table, the final Fahrenheit temperatures will be those given in the table when calculated according to the formula:

$\frac{p_2}{p_1}$ .	Final Temperature Fahrenheit.	$\frac{\frac{f_2}{p_1}}{p_1}.$	Final Temperature Fahrenheit.
2	$ \begin{array}{r} - 28 \\ - 75.9 \\ - 106.6 \\ - 12^{8}.7 \\ - 145.7 \\ - 159.4 \\ - 170.9 \\ \end{array} $	9	- 180.5
3		10	- 188.9
4		11	- 196.3
5		12	- 202.9
6		13	- 208.7
7		14	- 214.1
8		15	- 218.9

The same truth is also apparent from a study of the table in § 182. These very low temperatures cannot be secured unless the incoming air be at a very great pressure, and moisture in the air and the conductivity of the cylinder metal limit the attainment of the theoretical figures. It is also difficult to -cool the air in bulk to atmospheric temperature, so as to secure a cool admission.

The air-machine appears in two general forms. The closed-cycle machine, represented by the Allen Dense-air Ice-machine, and the open cycle, represented by the Bell-Coleman Machine of European practice. In the Allen machine, and others on the same principle, there are three cylinders taking hold upon a common crank-shaft. One is a steam-cylinder; number two is an air-compressing cylinder, taking its supply of air from the closed coil of the refrigerating-chamber, and compressing it to 200 pounds, or so, to the square inch. This compressed air is received into a cooling-tank or surface condenser, where the heat due to compression is removed so far as possible by circulating water, and the compressed air brought as nearly to the temperature of that water as is consistent with manageable bulk for the cooler.

From this cooling reservoir the compressed and cooled air enters number three cylinder, in which it acts as in an expansive air-engine, doing work upon the driving-shaft to relieve the duty of the steam-cylinder. The exhaust from this airengine cylinder is at a low temperature, as indicated by the table above, and is led into the cooling coils of the chamber or brine, which latter delivers its heat to the pipes enclosing the exhaust in the effort to equalize the differing temperatures.

The open cycle of the Bell-Coleman type acts as in the Joule air-engine reversed (§ 275). It draws air from the open cooling-chamber at about atmospheric pressure; compresses it into a cooling chamber with coils of pipes; expands it in a second cylinder to the pressure of the open chamber, lowering its temperature by such expansion, and finally exhausting the cooled air into the refrigerating-chamber again. Fig. 186 shows a diagram of the organs of such a machine, and



Fig. 187 the compression and expansion diagrams. The closed curve KadH is the work done by the expansion-cylinder, while CHKb is the work of the compressor, leaving the differ-

49I

ence *abcd* to be provided for by the exterior work of the steam-cylinder.

The standard tests of the performance of these two types of machine (expressing them in heat-withdrawal equivalent to melting pounds of ice at  $32^{\circ}$  F. into water at that temperature, when the latent heat of fusion of ice is 142.2 B.T.U.) give 3 pounds of ice-melting capacity per pound of fuel with the closed-cycle machine operating between 39 and 160 pounds pressure; and for the open cycle 3-4 pounds, assuming the engine to run with 3 pounds of coal per horse-



power per hour. The advantages which they offer are those from the cheapness and harmless character of their medium; their drawbacks proceed from the bulk and size of the machine and the proportionate effect of the frictional resistances; the effect of watery vapor in the air, causing snow in the pipes and connections; and the effect of clearance-losses. If high pressures are used, there is great difficulty in making valves which will keep tight, and the heat from the compressor-cylinder is sufficiently conducted to other parts of the machine to cause a loss of effectiveness. With high temperatures glycerine may be used as a lubricant.

330. Ammonia Refrigerating-machines. Compression Type.—Reference has been made above (§ 328) to the

American prevalence of ammonia as a medium for producing cold mechanically. This results from the commercial accessibility of ammonia as a by-product in gas-making or cokemaking, and the comparative ease with which anhydrous ammonia can be produced from ammonia-liquor by a fractional distillation process, since the ammonia-gas is more volatile than the steam-gas from water. The table on page 493 computed by the late Prof. De Volson Wood gives the properties of the saturated ammonia:

From this table the convenient adaptability of ammonia will be apparent on its physical side. It will remain a liquid under atmospheric pressure only when kept at the temperature of  $30^{\circ}$  F. below zero on that scale, and at the usual atmospheric temperatures in this climate of about  $70^{\circ}$  it will be kept a liquid only by maintaining it under a pressure of 115 pounds above the atmosphere. With reduction of pressure the liquid becomes a vapor, withdrawing from surrounding objects the heat necessary to change its state. This heat of vaporization at atmospheric pressure is 573 B.T.U., as compared with the 966 units required by water.

The volatile character of the anhydrous ammonia makes it unprofitable to use an expansion-cylinder in its cycle as is required with air, since the gas will expand of itself by simply allowing it to pass from a higher pressure vessel into another at lower tension and temperature through a regulating cock or valve, and in the change of state by such expansion the cooling effect is so much greater than that resulting from the exterior work done in an expansion cylinder, that the latter becomes negligible. Such separating-valve is called an "expansion-cock."

In using ammonia as a medium there are two principal systems, the compression system and the absorption system.

In operating a refrigerating plant on the compression system there is required a steam-engine operating an ammonia compressor; a cooler or surface condenser in whose

Temperature.		Pressure, p. (Absolute.)		orization. nts.	ať. nits.	t. nits,	apor ft.	quid ft.	Pounds.	
Degree F.	t.	Absolute. $T$ .	Lbs. per sq. ft.	Lbs. per sq. in.	Heat of Vapo Thermal U	External Head Thermal U 778	Internal Hea Thermal U $r_1 = r -$	Volume of V per lb., cu.	Volume of L per lb., cu. $v_{2}$ .	Weight of a c of Vapor. r
	40	420.66	1540	10.69	579.67	48.25	531.42	24.38	.0234	.0411
	35	425.66	1773.6	12.31	576.69	48.35	528.34	21.21	.0236	.0471
	30	430.66	2035.8	14.13	573.69	48.85	524.84	18.67	.0237	.0535
	25	435.66	2329.5	16.17	570.68	49.16	521.52	16.42	.0238	.0609
	20	440.66	2656.4	18.45	567.67	49.44	518.23	14.48	.0240	.0690
	15	445.66	3022.5	20.99	564.64	49. <b>7</b> 4	514.90	12.81	.0242	.0775
	10	450.66	3428.0	23.77	561.61	50.05	511.56	11.36	.0243	.0880
-	5	455.66	3968.0	27.57	558.56	50.44	508.12	9.89	.0244	.1011
Ŧ	0	460.66	4373.5	3 <sup>0.37</sup>	555.50	51.38	504.12	9.14	.0246	.1094
++++++	5	465.66	4920.5	34.17	552•43	50.84	501.59	8.04	. 0247	. 124 <b>3</b>
	10	470.66	5522.2	3 <sup>8</sup> .55	549•35	51.13	498.22	7.20	. 0249	. 1381
	15	475.66	6182.4	42.93	546•26	51.33	494.93	6.46	. 0250	. 1547
+	20	480.66	6905.3	47.95	543.15	51.65	491.50	5.82	.0252	. 1721
+	25	485.66	7695.2	53.43	540.03	51.81	488.22	5.24	.0253	. 1908
+	30	490.66	8556.4	59.41	536.92	52.02	484.90	.4.73	.0254	. 2111
++++	35	495.66	9493.9	65.93	533.78	52.22	481.56	4.28	.0256	. 2336
	40	500.66	10512	73.00	530.63	52.42	478.21	3.88	.0257	. 2577
	45	505.66	11616	80.66	527.47	52.62	474.77	3.53	.0260	. 2832
++++	50	510.66	12811	88.96	524.30	52.82	471.44	3.21	.02601	.3115
	55	515.66	14102	97.93	521.12	53.01	468.01	2.93	.02603	.3412
	60	520.66	15494	107.60	517.93	53.21	464.76	2.67	.0265	.3745
++++	05	525.66	16994	118.03	515.33	53.40	401.82	2.45	.0200	. 4081
	70	530.66	18606	129.21	511.52	53.67	457.95	2.24	.0268	. 4664
	75	535.66	20 <b>33</b> 9	141.25	508.29	53.76	454.70	2.05	.0270	. 4878
+++++++++++++++++++++++++++++++++++++++	80	540.00	22192	154.11	504.00	53.90	450.75	1.89	.0272	.5291
	85	545.66	24172	167.86	501.81	54.15	447.75	1.74	.0273	.5747
	90	550.66	26295	182.80	498.11	54.28	443.70	1.61	.0274	.6211
+ + 1	95 100	555.00	30980	190.37 215.14	495.29	54.54	437.35	1.48 1.36	.0270	·7353

## SATURATED AMMONIA.

coils the compressed ammonia may be cooled by the withdrawal of the heat due to the compression, which is made up of the equivalent of the mechanical work of such compression

together with the heat necessary to produce vaporization, or the latent heat; the expansion-cock, through which the cooled and liquified ammonia may expand into a gas, withdrawing in so doing the heat from the brine which surrounds the coil or vessel into which the expansion takes place. Subsidiary circulating-pumps will then circulate the cooled brine in the chambers or water to be chilled. Fig. 188 illustrates the organs and connections for such a brine plant.

If the direct-expansion system is used, the expansionvalve at the bottom of the ammonia-receiver is replaced by a manifold from which groups of expansion-valves connect with the cooling-coils in the cold rooms at their lower ends. The ammonia-gas suction-pipe is connected to the upper or warmer ends of these cooling-coils by proper valves, and the circulation of the cooling medium is thus maintained.

In the actual operation of a plant the suction side of the compressor is connected to the low-tension side of the vessel or coil controlled by the expansion-cock, and a suctionpressure of from 5 to 20 pounds per square inch above atmosphere is maintained there by regulating the speed of the compressor and the opening of the cock. In starting with a new charge of anhydrous ammonia, it is introduced into this suction-chamber from the exterior vessel in which it has been received from the chemical manufacturers. Coming into the suction-chamber or coil at atmospheric temperature, the liquid ammonia volatilizes under the reduced pressure, and the proportion to be volatilized will be determined by the temperatures surrounding the coil or suction-chamber. Usually 10 per cent so volatilizes, cooling the entire mass down to the temperature of ebullition proper to the suction-pressure. Then the remainder of the liquid ammonia (or 90 per cent) volatilizes by the withdrawal of heat from the surrounding coil and brine, and passes as a gas to the compressor-cylinder.

The compressing stroke raises the ammonia-pressure to perhaps 150 pounds and 70° F., and expels the gas to the



F1G. 188.

cooler or condenser, where the heat is withdrawn by circulation of water and submergence in it, and the gas condensed to a liquid again upon the high-pressure side of the expansioncock in the ammonia-receiver. Upon opening the latter, the cycle of the charging process is repeated, and the process goes on thereafter continuously. The amount of ammonia charge in a machine will vary with the amount of piping in the circuit. A usual allowance averages 0.3 of a pound per running foot. Leakage or wastage ought not to amount to 100 pounds a year in a machine of 50 to 75 tons of ice capacity per 24 hours.

It will be apparent that the temperature of the cooling brine will be determined by the boiling-point of the ammonia, and that this will be determined by the pressure of the suction side of the compressor. The brine is usually 6° colder than the space it cools, and about as much warmer than the vaporizing ammonia. When, therefore, a temperature as low as 0° F. is required, as in storage of fish, the suction-pressure is kept down to 5 pounds; for brewery work, where storage temperatures of  $34^{\circ}$  F. are low enough, a suction-pressure of 28 pounds will suffice. Cold-storage chambers for fresh meat can be maintained at  $25^{\circ}$  F. with 24 pounds suction-pressure.

331. Wet or Cold and Dry or Hot Systems of Ammoniacompression.—If the regulation of the supply of ammonia to the cooler on the suction side of the compressor is so adjusted to the pressure that vaporization is complete, the machine is said to operate dry, or to belong to the dry-compression system. If, on the other hand, some liquid ammonia is allowed to remain unvaporized, or if some liquid ammonia is injected into the space filled with vapor, the system will be known as the wet or cold compression system. Prof. Linde introduced the first wet system, which is often known by his name, and Mr. George Richmond the second or injection method. The difference in the wet and dry systems follows from the presence of the liquid ammonia in the com-

pressing cylinder. If sufficient liquid is brought into the compresser, the temperature cannot there be raised higher than the boiling-point corresponding to the highest temperature and pressure of the compression; while with the dry saturated gas the temperature may go much higher than the limit set by the other system. More circulating water, however, will be required in the latter case because the compression-cylinder must be water-jacketed, which is not necessary in the cold system. Tests seem to show the two methods to give about equal results in economy, the reactions of the hot cylinder-walls neutralizing the theoretical advantage of the wet system.

332. Ammonia Refrigerating-machines. Absorption Type.-In the absorption system of ammonia refrigeratingmachines advantage is taken of the property of water or of a weak ammonia hydrate, whereby it shows a strong avidity to dissolve in itself the dry ammonia-gas. At 59° F. water will absorb 727 times its volume of ammonia-vapor. Hence if a pipe leading to such an absorber be connected to the lower tension or cool side of the expansion-cock, the anhydrous vapor will be drawn off through it to unite with the weak liquor in the absorber at a rate comparable to that at which the suction-stroke of the ammonia-compressor acted in the compression system. The liquor in the absorber is drawn off by an ammonia-pump and fed into a still, or chamber, within which a coil of hot steam-pipes will vaporize the ammoniagas, and crack the volatile ammonia from the less volatile The ammonia-gas may be at the same pressure and water. temperature as it would have had under the compression system, and is led into a condenser, where it becomes liquid anhydrous ammonia, to be worked through an expansioncock as in the other system. Hence it will appear that the difference in the two systems results from a replacing in the absorption system of the compression-cylinder and its drivingengine by a vessel called the absorber with an ammonia-

liquor pump and a steam still. The cooling condenser, the expansion-cock, the brine-cooling appliance and its pumps will be identical for both systems. It usually follows that the absorption plant will be somewhat cheaper to install, and in many places it is convenient to avoid the running of the large compressor and its attendant expense. It is often convenient also to be able to use the commercial ammonia hydrate of 62 per cent water and 38 per cent ammonia with a specific gravity of .880. Fig. 189 shows a type of absorption plant with the essential organs.



FIG. 189.

333. Refrigerating-machines on Pictet System. Carbonic-acid Machines.—Previous to the more extensive introduction of the ammonia-machines into America, the Pictet machine was the most extensively employed. It is still in limited use, and is also of importance in Europe. The medium at first was pure sulphur dioxide (SO<sub>2</sub>), but is now more usually the so-called Pictet fluid of 97 per cent of SO<sub>2</sub> and 3 per cent of CO<sub>2</sub>. The dilution with carbonic acid enables a temperature 14° F. lower to be secured at atmo-

spheric pressure than can be attained with the pure sulphur dioxide. The Pictet machine requires a little greater bulk for its compressing cylinder than the ammonia-machine, but otherwise they should be of equal theoretical efficiency.

The pure carbonic-acid machines require to work through a range of pressures higher in the scale than the foregoing, and difficulties from leakage and from the tightness of valves have stood in their way. To operate between 5° F. and 64° limits of temperature, the suction-pressure has to be 300 pounds per square inch, and the compression over 800 pounds. The compression-cylinder will be of one quarter the volume of the equivalent ammonia-machine, and this fact has given interest to the use of the machine for yachts and similar marine conditions, where room and weight are of paramount importance. The carbonic acid is more effectively worked in an expansion-cylinder rather than through an expansion-cock.



334. Temperature-entropy Diagram of Refrigeration Cycle.—The discussions which have preceded should have made easy the graphic representation of the useful effect by the use of the temperature-entropy diagram (Fig. 190). The

expansion of a permanent gas medium in an expansioncylinder is practically adiabatic. Starting, therefore, from the upper right-hand corner and moving towards the left, a line ab is described which is a curve of constant pressure and decreasing temperature caused by the cooling by the condenser-water to the point b. Here adiabatic expansion down temperature takes place through the expansioncylinder to the point c. The brine heats the medium and increases its entropy and temperature along the constant volume line cd, and at d the compression raises the temperature without change of entropy from d to a. If the medium used is liquefiable gas, the changes of entropy occur at constant temperature and the lines ab and cd are horizontal, giving the Carnot cycle diagram of Fig. 80.

In direct-refrigerating or open systems (§ 327), using air for example, where the cooled medium is exhausted into the space to be cooled, it will usually happen that the line *cd* will not be a continuous one, since the refrigerating-chamber will not raise the temperature of the medium to that corresponding to d. If h, for example, represents some such temperature level  $T_{1}$ , then the line through h represents a loss between the medium and the compressing cylinder due to the warm metal walls of the latter, and for which no refrigerating effect is produced. If the cylinder could be kept cool enough to have adiabatic compression on the second or succeeding strokes begin at h and describe an adiabatic vertical through h, it would appear that by successive withdrawals from the continuously cooling refrigerator a continuous lowering of  $T_{a}$ could be made to follow. The practical limit is soon reached, however, from the impossibility of carrying the cylinder-metal temperature down as the process goes on.

If, however, the object of prime interest be the securing of a low temperature, the principle of the regenerator may be introduced which was discussed for the reverse process under Hot-air Engines (§ 268). The regenerator in a refrigerating-

501

machine is usually called an interchanger, and is applied to restore the heat to the medium which is called for by the gap between h and d. This lowering of the interchanger temperature may be used to cool the medium below the first



temperature corresponding to b, so that a lower entropy ordinate is reached down which the adiabatic expansion occurs (such as fg, for example). This lower range can be



utilized on the next circuit to carry the cycle still lower, the effect being cumulative as long as the expansion-cylinder can have its temperature lowered at the same pace. This latter imposes the practical limit.

Figs. 191 to 193, reduced from a very complete paper by Mr. George Richmond (see Appendix), present the temperature-entropy diagrams of ammonia, SO<sub>2</sub>CO<sub>2</sub>, and ether when these media are operated by using a compression and an expansion cylinder through the Carnot cycle. Fig. 192 shows the diagrams which result when the expansion-cylinder is omitted, and the media are operated with some of the liquid present

#### TABULAR DATA FOR CONSTRUCTION OF DIAGRAM FIG. 191.

							_			
	<i>T</i> <sub>1</sub>	$T_2$	L <sub>1</sub>		Lz		$\phi_1 = \frac{L_1}{T_1}$		$\phi_2 = \frac{L_2}{T_2}$	
Ammonia Sulphur dioxide Carbonic acid Ether	$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$		. 580.56 170.82 121.50 . 170.99		543.03 156.76 67.93 166.14		1.2501 .3678 .2616 .3682		1.0367 .2993 .1297 .3172	
Represented on dia- gram by	ab	fg	rectg. bd		rectg. hf		Ъс		gh	
	$h = \int_{T_1}^{T_2} T_1^{cdt}$	$\Delta \tau = \int_{-7}^{7} T$	$\int_{1}^{2} \frac{cdt}{T}$	Δφ -	$r = + \Delta \tau$		c	T <sub>3</sub>	$=T_{2\epsilon}\frac{f}{C_{p}}$	
Ammonia Sulphur dioxide Carbonic acid Ether	60.10 21.59 56.72 31.47	.121 .043 .114 .069	6 7 .8	0918 0248 0171 + .0188		.5084 .1544 .2 .475		627.47 156.00 570.5		
Represented on dia- gram by	area abgf	be		,	kc					

(I lb. of each.)

so as to prevent superheating and so as to give the wet or cold system. Additional work is required as represented by the area bge, but the heat removed is reduced by the same amount, because the heat is not removed from the liquid as in the other set cf conditions, and reducing the area of refrigeration by the area ef', equivalent to bge. When the

media are used in the dry system there will be a rise in temperature and entropy after the point h is reached, and additional work will be done as represented by the area of *khjc* (Fig. 193). Refrigeration is also increased by the area of the rectangle kd.



335. Efficiency in a Refrigerating Cycle.—The temperature-entropy diagram also makes apparent to the eye the meaning of the expression for the efficiency in a refrigerating cycle. In the heat-engine cycle or the direct cycle under the Carnot hypothesis, the high temperature of the source of heat is the starting-point, and the heat energy flows downward through the heat-engine, which utilizes it, and that which is not available for work is transferred to the refrigerator or condenser. The efficiency is then the fraction whose denominator is the maximum heat energy available, and whose numerator is that part of it which is transformed into work. The heat rejected will measure the excess of the denominator as compared with the numerator.

In the refrigerating cycle, which is the reverse of the direct cycle, the problem is to withdraw heat energy from the refrigerator and transfer it to the heater. Universal experience and the dictum of the second law of thermodynamics indicate that this can only be done by the expenditure of mechanical energy, or by a process analogous to pumping. The object will therefore be to remove the greatest quantity of heat energy by the expenditure of the least mechanical energy possible to accomplish this result. Efficiency of such heat-pumping will therefore be measured by a fraction whose denominator will be the mechanical work required, and whose numerator will be the entire amount of heat pumped out of The difference between the total heat the refrigerator. discharged into the condenser, and the heat pumped out of the refrigerator will be the equivalent of the work expended, and it will be obvious that the less heat converted into work, the more cooling is done and the more efficient the apparatus as a refrigerating device.

Referring then to the temperature-entropy diagrams, it will be apparent that the total heat energy of the cycle will be the product of the upper temperature value into the entropy range. Calling this upper value  $T_a$  and the entropy range  $\phi$ , we have

Heat energy obtained from refrigerator =  $\phi T_{2}$ .

The work of the compressor and expander is to take the medium used and operate with it between the larger value  $T_2$  and the lower value  $T_1$ . The work done will therefore be  $778\phi(T_2 - T_1)$  in foot-pounds or  $\phi(T_2 - T_1)$  in heat-units.

Hence the efficiency by definition will be

Efficiency 
$$\frac{\text{Energy obtained}}{\text{Energy expended}} = \frac{\phi T_2}{\phi (T_2 - T_1)} = \frac{T_2}{T_2 - T_1}$$

which is obviously an expression in the form of the reciprocal of the efficiency of a heat-engine. The peculiarity of this expression is that its value is greater than unity. This is due to the peculiar negative unit which it presupposes when the object is the pumping down of heat energy as a positive operation. Where the energy obtained is a part of the energy expended, as is the usual case, this apparent difficulty is avoided. For this reason many engineers prefer to use the relation between the heat actually withdrawn *as heat* to the work expended in the heat-pumping and call this the efficiency. That is,

Efficiency =  $\frac{\text{Cooling effect}}{\text{Work required to produce it}}$ .

This may become unity when equal areas of the temperatureentropy diagram are formed by the position of the line through  $T_i$ . As the work area grows less than one half the total heat-energy area, the efficiency is greater and transcends unity.

In either use, however, an important pair of conclusions is to be drawn:

Ist. The efficiency increases as the temperature of the refrigerating-room increases;

2d. The efficiency increases as the temperature of the condenser or cooler is lowered.

The practical use of the efficiency results from the fact that it gives the number of thermal units removed per 778 foot-pounds expended. If the latent heat of fusion of ice be called 142.2 B.T.U. per pound, there will be required per ton of 2000 pounds made per 24 hours an amount of heat represented by

 $142.2 \times 2000 = 284400.0$  heat-units.

Each horse-power per 24 hours will be represented by

$$\frac{33000 \times 60 \times 24}{778} = 61079$$
 heat-units.

Hence the number of tons of ice made from water at 32° F. per horse-power per day of 24 hours will be

$$E \times \frac{61079}{284400} = \frac{\text{Heat}}{\text{Work}} \times .214 = E \times .214,$$

in which the heat and work values can be scaled from the temperature-entropy diagram.

336. Refrigeration by a Series Process. The Step-bystep Method.—It is obviously possible in refrigeration also to make use of a succession of media for producing a low degree of temperature just as in the series heat-engine it was sought to widen the range of pressures within a given temperature range ( $\S$  315). The advantage secured is that by using a series each agent selected may be best adapted to the particular range of temperature through which it is used.

If the Carnot cycle be assumed for each medium in the



F1G. 195.

series, the operation as presented by the temperature-entropy diagram will be conducted in a series of steps as shown in Fig. 195. The medium adapted for the top of the range may act upon the material to be cooled by lowering its temperature from  $T_{\circ}$  to  $T_{1}$  by the adiabatic expansion of the medium down temperature through this range. The body to be cooled may then come into the second machine operating with a medium adapted for the lower range between  $T_{\bullet}$ 

and  $T_1$ , and by a similar expansion process may have its temperature lowered to  $T_2$ , and a third step with a third medium may drop its final temperature to  $T_4$ . Using again the analogy of heat-pumping, the action may be compared to a discharge of heat energy by each machine of the series into the suction or refrigerator of that above it, so that the work is done in three (or more) steps instead of doing it by the one step which might be difficult and even impossible. This method is used in liquefying some of the more difficult gases, and when used alone or in combination with free expansion methods can produce the lowest known limits of temperature.

337. Design of a Refrigerating-machine.—It would be manifestly impossible within the limits imposed by this discussion to refer exhaustively to all possible machines and combinations. The treatment of the air-compressor (Chapter XIII) and of the air-engine (Chapter XVIII) furnish all necessary formulæ for an air-machine, or one using a compression and an expansion cylinder. The heat to be withdrawn from the cold-storage room will be for each pound of air passing through the refrigerating-machine

$$C_p(t_1-t_4),$$

when  $t_i$  corresponds to  $p_i$ , the pressure at which the air enters the compression-cylinder, and  $t_i$ , corresponding to  $p_i$ , is the temperature in the cold chamber. If the amount of heat to be removed is given in units as well as the range, then the heat withdrawn will be

$$Q = MC_p(t_1 - t_4),$$

when M is the number of units of weight of air to be taken care of per minute. Q is usually given in terms of pounds of ice made or melted in a given time. If, for example, it be 400 pounds of ice per hour, then

$$M = \frac{Q}{C_t(t_1 - t_4)} = \frac{142.2 \times 400}{60 \times 0.2375(t_1 - t_4)}.$$

The work of compressing M units without account of clearance will be

$$W_{c} = M p_{1} v_{1} \frac{n}{n-1} \left\{ \left( \frac{p_{2}}{p_{1}} \right)^{\frac{n-1}{n}} - 1 \right\},$$

as shown in § 181, which may be written

$$W_c = \frac{MC_{\dagger}}{A}(t_2 - t_1)$$

since

$$\frac{T_{\bullet}}{T_{\bullet}} = \left(\frac{p_{\bullet}}{p_{\bullet}}\right)^{\frac{n-1}{n}} \quad \text{and} \quad C_{\bullet} - C_{v} = AR = C_{\flat} \frac{n-1}{n}.$$

The work in the expansion-cylinder (§ 254) will in like manner be

$$W_c = \frac{MC_*}{A}(t_s - t_*),$$

when  $t_s$  corresponds to the  $p_s$  at the point of cut-off in that cylinder, and  $t_4$  corresponds to the final pressure supposed to be that in the chamber when the expansion is complete, and the machine exhausts into the cooled chamber direct. Then the steam-cylinder must furnish a power enough greater than

$$W = W_c - W_c$$

to overcome its own friction and the friction of both the compressing and expanding cylinders, and the fly-wheel shaft and engine mechanisms.  $\overline{W}$  being expressed in foot-pounds per minute and properly increased,

H.P. 
$$=\frac{W'}{33000}$$
.

The cooling water required must be sufficient to cool the weight of air per minute from the compression temperature  $t_a$
to that at which the air enters the expansion-cylinder at  $t_s$ ; this will mean that a quantity of heat must be taken care of which is represented by

$$Q_w = MC_p(t_2 - t_3).$$

If the cooling water comes into the cooler at an initial temperature  $t_i$ , and leaves it with a final temperature  $t_j$ , the heat of the liquid for each pound is changed from  $q_i$  to  $q_j$ , so that a weight of water per minute H is required such that

$$H(q_f - q_i) = MC_p(t_2 - t_3),$$

or

$$H=\frac{MC_{p}(t_{s}-t_{s})}{q_{f}-q_{i}}.$$

With a compression-machine, operating in a closed cycle, and using a brine as a transfer agent, the problem usually comes in the form which calls for the dimensions of a machine having a certain ice-making or ice-melting effect per hour or per 24 hours. The weight of medium is then determined by the condition that each pound of it must withdraw from the refrigerant brine the heat required to change the liquid at  $t_1$ in the condenser with a heat'of liquid in each pound, represented by  $q_2$ , into saturated vapor with a temperature  $t_2$  in the vaporizer, where the total heat of vaporization for the pound will be represented by  $\lambda_2$ . Hence the heat withdrawn per minute per pound will be

$$Q = \lambda_2 - Q_1.$$

When the heat to be withdrawn is given in the form of ice made per hour, then the weight of medium (M) becomes per minute

$$\frac{142.2 \times \text{weight of ice per hour}}{60} = \mathcal{Q}_1 = \mathcal{M}(\lambda_2 - \mathcal{Q}_1).$$

### HEAT AND HEAT-ENGINES.

The compressing work being assumed to be adiabatic, the temperature  $(T_s)$  of the superheated vapor leaving the cylinder to go to the cooling-condenser will be

$$\frac{T_s}{\overline{T}_2} = \left(\frac{p_1}{p_2}\right)^{\frac{n-1}{n}}.$$

Hence a quantity of cooling water in the condenser will be required which will be represented by

$$Q_w = [MC_p(t_s - t_1) + r_1],$$

in which  $C_{\rho}$  is the specific heat of the superheated vapor at constant pressure, and  $r_1$  is the heat of vaporization (equal to  $\lambda - q$ , §§ 125, 127) of the medium at the pressure  $\rho_1$  of the condenser. To find the weight of cooling water per minute, where the initial and final temperatures for it are given, the method above given for the air-machine may be repeated.

The net horse-power of the steam-cylinder which drives the compressor must be 778 times the heat-units to be disposed of. Hence

H.P. = 
$$\frac{778 \times M[C_{p}(t_{1}-t_{1})+\lambda_{1}-\lambda_{2}]}{33000}$$
,

in which  $\lambda_1$  and  $\lambda_2$  are the respective total heats of vaporization at the pressures and temperatures in the condenser and the vaporizer. To this first or net result must be added the percentage allowance for the loss in the compressor, and the further allowance for the friction and other losses of the engine and compressor mechanisms.

The compressor-cylinder volume will be found by taking from tables the volume of one pound or unit weight of the medium. If this be called  $v_{a}$ , then the volume of M pounds  $(Mv_{a})$  will equal the required volume to be swept through per minute; or if the compressor makes N strokes per minute,

$$Mv_{s} \times \frac{I}{N} =$$
 volume for one stroke.

Corrections for clearance loss must be made as discussed in §§ 186, 187.

338. Performance of Refrigerating-machines. — The most complete résumé of the theory and performance of refrigerating-machines is to be found in the American issue of Ledoux's classic treatise on Ice-making Machines (see Appendix). From the tables there published it appears that on the assumption of an evaporation in a good boiler of 11.1 pounds of water per pound of combustible from and at  $212^{\circ}$  in an absorption-machine, or on the assumption of 3 pounds of coal per horse-power per hour with a compression-machine, an actual ice-melting capacity per pound of coal should be attained as follows:

With a brine temp refrigera	perature entering the ted space of	The ice-melting capacity in pounds ranges between			
37°	Fahr	<b>33 and 4</b> 6	Average	39 +	
28°	• • • • • • • • • • • • • • • • • • • •	· · · · · · · · · · · · · · · · · · ·	4.6	24	
23°	· · · · · · · · · · · · · · · · · · ·	16 and 33	4.6	24 +	
8°		17 and 22			
— 5°	••••••	10 and 16	4.4	13 +	

339. Freezing-mixtures. Some Low Temperatures. Liquid Air.—A limited degree of artificial cold results from the heat required for chemical reaction in certain mixtures of salts or salts and acids. Such freezing-mixtures are:

	Whe by w	n mixed weight.		Reduce Fahr. temp. f	from
Sodic sulphate, NaSO4	. 8	parts	l	"0° to	~ °
Hydrochloric acid, HCl	5	<i>4 6</i>	)	50 10	2
Sodic chloride (common salt), NaCl	. I	<i>4</i> 6	ł	TO <sup>°</sup> to	~°
Snow or pounded ice, H2O	. 2	4.4	5	50 to	0
Sodic sulphate, NaSO4	3	" "	ļ	r.0° +0	0°
Dilute nitric acid, HNO3	2	4.6	)	50 10 -	- 2
Sodic sulphate, NaSO,	. 6	" "	)		
Ammonic nitrate, NHNO3	5	6.6	}	50° to	-14°
Dilute nitric acid, HNO3	• 4	" "	)		
Sodic phosphate, Na(PO <sub>5</sub> ) <sub>2</sub>	9	6.6	l	ro <sup>e</sup> to	ao°
Dilute nitric acid, HNO3	4	4.6	)	50 10 -	20

The lowest ranges of temperature secured by the physicist

### HEAT AND HEAT-ENGINES.

have been in the liquefaction of gases by compression and cooling at the high pressure, with subsequent lowering of pressure by expansion. Faraday of England (1820–1860), Natterer of Vienna (1854), Cailletet and Pictet of Paris (1878), Dewar of London (1893), and Chas. E. Tripler of New York are names identified with these researches and results. Some of these low temperatures or the boiling-points of liquid gases are: .

For carbonic acid, CO <sub>2</sub>		220° F.
For oxygen, O	_	300° F.
For nitrogen, N		315° to 320° F.
For air, $O + N$		312° F.
For hydrogen, H		418° to 440° F.

Liquid Air is a product of considerable scientific interest by reason of the accessibility and cheapness of the agent. It is manufactured in 1899 by mechanical compression in three stages with intercooling (§ 189). The first cylinder  $(10\frac{1}{2}'' \times 16'')$  raises it from atmosphere to 65 pounds pressure; the second  $(6\frac{5''}{8} \times 16'')$  from 65 to 400; and the third  $(2\frac{5^{\prime\prime}}{8} \times 16^{\prime\prime})$  from 400 to 2000 or 2500 in the usual process of to-day. The cooling is done by ordinary water circulation in coils up to the stage of storage in proper reservoirs of the cleansed high-pressure air. The air is then allowed to expand down to nearly atmospheric pressure through a specially designed expansion-valve into an expansion-chamber wherein the high-pressure air is circulating in strong coils. The lowering of temperature at that pressure combined with the regenerating effect produced by the contact with the coils is sufficient to transform the air to a liquid combination of its two elements, and it can be drawn off in drops through an outlet-valve. Such an apparatus as described with a steam-cylinder  $16'' \times 16''$  at 85 to 90 pounds boilerpressure makes from 2 to 3 gallons of liquid air per hour at a

cost stated to range from twenty cents to one dollar per gallon.

Liquid air of course vaporizes again, withdrawing heat from the air and surrounding objects to the amount required to restore it. It is in this way that it can be used as a source of motive power. The difficulty is to control the evaporation within convenient limits of pressure-resisting power of containing vessels. Nor should it be forgotten that in withdrawing heat from the air or surrounding objects this withdrawal must be compensated elsewhere, or else the heat-level of the world is lowered towards a level of cold for which the human organism is unfitted.

# CHAPTER XXIII.

# THE INJECTOR.

340. Introductory. — The discussion of the dynamic theories belonging to heat-engine practice would not be complete without a reference to the injector as an appliance for introducing the heat medium into the boiler or generator against the pressure in the latter. The injector differs from a feed-pump for this same purpose, because the latter is based upon easily understood principles of pressure and resistance, and a greater volume of steam displaces a less volume of water where the head of steam-pressure and the resistancehead of the water-cylinder are the same. The injector, on the other hand, depends upon a direct conversion of heat energy into dynamic energy, and by a process not so obvious or plain as in the case of the steam-pump.

341. The Injector Defined. The Ejector.—The injector may be defined as an appliance or apparatus whereby a jet of steam moving at a velocity due to its pressure is made to impinge upon a mass of cool water, to which it transfers its energy to such an extent that the combined jet of steam and water will overcome a resistance-head equal to or greater than the pressure which actuated the original jet of steam. That is, a jet of steam issuing from a boiler into an injector will pick up a quantity of water, and will be able to force that water into the boiler against the pressure which actuated the jet, and will carry the steam in the original jet also back into the boiler from which it started.

The injector conforming to this definition consists of a hollow, somewhat tubular casting, usually of brass, into which are made three openings. The first one (A, Fig. 196),

which usually enters the top of the instrument, is for the delivery to it of hot, dry steam from the dome of the boiler or other convenient place. The second opening, B, is the inlet for the water to be fed, which is usually delivered to it from below. The third will be the feed-outlet, HI, opening towards the boiler, through which the feed-water impelled by the steam will pass to overcome the pressure on the check-valve and enter the boiler.

The injector properly so called has the cross-section of its tube proportions diminishing from the nozzle of the jet, in order that the velocity of the stream may increase from the point of meeting the water until the current streams into the vessel in which a high tension is maintained. If, on the other hand,

the tube proportions are arranged to flare or increase in cross-section beyond the combining point, the velocity of flow is decreased, less resistance-head will be overcome, and the instrument becomes properly designated an ejector. The injector may therefore properly be limited to instruments operating to force water against considerable resistances and in comparatively small volumes, the water becoming considerably raised in temperature in the process. The ejector, on the other hand, is adapted for handling large volumes against low resistances, and by virtue of the greater mass of water handled the latter becomes only slightly Both injector and ejector as appliances for moving warmed. water are wasteful of heat as compared with a good pump; when applied as a boiler-feeding appliance where heating of the feed-water is convenient and desirable, the injector does



FIG. 196.

what can only be done with a pump by adding to the latter much of complication in the way of heat-saving devices.

The injector depends on three sets of principles. Two of these are physical or mechanical, attaching to it because it is a jet and impact apparatus; the third are the thermal or heat principles, resulting from the heat-transfers when steam and water are the fluids concerned.

342. Mechanical Principles underlying the Injector. The Induced-current Principle.— The injector must be capable of lifting the water which it is to feed into the boiler from a level in a tank lower than the instrument itself. If circumstances permit the water to flow to it from a higher level, it does not require to use this capacity, and will be called a non-lifting injector. Where the machine must raise the water to its level it will be called a lifting injector.

The principle on which the injector depends for its capacity to lift water is known in pneumatics or hydraulics as the principle of induced currents. If a jet of steam or air or water is made to move with a considerable velocity in a line parallel to the axis of a second or larger tube which surrounds the issuing jet, the impact of the matter issuing from the moving jet upon the matter within the surrounding tube will cause the contents of the latter to move with the jet in its direction. The action may be an impact of particles, or it may be a frictional entrainment of the one fluid by the movement of the other. If the cross-section or profile of the inner jet and the outer tube be adjusted to each other in the light of experience, the jet will induce a continued flow, tending to exhaust the contents in the space in the outer tube B which lies behind the orifice of the inducing jet C. This principle is a familiar one in the exhaust-steam blast in the locomotive, in the atomizer of the chemist and physician, and in many much-used applications. As applied in the liftinginjector it requires that the space behind the nozzle of the operative jet be connected by an air-tight pipe to the suction-

### THE INJECTOR.

tank, within which it must be so immersed as to be watersealed. In front of the nozzle of the jet must be an orifice opening to the air or to some waste-connection. With this latter orifice open, if the operating-jet be started, it will carry with it the air behind the jet until the pressure between the jet and the suction-tank becomes so much less than the pressure of the free atmosphere that the latter forces water up the suction-pipe to maintain the equilibrium. If the suction-pipe be not too long—probably less than 20 feet of the possible 32 feet—and the water in the suction-pipe is not so warm as to form a vapor in it under the reduced pressure, the induced current of air will cause the water to rise and meet the impact of the steam at the issue from the nozzle.

The second mechanical principle is the principle of impact of a small mass of steam in the jet against the greater mass of the water which the induced current has lifted. This will be discussed in a succeeding paragraph.

343. Heat-transfer, Work, and Efficiency in the Injector.—The injector problem usually comes in the form that a certain weight of water  $W_w$  is to be forced into the boiler, and to do this work a weight of steam  $W_s$  must be expended. The weight of water will have its temperature raised from  $T_*$ , which it had in the tank, to the temperature  $T_2$ , which will be the temperature of the hot feed-water after leaving the injector, or  $W_w(T_2 - T_*)$ . The weight of steam condensed by this weight of water loses an amount of heat per pound which is represented by the equation

$$L = \mathcal{C}(T_1 - T_2) + xr,$$

in which the specific heat may be called unity, and the percentage of vaporized steam is 100, or x equals unity, and r is the heat of vaporization at the temperature  $T_1$  in the boiler, at which temperature the steam enters the injector. For a weight of steam W, this becomes

$$W_{sh} = W_{s}[(T_{1} - T_{2}) + r].$$

### HEAT AND HEAT-ENGINES.

The heat given by the steam must equal that absorbed by the water; or

$$W_w(T_2 - T_4) = W_s[(T_1 - T_2) + r],$$

whence

$$W_{s} = W_{w} \frac{t_{2} - t_{4}}{t_{1} - t_{2} + r}$$

in ordinary temperatures, since differences alone are used. The temperature  $t_2$  of the water in the pipe leaving the injector must be low enough to have the condensation complete, and yet the hotter it is the better so far as the boiler is concerned. It is likely to be about 160° with small or light feeding and 120° to 140° with heavier feeding. According as the upper or lower values are taken, a calculation within ordinary ranges of pressures will bring a relation of steam weight to weight of water ranging between 10 and 13. That is, the steam supplies from 10 to 13 times its weight of water. In the absence of tables for r, it may be calculated from the formula

$$r = a - bT_1 = 1114.4 - 0.7T_1$$

The water and the steam unite and flow together through the feed-pipe. The work to be done in the boiler where the water passes the check-valve will be the displacing per unit of time of a volume in cubic feet which is that of  $W_w + W_s$  pounds against the boiler-pressure. Since the pressure of the atmosphere is exerted within the injector  $(p_o)$ , the effective pressure to be overcome at the boiler is  $p_1 - p_o$ . The volume of  $W_w + W_s$  in cubic feet will be

$$\frac{W_w + W_s}{62.4} = 0.016(W_w + W_s);$$

hence the work will be, if pressures are in pounds per square inch,

Work =  $144(p_1 - p_0) \times 0.016(W_w + W_s)$  foot-pounds.

### THE INJECTOR.

From this it is easy to pass to the efficiency,

$$E = \frac{\text{Work done}}{\text{Heat expanded}} = \frac{144(p_1 - p_0) \times 0.016(W_w + W_s)}{778W_s(T_1 - T_2 + xr)},$$

which as a rule works out a small value only.

344. Mechanical Principle of Impact in the Injector.— The mass of steam which meets the water in the combining tube of the injector has to act upon the latter by impact of the condensed water upon the feed-water. These masses being related to each other in a high ratio, such as one of steam to ten or sixteen of water, it follows that the principle of the conservation of the motion of the centre of gravity will bring about a resultant velocity when they meet which will be to the velocity of the steam as  $W_s$  is to  $W_w$ . That is, if the mass of the steam be one and that of the water be ten, then the centre of gravity of the two bodies will lie nearest the water and at one eleventh of the distance separating them, and the velocity of the steam. If the ratio of masses be 15, then the resultant velocity will be  $\frac{1}{16}$  of that of the steam.

The accepted formulæ for the velocity of flow of a perfect gas from a reservoir within which is a pressure  $p_1$  into another chamber where the pressure  $p_2$  prevails are those of Joule and Thomson. When the weight of a unit of volume is denoted by  $w_1$  at the pressure  $p_1$  and the cooling during discharge is adiabatic, then

$$V^{2} = 2g\frac{k}{(k-1)}\frac{p_{1}}{w_{1}}\left[1-\frac{T_{2}}{T_{1}}\right] = 2g\frac{k}{k-1}p_{1}v_{1}\left[1-\left(\frac{p_{2}}{p_{1}}\right)^{\frac{k-1}{k}}\right],$$

in which k will have the value appropriate for the observed adiabatic expansion of the gas in question. For steam it is 1.111 according to Rankine, and according to Zeuner the value

$$k = 1.035 + 0.100x$$
,

### HEAT AND HEAT-ENGINES.

in which x is the initial proportion of dry steam-gas. Solving, with the assumption that the steam is dry,

$$V = 23.2687 \sqrt{p_1 v_1 \left[ 1 - \left(\frac{p_2}{p_1}\right)^{0.1189} \right]}.$$

The velocity of the mixture of steam and water will be less than the one-tenth or one-sixteenth of the foregoing values, because the impact of all particles cannot be in the line of propulsion. Calling this water velocity  $V_2$ , the cross-section of the water-tube inside the injector will be

Tube area = 
$$\frac{0.016(W_w + W_s)}{V_2}$$
.

The area of the steam-nozzle should be

Nozzle area =  $\frac{\text{Volume of steam corresponding to } W_s \text{ per sec.}}{V}$ 

from which the diameters will follow since the area will be  $\pi r^2$ .

It will be found, on making the calculation for any case, that the expenditure of heat-units resulting from the condensation process is so much greater than the equivalent expenditure in lifting the water by suction and of forcing it into the boiler, that these latter quantities are negligible by comparison.

345. Double-tube Injector. The Inspirator. — The necessity of adjusting the weight of water to the weight of steam in the jet, and the variation in the latter with varying steampressure, brought about the self-adjusting types of injector, where the combining tube was moved forward or backward, enlarging or constricting the water-area as the pressure outside of the tube might vary. This was a feature of improvements by Sellers & Co. as far back as 1865 (Fig. 197). In 1876–7 Körting of Hanover, Germany, (Fig. 198,) and Hancock of Boston introduced the use of two jets of steam to

### THE INJECTOR.

secure this same result. The first nozzle is the smaller and acts upon a relatively large mass of water to deliver it under a slight pressure to the second or larger steam-nozzle, which forces the supply to the boiler. The first jet will be the



FIG. 198.

lifting-jet when the injector requires to raise its water. Inspirator was the proprietary name given by Hancock to his double-tube design.

346. Restarting or Automatic Injectors.—An injector which will establish its action as a boiler-feeder automatically after the continuity of the combined jet has been broken by

### HEAT AND HEAT-ENGINES.

a stoppage of either the steam- or water-supply is called an automatic or restarting injector. The usual method of securing it is to have two steam-jets, one for lifting and one for forcing. When the continuity of the combined jet is broken by a failure of the water-supply, the discharge of steam from the forcing-jet finds its way to a waste-pipe through a checkvalve, while the lifting-jet keeps up maintaining a vacuum in the feed-pipe and draws up the water as soon as it can be supplied. The adjustment of tubes and nozzles is also so made as to favor a wide variation of steam-pressures before a break in the flow shall occur. The advantage of the restarting principle is the simplification of the apparatus by doing away with adjusting spindles and the like, so that a simple valve on the steam-pipe to the injector is all the regulating appliance required.

347. Exhaust-steam Injectors.—The steam-current for an injector may be derived from exhaust-steam when the back-pressure head is less than 75 pounds. The feed-water should flow to the apparatus and should be as cool as possible —never over 100° F. If a supplemental live-steam jet be added to revivify the exhaust-jet, the injector will feed up to 150 pounds.

348. Advantages of the Injector.—The advantages to be claimed for the injector are:

I. From its construction, it is cheap.

2. It is compact, and takes little space in proportion to its capacity for moving water.

3. It has few or no moving parts, and hence a small running cost for repairs.

4. It delivers the water warm to the boiler.

5. It has no exhaust-steam to dispose of.

349. Disadvantages of the Injector. — The disadvantages of the injector are those which belong to the apparatus as a class, and those which belong to certain forms of the instrument only. I. The impact of the jet on the water is not an effective method of pumping. As a pumping appliance the injector is about  $\frac{1}{5}$  as efficient as the equivalent steam-pump. Its duty is about 2 million foot-pounds, against 10 million for the pump.

2. It heats its water with live steam, while to utilize the heat of its exhaust a pump with feed-water heater should show a superior coal economy of 12 per cent from the saving of waste heat.

3. The feed-water must be cool enough to condense the steam-jet, and this limit is about  $100^{\circ}$  F. Hence the injector cannot be used upon hot water.

4. It will not start with pressures much lower than those for which it was designed.

5. If it is not a restarting instrument, it will stop working after the limit of co-relation of feed-water and steam are passed. Then it must be started anew by the operator. Often when it has become hot by the interruption of the water-jet, it can only be restarted by complete cooling with water.



#### LOGARITHMS.

35c. In arithmetical computations, the usual base of the system is 10, so that x, the logarithm for a number m, will be the exponent to which 10 is to be raised to give the quantity m, or  $x = \log_{10} m$ . In analytical mathematical work, the base generally employed is not 10, but is represented by e whose value is 2.71828 +. To convert common or Briggs logarithms into Napierian logarithms, the former are to be multiplied by 2.3026.

The equation of the hyperbola in the form xy = constant leads to the deduction that the area between the hyperbolic curve and its nearest asymptote cut off by two ordinates parallel to the other asymptote and distant respectively from the origin by a and b will be proportional to  $\log \frac{b}{a}$ . Hence it will be true that the integral of  $\frac{dx}{x}$  will be the hyperbolic logarithm of x. To save trouble of conversion, a table is appended covering the usual ranges required.

No.	Log.	No.	Log.	No.	Log.	No.	Log.	No.	Log.
1.01 1.02 1.03 1.04 1.05 1.06 1.07 1.08 1.09 1.10 1.11 1.12 1.13 1.14 1.15 1.16 1.17		1.20 1.21 1.22 1.24 1.25 1.26 1.27 1.28 1.29 1.30 1.31 1.32 1.33 1.33 1.34 1.35 1.36	. 1823 . 1906 . 1988 . 2070 . 2151 . 2231 . 2390 . 2469 . 2544 . 2700 . 2624 . 2700 . 2624 . 2700 . 2852 . 2927 . 3007 . 3075	1.39 1.40 1.41 1.42 1.43 1.44 1.45 1.46 1.47 1.46 1.47 1.49 1.50 1.51 1.52 1.53 1.53 1.55 1.55	.3293 .3365 .3436 .3597 .3577 .3546 .3716 .3784 .3853 .3920 .3988 .4055 .4187 .4253 .4187 .4253 .4388 .4383	1.58 1.59 1.60 1.61 1.62 1.63 1.64 1.65 1.66 1.67 1.68 1.69 1.70 1.71 1.72 1.73 1.74	-4574 -4637 -4762 -4762 -4824 -4886 -4947 -5068 -5068 -5068 -5128 -5247 -5365 -5365 -5365 -5365 -5365 -5365 -5365 -53881 -5530	1.77 1.78 1.79 1.80 1.81 1.82 1.83 1.84 1.85 1.84 1.85 1.86 1.87 1.86 1.87 1.90 1.91 1.92 1.93	.5710 .5766 .5822 .5878 .5983 .6043 .6098 .6152 .6206 .6259 .6313 .6366 .6471 .6523 .6575 .6575
1.18	.1055	1.37	.3148	1.50	.4511	1.76	.5653	1.95	.6678

HYPERBOLIC LOGARITHMS.

HYPERBOLIC LOGARITHMS.

No.	Log.	No.	Log.	No.	Log.	No.	Log.	No.	Log.
1.06	.6720	2.66	.9783	3.36	1.2119	4.06	1.4012	4.76	1.5602
1.97	.6780	2.67	.9821	3.37	1.2149	4.07	1.4036	4.77	1.5623
1.98	.6831	2.68	.9858	3.38	1.2179	4.08	1.4001	4.78	1.5644
1.99	.0881	2.09	.9895	3.39	1.2200	4.09	1.4005	4.79	1.5005
2.00	.6081	2.71	.0060	3.40	1.2267	4.11	1.4134	4.81	1.5707
2.02	.7031	2.72	1.0006	3.42	1.2296	4.12	1.4159	4.82	1.5728
2.03	. 7080	2.73	1.0043	3.43	1.2326	4.13	1.4183	4.83	1.5748
2.04	.7129	2.74	1.0080	3.44	1.2355	4.14	1.4207	4.84	1.5709
2.05	.7170	2.75	1.0110	3.45	1.2304	4.15	1.4255	4.86	1.5810
2.07	.7275	2.77	1.0188	3.47	1.2442	4.17	1.4279	4.87	1.5831
2.08	.7324	2.78	1.0225	3.48	1.2470	4.18	1.4303	4.88	1.5851
2.09	·7372	2.79	1.0200	3.49	1.2499	4.19	1.4327	4.89	1.5872
2.10	.7419	2.80	1.0290	3.50	1.2520	4.20	1.4351	4.90	1.5092
2.12	.7514	2.82	1.0367	3.52	1.2585	4.22	1.4308	4.92	1.5033
2.13	.7561	2.83	1.0403	3.53	1.2613	4.23	1.4422	4.93	1.5953
2.14	.7608	* 2.84	1.0438	3.54	1.2641	4.24	1.4446	4.94	1.5974
2.15	.7655	2.85	1.0473	3.55	1.2669	4.25	1.4469	4.95	1.5994
2.10	.7701	2.80	1.0500	3.50	1.2000	4.20	1.4493	4.90	1.0014
2.17	.7747	2.87	1.0578	3.58	1.2754	4.27	1.4540	4.08	1.6054
2.10	.7830	2.89	1.0613	3.59	1.2782	4.29	1.4563	4.99	1.6074
2.20	.7885	2.90	1.0647	3.60	1.2809	4.30	1.4586	5.00	1.6094
2.21	•7930	2.91	1.0682	3.61	1.2837	4.31	1.4609	5.01	1.6114
2.22	·~975	2 92	1.0710	3.02	1.2805	4.32	1.4033	5.02	1.0134
2.23	.8020	2.93	1.0750	3.03	1.2092	4.33	1.4050	5.04	1.6174
2.25	.8100	2.05	1.0513	3.65	1.2047	4.35	1.4702	5.05	1.6194
2.26	.8154	2.96	1.0852	3.66	1.2975	4.36	1.4725	5.00	1.6214
2.27	.8198	2.97	1.0886	3.67	1.3002	4.37	1.4748	5.07	τ.6233
2.28	.8242	2.98	1.0919	3.68	1.3020	4.38	1.4770	5.08	1.0253
2.29	.8280	2.99	1.0953	3.09	1.3050	4.39	1.4793	5.00	1.6202
2.31	.8372	3.01	1.1010	3.71	1.3110	4.41	1.4830	5.11	1.6312
2.32	.8416	3.02	1.1053	3.72	1.3137	4.42	1.4861	5.12	1.6332
2.33	.8458	3.03	1.1086	3.73	1.3164	4.43	1.4884	5.13	1.6351
2.34	.8502	3.04	1.1119	3.74	1.3191	4.44	1.4907	5.14	1.0371
2.35	.0544	3.05	1.1151	3.75	1.3210	4.45	1.4929	5.15	1.6400
2.37	.8620	3.07	1.1217	3.77	1,3271	4.47	1.4974	5.17	1.6420
2.38	.8671	3.08	1.1249	3.78	1.3297	4.48	1.4996	5.18	1.6448
2.39	.8713	3.09	1.1282	3.79	1.3324	4.49	1.5019	5.19	1.6467
2.40	·8755	3.10	1.1314	3.80	1.3350	4.50	1.5041	5.20	1.0487
2.41	.0790	3.11	1.1340	3.82	1.3370	4.51	1.5003	5.22	1.6525
2.43	.8879	3.13	1.1410	3.83	1.3429	4.53	1.5107	5.23	1.6514
2.44	.8920	3.14	1.1442	3.84	1.3455	4.54	1.5129	5.24	1.6563
2.45	.8961	3.15	1.1474	3.85	1.3481	4.55	1:5151	5.25	1.6:82
2.40	.9002	3.10	1.1500	3.80	1.3507	4.50	1.5173	5.20	1.0001
2.47	.9042	3.17	1.1537	3.88	1.3558	4.57	1.5195	5.28	1.6630
2.40	.9123	3.10	1.1600	3.89	1.3584	4.59	1.5230	5.29	1.6658
2.50	.9163	3.20	1.1632	3.90	1.3610	4.60	1.5261	5.30	1.6677
2.51	.9203	3.21	1.1663	3.91	1.3635	4.61	1.5282	5.31	1.6696
2.52	•9243	3.22	1.1094	3.92	1.3001	4.02	1.5304	5.32	1.0715
2.53	.9202	3.23	1.1745	3.93	1.3000	4.03	1.5320	5.33	1.6752
2.55	.9361	3.25	1.1787	3.95	1.3737	4.65	1.5360	5.35	1.6771
2.56	.9400	3.26	1.1817	3.96	1.3762	4.66	1.5390	5.36	1.6790
2.57	·9439	3.27	1.1848	3.97	1.3788	4.67	1.5412	5.37	1.6808
2.58	•9478	3.28	1.1878	3.98	1.3813	4.08	1.5433	5.38	1.0827
2.59	.0517	3.2)	1.1909	3.99	1.3030	4.09	1.5454	5.39	1.6864
2.61	.0594	3.31	1.1060	4.01	1.3888	4.71	1.5407	5.41	1.6882
2.62	.9632	3.32	1.1999	4.02	1.3913	4.72	1.5518	5.42	1.6901
2.63	.9670	3.33	1.2030	4.03	1.3938	4.73	1.5539	5.43	1.6919
2.04	•9708	3.34	I 2000	4.04	1.3902	4.74	1.5500	5.44	1.0938
4.05	9/40	5.55	1.2040	4.04	1.4907	4.13	1.2201	. 3.43	1.0930

			and the second se						
No.	Log.	No.	Log.	No.	Log.	No.	Log.	No.	Log.
5.46	1.6974	6.16	1.8181	6 86	1.9257	7.56	2.0220	8.22	2 118=
5.47	1.6993	6.17	1.8197	6.87	1.9272	7.57	2.0242	8.34	2.1211
5.48	1.7011	6.18	1.8213	6.88	1.9286	7.58	2.0255	8.36	2.1235
5.49	1.7029	0.19	1.8220	6.89	1.9301	7.59	2.0268	8.38	2.1258
5.50	1.7047	6.20	1.0245	6.90	1.9315	7.00	2.0281	8.40	2.1282
5.52	1 1.7084	6.22	1.8278	6.02	1.0344	7.62	2.0295	8.42	2.1306
5.53	1.7102	6.23	1.8204	6.03	1.0350	7.63	2.0321	8.46	2.1330
5.54	1.7120	6.24	1.8310	6.94	1.9373	7.64	2.0334	8.48	2.1353
5.55	1.7138	6.25	1.8326	6.95	1.9387	7.65	2.0347	8.50	2.1401
5.50	1.7150	6.20	1.8342	6.96	1.9402	7.66	2.0360	8.52	2.1424
5.57	1.7174	0.27	1.8358	0.97	1.9416	7.07	2.0373	8.54	2.1448
5.50	1.7210	6.20	1.8200	6.00	1.9430	7.00	2.0300	8.50	2.1471
5.60	1.7228	6.30	1.8405	7.00	1.9445	7.70	2.0399	8.60	2.1494
5.61	1.7246	6.31	1.8421	7.01	1.9473	7.71	2.0425	8.62	2.1541
5.62	1.7263	6.32	1.8437	7.02	1.9488	7.72	2.0438	8.64	2.1564
5.63	1.7281	6.33	1.8453	7.03	1.9502	7.73	2.0451	8.66	2.1587
5.04	1.7299	0.34	1.8469	7.04	1.9516	7.74	2.0464	8.68	2.1610
5.05	1.7317	0.35	1.0405	7.05	1.9530	7.75	2.0477	8.70	2.1633
5.67	1.7252	6 37	1.8516	7.00	1.0550	7.70	2.0490	8.74	2.1050
5.68	1.7370	6.38	1.8532	7.08	1.0573	7.78	2.0516	8.76	2.1079
5.69	1.7387	6.39	1.8547	7.09	1.9587	7.79	2.0528	8 78	2.1725
5.70	1 7405	6.40	1.8563	7.10	1.9601	7.80	2.0541	8.80	2.1748
5.71	1.7422	6.41	1.8579	7.11	1.9615	7.81	2.0554	8.82	2.1770
5.72	1.7440	0.42	1.8594	7.12	1.9629	7.82	2.0567	8 84	2.1793
5.73	1.7457	6.43	1.8010	7.13	1.9043	7.03	2.0580	8.80	2.1815
5.75	1.7402	6.45	1.8641	7.15	1.0671	7.85	2.0592	8.00	2.1030
5.76	1.7509	6.46	1.8656	7.16	1.0585	7.86	2.0618	8.02	2.1882
5.77	1.7527	6.47	1.8672	7.17	1.9699	7.87	2.0631	8.94	2.1005
5.78	1.7544	6.48	1.8687	7.18	1.9713	7.88	2.0643	8.96	2.1928
5.79	1.7561	6.49	1.8703	7.19	1.9727	7.89	2.0656	8.98	2.1950
5.80	1.7579	0.50 6 cr	1.0718	7.20	1.9741	7.90	2,0009	9.00	2.1972
5.82	1.7613	6.52	1.8740	7.22	1.0760	7.02	2.0604	9.04	2.1994
5.83	1.7630	6.53	1.8764	7.23	1.9782	7.93	2.0707	0.06	2,2030
5.84	1.7647	6.54	1.8779	7.24	1.9796	7.94	2.0719	9.08	2.2061
5.85	1.7664	6.55	1.8795	7.25	1.9810	7.95	2.0732	9.10	2.208;
5.86	1.7681	6.56	1.8810	7 26	1.9824	7.96	2.0744	9.12	2.2105
5.87	1.7099	0.57	1.0825	7.27	1.9838	7.97	2.0757	9.14	2.2127
5.00	1.7710	6 50	1.0040	7.20	1.9851	7.90	2.0782	9.10	2.2140
5.00	1.7750	6.60	1.8871	7.30	1.0870	8.00	2.0704	9.20	2.2102
5.91	1.7766	6.61	1.8886	7.31	1.9892	8.01	2.0807	9.22	2.2214
5.92	1.7783	6.62	1.8901	7.32	1.9906	8.02	2.0819	9.24	2.2235
5.93	1.7800	6.63	1.8916	7.33	1.9920	8.03	2.0832	9.26	2.2257
5.94	1.7817	0.04	1.8931	7.34	1.9933	8.04	2.0844	9.28	2.2279
5.95	1.7034	6.65	1.0040	7.35	1.9947	8.05	2 0860	9.30	2.2300
5.90	1.7867	6.67	1.8076	7.30	1.0074	8.07	2.0882	0.34	2.2343
5.98	1.7884	6,68	1.8901	7.38	1.9988	8.08	2.0894	9.36	2.2.64
5.99	1.7901	6.69	1.9006	7.39	2,0001	8.09	2.0906	9.38	2.2386
6.00	1.7918	6.70	1.9021	7.40	2,0015	8.10	2.0919	9.40	2.2407
6.01	1.7934	0.71	1.9030	7.4I	2.0028	8.11	2.0931	9.42	2.2428
6.02	1.7951	0.72	1.9051	7.42	2.0041	8 12	2.0043	9.44	2.2450
6.04	1.7084	6 74	1.9000	7.43	2.0055	8.14	2.0068	9.48	2.2402
6.05	1.8001	6.75	1.9005	7.45	2.0082	8.15	2.0980	9.50	2.2513
6.06	1.8017	6.76	1.9110	7.46	2.0096	8.16	2.0992	9.52	2.2534
6.07	1.8034	6.77	1.9125	7 • 47	2.0108	8.17	2.1005	9.54	2.2555
6.08	1.8050	6.78	1.9140	7.48	2.0122	8,18	2.1017	9.50	2.2576
0.09	1.8000	6.79	1.9155	7.49	2 0130	8.19	2.1029	9.50	2.2597
6.11	1.80003	6.87	1.0184	7.50	2.0149	8.22	2.1066	9.62	2.2638
6.12	1.8116	6.82	1.0100	7.52	2.0176	8.24	2.1090	9 64	2.2659
6.13	1.8132	6.83	1.9213	7.53	2.0189	8.26	2.1114	9.66	2.2680
6.14	1.8148	6.84	1.9228	7.54	2.0202	8.28	2.1138	9.68	2.2701
6.15	1.8165	6.85	1 9242	7.55	2.0215	8.30	2.1103	9.70	2.2721

No.	Log.	No.	Log.	No.	Log.	No.	Log.	No.	Log.
9.72	2.2742	10.25	2.3279	14.00	2.6391	21	3.0445	36	3.5835
9.74	2.2762	10.50	2.3513	14.25	2.6567	22	3.0010	37	3.6100
0.76	2.2783	10.75	2.3749	14.50	2.6740	23	3.1355	38	3.6376
9.78	2.2803	11.00	2.3979	14.75	2.6913	24	3.1781	39	3.6636
0.80	2.2824	11.25	2.4201	15.00	2.7081	25	3.2189	40	3.6889
9.82	2.2844	11.50	2.4430	15.50	2.7408	26	3.2581	41	3.7136
9.84	2.2865	11.75	2.4636	16.00	2.7726	27	3.2958	42	3.7377
9.86	2.2885	12.00	2.4849	16.50	2.8034	28	3.3322	43	3 7612
9.88	2.2905	12.25	2.5052	17.00	2.8332	29	3.3673	44	3.7842
9.90	2.2925	12.50	2.5262	17.50	2.8621	30	3.4012	45	3.8067
9.92	2.2946	12.75	2.5455	18.00	2.8904	31	3.4340	46	3.8286
9.94	2.2966	13.00	2.5649	18.50	2.9173	. 32	3.4657	47	3.8501
9.96	2.2986	13.25	2.5840	19.00	2.9444	33	3.4965	48	3.8712
9.98	2.3006	13.50	2.6027	19.50	2.9703	34	3.5263	49	3.8918
10.00	2.3026	13.75	2.6211	20.00	2.9957	35	3.5553	50	3.9120

#### HYPERBOLIC LOGARITHMS.

#### 351. HISTORICAL BIBLIOGRAPHY.

1798.	Sir Benjamin Thompson, Count Rumford. Inquiry concern	ing
	the Source of Heat which is excited by Friction. Royal Soci	ety
	of England, January, 1798.	
	Sir Humphry Down Manair on Heat light and the Combi	na-

- 1799. Sir Humphry Davy. Memoir on Heat, Light, and the Combinations of Light. Works, Vol. II.
- 1824. Nicholas Leonard Sadi Carnot. Réflexions sur la puissance motrice du feu. Also, Mémoire sur la puissance motrice de la chaleur. Journal de l'Ecole Polytech. 1834, Vol. 14, p. 170, and Poggendorff's Annalen, Vol. 59, p. 446.
- 1842. Julius Robert Mayer. Bemerkungen über die Kräfte der unbelebten Natur. Bemerkungen über das mechanische Aequivalent der Wärme (1857). Die Mechanik der Wärme (1867).
- 1843. James Prescott Joule. Memoir before the British Association. Phil. Maga., Vol. 23, p. 435.
- 1847. Hermann Ludwig Ferdinand Helmholtz. Ueber die Erhaltung der Kraft. Berlin.
- 1847. Henri Victor Regnault. Mémoires de l'Académie des Sciences, vols.
   21 and 26. Also, Comptes Rendus, 1854. Also, Mémoires de l'Institut de France, vol. 26.
- 1849. Sir William Thomson (Lord Kelvin, 1892). Account of Carnot's Theory of the Motive Power of Heat. Trans. Royal Soc. of Edinburgh, vol. 16. Also Math. and Phys. Papers, vol. 41, p. 113. Second paper (1851), amended. Trans. Royal Soc. Ed., vol. 20, p. 261.
- 1850. William J. Macquorn Rankine. First Paper on Molecular Vortices and a Mechanical Theory of Heat. Trans. Royal Soc. of Ed. (February), vol. 20, p. 147. Reprinted 1854, Phil. Maga. Series 4, Vol. 7. Second paper April, 1851.
- 1850. Rudolph Julius Emanuel Clausius. Ueber die mechanische Wärmetheorie. Berlin Academy (February). Poggendorff's Annalen, Band 79, March and April.

- 1858. Gustave Adolphe Hirn. Recherches sur l'équivalent mécanique de la chaleur. Paris.
- 1859. W. J. M. Rankine. Steam-engine and Other Prime Movers. Glasgow.
- 1859. Gustav Zeuner. Grundzüge der Mechanischen Wärmetheorie, 1859, second edition, 1866.

- 1360. J. E. C. Peclet. Traité de la chaleur. Paris.
- 1864. John Tyndall. Heat considered as a Mode of Motion.
- 1867. Sir William Thomson and Peter Guthrie Tait. Treatise on Natural Philosophy. Second edition, 1879.
- 1867. Rudolph Clausius. Ueber den zweiten Hauptsatz der Mechanischen Wärmetheorie. Braunschweig. On the Mechanical Theory of Heat. Bonn, 1875. Translated by Walter A. Browne, 1879.
- 1867. G. A. Hirn. Exposition analytique et expérimentale de la Théorie mecanique de la chaleur. Comptes Rendus de l'Academie de France. July.
- 1868. E. Verdet. Theorie Mécanique de la chaleur. Paris.
- 1870-78. Willard Gibbs. Equilibrium of a Heterogeneous System. Trans-Conn. Acad. of Sci.
- 1874. William Pettit Trowbridge. Heat as a Source of Power. New York.
- 1879-80. Henry A. Rowland. On the Mechanical Equivalent of Heat. Proc. Am. Acad. Arts and Sci., vol. 15, N.S. 7.
- 1888. Jas. Clerk Maxwell. Theory of Heat.

### 352. GENERAL BIBLIOGRAPHY.

COMTE DE PAMBOUR, 1835-39. Theory of the Locomotive; Theory of the R. V. DIXON, 1849. Treatise on Heat. Steam-engine. M. CAZIN. 1868. Laws of Heat. THOMAS BOX, London, 1868. Practical Treatise on Heat. BALFOUR STEWART, 1871. Elementary Treatise on Heat. R. S. MCCULLOUGH, 1876. Mechanical Theory of Heat. GUSTAV HERMANN, Aix-la-Chapelle, 1884. Die Graphische Behandlung der Mechanischen Wärmetheorie. P. G. TAIT, London, 1884. Heat. WILLIAM ANDERSON, London, 1887. Conversion of Heat into Work. ROBERT RÖNTGEN-A. JAY DU BOIS, Remscheid, New York, 1888. The-JAMES H. COTTERILL, London, 1890 .-Principles of Thermodynamics. The Steam-engine considered as a Thermodynamic Machine. DE VOLSON WOOD, New York, 1891. Thermodynamics, Heat Motors and Re-CECIL H. PEABODY, Boston, 1892. Thermo-frigerating Machines. dynamics of the Steam-engine and Other Heat Engines. J. A. Ewing,. Cambridge, England, 1894. The Steam-engine and Other Heat Engines .. SIDNEY A. REEVE, Worcester, 1897. The Temperature-Entropy Analysis B. F. STURTEVANT-WALTER B. SNOW, of Steam-engine Efficiencies. Boston, 1898. Mechanical Draft. C. WYE WILLIAMS, 1858. Ele-

Technische Thermodynamik, 1887-90.

mentary Treatise on Combustion of Coal and Prevention of Smoke. HERMAN POOLE, New York, 1898. Calorific Power of Fuels. WM. KENT, New York, 1895. Mechanical Engineers' Pocket-book. E. A. BRAYLEY-HODGETTS. Liquid Fuel. DUGALD CLERK, 1896. The Gas and Oil Engine, 1896. GARDNER D. HISCOX, 1898. Gas, Gasoline and Oil Vapor Engines. G. LIECKFIELD, 1896. Practical Handbook on Gas Engines. BRYAN DONKIN, 1896. Gas, Oil, and Air Engines. WILLIAM ROBINSON, 1890. Gas and Petroleum Engines. WÜLLNER. Lehre von der Wärme.

The Transactions of Engineering Societies are also to be referred to in general, but in particular the Bulletin de la Société Industrielle de Mulhouse; the Civil Engineers of Great Britain, and the American Society of Mechanical Engineers.

353. THE NAMES OF DISTINGUISHED SCIENTISTS and investigators (mainly physicists), who have contributed to the present knowledge of heat, group themselves into two classes. The first contains those who have made a specialty of heat, and the second includes those who have studied it in connection with other lines of research. The lists are by no means exhaustive, and include of course some of the writers in the preceding lists.

#### GROUP I.

Balfour-Stewart, Berthelot, Boyle, Charles, Colding, Davy, Dufour, Dulong, Favre, Forbes, Franz, Gay-Lussac, Helmholtz, Hopkins, Joule, Le Chatelier. Leslie, Mahler, Mariotte, Mayer, Melloni, Peclet, Petit, Plank, Playfair, Pouillet, Regnault, Rumford, Silbermann, Tait, Tyndall, Weidemann.

#### GROUP II.

Andrews, Angström, Arago, Béclard, Bérard, Bérnouilli, Bianchi, Black, Bunsen, Cauchy, Clapeyron, Dalton, De Candolle, de la Provostaye, de la Rive, de la Roche, Deluc, Desains, Despretz, Deville, Donny, Dumas, Fairbairn, Faraday, Fizeau, Foucault, Gandin, Grove, Guthrie, Hallström, Hallauer, Hess, Hirn, Kirchoff, Knoblauch, Krönig, Kupffer, Laplace, Lavoisier, Magnus, Mallard, Marcet, Masson, Moll, Mousson, Morin, Neumann, Person, Pictet, Poisson, Prevost, Redtenbacher, Rudberg, Saussure, Séguin, Tate, Thompson, Thomson, Tresca, Troost, Van Beck, Woestyn.

#### 354. NOTES AND REFERENCES.

10. See Heat as a Mode of Motion. John Tyndall, 1864, p. 85, also Joule, Mayer and Rowland in Bibliography.

11. Consult Trans. A. S. M. E., vol. 13, pp. 351-358.

12. Specific Heats. Consult Ganot's Physics, p. 341, also Röntgen-Dubois, *Thermodynamics*, pp. 134-137. Regnault's determinations. Average values, taken between freezing and boiling points. Water being unity.

# Solids.

Antimony	0.05077	Cadmium	0.05670
Copper	0.09515	Steel (soft)	0.11650
Gold	0.03244	Steel (hard)	0.11750
Wrought iron	0.11379	Zinc	0.09555
Glass	0.19768	Brass	0.09391
Cast iron (gray)	0.12983	Ice	0.50400
Lead	0.03140	Sulphur	0.20259
Platinum	0.03244	Charcoal	0.24111
Silver	0.05701	Alumina	0.19700
Tin	0.05623	Phosphorus	0.18949
Cobalt	0.10696	Nickel	0.10863
Mercury	0.03332	Phosphite	0.020107
Bismuth	0.03084	Arsenic	0.08140

# From other sources (Kent).

Brick-work and masonry		Magnesia	0.222
(about)	0,200	Soda	0.231
Marble	0.210	Corundum	0.198
Chalk	0.215	Gypsum	0.197
Quicklime	0.217	Stones generally	0.220
Silica	0.191	Oak wood	0.570
Pine wood	0.467	Pear wood	0.500
Fir wood	0.650		

# LIQUIDS.

Water	·1.0000	Mercury	0.0333
Melted lead	0.0402	Alcohol	0.7000
" sulphur	0.2340	Fusel oil (mixed alcohols)	0.5640
" bismuth	0.0308	Benzine	0.4500
" tin	0.0637	Ether	0.5034
Sulphuric acid	0.3350	Olive oil	0.3100
Hydrochloric acid	0.6000	Turpentine	0.4720
Bromine	1.1110		

# Gases. (See § 107.)

	Pressure Constant.	Volume Constant.
Air	0.23751	0.16847
Oxygen	0.21751	0.15507
Hydrogen	3.40900	2.41226
Nitrogen	0.24380	0.17273
Steam superheated	0.4805	0.346
Carbonic acid	0.217	0.1535
Olefiant gas (CH <sub>2</sub> )	0.404	0.173

	Pressure Constant.	Volume Constant.
Carbonic oxide	0.2479	0.1758
Ammonia	0.508	0.299
Alcohol	0 4534	0.3200
Acetic acid	0.4125	
Chloroform	0.1567	
Ether	0.4797	0.3411
Marsh gas (CH <sub>4</sub> )	0.5929	0.4683
Bisulphide of carbon	0.1570	
Sulphuric acid	0.1553	

Specific heats are greater if higher superior limit is taken than boilingpoint. Specific heat of water is not constant.

> At  $0^{\circ}$  C. = 1.0000 "  $50^{\circ}$  " = 1.0042 "  $100^{\circ}$  " = 1.0132 "  $150^{\circ}$  " = 1.0262 "  $200^{\circ}$  " = 1.0440 "  $230^{\circ}$  " = 1.0568 in F. degrees to equ

14. To convert readings in F. degrees to equivalents in C. degrees

C. = 
$$(F - 32)_{9}^{5}$$
  
F. =  ${}_{5}^{9}C + 32$ 

Care must be taken to observe signs when converting below the freezingpoint.

Réaumur's conversions use  $\frac{4}{3}$  and  $\frac{9}{4}$  respectively. Little used.

16. Joule and Thomson's investigations. Phil. Trans. vol. 144, p. 349, 1854. Rowland's investigations. Proc. Am. Acad., vol. 15 (N. S. 8), p. 75, 1879.

Absolute and Air Thermometer Scales Compared. Centigrade.

Air Thermometer Reads.	Absolute Scale should be	Correct Air Scale Reading by
0	0	0
IO	9.9972	- 0.0028
20	19.9952	- 0.0048
30	29.9939	- 0.006I
40	39.9933	- 0.0067
50	49.9932	- 0.0068
60	59.9937	- 0.0063
70	69.9946	- 0.0054
80	79.9956	- 0.0042
90	89.9978	- 0.0022
100	100.000	+ 0.
200	200.037	+ 0.037
300	300.092	+ 0.092
400	400.157	+ 0.157
500	500.228	+ 0.228

23. See investigations by Scheurer-Kestner and Meunier-Dollfus, Bulletin Soc. Indust. de Mulhouse (1868). Also Mahler's Test of Coals, *Mineral Industry*, vol. I, p. 97.

Consult also :

Barrus, Coal Calorimeter, Trans. A.S.M.E., vol. 14. p. 816. Carpenter " " " 16, p. 1040.

39. For tests of calorimetric power of bagasse see paper by Dr. W. O. Atwater, quoted in Sturtevant *Mechanical Draft*, pp. 39-42. For furnaces, see *ibid.*, pp. 310, 366, 371. Also L. A. Bocuel, Louisiana Sugar Chemists Assoc. 1892.

48-49. Hutton's Mechanical Engineering of Power Plants, pp. 567-573. Also Trans. Inst. Mech. Eng. of Gt. Btn. 1889. See also E. A. Brayley-Hodgetts, Liquid Fuel.

(Iron Age, Nov. 2, 1893.)—Test by the Twin City Rapid Transit Company of Minneapolis and St. Paul. This test showed that with the ordinary Lima oil weighing  $6\frac{4}{10}$  pounds per gallon, and costing  $2\frac{1}{4}$  cents per gallon, and coal that gave an evaporation of  $7\frac{1}{2}$  lbs. of water per pound of coal, the two fuels were equally economical when the price of coal was \$3.85 per ton of 2000 lbs. With the same coal at \$2.00 per ton, the coal was 37% more economical, and with the coal at \$4.85 per ton, the coal was 20% more expensive than the oil. These results include the difference in the cost of handling the coal, ashes, and oil.

In 1892 there were reported to the Engineers' Club of Philadelphia some comparative figures, from tests undertaken to ascertain the relative value of coal, petroleum, and gas :

	and	at 212°	F.
1 lb. anthracite coal evaporated	••	9.70	
I lb. bituminous coal	• • •	10.14	
I lb. free oil, 36° gravity	)	16.48	
I cubic foot gas, 20 C. P	••	1.28	

The gas used was that obtained in the distillation of petroleum, having about the same fuel-value as natural or coal gas of equal candle-power.

Taking the efficiency of bituminous coal as a basis, the calorific energy of petroleum is more than 60% greater than that of coal; whereas, theoretically, petroleum exceeds coal only about 45%—the one containing 14,500 heat-units and the other 21,000.

Crude Petroleum vs. Indiana Block Coal for Steam-raising at the South Chicago Steel Works. (E. C. Potter, Trans. A. I. M. E., xvii., 807.)—With coal, 14 tubular boilers 16 ft.  $\times$  5 ft. required 25 men to operate them; with fuel-oil, 6 men were required, a saving of 19 men at \$2 per day, or \$38 per day.

For one week's work 2731 barrels of oil were used, against 848 tons of coal required for the same work, showing 322 barrels of oil to be equivalent to 1 ton of coal. With oil at 60 cents per barrel and cool at \$2.15 per ton.

Lbs. Water, from

the relative cost of oil to coal is as 1.93 to 2.15. No evaporation tests were made.

50. *Ibid.* See also *Helios*, E. D. Meier, St. Louis, 1895. Also Colliery Engineer, 1889-90, articles by F. T. Rowan. Also D. K. Clark, Treatise on Steam-engine.

52. Producer Gas. See Trans. Am. Inst. Mining Eng., vol. 18, p. 205. W. J. Taylor. Also Kent's Pocket-book, p. 646.

58. See Hoadley, Trials of a Warm-blast Apparatus. Trans. A. S. M. E., vol. 6, p. 676.

59. Helios, E. D. Meier, St. Louis, Mo., 1895.

Kent, Pocket-book.

Sturtevant-Snow, Mechanical Draft, 1898.

Peabody-Miller, Notes on Steam Boilers, 1894.

See also Mineral Industry, Reports U. S. Geolog. Survey.

Commonweath of Pennsylvania. Report of commission appointed to Investigate the Waste of Coal Mining, with a View to Utilizing the Waste, May, 1893.

Furnaces for Burning Small Anthracite Coal, Coxe, Trans. Am. Inst. Mining Eng., vol. 22, 1894.

For effect of frequent firing, see Burnat, Bulletin de la Soc. Industrielle de Mulhouse, vol. 46, 1876. For loss in smoke, see Hoadley Warm-blast Apparatus (note 58) and Scheurer-Kestner and Meunier, Soc. Ind. de Mulhouse for 1868-69.

61. Hoadley, Warm-blast Apparatus (note 58).

A. G. Dursten, Inst. Civil Engineers of Gt. Btn., 1875.

D. K. Clark, Manual of the Steam Engine, London, 1890.

62-68. Consult H. M. Howe. Metallurgy of Steel.

Kent, Engineers' Pocket-book, pp. 448-554.

73-74. Consult Péclet, *Traité de la Chaleur*, 3<sup>e</sup> ed. 1860, p. 217; also W. M. Barr; W. W. Christie.

Wood, T	rans.	A.S. M. E.,	, vol.	II, p. 974.
Webb,		* *	**	11, p. 762.
"	"	**	" "	11, p. 772.
Wood,	" "	" "	"	11, p. 984.
Thurston	ı, ''	" "		12, p. 85.
Gale,	" "	* 4		II, p. 45I.

78. Peabody-Miller, Notes on Steam Boilers, Boston, 1894.

79. Steam. Babcock and Wilcox Co., New York, 1893.

83. Closed Stokeholes. Richard Sennett. Inst. Naval Archts., London, 1886. Steamships and their Machinery. J. W. C. Haldane, London and New York, 1893.

Mechanical Draft, Sturtevant, 1898.

Jas. Howden, On Forced Combustion in Furnaces of Steam Boilers. Trans. Inst. Naval Archts., London, 1886.

86. Mechanical Draft, W. R. Roney. Trans. A. S. M. E., vol. 15. See also Mechanical Engineering of Power Plants, Hutton, pp. 527-535.

88. See Whitham, Effect of Retarders. Trans. A. S. M. E., vol. 17, p. 450, No. 687.

89. See Reports on Smoke Prevention, Journal of Assoc. Engineering Societies, vol. 11, June, 1892, p. 201. See also *Iron Age*, April 7, 1892. Also O. H. Landreth, Report to State Board of Health, of Tennessee. See also *Eng'g News*, June 8, 1893: also Report, March 10, 1888, by C. E. Jones and C. F. White to O. N. Nelson, City Council of Chicago. See also D. R. Clark, Treatise on the Steam-engine; see Bryan, Down-draft Furnace, Trans. A. S. M. E., vol. 16, p. 773.

96. Hutton, Mech. Eng'g of Power Plants, pp. 504 to 636.

102. Hutton, Mech. Eng'g of Power Plants, pp. 680-682. Whitham, Surface Condensers, Trans. A. S. M. E., vol. 9, p. 425. Joule, Jour. Franklin Inst., 1862, p. 36.

Shock, Steam Boilers, p. 58.

Nicol, Engineering of London, vol. 20, 1875, p. 449.

124. The entropy equation for a medium such as all perfect gases can be reached by an interesting and easy process. If the exponent n be the

ratio between the specific heats or  $n = \frac{C_{p}}{C_{n}}$  we may write,

$$p_1 v_1^n = p_2 v_2^n,$$

$$(p_1 v_1)^{\overline{C_v}} = (p_2 v_2)^{\overline{C_v}},$$

$$\left(\frac{v_2}{v_1}\right)^{\overline{C_v}} = \left(\frac{p_1}{p_2}\right)^{\overline{C_v}},$$

$$C_p \text{ hyp. } \log \frac{v_2}{v_1} = C_v \text{ hyp. } \log \frac{p_1}{p_2}.$$

12

But the sum of these is the entropy, and for adiabatic expansion the entropy is constant or their difference is zero; as the equation shows.

Confusion is likely to follow an attempt to view the entropy-factor as a property of a heat medium. It is so only in the sense that  $\pi$  is a property of the area of the circle, when written to  $\pi r^3$ .

156. For high-speed vs. low-speed, see Mech. Eng'g of Power Plants, chap. 3.

195-205. For references on temperature-entropy, consult :

Belpaire, Thos.: Bulletin de l'académie royale de Belgique, vol. 34, 1872-Gibbs, F. Willard: Graphical Methods in the Thermodynamics of Fluids,

Trans. Conn. Acad. Arts and Sci., vol. 2, Part 2, p. 309, 1873.

Linde, Carl: Theorie der Kalte-Erzeugensmaschinen, 1875.

Schroedter, M.: Zeitschrift des Vereines Deutsch. Ingen., 1883.

Hermann, Gust: Die graphische Behandlung der mechan. Wärmetheorie. 1884.

Gray, J. MacFarlane: Inst. Mech. Eng'rs of Gt. Btn., 1889, and Rationalization of Regnault's Expts., 1890.

Boulvin, J.: Cours de Mécanique appliquée aux Machines, 3d part, 1893; also Translation by Bryan Donkin.

Cotterill, Jas. H.: Steam-engine Considered as a Thermodynamic Machine, 1890.

Ewing, J. A.: Steam-engine and other Heat-engines, 1894.

Willans, P. W.: Steam-engine Trials, Inst. C. E. of Gt. Btn., April 1893. Reeve, Sidney A.: Entropy-temperature Analysis of Steam-engine Efficiencies, 1897; also Theta-phi Diagram by N. A. Golding.

195-205. Geo. Richmond: Trans. Am. Soc. Mech. Engrs., vol. 14, p. 183, and vol. 19, p. 477; also Eng. Soc. of Columbia Univ., 1896-97.

180. For Compressed Air and Compressors, consult:

Pernolet, Peabody, Wood, Drinker on Tunneling, Röntgen, Wm. L. Saunders, Production of Compressed Air.

224. See Thurston, Trans. A. S. M. E., vol. 18, p. 160, No. 710. Promise and Potency of High-pressure Steam, from which the diagrams are reproduced by permission.

225. For Steam-jacket, see Trials of Steam Machinery U. S. Revenue Steamers Rush, Dexter, and Dallas, U. S. Treasury Dept., Nov. 1874, by C. H. Loring and C. E. Emery; also Tests of U. S. S. Gallatin, Dec. 1874 and Jan. 1875; also paper on Cylinder Condensation and Superheating, Soc. of Arts, Mass. Inst. Tech., April 1875, by Geo. B. Dixwell; also Thurston, Trans. A. S. M. E., vol. 15, p. 779, No. 590, and vol. 17, p. 488, No. 689.

228. Non-conducting cylinder linings, Novelty Iron Works experiments, 1864-68, C. E. Emery, Trans. A. S. M. E., vol. 7, p. 375, No. 204. Also vol. 1, p. 185.

229. For Superheating, see Isherwood, Experimental Researches, vol. 2; experiments on U. S. S. Mackinaw, Eutaw, and Georgeanna; also Thurston, Trans. A. S. M. E. Also M. G. Leloutre, Comptes Rendus de l'Académie de France, Dec. 21, 1891, and Soc. des Ingenieurs Civils de France, Jan. 8, 1892.

242. For Hirn's Analysis, see Hirn, Théorie Mécanique de la Chaleur, 1876. Also Hallauer, Bulletin de la Soc. Indust. de Mulhouse, vols. 47 to 53, 1877-1883. Also Peabody, chap. 17, Thermodynamics of the Steam Engine. Also Dwelshauvers-Déry, Revue Universelle des Mines, vol. 8, 1880, p. 362.

247. For Reeve's Temperature-entropy Chart, see Sidney A. Reeve: Entropy-temperature Analysis of Steam Engine Efficiencies, Progressive Age Pub. Co., New York, 1897.

250. For compressed-air engines, see Pernolet, Air Comprimé Röntgen-Dubois.

266. For hot-air engines, see Rankine, Steam Engine, § 270 to 278. Röntgen-Dubois; Ewing; also John Bourne, Examples of Steam Gas and

Air Engines, 1878. Also Bryan-Donkin Text-book of Gas, Oil, and Air Engines.

280-303. For Gas and Oil Engine, consult Clerk, Donkin, Robinson, Hiscox. See also School of Mines Quarterly, January 1897: Eng'g News, April 8, 1897, p. 218.

For Diesel Moter, see Jour. Frank. Inst., October 1898; also Zeitschrift des Vereines Deutscher Ingenieure, June 16, 1897, Trans. in Progressive Age, Jan. and Feb. 1898.

305. For Vapor Engines, consult

Van Nostrand, Eclectic Eng'g Maga. Nov. 1884, for paper by Gantt and Maury: rewritten 1890 by De Volson Wood, Trans. A. S. M. E., vol. 12, p. 155, No. 420; see also vol. 10, pp. 648 and 670, No. 343, 344: Substitutes for Steam, Babcock, Trans. A. S. M. E., vol. 7, p. 680, No. 220.

315. For Wellington Series Engine, consult Engineering News, April 8, 1897; p. 210: also p. 217, 394.

317. For Combined Vapor engines consult Rankine, Steam Engine, § 300. 325 et seq. On Refrigeration, consult

Ice-making Machines, by M. Ledoux, translated by J. E. Denton, D. S. Jacobus and Adam Riesenberger, 1897.

Trans. A. S. M. E. as follows:

Denton, Performance of 35-ton Absorption Machine, vol. 10, p. 792.

" of 75-ton Compression Machine, vol. 12, p. 326.

Wood, Mech. and Phys. Properties of SO<sub>2</sub>, vol. 12, p. 137.

" Some Properties of Ammonia, vol. 10, p. 627, vol. 11, p. 133.

" Test of a Refrig. Plant, vol. 11, p. 830.

Richmond, Note on Refrig. Process, vol. 14, p. 183.

Linde, Refrig. Machine of To-day, vol. 14, p. 1414.

340. For Injector, see

Strickland L. Kneass, Theory and Practice of the Injector, also Trans. A. S. M. E. as follows :

Webb, J. B., vol. 10, pp. 339, 888.

Peabody, C. H., vol. 11, p. 187.

See also Röntgen-Dubois, chap. 22, p. 531 : also Wood, Thermodynamics, p. 279 ; also Peabody, Thermodynamics, chap. 10, p. 145.

344. Flow of Steam in Pipes. A formula which has had some acceptance was published by Babcock and Wilcox in their catalogue "Steam." If Wbe the weight of steam in pounds, with a weight per cubic foot, D at an initial pressure p, then the loss of pressure from the resistance of a pipe of diameter d and of length L will result in a final pressure  $p_2$  at the farther end of the pipe. The loss of pressure can be assumed and the diameter calculated, or the diameter assumed and the loss calculated. The formula is:

$$W = 300 \sqrt{\frac{D(p_1 - p_2)d^5}{L\left(1 + \frac{3 \cdot 6}{d}\right)}}$$

The following table calculated by this formula for a length L = 240 dand a loss of pressure of one pound (or  $p_1 - p_2 = 1$ ) is quoted from the same source:

	Di	ameter of I	Pipe in Incl	nes. Lengt	h of each =	= 240 diame	ters.
Initial Pressur- by Gauge. Pounds per Square Inch.	3⁄4	I	11/2	2	21/3	3	4
	Weight	of Steam pe	er minute ir	n pounds, w	ith one pou	and loss of	pressure.
. I	1.16	2.07	5.7	10. <b>27</b>	15.45	25.38	46.85
10	1.44	2.57	7.I	12.72	19.15	31.45	58.05
20	1.70	3.02	8.3	14.94	22.49	36.94	68.20
30	1.91	3.40	9.4	16.84	25.35	41.63	76.84
40	2.10	3.74	10.3	18.61	27.87	45.77	84 49
50	2.27	4.04	11.2	20.01	30.13	49.48	91.34
60	2.43	4.32	11.9	21.38	32.19	52.87	97.60
70	2.57	4.58	12.6	22.65	34.10	56.00	103.37
80	2.71	4.82	13.3	23.82	35.87	58.91	108.74
90	2.83	5.04	13.9	24.92	37.52	61.62	113.74
100	2.95	5.25	14.5	25.90	39.07	64.18	118.47
120	3.10	5.03	15.5	27.85	41.93	68.87	127.12
150	3-45	0.14	17.0	30.37	45.72	75.09	138.01
	Diameter of Pipe in Inches. Length of each = 240 diameters.						
	Dia	ameter of P	ipe in Inch	es. Lengtl	n of each ==	240 diamet	ers.
Initial Pressure by Gauge. Pounds per Square Inch.	Dia 5	ameter of P	ipe in Inch 8	es. Lengtl	n of each $=$	240 diamet	ers. 18
Initial Pressure by Gauge. Pounds per Square Inch.	bia 5 Weight of	ameter of P 6 of Steam pe	ipe in Inch 8 er minute in	es. Lengtl 10 2 pounds, w	n of each =	240 diamet 15 und loss of	ers. 18 pressure.
Initial Pressur by Gauge. Pounds per Square Inch.	5 Weight 6	of Steam pe	ipe in Inch 8 er minute in	es. Lengtl	n of each $=$ 12 with one por	15 und loss of	ers. 18 pressure.
Initial Pressur by Gauge. Pounds per Square Inch.	5 Weight 0 77.3	of Steam pe	er minute in 211.4	es. Lengtl 10 2 pounds, w 341.1	n of each = 12 with one point 502.4 622.5	240 diamet 15 und loss of 804	ers. 18 pressure. 1177 1458
Initial Pressur by Gauge. Pounds per Square Inch. I IO 20	Dia 5 Weight 4 77 · 3 95.8 112.6	ameter of P 6 of Steam po 115.9 143.6 168.7	ipe in Inch 8 er minute in 211.4 262.0 307.8	es. Lengtl 10 2 pounds, w 341.1 422.7 406.5	$502.4 \\ 622.5 \\ 731.3 \\ $	240 diamet 15 und loss of 804 996	ers. 18 pressure. 1177 1458 1713
Initial Pressur by Gauge. Pounds per Square Inch. I I 20 30	Dia 5 Weight 0 77.3 95.8 112.6 126.0	ameter of P 6 of Steam po 115.9 143.6 168.7 190.1	ipe in Inch 8 er minute in 211.4 262.0 307.8 346.8	es. Lengtl 10 2 pounds, w 341.1 422.7 496.5 550.5	$502.4 \\ 622.5 \\ 731.3 \\ 821.1 \\ 12$	240 diamet 15 und loss of 804 996 1170 1318	ers. 18 pressure. 1177 1458 1713 1030
Initial Pressure by Gauge. Pounds per Square Inch. I IO 20 30 40	Dia 5 Weight ( 77.3 95.8 112.6 126.9 130.5	ameter of P 6 of Steam po 115.9 143.6 168.7 190.1 200.0	ipe in Inch 8 211.4 262.0 307.8 346.8 381.3	es. Lengtl 10 3 pounds, w 341.1 422.7 496.5 559.5 615.3	n of each = 12 yith one por 502.4 622.5 731.3 824.1 006.0	240 diamet 15 und loss of 804 996 1170 1318 1450	ers. 18 pressure. 1177 1458 1713 1930 2122
Initial Pressur by Gauge. Pounds per Square Inch. I IO 20 30 40 50	Dia 5 Weight 0 77.3 95.8 112.6 126.9 139.5 150.8	ameter of P 6 of Steam pe 143.6 168.7 190.1 209.0 226.0	ipe in Inch 8 211.4 262.0 307.8 346.8 381.3 412.2	es. Lengtl 10 10 10 10 10 10 10 10 10 10	n of each == 12 7ith one por 502.4 622.5 731.3 824.1 906.0 979.5	240 diamet 15 und loss of 804 996 1170 1318 1450 1567	ers. 18 pressure. 1177 1458 1713 1930 2122 2294
Initial Pressur by Gauge. Pounds per Square Inch. I IO 20 30 40 50 60	Dia 5 Weight 0 77.3 95.8 112.6 126.9 139.5 150.8 161.1	ameter of P 6 of Steam pe 143.6 168.7 190.1 209.0 226.0 241.5	ipe in Inch 8 211.4 262.0 307.8 346.8 381.3 412.2 440.5	es. Lengtl 10 10 10 10 10 10 10 10 10 10	n of each == 12 7ith one por 502.4 622.5 731.3 824.1 906.0 979.5 1046.7	240 diamet 15 und loss of 804 996 1170 1318 1450 1567 1675	ers. 18 pressure. 1177 1458 1713 1930 2122 2294 2451
Initial Pressur by Gauge. Pounds per Square Inch. I IO 20 30 40 50 60 70	Dia 5 Weight 0 77 · 3 95 · 8 112 · 6 126 · 9 139 · 5 150 · 8 161 · 1 170 · 7	ameter of P 6 of Steam pe 143.6 168.7 190.1 209.0 226.0 241.5 255.8	ipe in Inch 8 211.4 262.0 307.8 346.8 381.3 412.2 440.5 466.5	es. Lengtl 10 10 10 10 10 10 10 10 10 10	n of each == 12 vith one por 502.4 622.5 731.3 824.1 906.0 979.5 1046.7 1108.5	240 diamet 15 und loss of 804 996 1170 1318 1450 1567 1675 1774	ers. 18 pressure. 1177 1458 1713 1930 2122 2294 2451 2596
Initial Pressur by Gauge. Pounds per Square Inch. I IO 20 30 40 50 60 70 80	Dia 5 Weight 0 77.3 95.8 112.6 126.9 139.5 150.8 161.1 170.7 179.5	ameter of P 6 of Steam po 143.6 168.7 190.1 209.0 226.0 241.5 255.8 269.0	ipe in Inch 8 211.4 262.0 307.8 346.8 381.3 412.2 440.5 466.5	es. Lengtl 10 10 10 10 10 10 10 10 10 10	n of each == 12 12 12 12 12 12 12 12 502.4 622.5 731.3 824.1 906.0 979.5 1046.7 1108.5 1166.1	804 996 1170 1318 1450 1567 1675 1774 1866	ers. 18 pressure. 1177 1458 1713 1930 2122 2294 2451 2596 2731
Initial Pressur by Gauge. Pounds per Square Inch. I IO 20 30 40 50 60 70 80 90	Dia 5 Weight 0 77.3 95.8 112.6 126.9 139.5 150.8 161.1 170.7 179.5 187.8	ameter of P 6 of Steam po 143.6 168.7 190.1 209.0 226.0 241.5 255.8 269.0 281.4	ipe in Inch 8 211.4 262.0 307.8 346.8 381.3 412.2 440.5 466.5 490.7 513.3	es. Lengtl 10 3 pounds, w 341.1 422.7 496.5 559.5 615.3 665.0 710.6 752.7 791.7 828.1	12 $12$ $502.4$ $622.5$ $731.3$ $824.1$ $906.0$ $979.5$ $1046.7$ $1108.5$ $1166.1$ $1219.8$	240 diamet 15 und loss of 804 996 1170 1318 1450 1567 1675 1774 1866 1951	ers. 18 pressure. 1177 1458 1713 1930 2122 2294 2451 2596 2731 2856
Initial Pressur by Gauge. Pounds per Square Inch. I IO 20 30 40 50 60 70 80 90 IOO	Dia 5 Weight 0 77.3 95.8 112.6 126.9 139.5 150.8 161.1 170.7 179.5 187.8 195.6	ameter of P 6 of Steam pe 143.6 168.7 190.1 209.0 226.0 241.5 255.8 269.0 281.4 293.1	ipe in Inch 8 211.4 262.0 307.8 346.8 381.3 412.2 440.5 466.5 490.7 513.3 534.6	es. Lengtl 10 341.1 422.7 496.5 559.5 615.3 665.0 710.6 752.7 791.7 862.6	n of each == 12 502.4 622.5 731.3 824.1 906.0 979.5 1046.7 1108.5 1166.1 1219.8 1270.1	240 diamet 15 und loss of 804 996 1170 1318 1450 1567 1675 1774 1866 1951 2032	ers. 18 pressure. 1177 1458 1713 1930 2122 2294 2451 2596 2731 2856 2975
Initial Pressur by Gauge. Pounds per Square Inch. I IO 20 30 40 50 60 70 80 90 100 120	Dia 5 Weight 0 77.3 95.8 112.6 126.9 139.5 150.8 161.1 170.7 179.5 187.8 195.6 209.9	ameter of P 6 of Steam pe 143.6 168.7 190.1 209.0 241.5 255.8 269.0 281.4 293.1 314.5	ipe in Inch 8 211.4 262.0 307.8 346.8 381.3 412.2 440.5 466.5 490.7 513.3 534.6 573.7	es. Lengtl 10 10 10 10 10 10 10 10 10 10	n of each = 12 yith one poor 502.4 622.5 731.3 824.1 906.0 979.5 1046.7 1108.5 1166.1 1219.8 129.8 129.7 1363.3	240 diamet 15 und loss of 804 996 1170 1318 1450 1567 1675 1774 1866 1951 2032 2181	ers. 18 pressure. 1177 1458 1713 1430 2122 2294 2451 2596 2731 2856 2975 3193

For any other loss than one pound pressure, the tabular value should be multiplied by the square root of that loss; for any other length than 240 diameters, divide 240 by the desired length expressed in diameters, and multiply the tabular or calculated figure by the square root of this quotient.

Recent investigations by Ledoux (Annales des Mines, vol. 2, 1892) present a formula for the friction coefficient f in the form

$$f = \frac{\left(T_0^{1.94} - P_1^{1.94}\right)\delta^5}{0.000535 \ LM_0(M_0 - 0.000436 \ jdL)}$$

in which p is the pressure in atmospheres  $p_0$  at the beginning and  $p_1$  at the end;  $\delta$  is the diameter in meters and L the length in meters;  $M_0$  weight in kilograms supplied per second; and j is the weight of condensation per square meter per hour. The mean value from a series of experiments for f was 0.0011. The Babcock experiments agree quite closely with the foregoing.

539

-



# INDEX.

Abrasion, as source of heat	E
Absolute temperature	
Acetone as heat medium	1
Acetvlene gas	-
Adheating	20
Adjabatic compression of air	1
expansion, condensation in	66
expansion of heat medium 23	0
expansion, temperatures in 24	13
lines	8
work in terms of pressures 24	2
Advantages of compound engine 25	0
gas-and-oil engine 44	9
injector	2
mechanical draft II	9
oil-fuel 5	6
Aero-steam engine 48	0
After-burning, in gas-engines 42	8
Air, composition of 2	6
Air-compressor with pressures given 26	0
with volumes given 26	3
Air required for combustion of carbon 2	5
compounds 23	8
hydrogen 2	7
Air-thermometer	2
Alcohol as heat medium	4
Allen dense-air ice-machine 488	8
American stoker 13	5
Ammonia absorption ice-machine 49	7
as heat medium171, 45-	4
compression ice-machine 493	2
refrigerating machines, absorption type 49	7
$compression type \dots \dots \dots 49$	2
vapor engines 492	7
541	

	VDEX.
--	-------

PAG	E
Analysis of flue-gases III	I
power plant	3
Anthracite coal	4
Archer fuel process 55	5
Artificial and patent fuels 4	7
or mechanical or forced draft II	7
Asphalt 40	0
Astatki 49	9
Atkinson differential or cycle gas-engine 410	6
Atmosphere. See Air.	
Atomizers for burning oil 5:	3
Attrition, as source of heat 20	0
Automatic injector 52	I
Bagasse, straw, tan-bark 4.	4
Barrus' coal calorimeter 2	5
Beau de Rochas cycle 41:	2
Bell-Coleman ice-machine 48	8
Bibliography 52	8
Binary-vapor engines 47	4
Bituminous coals 3	9
Boilers. See other title of subject ; also Steam-boilers.	
Boiling-points of liquids	)4
Boyle's law17	9
Brayton gas-engine or ready motor of 1873 41	I
Brines	4
British thermal unit I	4
Buildings, heating of, by steam, data for 14	7
Caking coal, defined 3	8
Calorific power of a fuel 2	4
a hydrocarbon	3
gas	2
Caloric engine. See Hot-air Engine.	
Calorimeter, for coal	5
Cannel-coal, defined 3	8
Carbon, air required for combustion of 2	5
bisulphide as heat medium171, 45	4
Carbonic-acid ice-machine 49	8
Carnot's criterion of reversibility 30	2
cycle 29	8
Centigrade thermometer I	6
Charcoal 4	6
Charles' law 17	7
Chimney, cross-section of	6

I.	Ν	1	D.	E	Х	

- PAGE
Chimney, draft
formulæ and data 104
structure II3
Chloride of carbon as heat medium
Chloroform as heat medium
Circulation in transfer of heat 151
Classification, of gas-engines 420
scheme of 5
Clausius cycle
Clearance
effect of
losses diminished by compression
Clerk gas-engine
Closed ash nit system of draft
Cool colorimators
Coal Son Variation
Coal we extillumination and
Coal-gas, of mummating-gas
Coemcients of expansion 178
Coke
Coking methods of hring 124
Columbia stoker 134
Combined steam process of superheating 329
vapor engines, aero-steam engines
Combustibles, calorific power of
Combustion, air required for 25
as source of motor energy 3
heat from 20
of an analyzed fuel 29
phenomena of 21
products of
rate of
spontaneous 23
Compound air-compressors 270
compressed air-engine 371
gas-engines 440
or multiple-expansion engines 247
Compressed-air engine at full pressure, without cut-off 366
with complete expansion
incomplete expansion 369
isothermal expansion 370
Compression in two or more stages 270
of air and gases 260
Condensation in adiabatic expansion
internal, reduction of
Condensing surface

# INDEX.

	PAGE
Conduction, transfer of heat by	148
Conservation of energy	12
Constant or equal pressure lines. Isopiestic lines or isobars	186
temperature lines. Isothermal lines	187
volume lines. Isometric lines	187
Constant-pressure work with air or permanent gases	231
steam	232
Contact, transfer of heat by	145
Convection, transfer of heat by	151
Cooling of compressing cylinder	270
surface	163
Coxe chain-grate stoker	132
Critical temperature	214
Cross compound-engine	249
Cross-section of chimney	106
Culm, or dust, defined	36
Cut-off, defined	232
Cycle gas-engine, Atkinson	416
of actual steam-engine	311
Carnot	298
Clausius and Rankine	305
Cylinder design of piston-motors	245
volume, with vapor media	465
D'Arcy formula for compressed air	364
Data concerning fuels	<b>7</b> 8
De Laval steam turbine	259
Design of cylinders for piston-motors	245
refrigerating-machine	507
rotary engine	254
Diesel petroleum motor	445
Differential gas-engine	416
Dilution of the products of combustion	32
Direct-combustion engines. See Gas-engines.	-
Disadvantages of compound engine	253
gas-and-oil engine	451
injector	522
mechanical draft	121
oil-fuel	57
vapor media	471
Dissociation, defined	22
Double-tube injector. Inspirator	520
Dow's steam turbine	257
Down-draft furnace	125
Dowson gas-producer	64
	PAGE
--	------
Draft for combustion	96
gauges	107
natural and artificial	117
Duckett products of combustion-engine	404
Dugald Clerk gas-engine of 1880	415
Du Motay refrigerating-fluid	486
Dust, combustion of	24
Du Trembley series engine	476
Dynamic theory of heat	13
Economy of direct-combustion engines	447
Effect on efficiency of certain vapors by adjusting final pressure and ex-	467
Effect on efficiency of certain vapors by an increase in pressure-range	168
Efficiencies experimentally determined in terms of thermal units	227
Efficiency in a refrigerating-cycle	557
of air-compressor and air-engine	274
Carnot cycle	202
fuel	303
steam-hoiler	226
volatile vapor between given pressure limits	164
temperature limits	462
progress in	216
Figures Internet	510
Electromotive force from fuel	2
Ellis vapor engine	476
Energy intrinsic and total	10
sources of	-9
Entropy [see also Temperature]	100
curves for water and steam	201
of a mixture of liquid and vapor	215
Entropy temperature See Temperature-entropy.	5
Envirolent mechanical of heat	13
Equivalent, mechanical, of near	380
Ether as heat medium	454
Fthyl-alcohol	50
Emperation from a feed-water temperature	223
and at 212° Fabr	224
in hoilers per pound of coal	159
of water per pound of fuel	225
Evaporative power of a fuel efficiency, heat balance	74
Ryhanst-steam injectors	522
Expansion cock	492
coefficients of	178
defined	232

## INDEX,

PAGE
Experimental data for a problem in vapors as heat media
Explosion, defined 23
Factor of evaporation 225
Fire temperatures,
First law of thermodynamics 207
Flame, defined 22
Flue-gas analysis III
Fluid compressors 273
Forced draft
Formulæ for the work of a vapor 455
Four-phase cycle of beau de Rochas 412
Freezing mixtures
Friction, as source of heat 20
in pipes
Fuel, calorific power of 24, 34
defined
Fuel-oil
Fuels, data concerning
Furnaces for liquid fuel 51
Fusing-point of metals
Fusion, latent heat of
Gadev's hollow grate
Gaseous fuels, comparison of
Gases, air required for combustion of
as heat media
solids, and liquids, compared as heat media
Gasoline as heat medium 171. 473
engines
Gas-producers
Gav-Lussac. law of
Gordon's hollow grate
Graphical representation of thermal changes in a gas
work of a piston-engine
Grate-surface, ratio of, to heating-surface
Gravity, limitations of
,,,
Heat balance
carriers which have been used as media in heat-engines
from combustion
medium, characteristics of 166
of liquid 211
vaporization 212
range in the air-engine cylinder

Host transfer work and effetered is that the
Heat transfer work and enciency in the injector
Heating of buildings by steam, data for 149
Heating-surface, ratio of, to grate-surface 153, 257
Heights of chimneys 106
Hirn's analysis 343
Hit-or-miss gas-engine 414
Horse-power, values of
Hot-air engines 386
Ericsson's 394
Joule's 398
Stirling's 589
Hugon's gas-engine of 1865 409
Hydrogen, air required for combustion of 27
Hyperbolic logarithms 525
Ice-making 482
- Ideal and actual efficiency compared
Igniters for gas-engines 421
Igniting gas-charge in gas-engine 121
Ignition, defined 21
spontaneous
Illuminating-gas
Impact, as source of heat
in injector.
Incandescence, defined.
Indicator-diagrams from gas-engine
Indicator principle of
Induced currents in injector
Induced draft system
Induced-draft system
Ingerson-Seigeant two-stage tandem an-compressor
Injector denned
Inspirator
Internal-compustion not-air engine using solid luel
Internal condensation, reduction of
latent heat
Intrinsic energy
Isentropic lines. Entropy
Isobars ISO
Isodynamic or Isoenergic lines 188
Isometric lines 187
Isopiestic lines 186
Isothermal compression 266
expansion of heat medium 237
lines 187

INDEX.

	PAGE
Jacket. See Steam-jacket.	
Ioules' equivalent hot-air engine with closed cycle	402
law	184
Kent formula for chimney-draft	101
Kerosene	50
engine	411
engine	44*
Latent heat of steam	212
Law of Gay-Lussac, or Charles' law	177
Law of Mariotte, or Boyle's law	170
Le Chatelier thermo-electric pyrometer. Siemens pyrometer	02
Lencauchez gas-producer.	6=
Lenoir gas-engine of 1860	107
Lignite	407 -
Lighter and the force of another force of another	39
Limitations of muscular force and the force of gravity	1
Liqueraction, fusion, or meiting. Latent heat of fusion and vaporization	172
Liquefied vapors	480
Liquid air	511
fuel	48
Liquid-fuel furnaces	51
Liquids, solids, and gases, compared as heat media	164
volumes of	213
Logarithms	525
Loss by clearance	331
of energy in transmitting air through pipes	363
pressure and temperature from cooling in pipes	337
Losses in actual steam-engine	311
evaporating by fuels	74
revealed by the temperature-entropy diagram	357
Lowe process for making gas	62
Low temperatures	E T T
Low temperatures	511
Mariotte's law	179
Mean effective pressure, calculation of	335
in the compressing-cylinder	265
when clearance and compression are considered	335
Mechanical compression.	260
draft	117
equivalent of heat	11/
principle of impact in the injector	13
principle of impact in the injector. The induced evenest actual	519
principles underlying the injector. The induced-current princi-	
μιτ	510
	482
stoking	129
theory of heat	13

Madia for use in refrigerating mechanics Adventure 1 11 1	AGE
Media for use in felligerating-machines. Advantages and disadvantages	486
Welding lotont best of	100
Melting, latent heat of	172
Meining temperatures	88
Mesure and Noel's pyrometric telescope,	93
Metal-ball pyrometer	90
Methyl alcohol	50
Mixtures of gas and air	430
Motor-energy liberated on combustion	3
sources of	I
Muscular force, limitations of	I
Naphtha as heat medium 171,	473
Natural gas	58
Negative specific heat of saturated steam	219
Non-conducting cylinders	325
Oil. as fuel	533
Oil-engine for gasoline, or light volatile oils	411
kerosene or non-volatile oils	4.11
Oil.gas systems	55
Oil-vapor burners	50
Orsat flue-gas apparatus	111
Otto and Langen atmospheric or free-niston gas-engine of 1867	100
gos angine custa	110
gas-engine cycle	41.4
Output of a steam-hoiler in heat-units	226
	220
Patent fuels	49
Peat	40
Peclet theory of chimney-draft	93
Performance of refrigerating-machines	510
Permanent gas, defined165,	180
Petroleum as fuel [see also Oil, Liquid fuel]	48
Phenomena of combustion, ignition, flame, incandescence	21
ignition in the gas-engine	427
Pictet system of ice-machine	498
Pintsch oil-gas	55
Piston-engine, definition of	8
Piston speed	246
Powdered fuel	72
Power plant, analysis of	3
Preheating the air for the air-engine	376
Pressures and temperatures of steam	205
Prevention of smoke	123

1	Λ	11	D.	E	X	

PAGE
Producer gas
Products of combustion, dilution of 32
engine 403
weight and volume of 30
Progress in steam-engine efficiency 316
Pyrometers, general 89
Pyrometric telescope
R as symbol in heat equations 180
Radiation, transfer of heat by 142
Rankine and Clausius cycles 305
factor of evaporation 225
formula for pressure of saturated steam 203
Rate of combustion
Ratio of heating-surface to grate-surface 157
Réaumur, or Celsius' thermometer 16
Reducing internal condensation 319
Re-evaporation, losses by 315
Reeve's entropy-temperature diagram chart 359
Refining process for petroleum 49
Refrigerating-machines on Pictet system. Carbonic-acid machines 498
using air as a medium
surface
Refrigeration by a series process 505
for ice-making or for cooling-chambers. Brines
mechanical 482
Regenerator for hot-air engine
Reheating method of superheating 330
Relations of pressure and temperature in saturated-steam vapor (Regnault). 201
Re-starting injectors
Retarders, use of 151
Reversibility of Carnot's cycle
Rider hot-air engine
Ringelmann smoke-scale
Rockwood compound engine 250
Rotary engine, design of 254
Salt solution in refrigeration 485
Saturated steam
vapor-pressures and temperatures for media other than steam 210
Saw-dust as fuel
Second law of thermodynamics 297
Series vapor-motor
Siemens gas-producer
pyrometer

|--|

· · · · ·	PAGE
Sizing of coal	36
Smoke, defined	23
prevention	123
scale, Ringelmann	137
Solids, liquids, and gases	161
Sources of motor energy	I
Specific heat	531
at constant pressure and at constant volume	182
of steam	218
superheated steam at constant volume	210
volume of hot liquids	220
soturoted steem	213
saturated steam.	221
superneated steam	220
Splint coal, defined	38
Spontaneous combustion. Explosion	23
Sprinklers for burning oil	53
Stability and structure of chimneys	113
Stacks. See Chimney.	
Steam-boiler, efficiency of	226
heating of buildings, data for	147
jacket	321
Steam, properties of	211
specific heat of	218
Steam-tables	20.1
turbine	255
Step by step propose in refrigeration	205
Step-by-step process in reingeration	280
Summe not-all engine	309
	129
Storage of energy in liquefied vapors	480
Straw as fuel	44
Superheated steam 200,	218
Superheating to prevent cylinder condensation	325
. •	
Tan-bark as fuel	44
Taylor gas-producer	63
Temperature	15
absolute	18
changes in adiabatic expansion	243
critical	214
of fusion and boiling	93
of the fire	\$6
Temperature entropy diagram	277
applied to an ideal steam-engine working	
with complete expansion	28.1
for the pir-compressor	280
for the an-compressor	300

55I

Temperature-entropy diagram for the combined air-compressor and air- engine
engine.38rcompressed-air engine.377gas-engine.433ideal heat-engine.279Stirling hot-air engine.391in thermal analysis.353of a hot-air engine, changing temperature401non-isothermally401of refrigerating cycle499when expansion is incomplete.288steam is superheated.290Theoretical weight of heat medium for a given work.306Thermal analysis of heat-engines.340by temperature-entropy diagram.353lines.186resistance.151unit, British.14Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431surface.19second law of291second law of291heat of steam.19heat of steam.211Transfer of heat. General.140heat by radiation.142contact.145
compressed-air engine
gas-engine.433ideal heat-engine.270Stirling hot-air engine.391in thermal analysis.353of a hot-air engine, changing temperature353non-isothermally401of refrigerating cycle.409when expansion is incomplete.288steam is superheated.290there is no expansion.290Theoretical weight of heat medium for a given work.306Theory of chimney-draft by Peclet.98Thermal analysis of heat-engines.340by temperature-entropy diagram.353lines.186resistance.151unit, British.14Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431surface.291second law of.291Thermometer, air.17Thermometers.16Total and intrinsic energy.19heat of steam.211Transfer of heat. General.140heat by radiation.142contact.145
ideal heat-engine
Stirling hot-air engine
in thermal analysis
of a hot-air engine, changing temperature 953   of a hot-air engine, changing temperature 401   of refrigerating cycle 499   when expansion is incomplete. 288   steam is superheated. 290   there is no expansion. 290   Theoretical weight of heat medium for a given work. 306   Theory of chimney-draft by Peclet. 98   Thermal analysis of heat-engines. 340   by temperature-entropy diagram. 353   lines. 186   resistance. 151   unit, British. 14   Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431   surface. 185   Thermometer, air. 17   Thermometers,
of a hot-air engine, changing temperature   non-isothermally 401   of refrigerating cycle 499   when expansion is incomplete. 288   steam is superheated. 290   Theoretical weight of heat medium for a given work. 306   Theory of chimney-draft by Peclet. 98   Thermal analysis of heat-engines. 340   by temperature-entropy diagram. 186   resistance. 151   unit, British. 14   Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431 555   Thermometer, air. 17   Thermometers, 16   Total and intrinsic energy. 19   heat of steam. 211   Transfer of heat. General.   unit, by radiation. 142   contact. 142
non-isothermally 401   of refrigerating cycle 499   when expansion is incomplete. 288   steam is superheated. 290   there is no expansion. 290   Theoretical weight of heat medium for a given work. 306   Theory of chimney-draft by Peclet. 98   Thermal analysis of heat-engines. 340   by temperature-entropy diagram. 353   lines. 186   resistance. 151   unit, British. 14   Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431 291   surface. 185   Thermometer, air. 17   Thermometers, information of steam. 19   heat of steam. 211   Transfer of heat. General. 140   heat by radiation. 142   contact. 145
of refrigerating cycle 499   when expansion is incomplete. 288   steam is superheated. 290   there is no expansion. 290   Theoretical weight of heat medium for a given work. 306   Theory of chimney-draft by Peclet. 98   Thermal analysis of heat-engines. 340   by temperature-entropy diagram. 353   lines. 186   resistance. 151   unit, British. 14   Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431 291   scond law of 291   scond law of 291   Thermometer, air. 17   Thermometers. 16   Total and intrinsic energy. 19   heat of steam. 211   Transfer of heat. General. 140   heat by radiation. 142   contact. 145
when expansion is incomplete.288steam is superheated.290there is no expansion.290Theoretical weight of heat medium for a given work.306Theory of chimney-draft by Peclet.98Thermal analysis of heat-engines.340by temperature-entropy diagram.353lines.186resistance.151unit, British.14Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431surface.185Thermometer, air.17Thermometer, air.17That and intrinsic energy.19heat of steam.211Transfer of heat. General.142contact.145
steam is superheated.290there is no expansion.290Theoretical weight of heat medium for a given work.306Theory of chinney-draft by Peclet.98Thermal analysis of heat-engines.340by temperature-entropy diagram.353lines.186resistance.151unit, British.14Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431surface.185Thermodynamics, first law of.291second law of291Thermometer, air.17Thermometers.16Total and intrinsic energy.19heat of steam.211Transfer of heat. General.140heat by radiation.142contact.145
there is no expansion
Theoretical weight of heat medium for a given work. 306   Theory of chimney-draft by Peclet. 98   Thermal analysis of heat-engines. 340   by temperature-entropy diagram. 353   lines. 186   resistance. 151   unit, British. 14   Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431 surface.   surface. 185   Thermodynamics, first law of. 291   second law of 291   Thermometer, air. 17   Thermometers. 16   Total and intrinsic energy. 19   heat of steam. 211   Transfer of heat. General.   140 heat by radiation. 142   contact. 145
Theory of chimney-draft by Peclet. 98   Thermal analysis of heat-engines. 340   by temperature-entropy diagram. 353   lines. 186   resistance. 151   unit, British. 14   Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431 surface.   surface. 185   Thermodynamics, first law of. 291   second law of 291   Thermometer, air. 17   Thermometers. 16   Total and intrinsic energy. 19   heat of steam. 211   Transfer of heat. General.   I40 heat by radiation.   I42 contact.
Thermal analysis of heat-engines
by temperature-entropy diagram
lines
resistance
resistance 151   unit, British. 14   Thermodynamic efficiency of the Otto engine considered as a Carnot engine 431 14   surface. 185   Thermodynamics, first law of. 291   second law of. 291   Thermometer, air. 17   Thermometers. 16   Total and intrinsic energy. 19   heat of steam. 211   Transfer of heat. General.   Law indiction. 142   contact. 145
unit, British
Thermodynamic emclency of the Otto engine considered as a Carnot engine 431   surface. 185   Thermodynamics, first law of. 291   second law of. 291   Thermometer, air. 17   Thermometers. 16   Total and intrinsic energy. 19   heat of steam. 211   Transfer of heat. General.   Law or take 142   contact. 145
surface. 185   Thermodynamics, first law of. 291   second law of. 291   Thermometer, air. 17   Thermometers. 16   Total and intrinsic energy. 19   heat of steam. 211   Transfer of heat. General.   heat by radiation. 142   contact. 145
Thermodynamics, first law of. 291   second law of. 291   Thermometer, air. 17   Thermometers. 16   Total and intrinsic energy. 19   heat of steam. 211   Transfer of heat. General.   Ideat by radiation. 142   contact. 145
second law of
Thermometer, air. 17   Thermometers. 16   Total and intrinsic energy. 19   heat of steam. 211   Transfer of heat. General.   Heat by radiation. 142   contact. 145
Thermometers
Total and intrinsic energy. 19   heat of steam. 211   Transfer of heat. General.   heat by radiation. 142   contact. 145
heat of steam
Transfer of heat. General
heat by radiation142 contact
contact
conduction
convection Circulation
indicator disgram to the entropy typeserture disgram
Thursdor-diagram to the entropy-temperature diagram 204
1 ransmission of power, importance of
Travelling grate of mechanical stokers
Triple-expansion engine 249
Turbine, steam, computations 255
Uehling-Steinbart pyrometer
Urquhart nozzle-burner for oil 54
Value of the factor <i>n</i> in air-compressing
Vapor-engines, binary
Vapor media. Their disadvantages 471

	PAGE
Vaporization, latent heat of	172
Vapors as heat media 170, 454,	458
constants for	458
efficiency of	462
Volatile vapors	454
Volume of compressing-cylinder	269
cylinder of a compressed-air engine	371
products of combustion with an analyzed fuel	31
Warsop's aero-steam engine	480
Water-consumption in ideal and actual engines	307
Water, entropy curves for	291
Water-gas. Dowson gas	62
motors, limitations of	2
per horse-power per hour	160
Wave-motors, limitations of	2
Weight of heat medium for a given work	306
per horse-power calculated theoretically from an	
indicator-diagram	340
products of combustion with an analyzed fuel	30
Wellington series vapor-motor	476
Wethered's system of superheating	329
Wet or cold and dry or hot systems of ammonia compression	496
Wiborgh's air-pyrometer	91
Wilkinson stoker	133
Windmills, limitations of	2
Wire-drawing, loss by	315
Wood	42
alcohol	50
Woolf compound engine	247
Work diagram and area	10
done in expanding in a cylinder	232
in injectior	517
of an elastic heat medium expanding adibaticallyisothermally	239 237
a by diagram represented by an area	235
vapor	455
Work, unit of	6

















#### THIS BOOK IS DUE ON THE LAST DATE STAMPED BELOW

# AN INITIAL FINE OF 25 CENTS

WILL BE ASSESSED FOR FAILURE TO RETURN THIS BOOK ON THE DATE DUE. THE PENALTY WILL INCREASE TO 50 CENTS ON THE FOURTH DAY AND TO \$1.00 ON THE SEVENTH DAY OVERDUE.

0.00	
DEC 6 1931	
ner 18 1935	
DLU LU	
Bern	
IIIN OF SOME	
1011 20 13345	
o Mar A9 W	
9118- 34	
	LD 21-95m-7,'37



